

QA/QC Data Ratification and Intercalibration Report for the Automatic Urban and Rural Network, July-September 2006

**Report produced for the Department for Environment,
Food and Rural Affairs, Scottish Executive, Welsh
Assembly Government and the DoE in Northern
Ireland**

Unrestricted

AEAT/ENV/R/2375

Issue 1

March 2007



AEA Energy & Environment
From the AEA group


| | |
|--|---|
| Title | QA/QC Data Ratification and Intercalibration Report for the Automatic Urban and Rural Network, July-September 2006 |
| Customer | Department for Environment, Food and Rural Affairs, Scottish Executive, Welsh Assembly Government and the DoE in Northern Ireland |
| Customer reference | RMP 1883 |
| Confidentiality, copyright and reproduction | Unrestricted Copyright AEA Technology plc All rights reserved. Enquiries about copyright and reproduction should be addressed to the Commercial Manager, AEA Technology Environment. |
| File reference | AEAT/ENV/R/2375 |
| Reference number | ED45077 |

AEA Energy & Environment
 Building 551.11
 Harwell
 Didcot
 Oxfordshire
 OX11 0QR

tel: 0870 190 6465
 fax: 0870 190 6377

AEA Energy & Environment is a business name of AEA Technology plc.

AEA Energy & Environment is certificated to ISO9001 and ISO14001.

| | | |
|--------------------|-----------|--|
| Author | Name | Stewart Eaton |
| | Signature |  |
| Approved by | Name | Ken Stevenson |
| | Date | 26 March 2007 |

Executive Summary

This report is in 2 parts – Part A is the data ratification report for July – September 2006 and Part B is a report on the Intercalibration exercise in summer 2006.

AEA carries out the quality assurance and control (QA/QC) activities for the Automatic Urban and Rural Monitoring Network (AURN) on behalf of the UK Department for Environment, Food and Rural Affairs (Defra), Scottish Executive, Welsh Assembly Government and the DoE in Northern Ireland . .

Ratified hourly average data capture for the network averaged 90.3% for all pollutants (O₃, NO₂, SO₂, CO, PM₁₀ and PM_{2.5}) during the 3-month reporting period July-September 2006. For the pollutants CO, NO₂ and SO₂ the data capture was just below, but very close to 90%. PM_{2.5} data capture was only 81.1%, but this was mainly due to some problems with the newly installed analyser in Swansea Roadside.

Some sites were affected by relocation or temporary closure, which resulted in reduced data capture. A considerable amount of data were lost during July and August due to high ambient temperatures causing analysers to overheat, and several air conditioning units have failed during this period.

The first two TEOM FDMS analysers have been introduced into the network during this period. The QA/QC unit has developed new software to handle and ratify data from these analysers. In addition, a new section to the LSO manual has been published to cover these instruments. The Partisol LSO manual has also been updated.

During the summer 2006 intercalibration exercise, 128 sites were audited by the QA/QC Unit. The detailed results are given in Section B of this report. A total of 77 of the 441 analysers tested were identified as outliers.

A total of 8 cylinders used to scale data were identified as having drifted in concentration by more than 10% from the certified value. These were requested (where not empty) to be returned to the QA/QC unit for recalibration.

One NO_x analyser was found to have a software converter efficiency correction factor set to a value different from 100%. ESUs are reminded that software settings should not be used to correct for converter inefficiency.

Table of contents

Part A

Data Ratification Report July-September 2006

| | | |
|----------|---|-----------|
| 1 | Introduction..... | 1 |
| 1.1 | Recent Changes in the Network | 1 |
| 1.1.1 | Exeter Roadside | 1 |
| 1.1.2 | Swansea Roadside..... | 2 |
| 1.2 | Overview of Network Performance | 2 |
| 1.3 | LSO Manual | 4 |
| 1.4 | AURN Hub Updates..... | 4 |
| 2 | Generic Data Quality Issues..... | 5 |
| 2.1 | Progress on Monitoring Requirements of the EU Daughter Directives | 5 |
| 2.2 | Data Capture for Critical Sites in Zones and Agglomerations | 5 |
| 2.3 | Gravimetric PM ₁₀ Data Ratification | 7 |
| 2.4 | Auto-Calibration Run-ons | 8 |
| 3 | Site Specific Issues..... | 11 |
| 3.1 | Cwmbran SO ₂ | 11 |
| 3.2 | Bolton NOx..... | 11 |
| 3.3 | Other Analysers Highlighted in Recent Reports | 12 |
| 4 | Sites with Data Capture Below 90% | 13 |
| 4.1 | Sites with Low Data Capture | 13 |
| 5 | Ratified Data Capture Statistics..... | 20 |
| 6 | Introduction..... | 35 |
| 7 | Results Summary | 37 |
| 8 | Oxides of Nitrogen | 41 |
| 8.1 | Intercalibration Outliers..... | 41 |
| 8.2 | Leaking switching valves | 41 |
| 8.3 | Converter Tests | 42 |

| | | |
|-----------|---|-----------|
| 9 | Carbon Monoxide | 43 |
| 10 | Sulphur Dioxide | 43 |
| | 10.1 Intercalibration Outliers | 43 |
| | 10.2 m-xylene tests | 44 |
| 11 | Ozone | 44 |
| 12 | Particulate analysers | 45 |
| | 12.1 TEOM k ₀ | 45 |
| | 12.2 Analyser Flow Rates | 45 |
| 13 | Site Cylinder Concentrations | 46 |
| 14 | Site Information | 46 |
| 15 | CEN | 47 |
| 16 | Safety | 48 |
| 17 | Certification | 48 |
| 18 | Summary | 48 |

| | |
|-------------|---|
| Appendix A1 | Recommendations for replacing or up-grading equipment |
| Appendix A2 | List of critical sites in the AURN. |
| Appendix A3 | Inventory of Department-owned equipment used by QA/QC Unit. |
| Appendix A4 | Summary of recommendations |

PART A – Data Ratification Report for the Automatic Urban and Rural Network, July-September 2006

1 Introduction

This quarterly report covers the Quality Assurance and Control (QA/QC) activities undertaken by AEA to ratify automatic monitoring data from Defra and the Devolved Administrations' urban and rural air quality monitoring network (AURN) for the period July-September 2006. During this period there were 128 monitoring sites in the Network of which there are 90 urban sites, 24 rural sites and a further 14 sites in the London Air Quality Monitoring Network (LAQN) which are affiliated into the national network. There are currently 64 Defra-funded sites and 64 affiliate sites. Three sites (Belfast Clara Street, Northampton PM₁₀ and Brighton Roadside PM₁₀) measure PM₁₀ only and are included as individual sites in the total of 128, although Northampton PM₁₀ is co-located with the Northampton AURN site, and Brighton Roadside PM₁₀ is close to the Brighton Roadside AURN site.

1.1 Recent Changes in the Network

This section gives an overview of the main changes that have recently taken place in the network, including site closures, relocations or the addition of any new sites to the network. A summary of changes in the AURN for the period is given in Table 1.1.

Table 1.1 Changes in the Network, July-September 2006

| Site | Date closed | Date commissioned | Comments |
|------------------|-------------|-------------------|---|
| Exeter Roadside | | 10 July 2006 | Replacement NOx analyser installed |
| Swansea Roadside | - | 20 Sept 06 | Relocated Swansea site. PM _{2.5} analyser also installed and incorporated into the network |

The monitoring site at Swansea Roadside contains the first two TEOM FDMS (PM₁₀ and PM_{2.5}) analysers to be deployed in the AURN.

The QA/QC unit has developed new software techniques to handle and ratify data from TEOM FDMS analysers and has provided a new section of the LSO manual detailing LSO procedures for these analysers.

The QA/QC unit has also liaised closely with the CMCU to update the LSO manual for Partisol analysers and LSOs with Partisol analysers at their sites should now follow these new procedures.

Further details of these network changes, which are undertaken in close co-operation with Bureau Veritas and the relevant Local Authorities, are given in the following sections.

1.1.1 Exeter Roadside

The temporary analysers at Exeter Roadside were replaced with new, permanent analysers on 7 June (except for NOx, which was replaced on 10 July). The site was audited by the QA/QC unit on 18 July, which serves as a commissioning audit.

1.1.2 Swansea Roadside

The Swansea monitoring site was closed on 7 August, and has been relocated to a nearby roadside location, Swansea Roadside. This has the addition of a PM_{2.5} analyser. Both the PM_{2.5} and the PM₁₀ analysers are FDMS TEOMs, the first of these analysers to be introduced into the network. The site location is

Carmarthen Road (A483)
SS653945 183ft above sea level, 5m from kerbside.
Grid reference 265341 194458

1.2 Overview of Network Performance

Ratified hourly average data capture for the network averaged 90.3% for all pollutants (O₃, NO₂, SO₂, CO, PM₁₀ and PM_{2.5}) during the 3-month reporting period July-September 2006 (see Table 1.2 below). For the pollutants CO, NO₂ and SO₂ the data capture was just below, but very close to 90%. PM_{2.5} data capture was only 81.1%, but this was mainly due to some problems with the newly installed analyser in Swansea Roadside. For comparison, the annual average network data capture for the calendar year 2005 was 91%.

**Table 1.2 AURN Ratified Data Capture (%) by Quarter, 2006
(Using the start date of any new site)**

| Data Capture (%) | CO | NO ₂ | O ₃ | PM ₁₀ | PM _{2.5} | SO ₂ | Network Average |
|-------------------|------|-----------------|----------------|------------------|-------------------|-----------------|-----------------|
| Q1 Jan-Mar 2006 | 90.1 | 89.9 | 91.0 | 94.7 | 98.1 | 90.9 | 90.4 |
| Q2 Apr-June 2006 | 90.7 | 91.9 | 94.0 | 96.0 | 96.4 | 93.3 | 92.3 |
| Q3 July-Sept 2006 | 89.5 | 89.5 | 93.6 | 90.4 | 81.1 | 89.2 | 90.3 |

Overall, 326 out of the 424 analysers (77%) achieved data capture levels above the required 90% target during this reporting period (See Table 1.3).

Table 1.3 Number of Analysers with Data Capture below 90%

| Total Number Of Analysers | Q1 Jan-Mar 2006 | Q2 Apr-June 2006 | Q3 July-Sept 2006 |
|---------------------------|-----------------|------------------|-------------------|
| CO | 77 | 17 | 15 |
| NO ₂ | 109 | 20 | 29 |
| O ₃ | 87 | 14 | 13 |
| PM ₁₀ | 70* | 8 | 16 |
| PM _{2.5} | 6* | 0 | 1 |
| SO ₂ | 75 | 16 | 24 |
| Total <90% | 424 | 75 | 98 |

*Includes TEOM, TEOM FDMS and Partisol analysers

In total, 39 out of the 128 operational network sites (21%) had an average data capture rate below the required 90% level for the July-September 2006 period. These sites are listed in Table 1.4. The main site operational and QA/QC issues giving rise to data capture below the required 90% level are summarised in Section 4. A summary of the main recommendations made in this report to help improve network performance is given in Appendix A4.

**Table 1.4 Sites with Average Data Capture < 90%, July-September 2006
(Data capture calculated from site start date)**

Network Data Capture for 01/07/2006 to 30/09/2006 from start date of any new site

| Site | Owner | Site Average |
|------------------------|-----------|--------------|
| England | | |
| Barnsley 12 | DEFRA | 69.9 |
| Blackpool Marton | DEFRA | 86.5 |
| Brentford Roadside | Affiliate | 83.5 |
| Bury Roadside | Affiliate | 76.8 |
| Cambridge Roadside | Affiliate | 76.9 |
| Camden Kerbside | Affiliate | 78.4 |
| Ladybower | DEFRA | 75.1 |
| Liverpool Speke | Affiliate | 86.4 |
| London Bexley | Affiliate | 89.2 |
| London Bromley | Affiliate | 26.5 |
| London Hackney | Affiliate | 48.2 |
| London Marylebone Road | Affiliate | 83.9 |
| London Southwark | Affiliate | 80.4 |
| London Westminster | DEFRA | 77.9 |
| Northampton PM10 | Affiliate | 85.9 |
| Norwich Centre | DEFRA | 79.6 |
| Norwich Forum Roadside | Affiliate | 74.1 |
| Plymouth Centre | DEFRA | 73.8 |
| Reading New Town | DEFRA | 88.5 |
| Rotherham Centre | Affiliate | 62.1 |
| Salford Eccles | Affiliate | 85.6 |
| Sheffield Centre | DEFRA | 83.5 |
| Somerton | Affiliate | 89.3 |
| Southampton Centre | DEFRA | 71.2 |
| Southwark Roadside | Affiliate | 0.0 |
| Wigan Centre | Affiliate | 89.6 |
| Wirral Tranmere | DEFRA | 86.1 |
| Yarner Wood | DEFRA | 85.6 |
| N Ireland | | |
| Belfast Centre | DEFRA | 88.1 |
| Scotland | | |
| Bush Estate | DEFRA | 85.4 |
| Dumfries | DEFRA | 87.7 |
| Fort William | DEFRA | 77.3 |
| Glasgow Centre | DEFRA | 87.2 |
| Glasgow Kerbside | DEFRA | 87.8 |
| Lerwick | DEFRA | 89.8 |
| Wales | | |
| Cwmbran | Affiliate | 83.5 |
| Narberth | Affiliate | 87.1 |
| Swansea | Affiliate | 75.1 |
| Swansea Roadside | Affiliate | 67.7 |

1.3 LSO Manual

As noted in Section 1.1, the LSO Manual has been updated to include a section on the TEOM FDMS analysers. In addition, the Partisol section of the manual has been updated. LSOs with these analysers at their site should now use the new version of the manual.

Copies of the original Local Site Operator’s manual on disc (CD) were distributed to the network participants at the annual LSO meeting in December 2004. Copies of the new TEOM FDMS and Partisol sections will be distributed to the relevant LSOs shortly. If LSOs have not received a copy of the manual or further copies are required please contact Andy.Cook@aeat.co.uk. The manual, including the new TEOM and FDMS sections is available electronically on the following web sites:

AURN Hub <http://www.aeat.co.uk/com/AURNHUB/lsoman.html>

Air Quality Archive <http://www.aeat.co.uk/netcen/airqual/reports/lsoman/lsoman.html>

1.4 AURN Hub Updates


The AURN project information hub website is located at¹: <http://www.aeat.co.uk/com/AURNHUB/index.html>.

The site is regularly up-dated and some of the more recent information includes:

- Up-dated site lists (July 2006) and critical site list (July 2006)
- Monthly PM₁₀ (Gravimetric) exceedences up to December 2006
- QA/QC Unit’s data ratification and intercalibration report, April-June 2006
- Recent Management Unit reports (July-September 2006)
- Updated version of the LSO manual

The Hub has continued to provide a valuable source of information for interested organisations-see Figure 1.1

Figure 1.1 AURN Hub Monthly Usage Statistics January-December 2006



¹ Password protected site: username and password available from stephen.bird@aeat.co.uk

As is often observed, most interest in the hub seems to be around the time of the annual LSO meeting in December.

2 Generic Data Quality Issues

2.1 Progress on Monitoring Requirements of the EU Daughter Directives

Installation of all of the additional NO_x and O₃ analysers at existing sites required to comply with the third Daughter Directive (DD3) has now been completed. Further details on the third Daughter Directive can be found at:

<http://www.defra.gov.uk/environment/consult/air-23daughter/index.htm>

2.2 Data Capture for Critical Sites in Zones and Agglomerations

In order to meet the requirements of the Daughter Directives, any zone or agglomeration² with an exceedence of the limit value must be formally reported to the Commission. The critical sites are those which, if data capture falls below 90%, there will be insufficient data for the whole zone or agglomeration. In most cases the critical sites are those where there is only one site in the zone or agglomeration. However, for some pollutants (especially ozone) monitoring is required at several sites in each zone or agglomeration and hence these may all need to be classified as critical sites for that pollutant. The list of the critical sites in the Network necessary to meet the requirements of the first, second and third Daughter Directives is given in Appendix A2. In total 62 sites (195 analysers) have been identified as critical for DD1, DD2 or DD3 (25 sites in agglomerations and 36 in zones).

Data capture for all 62 of the critical sites during the 3-month period July-September 2006 is given in Section 5, Table 5.2. The critical sites with less than 90% total data capture and the main reasons for data loss at these sites are given in Table 2.1 below. In total, 32 out of the 187 critical site analysers (17%) did not meet the required 90% data capture during the period July-September 2006. Note that some critical sites also measure other pollutants, which are not themselves critical.

Table 2.1 Critical sites with <90% data capture, July-September 2006

| Site | CO | PM ₁₀ | NO ₂ | O ₃ | PM ₂₅ | SO ₂ | Site Average | Principle reason for loss |
|------------------------------|------|------------------|-----------------|----------------|------------------|-----------------|--------------|-------------------------------------|
| England | | | | | | | | |
| Blackpool Marton | 88.5 | 93.7 | 86.0 | 93.8 | - | 70.7 | 86.5 | Various equipment faults |
| Liverpool Speke | 94.0 | 89.5 | 77.0 | 94.0 | - | 77.6 | 86.4 | Numerous gaps; temperature problems |
| Northampton PM ₁₀ | - | 85.9 | - | - | - | - | 85.9 | Power and filter change failures |
| Norwich Centre | 99.5 | 0.0 | 99.5 | 99.5 | - | 99.6 | 79.6 | TEOM Ko 8% out; poor quality data |
| Plymouth | 90.5 | 24.8 | 96.4 | 63.1 | - | 94.3 | 73.8 | Noisy PM ₁₀ data, O3 |

² A definition of zones and agglomerations can be found under "Article 5 Assessment Zones and Agglomerations Monitoring Maps" at <http://www.defra.gov.uk/environment/airquality/index.htm>

| Site | CO | PM ₁₀ | NO ₂ | O ₃ | PM ₂₅ | SO ₂ | Site Average | Principle reason for loss |
|--------------------|-------------|------------------|-----------------|----------------|------------------|-----------------|--------------|--|
| Centre | | | | | | | | main valve fault |
| Reading New Town | 90.4 | 89.1 | 83.6 | 90.9 | - | 88.5 | 88.5 | Excessive hut temperature |
| Sheffield Centre | 95.9 | 96.0 | 40.7 | 95.9 | - | 89.1 | 83.5 | NOx converter fault |
| Somerton | - | - | 88.7 | 89.9 | - | - | 89.3 | |
| Southampton Centre | 52.1 | 94.1 | 83.0 | 89.9 | - | 36.9 | 71.2 | Various analyser faults and poor quality data |
| Wigan Centre | 91.4 | 85.5 | 92.8 | 91.3 | - | 87.1 | 89.6 | Gaps in data, suspected logger fault |
| Wirral Tranmere | 90.6 | 86.1 | 84.9 | 81.5 | - | 87.7 | 86.1 | Air con caused numerous power cuts |
| Yarner Wood | - | - | 75.3 | 96.0 | - | - | 85.6 | Struck by lightning, damaging logger |
| N Ireland | | | | | | | | |
| Belfast Centre | 88.9 | 88.3 | 85.3 | 89.1 | - | 89.1 | 88.1 | Sample manifold vandalised |
| Scotland | | | | | | | | |
| Bush Estate | - | - | 72.3 | 98.6 | - | - | 85.4 | NOx analyser flow fault |
| Dumfries | 94.6 | 75.0 | 93.4 | - | - | - | 87.7 | PM ₁₀ problems- see Section 2.3 |
| Fort William | - | - | 66.3 | 88.4 | - | - | 77.3 | O ₃ analyser fault; spurious NO ₂ baseline |
| Glasgow Centre | 68.0 | 93.1 | 97.4 | 97.4 | - | 80.1 | 87.2 | CO and SO ₂ analysers unstable |
| Wales | | | | | | | | |
| Cwmbran | 99.6 | 98.0 | 99.3 | 99.6 | - | 20.7 | 83.5 | Poor quality SO ₂ data- probably temperature related |
| Narberth | - | 82.4 | 90.8 | 89.7 | - | 85.4 | 87.1 | Temperature related faults |
| Swansea | 75.2 | 75.3 | 75.0 | 75.2 | - | 74.9 | 75.1 | Site relocated |
| Swansea Roadside | 95.1 | 12.9 | 95.1 | 95.1 | 12.9 | 95.1 | 67.7 | Problems with particle analysers, new site |

Shaded boxes are for data capture < 90%
 Bold data captures are for critical instruments and sites


Recommendation

Every effort should be made to ensure that data capture is maximised for the critical sites. LSOs and ESUs should undertake call-outs and repairs as soon as possible to avoid unnecessary data loss at these sites.

2.3 Gravimetric PM₁₀ Data Ratification

Gravimetric PM₁₀ analysers (Partisols) are located at eight sites in the network (Bournemouth, Northampton, Wrexham, Dumfries, Inverness, London Westminster, Auchencorth Moss (PM₁₀ and PM_{2.5}) and Brighton Roadside PM₁₀). The gravimetric PM₁₀ analyser at Northampton is also co-located with a TEOM analyser, which provides a comparison of data from the two techniques. Gravimetric PM₁₀ concentrations and the daily mean TEOM scaled by 1.3 at Northampton for the 3-month period July-September 2006 are shown in Figure 2.1. Throughout the period, the Partisol consistently overread the TEOMx1.3 data.

Figure 2.1 Partisol and TEOM (x1.3) Concentrations at Northampton (January-September 2006)



Data capture for the gravimetric PM₁₀ (Partisol) analysers for the period July-September 2006 is given in Table 2.3. Six of the eight sites for which data are available exceeded the 90% data capture target in this quarter, with average data capture over all eight analysers of 92.9%.

Table 2.3 Gravimetric PM₁₀ Data Capture (%) 2006

| Site | 3-months Data Capture (%) July-September 2006 |
|------------------------------------|--|
| Auchencorth Moss | 94.6 |
| Bournemouth | 100 |
| Brighton Roadside PM ₁₀ | 93.5 |
| London Westminster | 97.8 |
| Northampton | 85.9 |
| Dumfries | 75 |
| Inverness | 98.9 |
| Wrexham | 97.8 |

The reasons for data loss in the gravimetric analysers are reported elsewhere, but the major sources of data loss for sites below 90% data capture are given as follows:

Dumfries: Flow faults, 13 July to 7 August
 Northampton: Power failure 4 July; Filter change failures (8 days); delayed filter change (2 days)

Bureau Veritas has supplied the measured data, undertaken the filter weighing and calculated the particulate concentrations; AEA has ratified the results.

2.4 Auto-Calibration Run-ons

Autocalibration "run-on" is a generic problem affecting many analysers in the network and is due to autocalibration gas leaking into the sampling system during the ambient measurement period immediately after the autocalibration cycle. The problem can be identified by examining the diurnal variation of pollutant concentrations for the individual sites. Invalid measurements (usually between 01:30 and 02:00) have been removed during data ratification. This can be a serious source of data loss resulting in one hour out of twenty four being deleted, which is 4% of the annual data capture. At some sites significantly more data are being lost resulting in data capture below the 90% data capture target for the period.

The ESUs have investigated the autocalibration run-ons at many of the sites and tried different ways to resolve the problem including thorough cleaning of the solenoid valves and installation of Permapure or silica gel driers. In most cases this has improved the situation but it has not always eliminated the problem completely.

The 42 sites (47 analysers) showing continuing problems with the autocalibration run-on during July-September 2006 are given in Table 2.5. Any autocalibration run-on data that look visibly significant have been deleted from these data sets during ratification.

Table 2.5 Estimate of Spike or Dip due to Auto-calibration Run-on: July-September 2006

| Site | Pollutant | Run-On Conc | Autocal Conc | Hours lost | Period |
|----------------------|-----------------|-------------|--------------|------------|---------------|
| Blackpool Marton | CO | 0 | 40 | 1 | July and Sept |
| London Hillingdon | CO | 0.1 | 35 | 1 | July to Sept |
| London Southwark | CO | -1 | 48 | 4 | July to Sept |
| Stockport Shaw Heath | NO | 3 | 0 | 2 | July to Sept |
| Aberdeen | NO ₂ | 4 | 200 | 1 | July and Sept |

| | | | | | |
|------------------------|-----------------|-----|------|---|---------------|
| Aston Hill | NO ₂ | 0.6 | 300 | 1 | Sept |
| Belfast Centre | NO ₂ | 6 | 300 | 1 | July to Sept |
| Birmingham Centre | NO ₂ | 4 | 750 | 1 | July to Sept |
| Blackpool Marton | NO ₂ | 1 | 100 | 1 | July to Aug |
| Bournemouth | NO ₂ | 4 | 600 | 2 | July to Sept |
| Bury Roadside | NO ₂ | 12 | 350 | 1 | July to Sept |
| Derry | NO ₂ | 1 | 300 | 1 | July to Sept |
| Dumfries | NO ₂ | 6 | 400 | 2 | Aug |
| Edinburgh St Leonards | NO ₂ | 2 | 500 | 2 | July to Sept |
| Eskdalemuir | NO ₂ | 2.3 | 500 | 3 | July to Sept |
| Fort William | NO ₂ | 1 | 350 | 2 | July and Sept |
| Harwell | NO ₂ | 1.4 | 200 | 2 | July to Aug |
| Hull Freetown | NO ₂ | 4 | 200 | 1 | July to Sept |
| Leominster | NO ₂ | 3 | 500 | 2 | July to Sept |
| London Bloomsbury | NO ₂ | 6 | 700 | 1 | July to Sept |
| London Wandsworth | NO ₂ | 1 | 185 | 1 | July to Sept |
| Lullington Heath | NO ₂ | 2.5 | 300 | 1 | July to Sept |
| Newcastle Centre | NO ₂ | 4 | 300 | 1 | July to Sept |
| Oxford Centre Roadside | NO ₂ | 4 | 250 | 1 | July to Sept |
| Preston | NO ₂ | 3 | 500 | 1 | July to Sept |
| Southampton Centre | NO ₂ | 5 | 850 | 1 | July to Sept |
| St Osyth | NO ₂ | 2.9 | 300 | 2 | July to Sept |
| Thurrock | NO ₂ | 11 | 400 | 1 | July to Sept |
| West London | NO ₂ | 4 | 650 | 1 | July and Aug |
| Wirral Tranmere | NO ₂ | 3 | 300 | 1 | July to Sept |
| Wrexham | NO ₂ | 6 | 350 | 1 | July to Sept |
| | | | | | |
| Derry | O ₃ | -3 | 1000 | 1 | July to Sept |
| Stoke-on-Trent | O ₃ | -3 | 1000 | 1 | July to Sept |
| Wirral Tranmere | O ₃ | -5 | 600 | 1 | July to Sept |
| | | | | | |
| Derry | SO ₂ | 0 | 200 | 1 | July and Aug |
| London Brent | SO ₂ | 1 | 900 | 1 | July and Aug |
| London Marylebone Road | SO ₂ | 1 | 375 | 1 | July to Sept |
| London Southwark | SO ₂ | -1 | 800 | 4 | July to Sept |
| London Teddington | SO ₂ | 0.2 | 425 | 1 | Sept |
| Narberth | SO ₂ | 1.1 | 500 | 2 | July to Sept |
| Plymouth Centre | SO ₂ | 0 | 800 | 1 | July and Aug |
| Wirral Tranmere | SO ₂ | -1 | 450 | 1 | Aug and Sept |

Eskdalemuir NO_x and London Southwark CO and SO₂ should be prioritised as several hours per day are being lost at these sites. Eskdalemuir was highlighted as a problem in both the January-March and April to June QA/QC reports. Several sites continue to have autocalibration span concentrations set too high (eg Southampton Centre and Birmingham Centre-NO₂ and London Brent, London Southwark and Plymouth Centre-SO₂). These should be adjusted, where possible, at the next opportunity.

Recommendations

ESU to investigate and minimise effect where possible, especially at sites with large autocalibration run-ons or where data loss is in excess of 1 hour.

QA/QC Unit and CMCU have held meetings with the Equipment Support Units to discuss the autocalibration run-ons and to identify ways to resolve the problem. Solutions to the problems have been identified in many cases, and the necessary hardware upgrades are being installed either at routine services, or through call-outs.

Stockport Shaw Heath, Bournemouth, Dumfries, Edinburgh, Eskdalemuir, Fort William, Harwell, St Osyth and Leominster (all NO₂), London Southwark (CO and SO₂), Narberth (SO₂) should be prioritised as at least 2 hours per day are being lost at these sites. Eskdalemuir and Leominster have been highlighted as a priority in previous reports.


In the meantime, we recommend that the autocalibration devices be adjusted at the problem sites to reduce the concentration of the span gas. It is strongly advised that NO₂ autocalibration span concentrations of less than 200ppb (urban sites) and 100ppb (rural sites) are used throughout the network.

3 Site Specific Issues

3.1 Cwmbran SO₂

The SO₂ analyser at Cwmbran has showed an unstable and erratic response since early summer 2006. This is shown in Figure 3.1.

Figure 3.1 Cwmbran SO₂ mV plot



The air conditioning unit has been reported as blowing warm air by the ESU on 26 July, and it is likely that excessive temperature contributed to the unstable response.

Recommendation

The air conditioning unit at the Cwmbran site should be repaired or replaced as soon as possible, and in any case before the onset of warmer weather.

3.2 Bolton NO_x

The Bolton NO_x analyser converter efficiency was measured as 104.6% at the summer 2006 QA/QC audit, and 93% by the ESU in September. It is possible that the converter efficiency setting in the analyser software was set to a value other than 100%, which would mean the analyser was incorrectly scaling the data. Although the dataset was not entirely deleted in this case, ESUs should ensure that all converter settings in analyser software must be set to 100%.

Recommendation

ESUs to ensure software settings (where applicable) for converter efficiencies to be set at 100%

3.3 Other Analysers Highlighted in Recent Reports

Several analysers have been highlighted recently as being of concern to the QA/QC unit. An update is given in Table 3.2

Table 3.2 Status of Analysers Highlighted in Previous Reports

| Site | Analyser | Fault | Current status |
|--------------------|-----------------------|---|---|
| Glazebury | O ₃ | Analyser drift | Appears to be repaired; will be checked at next audit |
| Bolton | NO _x | Various | See Section 3.2 above |
| London Westminster | CO | Unstable response | Continued poor quality data deleted up to 20 September |
| Reading New Town | NO ₂ | PMT cooler | Now OK |
| Weybourne | O ₃ | No manual calibrations or IZS | No progress reported |
| Salford Eccles | CO | Constant zero baseline | No progress reported |
| Rural CO analysers | CO | Baseline drift | Drift still evident |
| Wicken Fen | O ₃ | Flow | Now fixed |
| Norwich Centre | SO ₂ | Large step change between old and replacement analysers | Situation is being closely monitored |
| Bush | NO _x | Succession of analyser faults | Poor performing analyser failed again on 6 July (24.8 days lost). |
| Narberth | O ₃ | Leak | Quality of O ₃ data still uncertain; significant outlier at summer 2006 audit. Installation of duplicate analyser still awaited. |
| Various | Rural ozone analysers | Temporary instruments installed some of which have no autocal | Two analysers have been upgraded by the manufacturer and are currently under test by the ESU |

Recommendation

QA/QC Unit would like to seek clarification from the Equipment Support Unit/manufacturer as to the current situation regarding the reason for the problems and what plans are in place to resolve them. We recommend that immediate attention is given to this issue as the majority of these instruments are located at critical sites.

4 Sites with Data Capture Below 90%

4.1 Sites with Low Data Capture

The following section provides a summary of the main site analyser operational problems, which have resulted in data capture below the required 90% level during the reporting period July-September 2006 (Table 4.1). The number of days and hours of data lost for each cause is also given. In some cases the data gap extends beyond this three-month reporting period.

Table 4.1 Sites with data capture below 90% July-September 2006
(Using the start date of any new site or end date of site closed)

| Pollutant | Data Capture (%) | Start date | End date | Reason | Comments | Number of days | Number of hours |
|---------------------------|------------------|-------------|-----------|-------------------------|---|---------------------------------|-----------------|
| England | | | | | | | |
| Barnsley 12 | | | | | | | |
| SO2 | 69.90% | 27-Jun-06 | 27-Jul-06 | Unstable response | poor analyser performance | 30 | 721 |
| | | 16-Aug-06 | 17-Aug-06 | ESU service | | 1 | 23 |
| Blackpool Marton | | | | | | | |
| CO | 88.50% | 14-Aug-06 | 17-Aug-06 | Instrument fault | Ambirak power failure. Replaced power supply and cooling fan ENG C/O Replaced pump | 3.3 | 78 |
| | | 5-Sep-06 | 7-Sep-06 | Sampling fault | | 2.4 | 57 |
| | | 19-Sep-06 | 21-Sep-06 | ESU service | | 2 | 49 |
| NO2 | 86.00% | 14-Aug-06 | 21-Aug-06 | Instrument fault | ENG C/O Ambirak power failure. Replaced power supply and cooling fan | 6.8 | 164 |
| | | 27-Aug-06 | 27-Aug-06 | Data gap | | 0.3 | 7 |
| | | 19-Sep-06 | 22-Sep-06 | ESU service | | 2.6 | 63 |
| | | 14-Aug-06 | 7-Sep-06 | Air Conditioning fault | | Unstable response | 24.3 |
| 19-Sep-06 | 21-Sep-06 | ESU service | 2 | 49 | | | |
| Bolton | | | | | | | |
| NO2 | 77.50% | 10-Sep-06 | 30-Sep-06 | ESU service | | 20 | 481 |
| SO2 | 83.90% | 20-Jul-06 | 20-Jul-06 | Data gap | | 0.3 | 6 |
| | | 20-Jul-06 | 21-Jul-06 | Data gap | | 0.9 | 21 |
| | | 21-Jul-06 | 22-Jul-06 | Data gap | | 1.1 | 27 |
| | | 23-Jul-06 | 23-Jul-06 | Data gap | | 0.3 | 6 |
| | | 25-Jul-06 | 27-Jul-06 | Data gap | | 1.7 | 41 |
| | | 29-Jul-06 | 31-Jul-06 | Switched out-of-service | ENG C/O Cooler fault | 2 | 47 |
| | | 23-Aug-06 | 25-Aug-06 | Data gap | | 1.4 | 34 |
| | | 25-Aug-06 | 28-Aug-06 | Data gap | | 3.8 | 90 |
| | | 21-Sep-06 | 22-Sep-06 | ESU service | | 1 | 25 |
| Bradford Centre | | | | | | | |
| SO2 | 84.40% | 18-Jul-06 | 26-Jul-06 | Air Conditioning fault | Call out: A/C unit failed | 8 | 192 |
| | | 16-Aug-06 | 18-Aug-06 | ESU service | | 2.4 | 57 |
| | | 3-Sep-06 | 6-Sep-06 | Low flow rate | | ENG C/O Replaced pump diaphragm | 3.4 |
| Brentford Roadside | | | | | | | |

| Pollutant | Data Capture (%) | Start date | End date | Reason | Comments | Number of days | Number of hours |
|--------------------|------------------|--------------|------------|------------------------|---|----------------|-----------------|
| CO | 87.60% | 12-Jun-06 | 5-Jul-06 | Air Conditioning fault | site turned off | 23 | 553 |
| | | 21-Jul-06 | 24-Jul-06 | Flat response | LSO reset at calibration. | 3.1 | 75 |
| | | 6-Aug-06 | 7-Aug-06 | Flat response | LSO reset at calibration. | 1 | 25 |
| | | 18-Sep-06 | 20-Sep-06 | Flat response | LSO reset at calibration. | 2 | 49 |
| NO2 | 79.40% | 3-Jun-06 | 5-Jul-06 | Air Conditioning fault | site turned off because of air conditioning fault. | 32.4 | 778 |
| | | 20-Jul-06 | 3-Aug-06 | Instrument fault | instrument step change + ozone pre heater required. | 14 | 337 |
| Bury Roadside | | | | | | | |
| CO | 28.80% | 27-Jul-06 | 23-Oct-06 | Unstable output | Poor data | 88.5 | 2123 |
| NO2 | 87.80% | 8-Aug-06 | 9-Aug-06 | ESU service | | 1.1 | 26 |
| | | 15-Aug-06 | 17-Aug-06 | Power cut | Power supply interruption | 1.9 | 46 |
| | | 5-Sep-06 | 7-Sep-06 | Logger fault | PC not logging site data | 1.7 | 40 |
| | | 28-Sep-06 | 23-Oct-06 | Logger fault | PC failure | 25.7 | 616 |
| O3 | 84.30% | 24-Jul-06 | 31-Jul-06 | Instrument fault | Faulty UV lamp | 6.8 | 163 |
| | | 8-Aug-06 | 9-Aug-06 | ESU service | Service - lamp board replaced | 1.1 | 26 |
| | | 15-Aug-06 | 17-Aug-06 | Power cut | Power supply interruption | 1.9 | 46 |
| | | 5-Sep-06 | 7-Sep-06 | Logger fault | PC not logging site data | 1.6 | 39 |
| 28-Sep-06 | 23-Oct-06 | Logger fault | PC failure | 25.7 | 616 | | |
| Cambridge Roadside | | | | | | | |
| NO2 | 76.90% | 4-Jul-06 | 6-Jul-06 | Monitoring suspended | LSO turned off power due to water leak. | 1.9 | 45 |
| | | 2-Aug-06 | 21-Aug-06 | Sampling fault | Internal sampling between cals | 19 | 457 |
| Camden Kerbside | | | | | | | |
| PM10 | 63.90% | 22-Jul-06 | 28-Jul-06 | Sampling fault | ENG C/O Water ingress into analyser. | 6.3 | 151 |
| | | 24-Aug-06 | 19-Sep-06 | High noise | Recalibrated Eng C/O All connector & boards removed & refitted. | 26.4 | 634 |
| Haringey Roadside | | | | | | | |
| PM10 | 81.80% | 13-Sep-06 | 29-Sep-06 | Sampling fault | PM10 main and total flows out by -13% failed both leak tests at audit | 16.2 | 388 |
| Hove Roadside | | | | | | | |
| NO2 | 71.70% | 5-Sep-06 | 3-Oct-06 | Instrument fault | unknown instrument fault. | 28.4 | 681 |
| Hull Freetown | | | | | | | |
| CO | 87.90% | 23-Jul-06 | 26-Jul-06 | Instrument fault | Optical bench fault | 3.1 | 74 |
| | | 21-Sep-06 | 28-Sep-06 | Instrument fault | Faulty power supply | 7.4 | 177 |
| Ladybower | | | | | | | |
| NO2 | 36.70% | 25-May-06 | 24-Aug-06 | Logger fault | Logger channel corrupt | 91.1 | 2187 |
| | | 27-Sep-06 | 20-Oct-06 | ESU service | | 23.2 | 556 |
| Leamington Spa | | | | | | | |
| SO2 | 63.00% | 4-Jul-06 | 5-Jul-06 | Flat response | Data deleted | 0.3 | 8 |
| | | 3-Aug-06 | 4-Aug-06 | ESU service | | 1.1 | 27 |
| | | 30-Aug-06 | 11-Oct-06 | Instrument fault | ENG C/O UV lamp not lit - suspect Lamp driver board. | 42.4 | 1018 |
| Leominster | | | | | | | |

| Pollutant | Data Capture (%) | Start date | End date | Reason | Comments | Number of days | Number of hours |
|------------------------|------------------|------------|-----------|-------------------------------|--|----------------|-----------------|
| NO2 | 90.00% | 1-Aug-06 | 2-Aug-06 | Power cut | | 1.1 | 26 |
| | | 7-Aug-06 | 8-Aug-06 | Power cut | | 0.6 | 15 |
| | | 21-Sep-06 | 22-Sep-06 | Logger fault | No data collected | 0.7 | 16 |
| Liverpool Speke | | | | | | | |
| NO2 | 77.00% | 2-Jul-06 | 7-Jul-06 | Air Conditioning fault | | 4.4 | 106 |
| | | 14-Jul-06 | 26-Jul-06 | Air Conditioning fault | | 11.3 | 271 |
| | | 17-Aug-06 | 19-Aug-06 | Data gap | | 2.7 | 64 |
| | | 12-Sep-06 | 12-Sep-06 | QA/QC audit | | 0.3 | 7 |
| | | 26-Sep-06 | 28-Sep-06 | ESU service | | 2 | 49 |
| PM10 | 89.50% | 30-Jun-06 | 3-Jul-06 | Flat response | | 2.9 | 69 |
| | | 2-Aug-06 | 3-Aug-06 | Instrument fault | ENG C/O Fixed locking up TEOM | 1.5 | 37 |
| | | 17-Aug-06 | 19-Aug-06 | Data gap | | 2.5 | 61 |
| | | 12-Sep-06 | 12-Sep-06 | QA/QC audit | | 0.3 | 7 |
| | | 26-Sep-06 | 28-Sep-06 | ESU service | | 2 | 49 |
| SO2 | 77.60% | 14-Aug-06 | 19-Aug-06 | Air Conditioning fault | | 5.8 | 138 |
| | | 12-Sep-06 | 12-Sep-06 | QA/QC audit | | 0.3 | 7 |
| | | 14-Sep-06 | 28-Sep-06 | Instrument fault | ENG C/O Replaced UV lamp | 14 | 337 |
| London Bexley | | | | | | | |
| NO2 | 77.60% | 1-Jul-06 | 5-Jul-06 | Data gap | Possible air conditioning fault. | 3.9 | 94 |
| | | 3-Aug-06 | 16-Aug-06 | Pump fault | Eng C/O serviced pump + audit findings. | 13.5 | 325 |
| | | 30-Aug-06 | 1-Sep-06 | ESU service | | 2.1 | 50 |
| London Bromley | | | | | | | |
| NO2 | 26.50% | 19-Apr-06 | 6-Sep-06 | Instrument removed for repair | | 141 | 3372 |
| London Cromwell Road 2 | | | | | | | |
| SO2 | 83.70% | 2-Jul-06 | 15-Jul-06 | Air Conditioning fault | ENG C/O SO2 Data flagged bad.UV lamp adjusted | 12.5 | 300 |
| | | 26-Sep-06 | 27-Sep-06 | Power cut | | 0.8 | 18 |
| | | 30-Sep-06 | 17-Oct-06 | Instrument fault | Eng C/O flow fault and service | 17.3 | 414 |
| London Hackney | | | | | | | |
| CO | 71.00% | 13-Aug-06 | 22-Aug-06 | Power cut | | 8.5 | 203 |
| | | 13-Sep-06 | 2-Oct-06 | Power cut | | 19.6 | 470 |
| NO2 | 73.60% | 2-Jul-06 | 2-Jul-06 | Air Conditioning fault | | 0.4 | 9 |
| | | 3-Jul-06 | 3-Jul-06 | Air Conditioning fault | | 0.3 | 7 |
| | | 17-Jul-06 | 30-Jul-06 | Air Conditioning fault | | 13.7 | 329 |
| | | 13-Aug-06 | 22-Aug-06 | Power cut | Power fault | 8.5 | 203 |
| O3 | 0.00% | 1-Jan-06 | 2-Oct-06 | Instrument fault | | 275 | 6591 |
| London Hillingdon | | | | | | | |
| NO2 | 87.90% | 6-Jul-06 | 6-Jul-06 | QAQC audit | Calibration + AUDIT | 0.3 | 6 |
| | | 24-Jul-06 | 3-Aug-06 | Instrument fault | zero step change follows follows service - reset at Eng C/O | 10.2 | 245 |
| London Marylebone Road | | | | | | | |
| CO | 26.70% | 4-Jul-06 | 5-Jul-06 | Instrument fault | ENG C/O Replaced Moleculite zero scrubbing material replaced | 0.7 | 16 |

| Pollutant | Data Capture (%) | Start date | End date | Reason | Comments | Number of days | Number of hours |
|------------------------|------------------|------------|-----------|---|--|----------------|-----------------|
| | | 26-Jul-06 | 18-Oct-06 | Instrument fault | ENG C/O Zero problem. | 84.1 | 2019 |
| London Southwark | | | | | | | |
| CO | 73.10% | 18-Jul-06 | 31-Jul-06 | Air Conditioning fault | LSO turned pump off as ambient temp was too hot | 13.3 | 319 |
| | | 4-Sep-06 | 5-Sep-06 | ESU service | | 1.1 | 27 |
| O3 | 64.60% | 1-Jan-06 | 31-Jul-06 | ESU service | | 212 | 5088 |
| | | 4-Sep-06 | 5-Sep-06 | ESU service | | 1.1 | 27 |
| SO2 | 85.70% | 4-Sep-06 | 5-Sep-06 | ESU service | | 1.1 | 27 |
| London Westminster | | | | | | | |
| CO | 11.30% | 26-Feb-06 | 20-Sep-06 | High noise | Noisy response | 207 | 4958 |
| SO2 | 87.90% | 20-Jul-06 | 25-Jul-06 | Pump fault | Call out: SO2 flow fault. | 5.8 | 139 |
| | | 9-Sep-06 | 11-Sep-06 | Low flow rate | ENG C/O Cleaned sample/cal valves - flow and pressure now OK | 2 | 49 |
| | | 18-Sep-06 | 20-Sep-06 | ESU service | | 2.2 | 52 |
| Manchester Piccadilly | | | | | | | |
| SO2 | 88.10% | 21-Aug-06 | 31-Aug-06 | Air Conditioning fault | | 9.7 | 232 |
| Norwich Centre | | | | | | | |
| PM10 | 0.00% | 18-Jun-06 | 9-Oct-06 | Ko 8% out at audit; poor quality data deleted | | 113 | 2716 |
| Norwich Forum Roadside | | | | | | | |
| NO2 | 74.10% | 14-Jul-06 | 18-Jul-06 | Logger fault | | 4.2 | 101 |
| | | 4-Aug-06 | 10-Aug-06 | Logger fault | Logger replaced | 6 | 144 |
| | | 1-Sep-06 | 13-Sep-06 | Instrument fault | PSU problem fragmented data | 12.5 | 301 |
| Plymouth Centre | | | | | | | |
| O3 | 63.10% | 20-Feb-06 | 3-Aug-06 | ESU service | | 164 | 3937 |
| PM10 | 24.80% | 5-Jul-06 | 6-Jul-06 | High noise | Bad filter change 15.15 to 11.30 on 6 Jul | 0.9 | 22 |
| | | 22-Jul-06 | 28-Sep-06 | Instrument fault | Data rejected by QA/QC to 28th September. | 68 | 1633 |
| Preston | | | | | | | |
| NO2 | 81.80% | 1-Jul-06 | 6-Jul-06 | Unstable response | Unstable baseline deleted | 5 | 121 |
| | | 25-Jul-06 | 26-Jul-06 | Unstable response | Unstable baseline deleted | 0.5 | 13 |
| | | 21-Sep-06 | 22-Sep-06 | Unstable response | Unstable baseline deleted | 0.5 | 12 |
| | | 25-Sep-06 | 5-Oct-06 | ESU service | | 10.2 | 244 |
| Reading New Town | | | | | | | |
| NO2 | 83.60% | 4-Jul-06 | 5-Jul-06 | Power cut | | 1 | 23 |
| | | 11-Jul-06 | 11-Jul-06 | QAQC audit | | 0.3 | 6 |
| | | 16-Jul-06 | 28-Jul-06 | ESU service | | 11.5 | 276 |
| | | 9-Sep-06 | 10-Sep-06 | Logger fault | possible logger fault | 1.8 | 44 |
| PM10 | 89.10% | 4-Jul-06 | 5-Jul-06 | Power cut | Probable power cut. | 1 | 24 |
| | | 11-Jul-06 | 11-Jul-06 | QAQC audit | | 0.3 | 6 |
| | | 17-Jul-06 | 21-Jul-06 | ESU service | | 4.1 | 98 |
| | | 1-Aug-06 | 3-Aug-06 | Unstable response | TEOM response fault after LSO routine cal. | 2 | 47 |
| | | 9-Sep-06 | 10-Sep-06 | Logger fault | possible logger fault | 1.8 | 44 |
| SO2 | 88.50% | 4-Jul-06 | 5-Jul-06 | Power cut | possible power cut | 0.9 | 22 |
| | | 17-Jul-06 | 22-Jul-06 | ESU service | | 6 | 143 |

| Pollutant | Data Capture (%) | Start date | End date | Reason | Comments | Number of days | Number of hours |
|---------------------------|------------------|------------|-----------|---------------------------------|--|----------------|-----------------|
| | | 27-Jul-06 | 28-Jul-06 | ESU service | | 1.1 | 26 |
| | | 9-Sep-06 | 10-Sep-06 | Logger fault | possible logger fault | 1.9 | 45 |
| Redcar | | | | | | | |
| PM10 | 81.60% | 15-Jul-06 | 16-Jul-06 | Air Conditioning fault | Site power tripping due to a/c fault | 0.9 | 21 |
| | | 17-Aug-06 | 18-Aug-06 | Air Conditioning fault | Site power tripping due to a/c fault | 1 | 24 |
| | | 9-Sep-06 | 22-Sep-06 | ESU service | | 13.3 | 318 |
| | | 29-Sep-06 | 2-Oct-06 | Air Conditioning fault | Site power tripping due to a/c fault | 2.6 | 62 |
| Rotherham Centre | | | | | | | |
| NO2 | 49.00% | 3-Jun-06 | 16-Aug-06 | Air Conditioning fault | Data rejected up to service | 74.6 | 1790 |
| SO2 | 40.40% | 3-Jun-06 | 24-Aug-06 | ESU service | | 82.5 | 1979 |
| | | 12-Sep-06 | 12-Sep-06 | Instrument fault | ENG C/O Reduced Signal Ref. & PMT High Volts | 0.3 | 7 |
| Salford Eccles | | | | | | | |
| CO | 63.60% | 26-Jul-06 | 27-Jul-06 | Data gap | No data collected | 1.2 | 28 |
| | | 30-Aug-06 | 9-Oct-06 | ESU service | | 40.2 | 964 |
| O3 | 82.70% | 21-Jul-06 | 4-Aug-06 | Instrument fault | Leak in internal inline filter | 14.1 | 338 |
| | | 30-Aug-06 | 31-Aug-06 | ESU service | | 1.1 | 26 |
| Sheffield Centre | | | | | | | |
| NO2 | 40.70% | 1-May-06 | 24-Aug-06 | Rapid zero or sensitivity drift | rejected as QA/QC P3 action ENG C/O Replaced Air Con. | 115 | 2770 |
| SO2 | 89.10% | 1-Jul-06 | 7-Jul-06 | Unstable response | spurious data | 5.6 | 135 |
| | | 12-Jul-06 | 13-Jul-06 | Unstable response | spurious data | 0.4 | 10 |
| | | 22-Jul-06 | 23-Jul-06 | Data gap | | 1.3 | 30 |
| | | 22-Aug-06 | 24-Aug-06 | ESU service | | 2.1 | 51 |
| Somerton | | | | | | | |
| NO2 | 88.70% | 17-Jul-06 | 25-Jul-06 | Logger fault | ENG C/O Logger comms Fault. | 8.6 | 206 |
| | | 29-Jul-06 | 29-Jul-06 | Power cut | | 0.3 | 7 |
| | | 10-Aug-06 | 11-Aug-06 | Switched out-of-service | out of service after LSO cal | 1 | 25 |
| O3 | 89.90% | 17-Jul-06 | 25-Jul-06 | Logger fault | ENG C/O Logger comms Fault. | 8.5 | 204 |
| | | 29-Jul-06 | 29-Jul-06 | Power cut | | 0.3 | 7 |
| Southampton Centre | | | | | | | |
| CO | 52.10% | 11-Jul-06 | 22-Aug-06 | Baseline truncated | possible truncation and flow fault | 41.7 | 1001 |
| | | 29-Aug-06 | 31-Aug-06 | ESU service | | 2.1 | 50 |
| NO2 | 83.00% | 22-Aug-06 | 3-Sep-06 | Instrument fault | O3 gen failure | 11.9 | 286 |
| O3 | 89.90% | 29-Aug-06 | 7-Sep-06 | ESU service | | 8.7 | 208 |
| SO2 | 36.90% | 10-Jul-06 | 6-Sep-06 | Rapid zero or sensitivity drift | ENG C/O Investigated slow response. Replaced sample filter | 58 | 1392 |
| Southwark Roadside | | | | | | | |
| CO | 0.00% | 9-Feb-06 | 31-Dec-06 | | Site closed | 326 | 7812 |
| NO2 | 0.00% | 21-Feb-06 | 4-Jan-07 | | Site closed | 317 | 7617 |
| SO2 | 0.00% | 8-Feb-06 | 31-Dec-06 | | Site closed | 327 | 7846 |

| Pollutant | Data Capture (%) | Start date | End date | Reason | Comments | Number of days | Number of hours |
|-----------------------------|------------------|------------|-----------|------------------------|--|----------------|-----------------|
| Wigan Centre | | | | | | | |
| PM10 | 85.50% | 3-Jul-06 | 3-Jul-06 | Logger fault | Intermittent data loss - suspect logger fault | 0.3 | 7 |
| | | 4-Jul-06 | 4-Jul-06 | Logger fault | Intermittent data loss - suspect logger fault | 0.3 | 6 |
| | | 17-Jul-06 | 17-Jul-06 | Logger fault | Intermittent data loss - suspect logger fault | 0.3 | 7 |
| | | 31-Jul-06 | 3-Aug-06 | Logger fault | Intermittent data loss - suspect logger fault | 2.9 | 69 |
| | | 4-Aug-06 | 5-Aug-06 | Logger fault | Intermittent data loss - suspect logger fault | 0.8 | 20 |
| | | 10-Aug-06 | 16-Aug-06 | Logger fault | Missing data 10/8-14/8 Service 14/8-16/8 | 6.1 | 147 |
| SO2 | 87.10% | 23-Jun-06 | 5-Jul-06 | Instrument fault | UV Lamp fault and loose mirror | 12.5 | 300 |
| | | 10-Aug-06 | 16-Aug-06 | Logger fault | Missing data 10/8-14/8 Service 14/8-16/8 | 6.1 | 147 |
| Wirral Tranmere | | | | | | | |
| NO2 | 84.90% | 2-Jul-06 | 3-Jul-06 | Air Conditioning fault | | 0.9 | 22 |
| | | 15-Jul-06 | 15-Jul-06 | Air Conditioning fault | | 0.3 | 6 |
| | | 16-Jul-06 | 16-Jul-06 | Air Conditioning fault | | 0.3 | 7 |
| | | 18-Jul-06 | 20-Jul-06 | Air Conditioning fault | Call out: Recurring power trip out due to A/C fault. | 1.9 | 45 |
| | | 25-Jul-06 | 28-Jul-06 | Air Conditioning fault | ENG C/O Fixed air con | 2.8 | 66 |
| | | 31-Jul-06 | 31-Jul-06 | Air Conditioning fault | power out due to faulty aircon | 0.4 | 10 |
| | | 7-Sep-06 | 8-Sep-06 | Instrument fault | Unstable response-data deleted | 0.9 | 22 |
| O3 | 81.50% | 18-Sep-06 | 20-Sep-06 | ESU service | | 2 | 47 |
| | | 2-Jul-06 | 3-Jul-06 | Air Conditioning fault | power out due to aircon | 0.8 | 18 |
| | | 18-Jul-06 | 19-Jul-06 | Air Conditioning fault | power out due to aircon | 0.7 | 17 |
| | | 19-Jul-06 | 20-Jul-06 | Air Conditioning fault | Call out: Recurring power trip out due to A/C fault. | 1.1 | 27 |
| | | 25-Jul-06 | 2-Aug-06 | Air Conditioning fault | ENG C/O Fixed air con | 7.8 | 188 |
| | | 7-Sep-06 | 8-Sep-06 | Data gap | | 0.5 | 12 |
| PM10 | 86.10% | 18-Sep-06 | 20-Sep-06 | ESU service | | 2 | 47 |
| | | 1-Jul-06 | 5-Jul-06 | Instrument fault | ENG C/O Serviced the mass flow controllers | 3.9 | 93 |
| | | 8-Jul-06 | 9-Jul-06 | High noise | Noisy rsnose | 0.5 | 12 |
| | | 18-Jul-06 | 20-Jul-06 | Air Conditioning fault | | 1.9 | 45 |
| | | 25-Jul-06 | 27-Jul-06 | Air Conditioning fault | ENG C/O Fixed air con | 1.8 | 44 |
| | | 23-Aug-06 | 24-Aug-06 | Air Conditioning fault | power out due to aircon | 1.3 | 30 |
| SO2 | 87.70% | 7-Sep-06 | 8-Sep-06 | Air Conditioning fault | power out due to aircon | 0.9 | 21 |
| | | 18-Sep-06 | 20-Sep-06 | ESU service | | 2 | 47 |
| | | 2-Jul-06 | 3-Jul-06 | Air Conditioning fault | power out due to aircon | 0.7 | 17 |
| | | 18-Jul-06 | 19-Jul-06 | Air Conditioning fault | power out due to aircon | 0.7 | 17 |
| | | 19-Jul-06 | 20-Jul-06 | Air Conditioning fault | Call out: Recurring power trip out due to A/C fault. | 1.1 | 27 |
| | | 25-Jul-06 | 28-Jul-06 | Air Conditioning fault | ENG C/O Fixed air con | 2.8 | 67 |
| Wolverhampton Centre | | | | | | | |
| CO | 88.40% | 4-Sep-06 | 12-Sep-06 | ESU service | | 8.1 | 195 |
| | | 29-Sep-06 | 2-Oct-06 | Sampling fault | Call out: CO chopper failure | 3.5 | 83 |
| Yarner Wood | | | | | | | |
| NO2 | 75.30% | 2-Jul-06 | 24-Jul-06 | Logger fault | Erratic data following lightning strike - logger damaged | 22.3 | 534 |

| Pollutant | Data Capture (%) | Start date | End date | Reason | Comments | Number of days | Number of hours |
|------------------|------------------|------------|-----------|------------------------|--|----------------|-----------------|
| N | | | | | | | |
| Ireland | | | | | | | |
| Belfast Centre | | | | | | | |
| CO | 88.90% | 3-Sep-06 | 13-Sep-06 | Sampling fault | Broken manifold (3/9-11/9) & Service (11/9-13/9) | 9.6 | 230 |
| NO2 | 85.30% | 3-Sep-06 | 13-Sep-06 | Sampling fault | Broken manifold (3/9-11/9) & Service (11/9-13/9) | 9.6 | 230 |
| O3 | 89.10% | 3-Sep-06 | 13-Sep-06 | Sampling fault | Broken manifold (3/9-11/9) & Service (11/9-13/9) | 9.6 | 230 |
| PM10 | 88.30% | 3-Sep-06 | 13-Sep-06 | Sampling fault | Broken manifold (3/9-11/9) & Service (11/9-13/9) | 9.6 | 230 |
| SO2 | 89.10% | 3-Sep-06 | 13-Sep-06 | Sampling fault | Broken manifold (3/9-11/9) & Service (11/9-13/9) | 9.6 | 230 |
| Scotland | | | | | | | |
| Bush Estate | | | | | | | |
| NO2 | 72.30% | 6-Jul-06 | 31-Jul-06 | Low flow rate | Flow fault | 24.8 | 596 |
| Eskdalemuir | | | | | | | |
| NO2 | 86.80% | 4-Aug-06 | 6-Aug-06 | ESU service | | 1.7 | 41 |
| Fort William | | | | | | | |
| NO2 | 66.30% | 2-Aug-06 | 16-Aug-06 | Spurious data | Spurious NO2 baseline | 14 | 336 |
| | | 23-Aug-06 | 5-Sep-06 | Spurious data | Spurious NO2 baseline | 12.9 | 309 |
| O3 | 88.40% | 20-Sep-06 | 13-Oct-06 | Unstable response | Relay board fault | 22.9 | 549 |
| Glasgow Centre | | | | | | | |
| CO | 68.00% | 10-Jul-06 | 8-Aug-06 | Unstable response | Unstable response | 29 | 696 |
| SO2 | 80.10% | 10-Jul-06 | 12-Jul-06 | ESU service | | 1.9 | 46 |
| | | 8-Aug-06 | 24-Aug-06 | Sampling fault | Sample flow fault between calcs 8/8 & 24/8 | 16.1 | 386 |
| Glasgow Kerbside | | | | | | | |
| NO2 | 86.00% | 1-Jul-06 | 1-Jul-06 | Instrument fault | Negative data | 0.4 | 9 |
| | | 5-Jul-06 | 12-Jul-06 | ESU service | Rapid baseline drift following service | 6.9 | 165 |
| | | 17-Aug-06 | 22-Aug-06 | Instrument fault | transducer switch and O3 Gen replaced | 4.9 | 117 |
| PM10 | 80.00% | 1-Jul-06 | 7-Jul-06 | Unstable response | TEOM response instability | 6.5 | 157 |
| | | 10-Jul-06 | 12-Jul-06 | ESU service | | 2 | 49 |
| | | 8-Aug-06 | 17-Aug-06 | Instrument fault | ENG C/O Replaced mass transducer microswitch | 9.3 | 224 |
| Lerwick | | | | | | | |
| O3 | 89.80% | 8-Aug-06 | 9-Aug-06 | Power cut | | 1 | 23 |
| | | 21-Aug-06 | 29-Aug-06 | Low flow rate | zero flow due to blocked internal sinter filter | 8.4 | 201 |
| Wales | | | | | | | |
| Cardiff Centre | | | | | | | |
| SO2 | 88.30% | 17-Jul-06 | 19-Jul-06 | ESU service | | 2.2 | 52 |
| | | 22-Aug-06 | 29-Aug-06 | Air Conditioning fault | Unstable data | 7.5 | 180 |
| Cwmbran | | | | | | | |

| Pollutant | Data Capture (%) | Start date | End date | Reason | Comments | Number of days | Number of hours |
|-------------------------|------------------|------------|-----------|------------------------|---|----------------|-----------------|
| SO2 | 20.70% | 1-Jun-06 | 11-Sep-06 | Air conditioning fault | Very unstable data deleted | 103 | 2465 |
| Narberth | | | | | | | |
| O3 | 89.70% | 1-Jul-06 | 4-Jul-06 | Air conditioning fault | | 2.5 | 61 |
| | | 16-Jul-06 | 20-Jul-06 | Air conditioning fault | ENG C/O Call out: Replaced faulty AC | 4 | 97 |
| | | 24-Jul-06 | 26-Jul-06 | ESU service | | 2 | 49 |
| PM10 | 82.40% | 1-Jul-06 | 7-Jul-06 | Air conditioning fault | | 5.8 | 140 |
| | | 16-Jul-06 | 26-Jul-06 | Air conditioning fault | Replaced faulty aircon | 9.8 | 235 |
| SO2 | 85.40% | 1-Jul-06 | 3-Jul-06 | Air conditioning fault | | 2.1 | 50 |
| | | 16-Jul-06 | 20-Jul-06 | Air conditioning fault | ENG C/O Call out: Replaced faulty AC | 3.9 | 93 |
| | | 24-Jul-06 | 26-Jul-06 | ESU service | | 2 | 49 |
| Swansea | | | | | | | |
| CO | 31.10% | 17-Jul-06 | 19-Jul-06 | Power cut | | 2.1 | 51 |
| | | 7-Aug-06 | | Site closed | Relocated to Swansea Roadside | 122 | 2928 |
| NO2 | 31.00% | 17-Jul-06 | 19-Jul-06 | Power cut | | 2.1 | 51 |
| | | 7-Aug-06 | | Site closed | Relocated to Swansea Roadside | 122 | 2928 |
| O3 | 31.10% | 17-Jul-06 | 19-Jul-06 | Power cut | | 2.1 | 51 |
| | | 7-Aug-06 | | Site closed | Relocated to Swansea Roadside | 122 | 2928 |
| PM10 | 31.10% | 17-Jul-06 | 19-Jul-06 | Power cut | | 2.1 | 51 |
| | | 7-Aug-06 | | Site closed | Relocated to Swansea Roadside | 122 | 2928 |
| SO2 | 30.90% | 17-Jul-06 | 19-Jul-06 | Power cut | | 2.2 | 53 |
| | | 7-Aug-06 | | Site closed | Relocated to Swansea Roadside | 122 | 2928 |
| Swansea Roadside | | | | | | | |
| PM10 | 12.90% | | 29-Sep-06 | | Site commissioned | 272 | 6518 |
| PM25 | 12.90% | | 29-Sep-06 | | Site commissioned | 272 | 6518 |
| Wrexham | | | | | | | |
| SO2 | 88.60% | 21-Sep-06 | 30-Sep-06 | ESU service | | 9.7 | 233 |

5 Ratified Data Capture Statistics

Table 5.1 provides the ratified data capture figures for each site for the 3-month period July-September 2006. Data capture values below 90% are shown in the shaded boxes.

Table 5.1 Ratified Network Data Statistics: July-September 2006
(Using the start date of any new site or end date of site closed)

Network Data Capture for 01/07/2006 to 30/09/2006 from start date of any new site

| Site | Owner | CO | PM ₁₀ | NO ₂ | O ₃ | PM ₂₅ | SO ₂ | Site Average |
|-----------------|-----------|------|------------------|-----------------|----------------|------------------|-----------------|--------------|
| England | | | | | | | | |
| Barnsley 12 | DEFRA | - | - | - | - | - | 69.9 | 69.9 |
| Barnsley Gawber | Affiliate | 90.8 | - | 92.7 | 94.9 | - | 94.4 | 93.2 |
| Bath Roadside | Affiliate | 95.0 | - | 97.6 | - | - | - | 96.3 |
| Billingham | DEFRA | - | - | 93.6 | - | - | - | 93.6 |

| Site | Owner | CO | PM ₁₀ | NO ₂ | O ₃ | PM ₂₅ | SO ₂ | Site Average |
|------------------------|-----------|-------------|------------------|-----------------|----------------|------------------|-----------------|--------------|
| Birmingham Centre | DEFRA | 94.0 | 94.2 | 90.2 | 94.1 | - | 91.9 | 92.9 |
| Birmingham Tyburn | Affiliate | 98.2 | 98.2 | 91.5 | 98.2 | - | 98.2 | 96.9 |
| Blackpool Marton | DEFRA | 88.5 | 93.7 | 86.0 | 93.8 | - | 70.7 | 86.5 |
| Bolton | Affiliate | 98.3 | 96.9 | 77.5 | 98.0 | - | 83.9 | 90.9 |
| Bottesford | Affiliate | - | - | - | 99.7 | - | - | 99.7 |
| Bournemouth | Affiliate | 95.5 | 100.0 | 90.4 | 97.6 | - | 97.4 | 96.2 |
| Bradford Centre | DEFRA | 93.6 | 90.9 | 92.9 | 93.7 | - | 84.4 | 91.1 |
| Brentford Roadside | Affiliate | 87.6 | - | 79.4 | - | - | - | 83.5 |
| Brighton Preston Park | DEFRA | - | - | 99.5 | 92.7 | - | - | 96.1 |
| Brighton Roadside | Affiliate | 99.4 | - | 99.4 | - | - | - | 99.4 |
| Brighton Roadside PM10 | Affiliate | - | 93.5 | - | - | - | - | 93.5 |
| Bristol Old Market | Affiliate | 98.4 | - | 98.4 | - | - | - | 98.4 |
| Bristol St Paul's | DEFRA | 97.2 | 94.2 | 97.0 | 97.2 | - | 97.2 | 96.6 |
| Bury Roadside | Affiliate | 28.8 | 91.6 | 87.8 | 84.3 | - | 91.6 | 76.8 |
| Cambridge Roadside | Affiliate | - | - | 76.9 | - | - | - | 76.9 |
| Camden Kerbside | Affiliate | - | 63.9 | 93.0 | - | - | - | 78.4 |
| Canterbury | Affiliate | - | 99.5 | 99.4 | - | - | - | 99.4 |
| Coventry Memorial Park | DEFRA | 98.1 | 97.7 | 98.6 | 97.5 | - | 98.2 | 98.0 |
| Exeter Roadside | Affiliate | 99.3 | - | 98.7 | 92.3 | - | 99.3 | 97.4 |
| Glazebury | DEFRA | - | - | 96.9 | 97.2 | - | - | 97.1 |
| Great Dun Fell | DEFRA | - | - | - | 98.4 | - | - | 98.4 |
| Haringey Roadside | Affiliate | - | 81.8 | 99.2 | - | - | - | 90.5 |
| Harwell | DEFRA | - | 97.8 | 91.4 | 97.8 | 97.9 | 97.4 | 96.5 |
| High Muffles | DEFRA | - | - | 96.7 | 93.5 | - | - | 95.1 |
| Hove Roadside | Affiliate | 99.3 | - | 71.7 | - | - | 99.3 | 90.1 |
| Hull Freetown | DEFRA | 87.9 | 98.9 | 95.1 | 99.4 | - | 99.3 | 96.1 |
| Ladybower | DEFRA | - | - | 36.7 | 97.0 | - | 91.6 | 75.1 |
| Leamington Spa | Affiliate | 97.6 | 97.6 | 97.6 | 97.6 | - | 63.0 | 90.7 |
| Leeds Centre | DEFRA | 98.0 | 99.8 | 94.3 | 99.2 | - | 99.2 | 98.1 |
| Leicester Centre | DEFRA | 98.3 | 97.7 | 98.1 | 98.2 | - | 98.3 | 98.1 |
| Leominster | DEFRA | - | - | 90.0 | 95.0 | - | - | 92.5 |
| Liverpool Speke | Affiliate | 94.0 | 89.5 | 77.0 | 94.0 | - | 77.6 | 86.4 |
| London A3 Roadside | DEFRA | 98.0 | 98.3 | 97.4 | - | - | - | 97.9 |
| London Bexley | Affiliate | 92.2 | 92.1 | 77.6 | 92.4 | - | 91.7 | 89.2 |
| London Bloomsbury | DEFRA | 97.2 | 99.5 | 95.0 | 98.8 | 99.4 | 99.4 | 98.2 |
| London Brent | Affiliate | 98.2 | 99.1 | 98.0 | 98.6 | - | 92.5 | 97.3 |
| London Bromley | Affiliate | - | - | 26.5 | - | - | - | 26.5 |
| London Cromwell Road 2 | DEFRA | 90.1 | - | 97.6 | - | - | 83.7 | 90.4 |
| London Eltham | Affiliate | - | 92.1 | 99.3 | 99.1 | - | 98.6 | 97.3 |
| London Hackney | Affiliate | 71.0 | - | 73.6 | 0.0 | - | - | 48.2 |
| London Haringey | Affiliate | - | - | - | 99.5 | - | - | 99.5 |
| London Harlington | Affiliate | 99.4 | 96.9 | 99.3 | 96.5 | - | - | 98.0 |
| London Hillingdon | DEFRA | 91.7 | 96.8 | 87.9 | 96.2 | - | 96.3 | 93.8 |
| London Lewisham | Affiliate | - | - | 90.5 | 99.5 | - | 99.5 | 96.5 |
| London Marylebone Road | Affiliate | 26.7 | 95.9 | 98.3 | 91.5 | 96.9 | 94.3 | 83.9 |
| London N. Kensington | Affiliate | 98.9 | 98.9 | 99.1 | 97.0 | - | 99.0 | 98.6 |
| London Southwark | Affiliate | 73.1 | - | 98.0 | 64.6 | - | 85.7 | 80.4 |
| London Teddington | Affiliate | - | - | 99.3 | 99.4 | - | 97.9 | 98.9 |

| Site | Owner | CO | PM ₁₀ | NO ₂ | O ₃ | PM ₂₅ | SO ₂ | Site Average |
|------------------------|-----------|-------------|------------------|-----------------|----------------|------------------|-----------------|--------------|
| London Wandsworth | Affiliate | - | - | 93.0 | 99.2 | - | - | 96.1 |
| London Westminster | DEFRA | 11.3 | 97.8 | 96.4 | 96.2 | - | 87.9 | 77.9 |
| Lullington Heath | DEFRA | - | - | 95.1 | 99.4 | - | 95.5 | 96.7 |
| Manchester Piccadilly | DEFRA | 95.7 | 94.7 | 94.5 | 95.6 | - | 88.1 | 93.8 |
| Manchester South | Affiliate | - | - | 95.7 | 96.5 | - | 96.4 | 96.2 |
| Manchester Town Hall | DEFRA | 95.7 | - | 98.6 | - | - | - | 97.1 |
| Market Harborough | DEFRA | 98.0 | - | 93.3 | 98.1 | - | - | 96.4 |
| Middlesbrough | Affiliate | 94.2 | 95.5 | 92.6 | 93.2 | - | 95.9 | 94.3 |
| Newcastle Centre | DEFRA | 99.3 | 99.2 | 95.0 | 99.3 | - | 99.3 | 98.4 |
| Northampton | Affiliate | 98.4 | 98.2 | 95.2 | 91.8 | - | 95.8 | 95.9 |
| Northampton PM10 | Affiliate | - | 85.9 | - | - | - | - | 85.9 |
| Norwich Centre | DEFRA | 99.5 | 0.0 | 99.5 | 99.5 | - | 99.6 | 79.6 |
| Norwich Forum Roadside | Affiliate | - | - | 74.1 | - | - | - | 74.1 |
| Nottingham Centre | DEFRA | 97.0 | 97.1 | 96.8 | 97.0 | - | 95.5 | 96.7 |
| Oxford Centre Roadside | Affiliate | 97.3 | - | 94.6 | - | - | 97.5 | 96.5 |
| Plymouth Centre | DEFRA | 90.5 | 24.8 | 96.4 | 63.1 | - | 94.3 | 73.8 |
| Portsmouth | Affiliate | 98.4 | 96.8 | 98.4 | 98.3 | - | 98.5 | 98.1 |
| Preston | DEFRA | 97.0 | 95.9 | 81.8 | 97.1 | - | 97.0 | 93.8 |
| Reading New Town | DEFRA | 90.4 | 89.1 | 83.6 | 90.9 | - | 88.5 | 88.5 |
| Redcar | Affiliate | 92.9 | 81.6 | 92.7 | 93.0 | - | 90.9 | 90.2 |
| Rochester | Affiliate | - | 98.1 | 98.6 | 98.6 | 98.5 | 91.4 | 97.0 |
| Rotherham Centre | Affiliate | - | - | 49.0 | 96.8 | - | 40.4 | 62.1 |
| Salford Eccles | Affiliate | 63.6 | 93.8 | 91.3 | 82.7 | - | 96.6 | 85.6 |
| Sandwell West Bromwich | Affiliate | 95.3 | - | 94.8 | 96.2 | - | 96.4 | 95.7 |
| Scunthorpe Town | Affiliate | - | 95.8 | - | - | - | 99.0 | 97.4 |
| Sheffield Centre | DEFRA | 95.9 | 96.0 | 40.7 | 95.9 | - | 89.1 | 83.5 |
| Sheffield Tinsley | DEFRA | 93.5 | - | 98.1 | - | - | - | 95.8 |
| Sibton | DEFRA | - | - | - | 98.7 | - | - | 98.7 |
| Somerton | Affiliate | - | - | 88.7 | 89.9 | - | - | 89.3 |
| Southampton Centre | DEFRA | 52.1 | 94.1 | 83.0 | 89.9 | - | 36.9 | 71.2 |
| Southend-on-Sea | DEFRA | 98.3 | 94.9 | 93.6 | 98.3 | - | 98.2 | 96.6 |
| Southwark Roadside | Affiliate | 0.0 | - | 0.0 | - | - | 0.0 | 0.0 |
| St Osyth | DEFRA | 97.1 | - | 91.6 | 94.7 | - | - | 94.5 |
| Stockport Shaw Heath | Affiliate | 98.6 | 98.5 | 92.9 | - | - | 98.7 | 97.2 |
| Stockton-on-Tees Yarm | Affiliate | 96.3 | 99.4 | 99.5 | - | - | - | 98.4 |
| Stoke-on-Trent Centre | DEFRA | 94.9 | 95.2 | 94.9 | 91.0 | - | 94.8 | 94.2 |
| Sunderland | DEFRA | - | - | - | - | - | 97.9 | 97.9 |
| Sunderland Silksworth | Affiliate | - | - | 97.5 | 98.5 | - | - | 98.0 |
| Thurrock | Affiliate | 95.4 | 96.2 | 90.1 | 96.0 | - | 95.8 | 94.7 |
| Tower Hamlets Roadside | Affiliate | 91.2 | - | 99.2 | - | - | - | 95.2 |
| Walsall Alumwell | DEFRA | - | - | 96.1 | - | - | - | 96.1 |
| Walsall Willenhall | Affiliate | - | - | 90.2 | - | - | - | 90.2 |
| West London | DEFRA | 99.7 | - | 96.9 | - | - | - | 98.3 |
| Weybourne | Affiliate | - | - | - | 99.9 | - | - | 99.9 |
| Wicken Fen | DEFRA | - | - | 98.9 | 91.4 | - | 94.0 | 94.8 |
| Wigan Centre | Affiliate | 91.4 | 85.5 | 92.8 | 91.3 | - | 87.1 | 89.6 |

| Site | Owner | CO | PM ₁₀ | NO ₂ | O ₃ | PM ₂₅ | SO ₂ | Site Average |
|--|-----------|-------------|------------------|-----------------|----------------|------------------|-----------------|--------------|
| Wirral Tranmere | DEFRA | 90.6 | 86.1 | 84.9 | 81.5 | - | 87.7 | 86.1 |
| Wolverhampton Centre | DEFRA | 88.4 | 97.0 | 93.2 | 97.2 | - | 97.2 | 94.6 |
| Yarner Wood | DEFRA | - | - | 75.3 | 96.0 | - | - | 85.6 |
| N Ireland | | | | | | | | |
| Belfast Centre | DEFRA | 88.9 | 88.3 | 85.3 | 89.1 | - | 89.1 | 88.1 |
| Belfast Clara St | Affiliate | - | 99.2 | - | - | - | - | 99.2 |
| Belfast East | DEFRA | - | - | - | - | - | 99.4 | 99.4 |
| Derry | Affiliate | 95.1 | 94.7 | 90.9 | 91.1 | - | 92.1 | 92.8 |
| Lough Navar | DEFRA | - | 98.3 | - | 98.8 | - | - | 98.6 |
| Scotland | | | | | | | | |
| Aberdeen | Affiliate | 97.6 | 97.4 | 94.0 | 97.4 | - | 97.5 | 96.8 |
| Auchencorth Moss | DEFRA | - | 94.6 | - | - | 94.6 | - | 94.6 |
| Bush Estate | DEFRA | - | - | 72.3 | 98.6 | - | - | 85.4 |
| Dumfries | DEFRA | 94.6 | 75.0 | 93.4 | - | - | - | 87.7 |
| Edinburgh St Leonards | DEFRA | 97.5 | 97.8 | 91.9 | 97.5 | - | 97.5 | 96.4 |
| Eskdalemuir | DEFRA | - | - | 86.8 | 97.9 | - | - | 92.4 |
| Fort William | DEFRA | - | - | 66.3 | 88.4 | - | - | 77.3 |
| Glasgow Centre | DEFRA | 68.0 | 93.1 | 97.4 | 97.4 | - | 80.1 | 87.2 |
| Glasgow City Chambers | DEFRA | 98.4 | - | 98.1 | - | - | - | 98.2 |
| Glasgow Kerbside | DEFRA | 97.4 | 80.0 | 86.0 | - | - | - | 87.8 |
| Grangemouth | Affiliate | 98.2 | 98.3 | 98.2 | - | - | 98.0 | 98.2 |
| Inverness | DEFRA | 99.0 | 98.9 | 98.5 | - | - | - | 98.8 |
| Lerwick | DEFRA | - | - | - | 89.8 | - | - | 89.8 |
| Strath Vaich | DEFRA | - | - | - | 98.6 | - | - | 98.6 |
| Wales | | | | | | | | |
| Aston Hill | DEFRA | - | - | 92.0 | 98.2 | - | - | 95.1 |
| Cardiff Centre | DEFRA | 97.2 | 91.3 | 97.1 | 97.3 | - | 88.3 | 94.2 |
| Cwmbran | Affiliate | 99.6 | 98.0 | 99.3 | 99.6 | - | 20.7 | 83.5 |
| Narberth | Affiliate | - | 82.4 | 90.8 | 89.7 | - | 85.4 | 87.1 |
| Port Talbot | Affiliate | - | 91.9 | 96.9 | 96.9 | - | 97.1 | 95.7 |
| Swansea | Affiliate | 75.2 | 75.3 | 75.0 | 75.2 | - | 74.9 | 75.1 |
| Swansea Roadside | Affiliate | 95.1 | 12.9 | 95.1 | 95.1 | 12.9 | 95.1 | 67.7 |
| Wrexham | DEFRA | 96.1 | 97.8 | 94.2 | - | - | 88.6 | 94.2 |
| Number of sites | | 79 | 73 | 112 | 90 | 6 | 77 | 128 |
| Number of sites < 90% | | 15 | 16 | 29 | 13 | 1 | 24 | 39 |
| Number of critical sites | | 32 | 34 | 46 | 46 | 0 | 29 | 62 |
| Number of critical sites < 90% | | 5 | 7 | 13 | 6 | 0 | 11 | 21 |
| Network Mean (%) | | 89.5 | 90.4 | 89.5 | 93.6 | 81.1 | 89.2 | 90.3 |

Shaded boxes are for data capture < 90%
 Bold data captures are for critical instruments and sites

Table 5.2 shows the ratified data capture statistics for each site for the 9-month period January-September 2006

Table 5.2 Ratified Network data Capture Statistics : January to September 2006

Network Data Capture for 01/01/2006 to 30/09/2006 from start date of any new site

| Site | Owner | CO | PM ₁₀ | NO ₂ | O ₃ | PM ₂₅ | SO ₂ | Site Average |
|------------------------------------|-----------|-------------|------------------|-----------------|----------------|------------------|-----------------|--------------|
| England | | | | | | | | |
| Barnsley 12 | DEFRA | - | - | - | - | - | 87.8 | 87.8 |
| Barnsley Gawber | Affiliate | 95.4 | - | 73.9 | 95.9 | - | 96.1 | 90.3 |
| Bath Roadside | Affiliate | 77.7 | - | 97.8 | - | - | - | 87.8 |
| Billingham | DEFRA | - | - | 97.5 | - | - | - | 97.5 |
| Birmingham Centre | DEFRA | 95.8 | 96.9 | 93.2 | 96.8 | - | 96.2 | 95.8 |
| Birmingham Tyburn | Affiliate | 98.4 | 95.0 | 82.9 | 98.3 | - | 98.4 | 94.6 |
| Blackpool Marton | DEFRA | 91.4 | 94.6 | 92.8 | 93.8 | - | 82.9 | 91.1 |
| Bolton | Affiliate | 98.0 | 97.6 | 64.4 | 98.0 | - | 85.1 | 88.6 |
| Bottesford | Affiliate | - | - | - | 99.6 | - | - | 99.6 |
| Bournemouth | Affiliate | 96.5 | 98.5 | 92.9 | 98.3 | - | 98.1 | 96.9 |
| Bradford Centre | DEFRA | 93.3 | 93.8 | 93.0 | 91.3 | - | 89.2 | 92.1 |
| Brentford Roadside | Affiliate | 60.6 | - | 82.1 | - | - | - | 71.3 |
| Brighton Preston Park | DEFRA | - | - | 98.7 | 96.2 | - | - | 97.4 |
| Brighton Roadside | Affiliate | 97.5 | - | 98.9 | - | - | - | 98.2 |
| Brighton Roadside PM ₁₀ | Affiliate | - | 97.4 | - | - | - | - | 97.4 |
| Bristol Old Market | Affiliate | 96.4 | - | 98.8 | - | - | - | 97.6 |
| Bristol St Paul's | DEFRA | 97.1 | 94.4 | 96.3 | 97.1 | - | 96.9 | 96.4 |
| Bury Roadside | Affiliate | 34.4 | 91.4 | 84.6 | 88.6 | - | 89.1 | 77.6 |
| Cambridge Roadside | Affiliate | - | - | 87.2 | - | - | - | 87.2 |
| Camden Kerbside | Affiliate | - | 81.4 | 96.1 | - | - | - | 88.7 |
| Canterbury | Affiliate | - | 99.1 | 98.7 | - | - | - | 98.9 |
| Coventry Memorial Park | DEFRA | 99.0 | 99.0 | 99.2 | 98.7 | - | 93.8 | 97.9 |
| Exeter Roadside | Affiliate | 98.5 | - | 96.7 | 96.2 | - | 88.3 | 94.9 |
| Glazebury | DEFRA | - | - | 97.3 | 98.4 | - | - | 97.8 |
| Great Dun Fell | DEFRA | - | - | - | 98.9 | - | - | 98.9 |
| Haringey Roadside | Affiliate | - | 82.3 | 95.5 | - | - | - | 88.9 |
| Harwell | DEFRA | - | 97.4 | 91.7 | 91.6 | 97.3 | 95.7 | 94.8 |
| High Muffles | DEFRA | - | - | 85.7 | 88.1 | - | - | 86.9 |
| Hove Roadside | Affiliate | 99.3 | - | 86.7 | - | - | 99.4 | 95.1 |
| Hull Freetown | DEFRA | 92.4 | 98.3 | 84.0 | 98.5 | - | 98.4 | 94.3 |
| Ladybower | DEFRA | - | - | 62.1 | 95.8 | - | 93.8 | 83.9 |
| Leamington Spa | Affiliate | 98.7 | 98.9 | 95.9 | 98.4 | - | 87.1 | 95.8 |
| Leeds Centre | DEFRA | 93.5 | 99.2 | 88.8 | 99.0 | - | 99.0 | 95.9 |
| Leicester Centre | DEFRA | 98.1 | 97.9 | 98.0 | 98.3 | - | 98.3 | 98.1 |
| Leominster | DEFRA | - | - | 91.2 | 95.2 | - | - | 93.2 |
| Liverpool Speke | Affiliate | 92.4 | 94.9 | 90.9 | 96.5 | - | 90.3 | 93.0 |
| London A3 Roadside | DEFRA | 96.9 | 98.1 | 97.4 | - | - | - | 97.5 |
| London Bexley | Affiliate | 96.5 | 88.3 | 90.0 | 95.7 | - | 96.3 | 93.4 |
| London Bloomsbury | DEFRA | 95.7 | 97.5 | 92.2 | 94.9 | 97.3 | 93.0 | 95.1 |
| London Brent | Affiliate | 98.6 | 99.0 | 98.0 | 98.7 | - | 94.3 | 97.7 |
| London Bromley | Affiliate | - | - | 46.6 | - | - | - | 46.6 |
| London Cromwell Road 2 | DEFRA | 95.1 | - | 89.6 | - | - | 91.9 | 92.2 |
| London Eltham | Affiliate | - | 96.5 | 99.0 | 96.7 | - | 96.7 | 97.2 |
| London Hackney | Affiliate | 89.7 | - | 78.2 | 0.0 | - | - | 56.0 |

| Site | Owner | CO | PM ₁₀ | NO ₂ | O ₃ | PM ₂₅ | SO ₂ | Site Average |
|------------------------------|-----------|------|------------------|-----------------|----------------|------------------|-----------------|--------------|
| London Haringey | Affiliate | - | - | - | 62.5 | - | - | 62.5 |
| London Harlington | Affiliate | 99.5 | 98.7 | 99.2 | 89.8 | - | - | 96.8 |
| London Hillingdon | DEFRA | 94.8 | 97.3 | 92.8 | 97.5 | - | 97.5 | 96.0 |
| London Lewisham | Affiliate | - | - | 92.0 | 99.5 | - | 97.3 | 96.3 |
| London Marylebone Road | Affiliate | 61.7 | 96.7 | 96.9 | 94.9 | 97.3 | 89.4 | 89.5 |
| London N. Kensington | Affiliate | 95.7 | 99.0 | 99.2 | 93.3 | - | 98.6 | 97.1 |
| London Southwark | Affiliate | 64.6 | - | 82.0 | 21.8 | - | 73.3 | 60.4 |
| London Teddington | Affiliate | - | - | 98.8 | 99.1 | - | 98.6 | 98.8 |
| London Wandsworth | Affiliate | - | - | 97.2 | 99.3 | - | - | 98.3 |
| London Westminster | DEFRA | 21.9 | 96.3 | 96.4 | 96.5 | - | 85.1 | 79.2 |
| Lullington Heath | DEFRA | - | - | 83.4 | 87.1 | - | 77.6 | 82.7 |
| Manchester Piccadilly | DEFRA | 93.5 | 95.9 | 96.7 | 88.2 | - | 94.5 | 93.8 |
| Manchester South | Affiliate | - | - | 84.4 | 97.7 | - | 96.0 | 92.7 |
| Manchester Town Hall | DEFRA | 32.2 | - | 83.6 | - | - | - | 57.9 |
| Market Harborough | DEFRA | 97.8 | - | 94.5 | 93.8 | - | - | 95.4 |
| Middlesbrough | Affiliate | 92.3 | 97.5 | 95.2 | 96.9 | - | 97.7 | 95.9 |
| Newcastle Centre | DEFRA | 98.5 | 98.1 | 89.3 | 98.4 | - | 98.6 | 96.6 |
| Northampton | Affiliate | 99.2 | 95.4 | 98.0 | 96.5 | - | 98.3 | 97.5 |
| Northampton PM ₁₀ | Affiliate | - | 91.9 | - | - | - | - | 91.9 |
| Norwich Centre | DEFRA | 99.6 | 57.3 | 99.6 | 99.6 | - | 99.6 | 91.1 |
| Norwich Forum Roadside | Affiliate | - | - | 90.0 | - | - | - | 90.0 |
| Nottingham Centre | DEFRA | 97.8 | 97.9 | 97.7 | 97.8 | - | 93.8 | 97.0 |
| Oxford Centre Roadside | Affiliate | 98.6 | - | 96.8 | - | - | 98.5 | 98.0 |
| Plymouth Centre | DEFRA | 95.7 | 60.9 | 80.7 | 39.7 | - | 91.8 | 73.7 |
| Portsmouth | Affiliate | 98.8 | 98.3 | 98.9 | 98.8 | - | 97.7 | 98.5 |
| Preston | DEFRA | 96.6 | 97.5 | 88.8 | 94.2 | - | 97.5 | 94.9 |
| Reading New Town | DEFRA | 95.6 | 92.9 | 70.9 | 93.2 | - | 93.2 | 89.2 |
| Redcar | Affiliate | 94.4 | 88.8 | 93.0 | 92.5 | - | 90.6 | 91.9 |
| Rochester | Affiliate | - | 91.3 | 91.2 | 98.7 | 98.3 | 96.1 | 95.1 |
| Rotherham Centre | Affiliate | - | - | 70.5 | 89.0 | - | 27.6 | 62.4 |
| Salford Eccles | Affiliate | 86.5 | 95.4 | 95.8 | 93.0 | - | 97.1 | 93.6 |
| Sandwell West Bromwich | Affiliate | 97.4 | - | 97.5 | 97.6 | - | 97.5 | 97.5 |
| Scunthorpe Town | Affiliate | - | 97.1 | - | - | - | 92.7 | 94.9 |
| Sheffield Centre | DEFRA | 97.5 | 96.5 | 38.2 | 97.4 | - | 92.0 | 84.3 |
| Sheffield Tinsley | DEFRA | 90.9 | - | 98.6 | - | - | - | 94.7 |
| Sibton | DEFRA | - | - | - | 99.3 | - | - | 99.3 |
| Somerton | Affiliate | - | - | 74.3 | 89.7 | - | - | 82.0 |
| Southampton Centre | DEFRA | 73.1 | 94.0 | 88.2 | 93.1 | - | 73.6 | 84.4 |
| Southend-on-Sea | DEFRA | 98.8 | 95.7 | 97.2 | 98.8 | - | 98.8 | 97.9 |
| Southwark Roadside | Affiliate | 14.3 | - | 18.8 | - | - | 13.9 | 15.7 |
| St Osyth | DEFRA | 89.7 | - | 93.4 | 97.5 | - | - | 93.6 |
| Stockport Shaw Heath | Affiliate | 98.7 | 98.6 | 95.3 | - | - | 98.8 | 97.8 |
| Stockton-on-Tees Yarm | Affiliate | 98.0 | 98.9 | 99.1 | - | - | - | 98.7 |
| Stoke-on-Trent Centre | DEFRA | 93.8 | 95.6 | 91.7 | 92.7 | - | 94.6 | 93.7 |
| Sunderland | DEFRA | - | - | - | - | - | 97.3 | 97.3 |
| Sunderland | Affiliate | - | - | 96.8 | 93.8 | - | - | 95.3 |

| Site | Owner | CO | PM ₁₀ | NO ₂ | O ₃ | PM ₂₅ | SO ₂ | Site Average |
|---------------------------------|-----------|-------------|------------------|-----------------|----------------|------------------|-----------------|--------------|
| Silksworth | | | | | | | | |
| Thurrock | Affiliate | 97.6 | 97.7 | 93.0 | 97.9 | - | 97.8 | 96.8 |
| Tower Hamlets Roadside | Affiliate | 89.0 | - | 99.5 | - | - | - | 94.2 |
| Walsall Alumwell | DEFRA | - | - | 97.3 | - | - | - | 97.3 |
| Walsall Willenhall | Affiliate | - | - | 85.8 | - | - | - | 85.8 |
| West London | DEFRA | 81.2 | - | 95.4 | - | - | - | 88.3 |
| Weybourne | Affiliate | - | - | - | 85.1 | - | - | 85.1 |
| Wicken Fen | DEFRA | - | - | 96.9 | 83.6 | - | 90.5 | 90.3 |
| Wigan Centre | Affiliate | 95.5 | 93.4 | 96.7 | 95.2 | - | 92.2 | 94.6 |
| Wirral Tranmere | DEFRA | 94.6 | 92.6 | 91.5 | 89.0 | - | 78.8 | 89.3 |
| Wolverhampton Centre | DEFRA | 91.6 | 97.3 | 95.6 | 97.3 | - | 97.2 | 95.8 |
| Yarner Wood | DEFRA | - | - | 87.8 | 98.0 | - | - | 92.9 |
| N Ireland | | | | | | | | |
| Belfast Centre | DEFRA | 80.5 | 93.5 | 89.8 | 93.7 | - | 92.6 | 90.0 |
| Belfast Clara St | Affiliate | - | 99.2 | - | - | - | - | 99.2 |
| Belfast East | DEFRA | - | - | - | - | - | 98.9 | 98.9 |
| Derry | Affiliate | 94.2 | 96.3 | 84.8 | 76.1 | - | 90.9 | 88.5 |
| Lough Navar | DEFRA | - | 98.2 | - | 98.5 | - | - | 98.4 |
| Scotland | | | | | | | | |
| Aberdeen | Affiliate | 98.7 | 93.2 | 96.2 | 98.7 | - | 98.4 | 97.0 |
| Auchencorth Moss | DEFRA | - | 87.9 | - | - | 87.9 | - | 87.9 |
| Bush Estate | DEFRA | - | - | 82.9 | 97.7 | - | - | 90.3 |
| Dumfries | DEFRA | 96.2 | 84.6 | 92.9 | - | - | - | 91.2 |
| Edinburgh St Leonards | DEFRA | 98.4 | 98.4 | 92.9 | 98.2 | - | 98.4 | 97.2 |
| Eskdalemuir | DEFRA | - | - | 88.9 | 98.6 | - | - | 93.7 |
| Fort William | DEFRA | - | - | 68.4 | 88.9 | - | - | 78.7 |
| Glasgow Centre | DEFRA | 88.0 | 91.0 | 97.8 | 98.0 | - | 92.1 | 93.4 |
| Glasgow City Chambers | DEFRA | 98.7 | - | 97.9 | - | - | - | 98.3 |
| Glasgow Kerbside | DEFRA | 94.7 | 83.3 | 90.3 | - | - | - | 89.4 |
| Grangemouth | Affiliate | 95.6 | 96.3 | 97.8 | - | - | 97.9 | 96.9 |
| Inverness | DEFRA | 99.1 | 89.7 | 98.8 | - | - | - | 95.9 |
| Lerwick | DEFRA | - | - | - | 95.7 | - | - | 95.7 |
| Strath Vaich | DEFRA | - | - | - | 96.8 | - | - | 96.8 |
| Wales | | | | | | | | |
| Aston Hill | DEFRA | - | - | 67.7 | 92.0 | - | - | 79.8 |
| Cardiff Centre | DEFRA | 98.0 | 94.0 | 96.3 | 97.7 | - | 94.6 | 96.1 |
| Cwmbran | Affiliate | 99.1 | 98.2 | 94.1 | 99.3 | - | 61.7 | 90.5 |
| Narberth | Affiliate | - | 90.3 | 95.0 | 91.9 | - | 78.6 | 89.0 |
| Port Talbot | Affiliate | - | 90.4 | 96.5 | 97.9 | - | 96.0 | 95.2 |
| Swansea | Affiliate | 86.3 | 93.3 | 90.8 | 93.1 | - | 86.1 | 89.9 |
| Swansea Roadside | Affiliate | 95.1 | 12.9 | 95.1 | 95.1 | 12.9 | 95.1 | 67.7 |
| Wrexham | DEFRA | 97.6 | 95.2 | 94.1 | - | - | 92.1 | 94.7 |
| Number of sites | | 79 | 73 | 112 | 90 | 6 | 77 | 128 |
| Number of sites < 90% | | 17 | 11 | 37 | 16 | 1 | 18 | 38 |
| Network Mean (%) | | 90.1 | 92.9 | 90.0 | 92.4 | 80.6 | 91.1 | 90.6 |

Shaded boxes are for data capture < 90%
 Bold data captures are for critical instruments and sites

Table 5.3 shows the ratified AURN data capture for the 62 operational **critical sites** in the network for the 9-month period January to September 2006. Sites with less than 90% data capture are shaded. This table contains the overall data capture for 9 months, regardless of when sites started or finished monitoring. A total of 13 critical sites had a data capture of less than 90%.

**Table 5.3 AURN Ratified Data Capture (%) for Critical Sites
January to September 2006**

Network Data Capture for 01/01/2006 to 30/09/2006 from start date of any new site

| Site | Owner | CO | PM ₁₀ | NO ₂ | O ₃ | SO ₂ | Site Average |
|------------------------------------|-----------|------|------------------|-----------------|----------------|-----------------|--------------|
| England | | | | | | | |
| Barnsley Gawber | Affiliate | 95.4 | - | 73.9 | 95.9 | 96.1 | 90.3 |
| Blackpool Marton | DEFRA | 91.4 | 94.6 | 92.8 | 93.8 | 82.9 | 91.1 |
| Bournemouth | Affiliate | 96.5 | 98.5 | 92.9 | 98.3 | 98.1 | 96.9 |
| Brighton Preston Park | DEFRA | - | - | 98.7 | 96.2 | - | 97.4 |
| Brighton Roadside PM ₁₀ | Affiliate | - | 97.4 | - | - | - | 97.4 |
| Canterbury | Affiliate | - | 99.1 | 98.7 | - | - | 98.9 |
| Coventry Memorial Park | DEFRA | 99.0 | 99.0 | 99.2 | 98.7 | 93.8 | 97.9 |
| Glazebury | DEFRA | - | - | 97.3 | 98.4 | - | 97.8 |
| Great Dun Fell | DEFRA | - | - | - | 98.9 | - | 98.9 |
| High Muffles | DEFRA | - | - | 85.7 | 88.1 | - | 86.9 |
| Hove Roadside | Affiliate | 99.3 | - | 86.7 | - | 99.4 | 95.1 |
| Hull Freetown | DEFRA | 92.4 | 98.3 | 84.0 | 98.5 | 98.4 | 94.3 |
| Leamington Spa | Affiliate | 98.7 | 98.9 | 95.9 | 98.4 | 87.1 | 95.8 |
| Leicester Centre | DEFRA | 98.1 | 97.9 | 98.0 | 98.3 | 98.3 | 98.1 |
| Leominster | DEFRA | - | - | 91.2 | 95.2 | - | 93.2 |
| Liverpool Speke | Affiliate | 92.4 | 94.9 | 90.9 | 96.5 | 90.3 | 93.0 |
| Newcastle Centre | DEFRA | 98.5 | 98.1 | 89.3 | 98.4 | 98.6 | 96.6 |
| Northampton | Affiliate | 99.2 | 95.4 | 98.0 | 96.5 | 98.3 | 97.5 |
| Northampton PM ₁₀ | Affiliate | - | 91.9 | - | - | - | 91.9 |
| Norwich Centre | DEFRA | 99.6 | 57.3 | 99.6 | 99.6 | 99.6 | 91.1 |
| Nottingham Centre | DEFRA | 97.8 | 97.9 | 97.7 | 97.8 | 93.8 | 97.0 |
| Oxford Centre Roadside | Affiliate | 98.6 | - | 96.8 | - | 98.5 | 98.0 |
| Plymouth Centre | DEFRA | 95.7 | 60.9 | 80.7 | 39.7 | 91.8 | 73.7 |
| Portsmouth | Affiliate | 98.8 | 98.3 | 98.9 | 98.8 | 97.7 | 98.5 |
| Preston | DEFRA | 96.6 | 97.5 | 88.8 | 94.2 | 97.5 | 94.9 |
| Reading New Town | DEFRA | 95.6 | 92.9 | 70.9 | 93.2 | 93.2 | 89.2 |
| Scunthorpe Town | Affiliate | - | 97.1 | - | - | 92.7 | 94.9 |
| Sheffield Centre | DEFRA | 97.5 | 96.5 | 38.2 | 97.4 | 92.0 | 84.3 |
| Sibton | DEFRA | - | - | - | 99.3 | - | 99.3 |
| Somerton | Affiliate | - | - | 74.3 | 89.7 | - | 82.0 |
| Southampton Centre | DEFRA | 73.1 | 94.0 | 88.2 | 93.1 | 73.6 | 84.4 |
| Southend-on-Sea | DEFRA | 98.8 | 95.7 | 97.2 | 98.8 | 98.8 | 97.9 |
| St Osyth | DEFRA | 89.7 | - | 93.4 | 97.5 | - | 93.6 |
| Stockton-on-Tees Yarm | Affiliate | 98.0 | 98.9 | 99.1 | - | - | 98.7 |
| Stoke-on-Trent | DEFRA | 93.8 | 95.6 | 91.7 | 92.7 | 94.6 | 93.7 |

| Site | Owner | CO | PM ₁₀ | NO ₂ | O ₃ | SO ₂ | Site Average |
|--|-----------|------|------------------|-----------------|----------------|-----------------|--------------|
| Centre | | | | | | | |
| Sunderland | DEFRA | - | - | - | - | 97.3 | 97.3 |
| Sunderland Silksworth | Affiliate | - | - | 96.8 | 93.8 | - | 95.3 |
| Thurrock | Affiliate | 97.6 | 97.7 | 93.0 | 97.9 | 97.8 | 96.8 |
| Wicken Fen | DEFRA | - | - | 96.9 | 83.6 | 90.5 | 90.3 |
| Wigan Centre | Affiliate | 95.5 | 93.4 | 96.7 | 95.2 | 92.2 | 94.6 |
| Wirral Tranmere | DEFRA | 94.6 | 92.6 | 91.5 | 89.0 | 78.8 | 89.3 |
| Yarner Wood | DEFRA | - | - | 87.8 | 98.0 | - | 92.9 |
| N Ireland | | | | | | | |
| Belfast Centre | DEFRA | 80.5 | 93.5 | 89.8 | 93.7 | 92.6 | 90.0 |
| Derry | Affiliate | 94.2 | 96.3 | 84.8 | 76.1 | 90.9 | 88.5 |
| Lough Navar | DEFRA | - | 98.2 | - | 98.5 | - | 98.4 |
| Scotland | | | | | | | |
| Aberdeen | Affiliate | 98.7 | 93.2 | 96.2 | 98.7 | 98.4 | 97.0 |
| Bush Estate | DEFRA | - | - | 82.9 | 97.7 | - | 90.3 |
| Dumfries | DEFRA | 96.2 | 84.6 | 92.9 | - | - | 91.2 |
| Edinburgh St Leonards | DEFRA | 98.4 | 98.4 | 92.9 | 98.2 | 98.4 | 97.2 |
| Eskdalemuir | DEFRA | - | - | 88.9 | 98.6 | - | 93.7 |
| Fort William | DEFRA | - | - | 68.4 | 88.9 | - | 78.7 |
| Glasgow Centre | DEFRA | 88.0 | 91.0 | 97.8 | 98.0 | 92.1 | 93.4 |
| Grangemouth | Affiliate | 95.6 | 96.3 | 97.8 | - | 97.9 | 96.9 |
| Inverness | DEFRA | 99.1 | 89.7 | 98.8 | - | - | 95.9 |
| Strath Vaich | DEFRA | - | - | - | 96.8 | - | 96.8 |
| Wales | | | | | | | |
| Aston Hill | DEFRA | - | - | 67.7 | 92.0 | - | 79.8 |
| Cardiff Centre | DEFRA | 98.0 | 94.0 | 96.3 | 97.7 | 94.6 | 96.1 |
| Cwmbran | Affiliate | 99.1 | 98.2 | 94.1 | 99.3 | 61.7 | 90.5 |
| Narberth | Affiliate | - | 90.3 | 95.0 | 91.9 | 78.6 | 89.0 |
| Swansea | Affiliate | 86.3 | 93.3 | 90.8 | 93.1 | 86.1 | 89.9 |
| Swansea Roadside | Affiliate | 95.1 | 12.9 | 95.1 | 95.1 | 95.1 | 78.6 |
| Wrexham | DEFRA | 97.6 | 95.2 | 94.1 | - | 92.1 | 94.7 |
| | | | | | | | |
| Number of sites | | 40 | 42 | 54 | 50 | 40 | 62 |
| Number of sites < 90% | | 5 | 5 | 18 | 7 | 7 | 13 |
| Number of critical sites | | 32 | 34 | 46 | 46 | 29 | 62 |
| Number of critical sites < 90% | | 3 | 3 | 15 | 6 | 5 | 13 |

RECOMMENDATION

Every effort should be made to ensure that data capture is maximised for the critical sites. LSOs and ESUs should undertake call-outs and repairs as soon as possible to avoid unnecessary data loss at these sites.

Appendices

Appendix A1: Recommendations for Upgrade or Replacement of Equipment

Appendix A2: Critical Sites in the AURN (January 2007)

Appendix A3: Inventory of Defra-Owned Equipment

Appendix A4: Summary of Recommendations

Appendix A1

Recommendations for Upgrade or Replacement of Equipment

As requested by the Department, QA/QC Unit has provided a list of suggestions for equipment that may need replacing or upgrading in the network. The following provides a summary of the outstanding issues to date since July 2005. Recommendations have been prioritised as follows:

| Priority | Definition | Time-scale |
|----------|---|----------------|
| High | Immediate action necessary to avoid compromising data capture/quality or safety. Critical sites should be treated as high priority. | Within 2 weeks |
| Medium | Essential but not immediate | 3-6 months |
| Low | Desirable but not essential | As appropriate |

*Note – QA/QC Unit's practice is to notify CMCU immediately of any high priority issues at the time of the event.

| | Recommendations January 2007 | Priority | Action |
|-------------------------------------|--|----------|--|
| 21 | The air conditioning unit at Cwmbran should be repaired or replaced as soon as possible, and in any case before the onset of warmer weather. | High | ESU to repair air conditioning |
| 22 | ESUs to ensure all NOx converter software settings to be 100% | High | ESUs to check at service |
| Recommendations October 2006 | | | |
| 20 | The noisy analysers at Bolton (NOx) and London Westminster (CO) should be repaired or replaced at the earliest opportunity | High | ESUs to repair or replace as appropriate |
| Recommendations July 2006 | | | |
| 19 | Weybourne O ₃ analyser should be upgraded to allow monthly LSO calibrations and daily autocalibrations | Medium | ESU to provide CMCU with quotation for necessary work |
| Recommendations April 2006 | | | |
| | None | | |
| Recommendations January 2006 | | | |
| 17 | The performance of CO analysers needs close attention by all parties, and poorly performing analysers replaced or upgraded | High | LSOs and CMCU to check performance carefully; ESU's to action repairs promptly |
| Recommendations July 2005 | | | |
| 14 | Several analysers still exhibit poor performance | High | Repair/replacement to be actioned by ESUs |
| 13 | Continuing problems with some autocal run-ons causing loss of up to 2 hours per day-see Section 2.4 | High | Many sites now cured, but some need attention at next ESU visit |

Appendix A2

Critical Sites In The AURN (January 2007)

Table A1 Critical Sites in Agglomerations

| Site Name | Agglomeration | Critical Pollutants | | |
|------------------------------------|---------------------------------|--|------------------|--------------------------------|
| | | DD1 | DD2 ⁷ | DD3 |
| Belfast Centre | Belfast Urban Area | NO ₂ | CO | NO ₂ O ₃ |
| Blackpool Marton | Blackpool Urban Area | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Bournemouth+ | Bournemouth Urban Area | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Brighton Preston Park | Brighton/Worthing/Littlehampton | | | NO ₂ O ₃ |
| Brighton Roadside PM ₁₀ | Brighton/Worthing/Littlehampton | PM ₁₀ | | |
| Bristol St Pauls | Bristol Urban Area | PM ₁₀ SO ₂ | | NO ₂ O ₃ |
| Cardiff Centre | Cardiff Urban Area | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Coventry Memorial Park+ | Coventry/Bedworth | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Edinburgh St Leonards | Edinburgh Urban Area | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Glasgow Centre | Glasgow Urban Area | SO ₂ | | NO ₂ O ₃ |
| Hove Roadside+ | Brighton/Worthing/Littlehampton | SO ₂ | | |
| Hull Freetown | Kingston upon Hull | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Leicester Centre | Leicester Urban Area | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Liverpool Speke | Liverpool Urban Area | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Newcastle Centre | Tyneside | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Nottingham Centre | Nottingham Urban Area | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Portsmouth+ | Portsmouth Urban Area | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Preston | Preston Urban Area | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Reading New Town | Reading/Wokingham Urban Area | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Sheffield Centre | Sheffield Urban Area | PM ₁₀ | | |
| Southampton Centre | Southampton Urban Area | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Southend-on-Sea | Southend Urban Area | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Stoke-on-Trent Centre | The Potteries | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Swansea Roadside+ | Swansea Urban Area | | CO | |
| Wirral Tranmere | Birkenhead Urban Area | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |

"+" indicates Affiliate site"

Note 7: Addresses CO, Benzene not included here

Table A2 Critical Sites in Zones

| Site Name | Zone | Critical Pollutant | | |
|------------------------------|-------------------------|---|------------------|--------------------------------|
| | | DD1 | DD2 ⁷ | DD3 |
| Aberdeen+ | North East Scotland | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Aston Hill | North Wales | | | NO ₂ O ₃ |
| Barnsley Gawber+ | Yorkshire & Humberside | NO ₂ | CO | NO ₂ O ₃ |
| Bush Estate | Central Scotland | | | NO ₂ O ₃ |
| Canterbury+ | South East | PM ₁₀ | | |
| Cwmbran+ | South Wales | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Derry+ | Northern Ireland | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Dumfries | Scottish Borders | NO ₂ PM ₁₀ | CO | |
| Eskdalemuir | Scottish Borders | | | NO ₂ O ₃ |
| Fort William | Highland | | | NO ₂ O ₃ |
| Glazebury | North West & Merseyside | | | NO ₂ O ₃ |
| Grangemouth+ | Central Scotland | NO ₂ PM ₁₀ SO ₂ | CO | |
| Great Dun Fell | North West & Merseyside | | | O ₃ ³ |
| High Muffles | Yorkshire & Humberside | | | NO ₂ O ₃ |
| Inverness | Highland | NO ₂ PM ₁₀ | | |
| Leamington Spa+ | West Midlands | PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Leominster | West Midlands | | | NO ₂ O ₃ |
| Lough Navar | Northern Ireland | | | O ₃ ³ |
| Narberth | South Wales | | | O ₃ ³ |
| Northampton+ | East Midlands | NO ₂ PM ₁₀ ² SO ₂ | CO | NO ₂ O ₃ |
| Northampton PM ₁₀ | East Midlands | PM ₁₀ | | |
| Norwich Centre | Eastern | | | NO ₂ O ₃ |
| Oxford Centre Roadside+ | South East | SO ₂ | CO | |
| Plymouth Centre | South West | PM ₁₀ | | |
| Scunthorpe Town+ | Yorkshire & Humberside | PM ₁₀ | | |
| Sibton | Eastern | | | O ₃ ³ |
| Somerton | South West | | | NO ₂ O ₃ |
| St Osyth | Eastern | | | NO ₂ O ₃ |
| Stockton-on-Tees Yarm+ | North East | NO ₂ PM ₁₀ | CO | |
| Strath Vaich | Highland | | | O ₃ ³ |
| Sunderland | North East | SO ₂ | | |
| Sunderland Silkworth+ | North East | | | NO ₂ O ₃ |
| Thurrock | Eastern | | | NO ₂ O ₃ |
| Wicken Fen | Eastern | | | NO ₂ O ₃ |
| Wigan Centre ⁺ | North West & Merseyside | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Wrexham | North Wales | NO ₂ PM ₁₀ SO ₂ | CO | |
| Yarner Wood | South West | | | NO ₂ O ₃ |

Total of 62 Critical Sites (25 in Agglomerations and 37 in Zones)
 51% of network stations critical under one or more Daughter Directives
 "+ indicates Affiliate site"

Note 3: DD3 Critical as Rural Background station
 Note 7: Addresses CO, Benzene not included here

Appendix A3

Inventory of Defra owned Equipment

An up-to-date inventory of Department-owned equipment used by the QA/QC Unit is provided below:

QA/QC Unit's inventory of Department-owned equipment, August 2006

| | |
|-------------------------|--|
| Computer software | The HIS (Heuristic Information System) software suite used for all data management. A few specific capabilities of HIS were developed in order to meet specific Department deliverables or requirements (examples include software for annual report analysis/compilation, for formatting/transmitting network data to archive or DDU and for reporting Directive compliance data to the EC). |
| Field support equipment | Field support equipment: 1 intercalibration equipment set (includes mass flow controllers and read-out unit) A second intercalibration (commissioned January 2001) UV photometers: API model M401 s/n 123- purchased April 1999 (on temporary loan to Siemens) API model 401 s/n 151 - purchased October 2000 API model 401 s/n 176 – purchased December 2002 (on temporary loan to Horiba) API model 401 s/n 290 – purchased May 2004 API model 401 s/n 291 – purchased May 2004 API model 401 s/n 292 purchased May 2004 API model 401 s/n 293 purchased May 2004 Mass flow controllers - purchased April 2002 (incorporated into existing audit dilution apparatus) 3 Drycal flow meters - purchased September 2002 1 Mass flow controller read-out unit to be incorporated in the audit dilution apparatus – purchased September 2002. A third intercalibration kit (commissioned May 2004) Drycal flow meter – purchased March 2004 Sabio 2010 dilution calibrator – purchased February 2005 Sabio 2020 zero air generator – purchased February 2005 Sabio 2030 ozone photometer – purchased February 2005 Sabio 2010 dilution calibrator – purchased June 2006 Sabio 2020 zero air generator – purchased June 2006 Sabio 2030 ozone photometer – purchased June 2006 |
| Zero air pumps | 6 spare zero air pumps for routine maintenance/repair of zero air generators in the AURN. |
| Analysers | AC31 dual chamber NO _x analyser TEI 43C SO ₂ analyser TEI 48C CO analyser M265 chemiluminescent ozone analyser (All of the above purchased on behalf of Defra by Casella Stanger in March 2003 and transferred to QA/QC Unit) |

Appendix A4

Summary of recommendations

This appendix provides a summary of all the recommendations given in this report.

| | Need | Recommendation | Section | FAO |
|---|--|---|---------|---------------|
| 1 | Improve data capture at critical sites | LSOs and ESUs should undertake call-outs as soon as possible at these sites | 2.2 +5 | LSOs and ESUs |
| 2 | Autocalibration run-on | Investigate problem of autocalibration run on at sites given in Table 2.5. Stockport Shaw Heath, Bournemouth, Dumfries, Edinburgh, Eskdalemuir, Fort William, Harwell, St Osyth and Leominster (all NO ₂), London Southwark (CO and SO ₂), Narberth (SO ₂) should be prioritised as at least 2 hours per day are being lost at these sites. Eskdalemuir and Leominster have been highlighted as a priority in previous reports. Autocalibration span concentrations to be <200ppb for urban sites and <100ppb for rural sites. | 2.4 | ESUs |
| 3 | Poor performance of Cwmbran SO ₂ analyser (NB other sites also have air con problems) | The Cwmbran air conditioning unit needs repair or replacement | 3.1 | ESU |
| 4 | Bolton NOx | ESUs to ensure software settings for converter efficiencies to be set at 100% | 3.2 | ESU |
| 5 | Poor performance of analysers-see Section 3.6 | QA/QC Unit would like to seek clarification from the Equipment Support Unit/manufacturer as to the current situation regarding the reason for the problems and what plans are in place to resolve them. We recommend that immediate attention is given to this issue as the majority of these instruments are located at critical sites. | 3.6 | ESU |
| 6 | Leakage of NOx switching valves | It is recommended that LSO's continue to pay particular attention to the NO ₂ calibration results, to see whether the NO response is significantly higher (>10ppb) than that obtained for the zero calibration. These observations should be reported to CMCU as soon as possible | 8.2 | LSO |
| 7 | Leakage of NOx switching valves | It is strongly recommended that ESU's clean all NOx analyser switching valves during servicing, and ensure the valve is leak checked afterwards. The Stockport Shaw Heath analyser should be repaired as soon as possible | 8.2 | ESU |

PART B - Intercalibration Report for the Automatic Urban and Rural Network, July-September 2006

6 Introduction

In July to September 2006, AEA Energy and Environment undertook an intercalibration of the 128 monitoring stations in operation in the Defra and the Devolved Administrations sponsored Urban and Rural Monitoring Network. This has allowed data from all of the analysers in the networks to be harmonised to a single set of audit standards, thereby improving confidence in the accuracy, consistency and traceability of air pollution measurements made in the UK.

The tests were undertaken to cross-reference the individual data sets to common traceable calibration standards. This enabled the consistency of measurements throughout the network to be determined. The following major checks are made:

1. **Analyser accuracy and precision**, as a basic check to ensure reliable datasets from the analysers.
2. **Instrument linearity**, to check that doubling a concentration of gas to the analyser results in a doubling of the analyser signal response. If an analyser is not linear, data cannot be reliably scaled into concentrations.
3. **Instrument signal noise**, to check for a stable analyser response to calibration gases.
4. **Analyser response time**, to check that the analyser responds quickly to a change in gas concentrations.
5. **Leak and flow checks**, to ensure that ambient air reaches the analysers, without being compromised in any way.
6. **NO_x analyser converter efficiency**, to ensure reliable operation. This is the device that allows the measurement of NO₂ to be undertaken, so it must work correctly.
7. **TEOM k_o evaluation**. The analyser uses this factor to calculate mass concentrations, so the value is calculated to determine its accuracy.
8. **Particulate analyser flow rate checks**, to ensure that the flow rates through critical parts of the analyser are within specified limits.
9. **SO₂ analyser hydrocarbon interference**, as certain hydrocarbons are known to interfere with the SO₂ detector.
10. **Evaluation of site cylinder concentrations**, using a set of AEA certified cylinders that are taken to all the sites. The concentrations of the site cylinders are used to scale pollution datasets, so it is important to ensure that the concentration of gas in the cylinder does not change.
11. **Competence of Local Site Operators (LSO)** in undertaking calibrations. As it is the calibrations by the LSO's that are used to scale pollution datasets, it is important to check that these are undertaken competently.

In addition to the above tests, a "Network Intercomparison" is conducted. This exercise utilises audit gas cylinders transported to each site in the Network. These cylinders have been recently calibrated by the Calibration Laboratory at AEA, and allow us to examine how different site analysers respond when they are supplied with the same gas used at other sites. For ozone analysers, the calibration is undertaken with recently calibrated ozone photometers.

The technique used to process the intercomparison results is broadly as follows:

- The analyser responses to audit gas are converted into concentrations, using provisional calibration factors obtained on the day of the intercalibration. This factor is also used for the provisional data supplied to the web/teletext.
- These individual results are tabulated, and statistical analyses undertaken (e.g. network average result, network standard deviation, deviation of individual sites from the network mean etc.)

These results are then used to pick out problem sites, or “outliers”, which are investigated further to determine reasons and investigate possible remedies for the outliers. The definition of an outlier is a site result that falls outside the following limits:

- $\pm 10\%$ of the network average for NO_x, CO and SO₂ analysers,
- $\pm 5\%$ of the reference standard photometer for Ozone analysers,
- $\pm 2.5\%$ of the stated k_0 value for TEOM analysers,
- $\pm 10\%$ for particulate analyser flow rates,
- $\pm 10\%$ for the recalculation of site cylinder concentrations.

Thus, the intercalibration investigates the quality of provisional data output by the Management Units for use in forecasting, teletext and the web. It also provides input into the ratification process by highlighting sites where close scrutiny of datasets is likely to be required.

As stated earlier, any outliers that are identified are rigorously checked to determine the cause, and corrective action taken, if necessary. There are a number of likely main causes for outlier results, as discussed below:

- Drift of an analyser between scheduled LSO calibrations. This is by far the most common cause of an outlier result, and one that is simply corrected for during ratification of data.
- Drift of site cylinder concentrations between intercalibrations. Site cylinders can sometimes become unstable, especially at low pressures. All site cylinder concentrations are checked every six months, and are replaced as necessary.
- Erroneous calibration factors. It can occasionally happen that an analyser calibration is unsuccessful, and results in unsuitable scaling factors being used to produce pollution datasets. These are identified and corrected during ratification.
- Pressurisation of the sampling system at the audit. Occasionally, an analyser can be very sensitive to small changes in applied flow rates of calibration gas. This is more difficult to identify and correct, and may have consequences for data quality.
- Leaks, sample switching valves, etc. Outliers can be generated if an analyser is not sampling ambient air properly. It is likely that if a leaking analyser is identified, data losses will result.

The procedures used to determine network performance are documented in AEA Work Instructions. These methods are regularly updated and improved and have been evaluated by the United Kingdom Accreditation Service (UKAS). AEA holds ISO17025 accreditation for the on-site calibration of all the analyser types (NO_x, CO, SO₂, O₃) and for the determination of the TEOM k_0 factor and particulate analyser flow rates used in the network. An ISO17025 certificate of calibration for the AURN is appended to this report.

A total of 126 sites out of the 128 that operated during the period were audited in this exercise; Soutwark Roadside was not audited due to site redevelopment plans. Also, during this period, a new site was established at Swansea Roadside, replacing the Swansea Centre site. Though both these sites were operational in the reporting period, only the Swansea Roadside could be audited.

The following sections of this report identify analysers that did not meet performance standards, investigates the possible causes of these results and recommends any remedial action required.

7 Results Summary

The results of the intercalibration are summarised in Table 7.1 below:

Table 7.1 – Summary of audited analyser performance

| Parameter | Number of outliers | Number in network | % outliers in total |
|--|------------------------------|---|---------------------|
| NO _x analyser | 24 | 109 | 22% |
| CO analyser | 2 | 77 | 3% |
| SO ₂ analyser | 10 | 75 | 13% |
| Ozone analyser | 35 | 88 | 40% |
| TEOM and BAM analysers | 3 k ₀ , 3 flow | 70 TEOM PM ₁₀ 1 BAM* 5 PM _{2.5} | 8% |
| Gravimetric PM ₁₀ analysers | 0 | 8 PM ₁₀ 2 PM _{2.5} | 0% |
| Total | 77 | 441 | 17% |

* The BAM analyser is operational at Belfast Clara Street as a duplicate instrument, but is no longer formally part of the AURN.

An outlier is defined as an analyser that shows a deviation from the network mean of greater than 10% for NO_x, CO and SO₂ and 5% from the standard photometer for O₃. For PM₁₀ and PM_{2.5} analysers, the flow rates must be within 10% of the specified limits and the TEOM k₀ factor must be within 2.5% of the stated value.

In addition to these results, 8 of the 377 site cylinders (~2%) used to scale instrument data into concentrations appeared to have drifted by more than 10% from their certificated values.

One NO_x converter was found to be lower than the 95% acceptance limit, while a further converter was found to be higher than 105%.

The number of analyser outliers identified is slightly higher than the previous exercise. At the winter 2006 intercalibration 16% of the analysers in use were identified as outliers.

Table 7.2 below presents a breakdown of the outliers identified, on a site-by-site basis:

Table 7.2 – Performance Breakdown

| SITE | Date visited | NO _x | CO | SO ₂ | O ₃ | PM ₁₀ | PM _{2.5} |
|------------------------------------|--------------|--------------------------------|----|-----------------|----------------|------------------------------|-------------------|
| ENGLAND | | | | | | | |
| Barnsley 12 | 7-Aug | | | Outlier -11% | | | |
| Barnsley Gawber | 8-Aug | OK | OK | OK | Outlier -19% | | |
| Bath Roadside | 7-Sep | Outlier +20% | OK | | | | |
| Billingham | 12-Sep | Outlier +11% Converter 111% | | | | | |
| Birmingham Centre | 9-Aug | OK | OK | OK | OK | OK | |
| Birmingham Tyburn | 6-Sep | OK | OK | OK | OK | k ₀ outlier -3.3% | |
| Blackpool Marton | 13-Sep | Outlier +66% | OK | OK | OK | OK | |
| Bolton | 1-Aug | OK | OK | OK | Outlier +12% | OK | |
| Bottesford | 21-Jul | | | | OK | | |
| Bournemouth | 23-Aug | OK | OK | OK | OK | OK | |
| Bradford Centre | 31-Jul | OK | OK | OK | OK | OK | |
| Brentford Roadside | 12-Jul | OK | OK | | | | |
| Brighton Preston Park | 18-Sep | OK | | | OK | | |
| Brighton Roadside | 18-Sep | OK | OK | | | | |
| Brighton Roadside PM ₁₀ | 18-Sep | | | | | OK | |
| Bristol St Paul's | 17-Jul | OK | OK | OK | OK | OK | |
| Bristol Old Market | 17-Jul | OK | OK | | | | |
| Bury Roadside | 2-Aug | OK | OK | Outlier +11% | OK | OK | |
| Cambridge Roadside | 4-Sep | OK | | | | | |
| Camden Kerbside | 15-Aug | OK | | | | OK | |
| Canterbury | 28-Sep | OK | | | | OK | |
| Coventry Memorial Park | 2-Aug | OK | OK | OK | Outlier +12% | OK | |
| Exeter Roadside | 18-Jul | OK | OK | OK | OK | | |
| Glazebury | 16-Aug | OK | | | Outlier -30% | | |
| Great Dun Fell | 25-Jul | | | | OK | | |
| Haringey Roadside | 13-Sep | OK | | | | Flow outlier | |
| Harwell | 13-Jul | Outlier +12% | | OK | OK | OK | OK |
| High Muffles | 25-Jul | OK | | | Outlier +12% | | |
| Hove Roadside | 19-Sep | Outlier +26% | OK | OK | | | |
| Hull Freetown | 1-Aug | OK | OK | OK | Outlier +8% | OK | |
| Ladybower | 27-Sep | Outlier -12% | | OK | Outlier +11% | | |
| Leamington Spa | 23-Aug | OK | OK | OK | Outlier +21% | OK | |
| Leeds Centre | 2-Aug | Outlier +24% | OK | OK | OK | OK | |
| Leicester Centre | 22-Aug | Outlier +12% | OK | OK | Outlier +6% | OK | |
| Leominster | 24-Jul | OK | | | OK | OK | |
| Liverpool Speke | 12-Sep | OK | OK | Outlier +14% | OK | OK | |
| London A3 Roadside | 6-Jul | OK | OK | | | OK | |
| London Bexley | 21-Aug | Outlier +27% | OK | OK | OK | OK | |
| London Bloomsbury | 19-Jul | OK | OK | OK | OK | OK | OK |
| London Brent | 4-Jul | OK | OK | OK | OK | OK | |
| London Bromley | 5-Jul | OK | OK | | | | |
| London Cromwell Road 2 | 9-Oct | OK | OK | OK | OK | | |
| London Eltham | 21-Aug | OK | | OK | Outlier -11% | OK | |
| London Hackney | 5-Jul | OK | OK | | Outlier +10% | | |
| London Haringey | 13-Sep | | | | Outlier +6% | | |

| SITE | Date visited | NO _x | CO | SO ₂ | O ₃ | PM ₁₀ | PM _{2.5} |
|-------------------------------------|--------------|-----------------|--------------|-----------------|----------------|----------------------------|-------------------|
| London Harlington | 31-Aug | OK | OK | | OK | OK | |
| London Hillingdon | 6-Jul | Outlier +20% | OK | OK | OK | OK | |
| London Lewisham | 12-Sep | OK | | OK | Outlier +12% | | |
| London Marylebone Road | 5-Sep | OK | OK | OK | OK | OK | OK |
| London N. Kensington | 20-Jul | OK | OK | OK | OK | OK | |
| London Southwark | 14-Aug | OK | OK | OK | OK | | |
| London Teddington | 31-Jul | OK | | Outlier +24% | OK | | |
| London Wandsworth | 31-Aug | OK | | | OK | | |
| London Westminster | 14-Sep | Outlier -14% | OK | OK | OK | OK | |
| Lullington Heath | 25-Sep | OK | | Outlier +15% | Outlier +10% | | |
| Manchester Piccadilly | 15-Aug | Outlier +15% | OK | OK | Outlier -6% | OK | |
| Manchester South | 14-Aug | Outlier +12% | | OK | OK | | |
| Manchester Town Hall | 15-Aug | OK | Outlier -11% | | | | |
| Market Harborough | 18-Jul | OK | OK | | OK | | |
| Middlesbrough | 13-Sep | OK | OK | OK | Outlier -28% | OK | |
| Newcastle Centre | 11-Sep | OK | OK | OK | Outlier +11% | OK | |
| Northampton | 26-Jul | OK | OK | OK | OK | OK | |
| Northampton PM ₁₀ (Grav) | 26-Jul | | | | | OK | |
| Norwich Centre | 25-Sep | Outlier +12% | OK | Outlier -11% | Outlier +13% | k ₀ outlier -8% | |
| Norwich Forum Roadside | 26-Sep | OK | | | | | |
| Nottingham Centre | 17-Jul | OK | OK | OK | OK | OK | |
| Oxford Centre Roadside | 4-Jul | OK | OK | OK | | | |
| Plymouth Centre | 19-Jul | OK | OK | OK | Outlier -37% | OK | |
| Portsmouth | 8-Aug | OK | OK | OK | OK | OK | |
| Preston | 13-Sep | Outlier +16% | OK | OK | OK | OK | |
| Reading New Town | 11-Jul | OK | OK | OK | OK | OK | |
| Redcar | 13-Sep | OK | OK | OK | Outlier +10% | Flow outlier | |
| Rochester | 13-Oct | OK | | OK | Outlier -8% | OK | OK |
| Rotherham Centre | 9-Aug | OK | | Outlier +53% | OK | | |
| Salford Eccles | 15-Aug | OK | OK | OK | OK | OK | |
| Sandwell West Bromwich | 25-Jul | Outlier +16% | OK | OK | OK | | |
| Scunthorpe Town | 1-Aug | | | OK | | OK | |
| Sheffield Centre | 7-Aug | Converter 92% | OK | OK | OK | OK | |
| Sheffield Tinsley | 7-Aug | OK | OK | | | | |
| Sibton | 5-Sep | | | | Outlier +10% | | |
| Somerton | 20-Jul | OK | | | Outlier +6% | | |
| Southampton Centre | 22-Aug | OK | OK | OK | Outlier +8% | OK | |
| Southend-on-Sea | 5-Oct | Outlier +12% | OK | OK | Outlier +38% | OK | |
| Southwark Roadside | | Site | not | operational | | | |
| St Osyth | 5-Oct | OK | OK | | Outlier -12% | | |
| Stockport Shaw Heath | 2-Aug | OK | OK | Outlier+12% | | OK | |
| Stockton-on-Tees Yarm | 12-Sep | Outlier +14% | OK | | | OK | |
| Stoke-on-Trent Centre | 14-Aug | OK | OK | | Outlier -18% | OK | |
| Sunderland | 14-Sep | | | Outlier -12% | | | |
| Sunderland Silksworth | 14-Sep | Outlier +11% | | | OK | | |
| Thurrock | 6-Sep | OK | OK | | Outlier +7% | OK | |
| Tower Hamlets Roadside | 31-Jul | OK | OK | | | | |
| Walsall Alumwell | 10-Jul | Outlier -13% | | | | | |

| SITE | Date visited | NO _x | CO | SO ₂ | O ₃ | PM ₁₀ | PM _{2.5} |
|-------------------------|--------------|-----------------|--------------|-----------------|----------------|------------------------------|-------------------|
| Walsall Willenhall | 24-Aug | OK | | | | | |
| West London | 9-Oct | OK | OK | | | | |
| Weybourne | 5-Sep | | | | OK | | |
| Wicken Fen | 27-Sep | OK | | OK | OK | | |
| Wigan Centre | 1-Aug | OK | OK | OK | OK | OK | |
| Wirral Tranmere | 12-Sep | OK | OK | OK | OK | OK | |
| Wolverhampton Centre | 30-Aug | OK | OK | OK | OK | OK | |
| Yarner Wood | 28-Sep | OK | | | Outlier +6% | | |
| NORTHERN IRELAND | | | | | | | |
| Belfast Centre | 14-Aug | OK | OK | OK | OK | OK | |
| Belfast Clara St | 16-Aug | | | | | OK | |
| Belfast East | 14-Aug | | | OK | | | |
| Derry | 30-Aug | OK | OK | OK | OK | OK | |
| Lough Navar | 22-Aug | | | | OK | OK | |
| SCOTLAND | | | | | | | |
| Aberdeen | 18-Jul | Outlier +14% | OK | OK | Outlier +9% | OK | |
| Auchencorth Moss | 5-Oct | | | | Not available | OK | OK |
| Bush Estate | 12-Jul | OK | | | Outlier +6% | | |
| Dumfries | 24-Jul | OK | OK | | | OK | |
| Edinburgh St Leonards | 12-Jul | OK | OK | Outlier -18% | Outlier +9% | OK | |
| Eskdalemuir | 24-Jul | OK | | | OK | | |
| Fort William | 5-Jul | OK | | | OK | | |
| Glasgow Centre | 4-Jul | Outlier -11% | OK | OK | OK | OK | |
| Glasgow City Chambers | 6-Jul | OK | OK | | | | |
| Glasgow Kerbside | 4-Jul | OK | OK | | | OK | |
| Grangemouth | 14-Jul | OK | OK | OK | OK | Flow outlier | |
| Inverness | 19-Jul | OK | OK | | | OK | |
| Lerwick | 26-Oct | | | | Outlier +23% | | |
| Strath Vaich | 20-Jul | | | | OK | | |
| WALES | | | | | | | |
| Aston Hill | 26-Sep | OK | | | OK | | |
| Cardiff Centre | 12-Jul | OK | OK | OK | OK | OK | |
| Cwmbran | 11-Jul | Outlier +52% | Outlier +13% | OK | Outlier +10% | OK | |
| Narberth | 13-Jul | Outlier -13% | | OK | Outlier -21% | k ₀ outlier +3.6% | |
| Port Talbot | 10-Jul | OK | | OK | OK | OK | |
| Swansea | - | Site | Closed | | | | |
| Swansea Roadside | 10-Jul | OK | OK | OK | OK | Leak test fail | OK |
| Wrexham | 11-Sep | OK | OK | OK | | OK | |

The following sections look at each pollutant in turn and investigate causes for outliers.

8 Oxides of Nitrogen

8.1 Intercalibration Outliers

The intercalibration highlighted that the results from 24 sites were outside the $\pm 10\%$ acceptance limit from the network mean. This result is better than the winter exercise, when 33 analysers were identified as outliers.

4 outliers can be attributed to significant changes in the site cylinder concentrations, as listed below:

1. Blackpool Marton
2. Leeds Centre
3. London Hillingdon
4. Cwmbran

A further 5 outliers arose as a result of minor changes in site cylinder concentrations:

1. Ladybower
2. London Westminster
3. Norwich Centre
4. Preston
5. Southend

The actions arising as a result of cylinder outliers are described in Section 13.

Data from all the affected sites has been carefully examined and rescaled as needed. No data have been lost as a result of the rescaling.

The Billingham outlier was caused by a poor converter test result.

The remaining 14 outliers can be attributed to drifts in calibration factors between LSO calibrations, and no data will be lost as a result of these findings.

Using the methodology detailed in Section 6, comparison of the network averages to audit cylinder concentrations showed that the network measures concentrations of NO_x, NO and NO₂ to within 3% of the network standards. The percentage standard deviations of these results, which are an indication of how close the results are grouped together, were less than 5% in all cases. These are very good results, and demonstrate that data from the vast majority of NO_x analysers are accurate, harmonised and traceable to national metrology standards.

8.2 Leaking switching valves

This phenomenon has been observed as a significant cause of outliers in NO_x analysers. When NO₂ gas is used for calibration, some analysers have been seen to produce a significant NO signal. This gives cause for concern, because a cylinder of NO₂ will be virtually 100% NO₂, very little NO will be present in the mixture.

Analysers that exhibit this behaviour could be underestimating concentrations of NO₂, as highlighted by the following nine analysers:

1. Ladybower - measured 13 ppb NO in an NO₂ cylinder (outlier)
2. Leamington Spa – measured 22 ppb NO in an NO₂ cylinder ® (not outlier)
3. Somerton - measured 18 ppb NO in an NO₂ cylinder ® (not outlier)
4. Stockport Shaw Heath - measured 29 ppb NO in an NO₂ cylinder 2x® (not outlier)
5. West London - measured 12 ppb NO in an NO₂ cylinder ® (not outlier)
6. Glasgow Kerbside – measured 17 ppb NO in an NO₂ cylinder ® (not outlier)

® denotes a repeat offender

These results are better than those found at the winter 2006 exercise where 9 analysers were seen to have this response.

The analyser at Stockport Shaw Heath has now caused outliers to be identified on three occasions – it is therefore strongly recommended that the ESU takes urgent action to remedy this fault.

The most likely cause for this observation is a leaking switching valve inside the analyser. The valves cycle the analysers between sampling NO_x, NO and, on some models, reference gases, and any leaks within these systems appear to manifest themselves when calibrating the analysers with NO₂ gas. In many ways, this phenomenon is similar to the leaking main valve faults common to ozone analysers. Unfortunately, as the valves are inside the analysers, it is not possible for LSO's or QA/QC to leak check these valves.

Recommendation

It is recommended that LSO's continue to pay particular attention to the NO₂ calibration results, to see whether the NO response is significantly higher (>10ppb) than that obtained for the zero calibration. These observations should be reported to CMCU as soon as possible.

These faults were highlighted to the ESU's in the weekly report emails during the intercalibration, to ensure that particular attention was paid to servicing and cleaning these switching valves during services, to try to minimise the occurrence of these outliers.

Recommendation

It is strongly recommended that ESU's clean all NO_x analyser switching valves during servicing, and ensure the valve is leak checked afterwards.

The Stockport Shaw Heath analyser should be repaired as soon as possible.

AEA will continue to monitor these results at audit visits.

8.3 Converter Tests

The converter at Sheffield Centre was found to be 92% efficient.
The converter at Billingham was found to be 111% efficient.

As a result of these findings some data have been rejected from these sites in the third quarter of 2006.

The Bolton NO_x analyser was found to have a converter efficiency of 104.6% at the intercalibration. This was found to be due to the software settings on the analyser. This may cause incorrect scaling of the data, and the analyser converter setting must be set to 100%.

9 Carbon Monoxide

The intercalibration showed that the results from two analysers were outside the $\pm 10\%$ acceptance criterion. This result is slightly worse than the winter intercalibration, when all analysers were within the required performance standards.

Both outliers were caused by instrument drift between calibrations: no data will be lost as a result of the audit findings.

Comparison of the network average to the audit cylinder concentration showed that the network measures CO concentrations to within 1% of the reference standard. The percentage standard deviation was less than 3%.

These are excellent results, and demonstrate that data from the CO analysers are accurate, harmonised and traceable to national metrology standards.

10 Sulphur Dioxide

10.1 Intercalibration Outliers

The intercalibration showed that the results from 10 analysers were outside the $\pm 10\%$ acceptance criterion. This is similar to the winter intercalibration, when 9 analysers were identified as outliers.

Seven outliers can be attributed to drifts in calibration factors between LSO calibrations, and no data were lost as a result of this.

The outlier at Lullington Heath arose as a result of a significant change in the site cylinder concentration.

The outliers at London Teddington and Norwich Centre arose as a result of minor changes in site cylinder concentrations.

Actions arising from cylinder outliers are described in Section 13.

Data from all the affected sites has been carefully examined and rescaled as needed. No data have been lost as a result of the rescaling.

Comparison of the network average to the audit cylinder concentration showed that the network measures SO₂ concentrations to within 1% of the reference standard. The percentage standard deviation was less than 5%. These are good results, and demonstrate that data from the SO₂ analysers are accurate, harmonised and traceable to national metrology standards.

10.2 m-xylene tests

The efficiency of the hydrocarbon “kicker” was evaluated with a 1 ppm m-xylene cylinder. The kicker selectively removes hydrocarbons from the sample inlet prior to analysis. This is an important test, because m-xylene behaves in a similar manner to SO₂ when exposed to UV light within the analyser, and could therefore interfere with the analyser response, if the kicker does not function properly.

To pass the test, the analyser must not respond by more than 1% (10 ppb) of the m-xylene cylinder concentration. However, it should be noted that this particular test is very demanding; typical ambient hourly maximum concentrations of this pollutant rarely exceed 50 ppb, and annual concentrations rarely exceed 5 ppb. In future, there will be no formal requirement for analysers in the field to pass this test, once type approval has been granted. For these reasons, the acceptance criteria have been relaxed to allow a maximum response of 50ppb.

There were no outliers identified during this intercalibration: the maximum m-xylene response observed for any analyser was 40ppb (at two sites: Rotherham and London Eltham)

11 Ozone

Calibration of the network analysers against the AEA reference photometers showed that 35 analysers were outside the $\pm 5\%$ acceptance criterion. This is significantly worse than the previous exercise, where 23 analysers tested were identified as outliers.

Of the 35 analysers, 17 had responses within 10% of the reference photometers; ratification of these datasets was straightforward, with no loss of data.

11 of the remaining analysers had responses between 10 and 20% of the reference photometers. Ratification of the data from these analysers has been more complex, to ensure that suitable scaling of the data could be applied, but no losses of data were necessary.

The other 7 analysers were more than 20% from the reference photometers. Detailed investigations have shown that data from 6 of the sites are recoverable, but owing to a main valve leak, 5 months data have been rejected from the Plymouth Centre analyser.

These results are worse than the winter intercalibration, when 3 analysers were found to be more than 20% from the reference photometer.

During this intercalibration, AEA initiated a follow-up programme to identify root causes for these outliers. This involved a multi-staged approach, as described below:

- ESU's were promptly informed of any ozone analysers identified as gross outliers.
- The ESU was asked to confirm this result pre-service before commencing with the service. If the QA/QC and ESU results were in good agreement, no further action in the field was required.
- If the two results disagreed, further investigations were undertaken; either by QA/QC undertaking a repeat site audit or by the ESU returning their photometers to Harwell to determine their stability.

As a result of these findings and subsequent investigations, the calibrations by QA/QC were found to be valid for all 7 gross outliers. The exercise identified two generic explanations for outliers or discrepancies between results, as follows:

1. Site instrument faults (genuine drift or leaking main valves)
2. Faulty ESU photometers

The programme has been very successful, both in terms of improving data quality from site analysers and in improving the performance of ESU's and their photometers. We will continue to use this tool to ensure high quality ozone data in future intercalibration exercises.

12 Particulate analysers

12.1 TEOM k_0

There were three outliers for TEOM k_0 during this intercalibration:

1. Birmingham Tyburn +3.3%
2. Norwich Centre -8%
3. Narberth +3.6%

Data from these analysers have been carefully examined and rescaled as necessary, with the exception of Norwich Centre. The data from this site were of poor quality and were deleted from this site for all of this period.

All other analyser calibration factors were calculated to be within 2.5% of their stated values.

It appears that ESU's, on occasion, swap Sensor Units in and out of sites without either replacing the associated Control Unit or updating the k_0 factor on the existing Control Unit. As it is the Control Unit that performs calculations to determine mass concentrations, ESU's are strongly reminded of the importance of ensuring that k_0 values are matched on the two parts of a TEOM

12.2 Analyser Flow Rates

The flow rates of the analysers at three sites were found to be outside the $\pm 10\%$ acceptance limit:

- | | |
|----------------------|---------------------------------|
| 1. Haringey Roadside | (Main Flow and Aux Flow -13%) |
| 2. Redcar | (Main Flow -79%, Aux Flow -27%) |
| 3. Grangemouth | (Main Flow +11%) |

The analysers at Redcar and Haringey Roadside also failed the leak tests.

Careful examination of the analyser datasets, and the circumstances surrounding the faults, has resulted in two weeks of data rejection from Haringey Roadside and Redcar; no loss of data was necessary at Grangemouth.

13 Site Cylinder Concentrations

During the intercalibration, the concentrations of the on-site cylinders were evaluated using the audit cylinder standards. The calculated results showed that 8 of the 377 cylinders (~2.1%) used to scale analyser data into concentrations (NO, CO and SO₂) appear to be outside the ±10% acceptance criterion. This is similar to the Winter 2006 roadshow, where 10 cylinders were outside the acceptance limits.

During this exercise, the following poorly performing site cylinders were replaced:

1. Newcastle Centre CO
2. Leeds CentreNO
3. Southampton Centre NO
4. Blackpool Marton NO
5. Hillingdon NO
6. Cwmbran NO
7. Exeter Roadside NO
8. Preston NO

In addition, the concentrations of 27 NO₂ cylinders appear to have drifted by more than 10%. NO₂ cylinders are not used for the scaling of data and so will not be replaced at this time.

Hence, a total of 35 of the 377 cylinders were outside the acceptance limits. This is slightly worse than the previous intercalibration, where 33 of the cylinders were found to be out of specification.

The site cylinder evaluations are performed by calibrating the analysers with site and audit cylinder gas through the same inlet system, and using the conditioned site cylinder regulators, thus minimising any possible errors due to contaminated tubing or regulators.

14 Site Information

We have compiled additional information about the monitoring stations in the network, including the types of sampling systems deployed on site. This database has been made available to Management Units and can be emailed to other parties, on request.

The table below presents information about the sampling systems deployed at new sites, together with accurate, validated grid references. It should be noted that while the measurements are stated to within 1 metre, the uncertainty of the GPS system used is typically the order of ±10 metres.

The following Table presents the information collated at sites established since July 2006: Auchencorth Moss was established at the start of 2006, but data have only recently been supplied to the QA/QC Unit. So far, only gravimetric particle (PM₁₀ and PM_{2.5}) data are available from this site.

Table x.1 – Site Information

| Site Name | Manifold type | Grid Reference | 6 figure easting | 6 figure northing | Longitude | Latitude | Altitude (m) |
|------------------|---------------|----------------|------------------|-------------------|--------------|-------------|--------------|
| Auchencorth Moss | N/a | NT222561 | 322227 | 656143 | 55° 47' 32"N | 3° 14' 31"W | 270 |
| Swansea Roadside | Glass | SS653945 | 265341 | 194458 | 51° 37' 58"N | 3° 56' 51"W | 54 |

The grid references quoted in the above table are obtained from GPS measurements, confirmed by reference to Ordnance Survey 1:25000 maps and internet mapping services. The 6 figure easting and northing references are obtained from GPS measurements, quoted to 1 metre accuracy, and also referenced to internet street mapping services. It should be noted that these figures are likely to carry a maximum uncertainty of ± 10 metres.

It is suggested that Management Units check the accuracy of their databases and websites against these data, and provide feedback or update accordingly.

15 CEN

The European Committee for Normalisation (CEN) have prepared a series of documents prescribing how analysers must be operated, to produce datasets that conform to the Data Quality Objectives of the EC Directives. The CEN documents for operation of air pollution analysers; BS EN14211 (NO_x), BS EN14212 (SO₂), BS EN14626 (CO) and BS EN14625 (O₃) set out a series of performance criteria for analysers which must be achieved, both in the field and under laboratory conditions.

By way of example, the performance of an analyser in the field must pass a number of tests, including:

- Linearity – the analyser must have a maximum error at any point of less than 6% of the predicted value. AEA now reports maximum residuals from linearity tests, to evaluate the performance of current analysers against these tougher requirements.
- NO_x Converter efficiency must be better than 95%. Data must be rescaled for efficiencies between 95 and 99.9%, but rejected if below 95%. Again, this is tighter than currently, where we accept “borderline” failures. AEA already use the CEN method for undertaking converter tests.
- The sampling system that delivers air to the analyser must remove no more than 2% of the pollutant to be analysed. AEA continue to evaluate systems to calibrate sampling systems, but this is not currently undertaken on a routine basis in the UK. A report on the evaluation of methodologies to test losses of gases to sampling manifolds has been completed by QA/QC Unit and this is available on the AURN Hub and Air Quality Archive.
- The uncertainty of the site cylinder concentrations is, by and large, the largest single component of the entire measurement uncertainty budget. Recent intercalibrations have been used to evaluate a new methodology for calculating site cylinder concentrations and uncertainties. Unfortunately, it was discovered that analyser performance could not be relied upon to allow the scaling of cylinder concentrations with sufficient accuracy, particularly so for NO_x analysers. It is likely that site environmental conditions (for example temperature variations) significantly affected these assessments. QA/QC are currently investigating alternative methodologies and will report on these in the future.
- The determination of an SO₂ analyser response to meta-xylene will not be required for ongoing field tests. For the AURN, QA/QC will continue to assess the performance of the hydrocarbon kickers, but action will not be recommended unless the result is very high (greater than 50ppb response to a 1ppm m xylene cylinder)

The CEN operating methodologies are now finalised and published and are, at present, being incorporated into the requirements of the Framework and Daughter Directives. It is likely that Member States will have until 1 January 2008 to ensure their monitoring networks are compliant. AEA are taking steps to ensure the procedures used in the UK comply with the requirements ahead of any imposed deadlines. To this end, the procedures used for the intercomparisons have been fully compliant with the CEN protocols since January 2006.

16 Safety

AEA undertakes regular extensive risk assessments of all its activities on-site, to ensure that its staff are not exposed to unsafe practices while working.

There are no significant issues identified that presented significant risk during this intercalibration exercise. A complete risk assessment updating exercise will be undertaken at all AURN sites during the Winter 2007 audit.

17 Certification

The Network Certificate of Calibration is presented in Appendix B1. This certificate presents the results of the individual analyser scaling factors on the day of the audit, as calculated by AEA using the audit cylinder standards, in accordance with our ISO17025 accreditation.

18 Summary

The intercalibration exercise has demonstrated its value as an effective tool in determining overall site performance and assessing the reliability and traceability of air quality measurements from a large scale network. The results from this intercalibration have been used to assess data quality during the ratification of the network datasets for the period April to September 2006.

APPENDIX B1

Certificate of Calibration

CERTIFICATE OF CALIBRATION

551.11, Harwell, Didcot, Oxfordshire OX11 0QJ. Telephone 0870 1906465 Fax 0870 1906377

Certificate Number: 01668
AEA Identification Number: ED45077030

Page 1 of 14 0401

Approved Signatories: K. Stevenson
S. Eaton ✓

Signed: Date:

Date of issue: 12 March 2007

Customer Name and Address: Dr Janet Dixon
AEQ Division
Department for Environment, Food and Rural Affairs
Ashdown House (Zone E14)
123 Victoria Street
London SW1E 6DE

Description: Calibration factors for monitoring stations in the Automatic Urban Monitoring Network

1. Carbon Monoxide

| Date Year =2006 | Site | Analyser number | ¹ Zero output | Uncertainty (ppm) | ² Calibration Factor | Uncertainty (%) | *Maximum Residual (%) |
|-----------------------|-----------------------|-----------------|--------------------------|-------------------|---------------------------------|-----------------|-----------------------|
| Scottish Sites | | | | | | | |
| 18-Jul | Aberdeen | 614 | 0 | 0.3 | 1.051 | 3 | 3.6 |
| 24-Jul | Dumfries | 1498 | -1 | 0.3 | 0.992 | 3 | 3.5 |
| 12-Jul | Edinburgh St Leonards | 240 | 0 | 0.3 | 1.038 | 3 | 1.4 |
| 04-Jul | Glasgow Centre | 0410-009 | -4 | 0.3 | 0.049 | 3 | 2.6 |
| 06-Jul | Glasgow City Chambers | 721 | 1 | 0.3 | 1.000 | 3 | 1.4 |
| 04-Jul | Glasgow Kerbside | Ambirak 002 | 11 | 0.3 | 0.054 | 3.2 | 1.9 |
| 14-Jul | Grangemouth | 1710 | 1 | 0.3 | 0.995 | 3 | 3.6 |
| 19-Jul | Inverness | 1500 | 1 | 0.3 | 1.005 | 3 | 0.7 |
| Welsh Sites | | | | | | | |
| 12-Jul | Cardiff Centre | 242 | 0 | 0.3 | 0.926 | 3 | 1.2 |
| 11-Jul | Cwmbran | 103006 | 0 | 0.3 | 1.004 | 3 | 0.8 |
| 10-Jul | Swansea | 70 | 27 | 0.3 | 0.049 | 3 | 2.7 |
| 11-Sep | Wrexham | 12556 | 1 | 0.3 | 0.951 | 3 | 0.6 |
| N.Irish Sites | | | | | | | |
| 14-Aug | Belfast Centre | m1811-m491 | 37 | 0.3 | 0.049 | 3 | 2.8 |
| 30-Aug | Derry | j-ar-009 | 3 | 0.3 | 0.053 | 3 | 3.1 |

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor k=2 providing a level of confidence of approximately 95%. The uncertainty evaluation has been carried out in accordance with UKAS requirements.

This certificate is issued in accordance with the laboratory accreditation requirements of the United Kingdom Accreditation Service. It provides traceability of measurement to recognised national standards, and to units of measurement realised at the National Physical Laboratory or other recognised national standards laboratories. This certificate may not be reproduced other than in full, except with the prior written approval of the issuing laboratory.

CERTIFICATE OF CALIBRATION

551.11, Harwell, Didcot, Oxfordshire OX11 0QJ. Telephone 0870 1906465 Fax 0870 1906377


 Certificate Number: 01668
 AEA Identification Number: ED45077030

Page 2 of 14

0401

| Date Year =2006 | Site | Analyser number | ¹ Zero output | Uncertainty (ppm) | ² Calibration Factor | Uncertainty (%) | *Maximum Residual (%) |
|-----------------------|---------------------------|--------------------|-----------------------------|----------------------|------------------------------------|--------------------|-----------------------------|
| | English Sites | | | | | | |
| 08-Aug | Barnsley Gawber | | -8 | 0.3 | 0.050 | 3 | 0.2 |
| 07-Sep | Bath Roadside | 95483 | -12 | 0.3 | 0.051 | 3 | 1.4 |
| 09-Aug | Birmingham Centre | 14418 | -8 | 0.3 | 0.050 | 3 | 0.4 |
| 06-Sep | Birmingham Tyburn | 106006 | 0 | 0.3 | 1.050 | 3 | 1 |
| 13-Sep | Blackpool Marton | l-ar-010 | 1 | 0.3 | 0.051 | 3 | 0.9 |
| 01-Aug | Bolton | 440 | 0 | 0.3 | 1.008 | 3 | 1.5 |
| 23-Aug | Bournemouth | 1501 | 0 | 0.3 | 1.052 | 3 | 2.1 |
| 31-Jul | Bradford Centre | | -1 | 0.3 | 0.046 | 3 | 3.8 |
| 12-Jul | Brentford Roadside | 168 | 0 | 0.3 | 0.955 | 3 | 1.1 |
| 18-Sep | Brighton Roadside | 1434 | 1 | 0.3 | 1.042 | 3.2 | 3.5 |
| 17-Jul | Bristol Old Market | 717 | 0 | 0.3 | 1.001 | 3 | 0.9 |
| 17-Jul | Bristol St Paul's | 257 | 0 | 0.3 | 1.005 | 3 | 0.1 |
| 02-Aug | Bury Roadside | 277 | -1 | 1.1 | 1.045 | 3 | 1.1 |
| 02-Aug | Coventry Memorial Park | | -1 | 0.3 | 1.026 | 3 | 0.5 |
| 18-Jul | Exeter Roadside | f010070s | 0 | 1.0 | 0.985 | 3 | 0.9 |
| 19-Sep | Hove Roadside | 1433 | 0 | 0.3 | 0.986 | 3 | 1.4 |
| 01-Aug | Hull Freetown | M489 | 53 | 0.3 | 0.050 | 3 | 3.9 |
| 23-Aug | Leamington Spa | 2198 | 21 | 0.3 | 0.050 | 3 | 1.7 |
| 02-Aug | Leeds Centre | 207003 | 0 | 0.3 | 1.035 | 3 | 1.5 |
| 22-Aug | Leicester Centre | 207004 | 0 | 0.3 | 1.037 | 3 | 0.6 |
| 12-Sep | Liverpool Speke | 487 | 50 | 0.3 | 0.051 | 3 | 1.4 |
| 06-Jul | London A3 Roadside | h-ar-001 | 0 | 0.3 | 0.045 | 3 | 0.2 |
| 21-Aug | London Bexley | 443 | 0 | 0.3 | 1.002 | 3 | 5.1 |
| 19-Jul | London Bloomsbury | 14330 | 9 | 0.3 | 0.049 | 3 | 0.9 |
| 04-Jul | London Brent | 1694 | 21 | 0.3 | 0.049 | 3 | 1.2 |
| 09-Oct | London Cromwell Road 2 | 868 | 14 | 0.3 | 0.051 | 3 | 1.3 |
| 05-Jul | London Hackney | 2113-m546 | 1 | 0.3 | 0.947 | 3 | 2.1 |
| 31-Aug | London Harlington | 11492 | 0 | 0.3 | 0.990 | 3 | 1.5 |
| 06-Jul | London Hillingdon | 5 | -78 | 0.3 | 0.044 | 3 | 1.8 |
| 05-Sep | London Marylebone Rd | 10073 | -2 | 0.3 | 1.039 | 3 | 3.7 |
| 20-Jul | London N. Kensington | 360 | 1 | 0.3 | 1.002 | 3 | 2.4 |
| 14-Aug | London Southwark | 843 | 0 | 1.0 | 1.002 | 3 | 1.0 |
| 14-Sep | London Westminster | 65 | -17* | | 0.049* | | |
| 15-Aug | Manchester Piccadilly | 8 | -3 | 0.3 | 0.049 | 3 | 1.2 |
| 15-Aug | Manchester Town Hall | 828 | 0 | 0.3 | 1.028 | 3 | 1.8 |
| 18-Jul | Market Harborough | 60983-329 | 289 | 0.3 | 0.005 | 19.0 | 0.1 |
| 13-Sep | Middlesbrough | 204 | 0 | 0.3 | 0.996 | 3 | 2.0 |
| 11-Sep | Newcastle Centre | m488 | 51 | 0.3 | 0.049 | 3 | 0.9 |
| 26-Jul | Northampton | 8905410102 | 0 | 0.3 | 0.979 | 3 | 0.6 |
| 25-Sep | Norwich Centre | 207002 | 0 | 1.1 | 1.044 | 3 | 0.7 |
| 17-Jul | Nottingham Centre | 0410-010 | -1 | 0.3 | 0.049 | 3 | 2.0 |
| 04-Jul | Oxford Centre Roadside | 127 | 101 | 0.3 | 0.048 | 3 | 0.6 |
| 19-Jul | Plymouth Centre | gra0410007 | 39 | 0.3 | 0.005 | 3 | 0.5 |
| 08-Aug | Portsmouth | 902015 | 0 | 0.3 | 1.115 | 3 | 0.4 |

CERTIFICATE OF CALIBRATION

551.11, Harwell, Didcot, Oxfordshire OX11 0QJ. Telephone 0870 1906465 Fax 0870 1906377


 Certificate Number: 01668
 AEA Identification Number: ED45077030

Page 3 of 14

0401

| Date Year =2006 | Site | Analyser number | ¹ Zero output | Uncertainty (ppm) | ² Calibration Factor | Uncertainty (%) | *Maximum Residual (%) |
|-----------------|------------------------|-----------------|--------------------------|-------------------|---------------------------------|-----------------|-----------------------|
| 13-Sep | Preston | l-ar-013 | 6 | 0.3 | 0.045 | 3 | 1.4 |
| 11-Jul | Reading New Town | | 12 | 0.3 | 0.045 | 3 | 0.8 |
| 13-Sep | Redcar | 610 | 1 | 0.3 | 0.053 | 3 | 5.5 |
| 15-Aug | Salford Eccles | 2386 | 0 | 1.0 | 1.004 | 3 | 4.1 |
| 25-Jul | Sandwell West Bromwich | 94603 | -9 | 0.3 | 0.051 | 3 | 1.7 |
| 07-Aug | Sheffield Centre | 410-006 | 3 | 0.3 | 0.049 | 3 | 1.4 |
| 07-Aug | Sheffield Tinsley | 517 | 3 | 0.3 | 0.050 | 3 | 2.8 |
| 22-Aug | Southampton Centre | m490 | 52 | 0.3 | 0.048 | 3 | 1.3 |
| 05-Oct | Southend-on-Sea | | 0 | 0.3 | 1.004 | 3 | 1.5 |
| 05-Oct | St Osyth | 60872 | 0 | 0.3 | 0.541 | 19.2 | 0.2 |
| 02-Aug | Stockport Shaw Heath | 1701 | 20 | 0.3 | 0.050 | 3 | 0.9 |
| 12-Sep | Stockton-on-Tees Yarm | M339 | 0 | 0.3 | 1.049 | 6.6 | 5.0 |
| 14-Aug | Stoke-on-Trent Centre | | -21 | 0.3 | 0.043 | 3 | 2.8 |
| 06-Sep | Thurrock | 262 | -32 | 0.3 | 0.049 | 3 | 9.5 |
| 31-Jul | Tower Hamlets Roadside | 272 | 4 | 0.3 | 1.008 | 3 | 1.7 |
| 09-Oct | West London | 81 | -14 | 0.3 | 0.052 | 3 | 1.7 |
| 01-Aug | Wigan Centre | 6011 | 0 | 0.3 | 1.037 | 3 | 0.6 |
| 12-Sep | Wirral Tranmere | 0 | 0 | 0.3 | 0.051 | 3 | 0.8 |
| 30-Aug | Wolverhampton Centre | 410 | -7 | 0.3 | 0.052 | 3 | 3.8 |

2. Sulphur Dioxide

| Date Year =2006 | Site | Analyser number | ¹ Zero output | Uncertainty (ppb) | ² Calibration Factor | Uncertainty (%) | *Max Residual (%) | *m-xylene interference (ppb) |
|-----------------------|-----------------------|-----------------|--------------------------|-------------------|---------------------------------|-----------------|-------------------|------------------------------|
| Scottish Sites | | | | | | | | |
| 18-Jul | Aberdeen | 12182 | 4 | 4.3 | 1.022 | 5.3 | 1.5 | 15.6 |
| 12-Jul | Edinburgh St Leonards | 71 | 4 | 4.2 | 1.077 | 5.7 | 1.5 | |
| 04-Jul | Glasgow Centre | 43C-1400 | 16 | 4.1 | 0.188 | 5.8 | 2.1 | 1.7 |
| 14-Jul | Grangemouth | 703B-274 | -1 | 4.3 | 0.954 | 5.7 | 2.6 | 20.5 |
| Welsh Sites | | | | | | | | |
| 12-Jul | Cardiff Centre | 70 | 6 | 4.2 | 1.049 | 5 | 0.8 | 11.8 |
| 11-Jul | Cwmbran | 408001 | 1 | 4.2 | 0.987 | 5 | 0.6 | 4.9 |
| 13-Jul | Narberth | RAG4580 | 8 | 4.2 | 1.131 | 5 | 0.3 | 29.4 |
| 10-Jul | Port Talbot | 943 | -2 | 4.2 | 1.296 | 5 | 1.2 | 22.0 |
| 10-Jul | Swansea | 168 | -8 | 4.1 | 0.201 | 5 | 2.2 | 6.2 |
| 11-Sep | Wrexham | 12183 | 0 | 4.3 | 1.083 | 5 | 0.4 | 11.6 |
| N.Irish Sites | | | | | | | | |
| 14-Aug | Belfast Centre | m1637-m637 | 173 | 4 | 0.167 | 5.4 | 0.9 | 25.1 |
| 14-Aug | Belfast East | 703 | 1 | 4.1 | 0.903 | 5 | 0.3 | 4.5 |
| 30-Aug | Derry | j-ar-009 | 27 | 4.3 | 1.475 | 6.8 | 4.3 | 7.4 |
| English Sites | | | | | | | | |
| 07-Aug | Barnsley 12 | 706 | 4 | 4.3 | 0.962 | 5.7 | 1.5 | 20.7 |
| 08-Aug | Barnsley Gawber | | 125 | 4.4 | 1.855 | 5 | 0.3 | 7.4 |
| 09-Aug | Birmingham Centre | 14352 | 34 | 4.3 | 0.210 | 5 | 0.9 | 22.4 |
| 06-Sep | Birmingham Tyburn | 301002 | 2 | 4.2 | 1.058 | 5 | 0.8 | 3.2 |
| 13-Sep | Blackpool Marton | l-ar-010 | 27 | 4.3 | 1.531 | 8.6 | 3.3 | 6.1 |

CERTIFICATE OF CALIBRATION

551.11, Harwell, Didcot, Oxfordshire OX11 0QJ. Telephone 0870 1906465 Fax 0870 1906377


 Certificate Number: 01668
 AEA Identification Number: ED45077030

Page 4 of 14

0401

| Date Year =2006 | Site | Analyser number | ¹ Zero output | Uncertainty (ppb) | ² Calibration Factor | Uncertainty (%) | *Max Residual (%) | *m-xylene interference (ppb) |
|-----------------------|------------------------|--------------------|-----------------------------|----------------------|------------------------------------|--------------------|-------------------------|------------------------------------|
| 01-Aug | Bolton | 760 | 0 | 4.2 | 0.975 | 5 | 0.8 | 15.6 |
| 23-Aug | Bournemouth | 1179 | 0 | 4.2 | 1.069 | 5 | 0.4 | 15.0 |
| 31-Jul | Bradford Centre | | 38 | 5.1 | 1.355 | 6.7 | 2.6 | 7.5 |
| 17-Jul | Bristol St Paul's | 73 | 1 | 4.2 | 1.034 | 5 | 0.2 | 23.8 |
| 02-Aug | Bury Roadside | 559 | 5 | 4.3 | 0.937 | 5.6 | 3.6 | 23.0 |
| 02-Aug | Coventry Memorial Park | | 1 | 4.2 | 0.975 | 5 | 0.4 | 2.2 |
| 18-Jul | Exeter Roadside | j000f1s0 | 1 | 4.1 | 0.938 | 5 | 0.3 | 19.7 |
| 13-Jul | Harwell | 79 | 7 | 4.1 | 0.541 | 5 | 2.2 | 8.7 |
| 19-Sep | Hove Roadside | 1178 | 3 | 4.2 | 0.998 | 5 | 1.6 | 15.7 |
| 01-Aug | Hull Freetown | M686 | 245 | 4 | 0.124 | 5.1 | 1.1 | 20.9 |
| 27-Sep | Ladybower | 84 | -1 | 4.1 | 0.466 | 7.1 | 4.1 | 11.6 |
| 23-Aug | Leamington Spa | 1793 | 22 | 4.2 | 0.865 | 5 | 0.4 | 10.6 |
| 02-Aug | Leeds Centre | 214004 | 1 | 4.2 | 0.990 | 5 | 1.3 | 2.0 |
| 22-Aug | Leicester Centre | 215001 | 1 | 4.2 | 1.262 | 5 | 0.9 | 2.5 |
| 12-Sep | Liverpool Speke | 626 | 252 | 4.1 | 0.330 | 5.4 | 0.7 | 8.4 |
| 21-Aug | London Bexley | 318 | -2 | 4.4 | 1.287 | 5 | 1 | 20.3 |
| 19-Jul | London Bloomsbury | 14323 | -13 | 4 | 0.195 | 5.1 | 2.1 | 20.7 |
| 04-Jul | London Brent | 1828 | 17 | 19.3 | 0.971 | 5 | 1.1 | 21.8 |
| 21-Aug | London Eltham | 822 | 34 | 4.2 | 1.246 | 5 | 0.4 | 39.9 |
| 06-Jul | London Hillingdon | 386 | 3 | 4 | 0.194 | 5.6 | 3.2 | 6.8 |
| 12-Sep | London Lewisham | m1220-m498 | 1 | 4.3 | 0.883 | 5 | 0.4 | 20.8 |
| 05-Sep | London Marylebone Road | 10071 | -7 | 4.4 | 1.146 | 5.9 | 4.9 | 21.2 |
| 20-Jul | London N. Kensington | 1020 | 52 | 4.3 | 1.031 | 5.1 | 1 | 35.6 |
| 14-Aug | London Southwark | 535 | -2 | 4.2 | 0.997 | 5 | 0.9 | 6.0 |
| 31-Jul | London Teddington | 58811-320 | 3 | 4.1 | 0.857 | 5 | 0.7 | 4.3 |
| 14-Sep | London Westminster | 705 | 4 | 4.4 | 1.114 | 5 | 0.4 | 20.6 |
| 25-Sep | Lullington Heath | 690 | 100 | 4.1 | 0.425 | 5.4 | 2.9 | 21.9 |
| 15-Aug | Manchester Piccadilly | 477 | 56 | 4.2 | 0.208 | 5 | 0.3 | 12.4 |
| 14-Aug | Manchester South | 13 | -8 | 4 | 0.196 | 5 | 0.6 | 33.0 |
| 13-Sep | Middlesbrough | 1660 | 7 | 4.1 | 0.732 | 5.2 | 1.3 | 9.6 |
| 11-Sep | Newcastle Centre | m689 | 245 | 4.2 | 0.431 | 6.1 | 1.2 | 23.9 |
| 26-Jul | Northampton | 890563033 | 3 | 4.1 | 0.892 | 5 | 1.1 | 2.7 |
| 25-Sep | Norwich Centre | 214005 | 1 | 4.3 | 0.997 | 5 | 0.8 | 27.4 |
| 17-Jul | Nottingham Centre | | 8 | 4 | 0.200 | 5 | 0.7 | 0.4 |
| 04-Jul | Oxford Centre Roadside | 161 | 101 | 4.3 | 0.955 | 5 | 1.1 | 2.4 |
| 19-Jul | Plymouth Centre | 77551-386 | 34 | 4 | 0.098 | 5 | 2.2 | 8.2 |
| 08-Aug | Portsmouth | 578323093 | -1 | 4.2 | 1.015 | 5 | 0 | 9.1 |
| 13-Sep | Preston | l-ar-013 | 70 | 4.5 | 1.230 | 5 | 0.4 | 6.8 |
| 11-Jul | Reading New Town | | 50 | 5.1 | 1.112 | 9.5 | 5.3 | 17.2 |
| 13-Sep | Redcar | 482 | 3 | 4.1 | 0.921 | 5.5 | 1.8 | 12.0 |
| 13-Oct | Rochester | 95058 | 2 | 4.2 | 1.014 | 5.9 | 3.9 | 9.1 |
| 09-Aug | Rotherham Centre | 16 | 3 | 4.2* | 0.634* | 54.7* | 20.9* | 40.4* |
| 15-Aug | Salford Eccles | 2346 | -5 | 4.9 | 1.842 | 6.8 | 1.7 | 19.3 |
| 25-Jul | Sandwell West Bromwich | 93082 | -3 | 4.2 | 1.106 | 5 | 0.9 | 15.5 |
| 01-Aug | Scunthorpe Town | 468 | 4 | 4.3 | 1.090 | 5 | 0.6 | 19.9 |
| 07-Aug | Sheffield Centre | 0477-015 | 57 | 4.1 | 0.228 | 5 | 0.4 | 15.6 |
| 22-Aug | Southampton Centre | m676 | 184 | 4.1 | 0.185 | 10.0 | 4.2 | 2.6 |

CERTIFICATE OF CALIBRATION

551.11, Harwell, Didcot, Oxfordshire OX11 0QJ. Telephone 0870 1906465 Fax 0870 1906377


 Certificate Number: 01668
 AEA Identification Number: ED45077030

Page 5 of 14

0401

| Date Year =2006 | Site | Analyser number | ¹ Zero output | Uncertainty (ppb) | ² Calibration Factor | Uncertainty (%) | *Max Residual (%) | *m-xylene interference (ppb) |
|-----------------------|-----------------------|--------------------|-----------------------------|----------------------|------------------------------------|--------------------|-------------------------|------------------------------------|
| 05-Oct | Southend-on-Sea | | 0 | 4.2 | 1.014 | 7.8 | 3 | 2.2 |
| 02-Aug | Stockport Shaw Heath | 1690 | 20 | 4.2 | 0.988 | 5 | 2.2 | 24.7 |
| 14-Aug | Stoke-on-Trent Centre | | 54 | 4.4 | 0.852 | 5 | 0.2 | 22.4 |
| 14-Sep | Sunderland | 72 | 1 | 4.2 | 1.173 | 5.7 | 2.4 | 14.1 |
| 06-Sep | Thurrock | 555 | 15 | 4.2 | 0.858 | 5 | 0.4 | 18.5 |
| 27-Sep | Wicken Fen | 14349 | -2 | 4.2 | 0.756 | 5 | 0.9 | 21.5 |
| 01-Aug | Wigan Centre | 57674025 | 1 | 4.2 | 1.000 | 5 | 2.3 | 2.0 |
| 12-Sep | Wirral Tranmere | | 8 | 4.5 | 1.861 | 5 | 0.2 | 13.0 |
| 30-Aug | Wolverhampton Centre | 43c | 8 | 4 | 0.187 | 5 | 0.4 | 0.9 |

3. Ozone

| Date Year =2006 | Site | Analyser number | ¹ Zero output | Uncertainty (ppb) | ² Calibration Factor | Uncertainty (%) | *Max Residual (%) |
|-----------------------|------------------------|--------------------|-----------------------------|----------------------|------------------------------------|--------------------|-------------------------|
| Scottish Sites | | | | | | | |
| 18-Jul | Aberdeen | 800 | 1 | 3 | 0.914 | 3 | 1.3 |
| 12-Jul | Bush Estate | 77087-385 | 1 | 3 | 0.481 | 3 | 1.5 |
| 12-Jul | Edinburgh St Leonards | 136 | 1 | 3 | 0.924 | 3 | 0.7 |
| 24-Jul | Eskdalemuir | 145 | 4 | 3 | 0.504 | 3 | 2.4 |
| 05-Jul | Fort William | M400E 434 | 0 | 3 | 1.000 | 3 | 0.9 |
| 04-Jul | Glasgow Centre | GRA427-013 | -23 | 3.5 | 0.202 | 3 | 3.5 |
| 26-Oct | Lerwick | 841b-176 | 2 | 3 | 0.812 | 3.3 | 0.8 |
| 20-Jul | Strath Vaich | 324 | 4 | 3 | 0.471 | 3 | 2.0 |
| Welsh Sites | | | | | | | |
| 26-Sep | Aston Hill | 144 | -9 | 3 | 0.496 | 3 | 0.3 |
| 12-Jul | Cardiff Centre | 168 | 0 | 3 | 0.993 | 3 | 0.7 |
| 11-Jul | Cwmbran | 205004 | 9 | 3 | 0.901 | 3 | 1.8 |
| 13-Jul | Narberth | RAG4580 | 2 | 3.2 | 1.282 | 3 | 2.4 |
| 10-Jul | Port Talbot | 339 | 4 | 3 | 0.499 | 3 | 0.4 |
| 10-Jul | Swansea | 156 | 17 | 3 | 0.104 | 3 | 1.6 |
| N.Irish Sites | | | | | | | |
| 14-Aug | Belfast Centre | m1626-m335 | 209 | 3 | 0.099 | 3 | 0.4 |
| 30-Aug | Derry | j-ar-009 | 0 | 3 | 0.950 | 3 | 1.6 |
| 22-Aug | Lough Navar | 337 | -9 | 3 | 0.520 | 3 | 1.1 |
| English Sites | | | | | | | |
| 08-Aug | Barnsley Gawber | | 2 | 3 | 1.244 | 3 | 1.7 |
| 09-Aug | Birmingham Centre | 14357 | -9 | 3 | 0.099 | 3 | 0.6 |
| 06-Sep | Birmingham Tyburn | 301002 | 1 | 3 | 0.984 | 3 | 0.4 |
| 13-Sep | Blackpool Marton | l-ar-010 | 0 | 3 | 0.958 | 3 | 1.5 |
| 01-Aug | Bolton | 196 | 1 | 3 | 0.897 | 3 | 0.7 |
| 21-Jul | Bottesford | 61689-332 | 3 | 3 | 0.964 | 3 | 0.6 |
| 23-Aug | Bournemouth | 824 | 1 | 3 | 0.996 | 3 | 0.3 |
| 31-Jul | Bradford Centre | | 3 | 3 | 0.975 | 3 | 2.7 |
| 18-Sep | Brighton Preston Park | 542 | 4 | 3 | 0.503 | 3 | 0.5 |
| 17-Jul | Bristol St Paul's | 155 | 3 | 3 | 0.986 | 3 | 1.0 |
| 02-Aug | Bury Roadside | 106 | 2 | 4.1 | 0.975 | 3 | 4.7 |
| 02-Aug | Coventry Memorial Park | | 1 | 3 | 0.895 | 3 | 0.6 |
| 18-Jul | Exeter Roadside | 1317 | 1 | 3 | 0.955 | 3 | 1.9 |

CERTIFICATE OF CALIBRATION

551.11, Harwell, Didcot, Oxfordshire OX11 0QJ. Telephone 0870 1906465 Fax 0870 1906377


 Certificate Number: 01668
 AEA Identification Number: ED45077030

Page 6 of 14

0401

| Date Year =2006 | Site | Analyser number | ¹ Zero output | Uncertainty (ppb) | ² Calibration Factor | Uncertainty (%) | *Max Residual (%) |
|-----------------------|------------------------|--------------------|-----------------------------|----------------------|------------------------------------|--------------------|-------------------------|
| 16-Aug | Glazebury | 138 | 8 | 3 | 0.716 | 3 | 1.3 |
| 25-Jul | Great Dun Fell | 176 | -2 | 3 | 0.515 | 3 | 0.9 |
| 13-Jul | Harwell | 1018 | -51 | 3 | 0.533 | 3 | 1.0 |
| 25-Jul | High Muffles | 346 | -21 | 3 | 0.451 | 3 | 2.0 |
| 01-Aug | Hull Freetown | M356 | 243 | 3 | 0.092 | 3 | 0.4 |
| 27-Sep | Ladybower | 125b-101 | 54 | 3 | 0.454 | 3 | 1.5 |
| 23-Aug | Leamington Spa | 1469 | 19 | 3 | 0.836 | 3 | 0.8 |
| 02-Aug | Leeds Centre | 206003 | 2 | 3 | 0.969 | 3 | 0.3 |
| 22-Aug | Leicester Centre | 205006 | 1 | 3 | 0.936 | 3 | 1.5 |
| 24-Jul | Leominster | 14470 | -1 | 3 | 0.970 | 3 | 0.5 |
| 12-Sep | Liverpool Speke | 331 | 237 | 3 | 0.098 | 3 | 0.6 |
| 21-Aug | London Bexley | 403 | 1 | 3 | 0.985 | 3 | 3.2 |
| 19-Jul | London Bloomsbury | 14907 | 20 | 3 | 0.101 | 3 | 0.5 |
| 04-Jul | London Brent | 1608 | 21 | 3 | 0.974 | 3 | 1.0 |
| 21-Aug | London Eltham | 375 | 9 | 3 | 1.122 | 3 | 0.5 |
| 05-Jul | London Hackney | M2110-m382 | 2 | 3 | 0.904 | 3 | 4.9 |
| 13-Sep | London Haringey | 538 | 10 | 3 | 0.944 | 3 | 2.7 |
| 31-Aug | London Harlington | 14309 | -1 | 3 | 0.955 | 3 | 1.2 |
| 06-Jul | London Hillingdon | 12 | 7 | 3 | 0.103 | 3 | 1.1 |
| 12-Sep | London Lewisham | 939b-187 | 2 | 3 | 0.915 | 3 | 3.2 |
| 05-Sep | London Marylebone Road | 10074 | 2 | 3 | 1.009 | 3 | 0.4 |
| 20-Jul | London N. Kensington | 497 | 10 | 3 | 0.961 | 3 | 0.1 |
| 14-Aug | London Southwark | 5776 | -1 | 3 | 0.999 | 3 | 0.8 |
| 31-Jul | London Teddington | 374 | -18 | 3 | 0.192 | 3 | 2.1 |
| 31-Aug | London Wandsworth | 491 | 10 | 3 | 0.993 | 3 | 0.5 |
| 14-Sep | London Westminster | 879 | 12 | 3 | 0.488 | 3 | 0.4 |
| 25-Sep | Lullington Heath | 337 | 99 | 3 | 0.459 | 3 | 1.5 |
| 15-Aug | Manchester Piccadilly | 17 | -7 | 3 | 0.213 | 3 | 1.1 |
| 14-Aug | Manchester South | 3 | -35 | 3 | 0.098 | 3 | 1.1 |
| 18-Jul | Market Harborough | 60894-328 | 3 | 3 | 0.480 | 3 | 0.6 |
| 13-Sep | Middlesbrough | 944 | 3 | 3 | 1.399 | 3 | 0.6 |
| 11-Sep | Newcastle Centre | m357 | 245 | 3 | 0.089 | 3 | 1.6 |
| 26-Jul | Northampton | 8905240110 | 1 | 3 | 0.980 | 3 | 1.5 |
| 25-Sep | Norwich Centre | 206002 | 1 | 3 | 0.882 | 3 | 4.5 |
| 17-Jul | Nottingham Centre | 0427-011 | -13 | 3 | 0.098 | 3 | 0.6 |
| 19-Jul | Plymouth Centre | 35925-251 | 57 | 3 | 0.080 | 3 | 1.4 |
| 08-Aug | Portsmouth | 205002 | 0 | 3 | 0.956 | 3 | 0.3 |
| 13-Sep | Preston | l-ar-013 | 0 | 3 | 0.954 | 3 | 1.0 |
| 11-Jul | Reading New Town | | 11 | 4.7 | 1.043 | 3.1 | 3.9 |
| 13-Sep | Redcar | 799 | 12 | 3 | 0.459 | 3 | 0.6 |
| 13-Oct | Rochester | 95063 | 3 | 3 | 1.084 | 3 | 1.6 |
| 09-Aug | Rotherham Centre | ra427 | 6 | 3 | 0.991 | 3.6 | 0.9 |
| 15-Aug | Salford Eccles | 2363 | -2 | 3 | 0.948 | 3 | 0.5 |
| 25-Jul | Sandwell West Bromwich | 121 | 1 | 3 | 0.483 | 3 | 0 |
| 07-Aug | Sheffield Centre | 427-010 | 5 | 3 | 0.102 | 3 | 1.5 |
| 05-Sep | Sibton | 219 | 11 | 3 | 0.482 | 3 | 0.7 |
| 20-Jul | Somerton | 95249 | 4 | 3 | 0.475 | 3 | 1.2 |
| 22-Aug | Southampton Centre | m354 | 245 | 3 | 0.096 | 3 | 1.0 |
| 05-Oct | Southend-on-Sea | | -14 | 3 | 0.724 | 3 | 1.2 |

CERTIFICATE OF CALIBRATION

551.11, Harwell, Didcot, Oxfordshire OX11 0QJ. Telephone 0870 1906465 Fax 0870 1906377


 Certificate Number: 01668
 AEA Identification Number: ED45077030

Page 7 of 14

0401

| Date Year =2006 | Site | Analyser number | ¹ Zero output | Uncertainty (ppb) | ² Calibration Factor | Uncertainty (%) | *Max Residual (%) |
|-----------------|-----------------------|-----------------|--------------------------|-------------------|---------------------------------|-----------------|-------------------|
| 05-Oct | St Osyth | 60869 | 0 | 3 | 56.301 | 3 | 0.4 |
| 14-Aug | Stoke-on-Trent Centre | | 5 | 3.1 | 1.239 | 3 | 1.7 |
| 14-Sep | Sunderland Silksworth | 436 | 1 | 3 | 0.983 | 3 | 0.7 |
| 06-Sep | Thurrock | 2040 | -3 | 3 | 0.466 | 3 | 1.4 |
| 05-Sep | Weybourne | 70532-366 | 2 | 3 | 0.984 | 3 | 1.7 |
| 27-Sep | Wicken Fen | 14345 | | Not | tested | | |
| 01-Aug | Wigan Centre | 4009 | -1 | 3 | 0.997 | 3 | 0.8 |
| 12-Sep | Wirral Tranmere | | 2 | 3 | 0.963 | 3 | 1.7 |
| 30-Aug | Wolverhampton Centre | 427-009 | 2 | 3 | 0.998 | 3 | 1.6 |
| 28-Sep | Yarner Wood | 437 | -29 | 3 | 0.465 | 3 | 1.0 |

4. Oxides of Nitrogen

| Date Year =2006 | Site | | Analyser number | ¹ Zero output | Uncertainty (ppb) | ² Calibration Factor | Uncertainty (%) | *Max residual (%) | *Converter efficiency (%) |
|-----------------|-----------------------|-----------|-----------------|--------------------------|-------------------|---------------------------------|-----------------|-------------------|---------------------------|
| | Scottish Sites | | | | | | | | |
| 18-Jul | Aberdeen | NO NOx | | 1 0 | 5 5.5 | 1.74 1.75 | 5 5.1 | 2.2 2.1 | 99.3 |
| 24-Jul | Dumfries | NO NOx | 781 | 2 2 | 5 5.4 | 1.32 1.32 | 5 5 | 1.0 0.4 | 99.6 |
| 12-Jul | Edinburgh St Leonards | NO NOx | 73 | 4 4 | 5 5.3 | 1.20 1.21 | 5 5.1 | 0.9 0.6 | 97.4 |
| 24-Jul | Eskdalemuir | NO NOx | 347 | 1 -1 | 5 5.4 | 1.19 1.09 | 5 5.2 | 1.6 2.0 | 100.2 |
| 05-Jul | Fort William | NO NOx | M200E 344 | 1 1 | 5 5.3 | 1.03 1.04 | 5 5 | 1.1 0.9 | 100.5 |
| 04-Jul | Glasgow Centre | NO NOx | 447 | 5 5 | 5 5.2 | 0.52 0.52 | 5.7 5.6 | 1.6 3.3 | 96.9 |
| 06-Jul | Glasgow City Chambers | NO NOx | 575 | 1 3 | 5 5.4 | 1.32 1.38 | 5 5 | 1.4 0.9 | 100.0 |
| 04-Jul | Glasgow Kerbside | NO NOx | | -12 -10 | 5 8.9 | 3.33 3.35 | 5.6 6.9 | 0.9 1.1 | 98.4 |
| 14-Jul | Grangemouth | NO NOx | 700B-312 | 1 2 | 5 5.4 | 1.02 1.03 | 5 5.3 | 1.9 2.3 | 95.7 |
| 19-Jul | Inverness | NO NOx | | 0 3 | 5 5.3 | 1.19 1.18 | 5 5.1 | 0.7 0.7 | 97.6 |
| | Welsh Sites | | | | | | | | |
| | Aston Hill | NO NOx | 2221 | | Not | tested | | | |
| 12-Jul | Cardiff Centre | NO NOx | 71 | 2 3 | 5 5.4 | 1.28 1.30 | 5.2 5.7 | 0.9 0.3 | 100.2 |
| 11-Jul | Cwmbran | NO NOx | 406003 | -3 -3 | 5 5.3 | 1.19 1.14 | 5 5.4 | 0.5 0.4 | 96.8 |
| 13-Jul | Narberth | NO NOx | RAG4580 | 42 40 | 5 5.4 | 1.02 1.02 | 7 6.6 | 2.2 1.8 | 100.4 |
| 10-Jul | Port Talbot | NO NOx | 320 | -1 -1 | 5 5.4 | 1.29 1.31 | 5 5.1 | 0.7 0.9 | 97.4 |
| 10-Jul | Swansea | NO NOx | 148 | 0 5 | 5 5.2 | 0.52 0.52 | 5 5.7 | 0.2 1.2 | 100.1 |
| 11-Sep | Wrexham | NO NOx | 12185 | 0 1 | 5 5.3 | 1.03 1.01 | 5 5 | 0.3 0.6 | 99.9 |

CERTIFICATE OF CALIBRATION

551.11, Harwell, Didcot, Oxfordshire OX11 0QJ. Telephone 0870 1906465 Fax 0870 1906377


 Certificate Number: 01668
 AEA Identification Number: ED45077030

Page 8 of 14

0401

| Date Year =2006 | Site | | Analyser number | ¹ Zero output | Uncertainty (ppb) | ² Calibration Factor | Uncertainty (%) | *Max residual (%) | *Converter efficiency (%) |
|-----------------------|---------------------------|-----------|--------------------|-----------------------------|----------------------|------------------------------------|--------------------|-------------------------|---------------------------------|
| | N.Irish Sites | | | | | | | | |
| 14-Aug | Belfast Centre | NO NOx | m1804- m733 | 243 248 | 5 5.2 | 0.44 0.46 | 5 5 | 0.8 0.8 | 101.9 |
| 30-Aug | Derry | NO NOx | j-ar-009 | 56 56 | 5 5.4 | 1.59 1.62 | 5 5.2 | 1.5 2.1 | 102.9 |
| | English Sites | | | | | | | | |
| 08-Aug | Barnsley Gawber | NO NOx | | 11 10 | 5 6.5 | 2.77 2.80 | 5 8.9 | 0.6 2.2 | 96.6 |
| 07-Sep | Bath Roadside | NO NOx | 12758 | 12 12 | 5 5.4 | 1.57 1.57 | 5 5 | 0.6 0.2 | 97.7 |
| 12-Sep | Billingham | NO NOx | 574 | 1 2 | 5 5.3 | 1.15 1.16 | 5 5 | 1.5 0.9 | 111.3 |
| 09-Aug | Birmingham Centre | NO NOx | 14324 | -7 0 | 5 5.2 | 0.45 0.45 | 5 5 | 1.7 1.7 | 100.1 |
| 06-Sep | Birmingham Tyburn | NO NOx | 209006 | 0 1 | 5 5.3 | 1.01 1.01 | 5 5 | 0.7 0.1 | 97.8 |
| 13-Sep | Blackpool Marton | NO NOx | l-ar-010 | 68 68 | 5 5.4 | 1.59 1.62 | 5 5.8 | 1.8 0.7 | 98.2 |
| 01-Aug | Bolton | NO NOx | 433 | -2 7 | 5 5.7 | 1.00 0.96 | 5 5 | 0.1 1.3 | 104.5 |
| 23-Aug | Bournemouth | NO NOx | 522 | -1 -4 | 5 5.3 | 1.08 1.07 | 5 5 | 0.9 0.6 | 99.7 |
| 31-Jul | Bradford Centre | NO NOx | | 12 12 | 5 5.5 | 1.79 1.87 | 5 5.8 | 2.1 2.1 | 96.9 |
| 12-Jul | Brentford Roadside | NO NOx | 712 | -2 8 | 5 5.5 | 1.09 1.10 | 5 5 | 0.8 0.3 | 100.2 |
| 18-Sep | Brighton Preston Park | NO NOx | 2222 | -1 -1 | 5 5.4 | 1.31 1.29 | 5 5 | 1.0 0.2 | 95.4 |
| 18-Sep | Brighton Roadside | NO NOx | 1225 | 9 10 | 5 5.4 | 1.39 1.37 | 5 5.7 | 0.5 0.8 | 95.2 |
| 17-Jul | Bristol Old Market | NO NOx | 10510 | 0 1 | 5 5.6 | 1.29 1.29 | 5 5 | 0.7 1.0 | 100.1 |
| 17-Jul | Bristol St Paul's | NO NOx | 77 | 3 10 | 5 5.3 | 1.07 1.10 | 5 5 | 2.1 0.8 | 99.9 |
| 02-Aug | Bury Roadside | NO NOx | 229 | 0 5 | 5 5.5 | 1.20 1.21 | 5 5.2 | 1.4 2.8 | 100.8 |
| 04-Sep | Cambridge Roadside | NO NOx | 303 | -2 -3 | 5 5.4 | 0.94 0.93 | 5 5 | 0.5 0.7 | 97.6 |
| 15-Aug | Camden Kerbside | NO NOx | 623 | 2 4 | 5 5.4 | 1.02 1.06 | 5 5 | 0.4 0.5 | 98.1 |
| 28-Sep | Canterbury | NO NOx | 11666 | 1 4 | 5 5.4 | 1.33 1.34 | 5 5.3 | 0.6 0.2 | 99.7 |
| 02-Aug | Coventry Memorial Park | NO NOx | | -1 -5 | 5 5.3 | 1.07 1.09 | 5 5 | 0.3 0.5 | 97.0 |
| 18-Jul | Exeter Roadside | NO NOx | g0000d1s | 0 0 | 5 5.3 | 0.97 0.98 | 5 5 | 0.7 0.6 | 100.5 |
| 16-Aug | Glazebury | NO NOx | 78 | 1 -3 | 5 5.3 | 0.62 0.61 | 5 5 | 1.0 1.1 | 97.1 |
| 13-Sep | Haringey Roadside | NO NOx | 397 | 4 5 | 5 5.7 | 1.10 0.80 | 5.6 5.8 | 3.9 3.5 | 95.6 |
| 13-Jul | Harwell | NO NOx | 83 | 15 13 | 5 5.3 | 0.79 0.78 | 5 5 | 0.2 0.8 | 100 |

CERTIFICATE OF CALIBRATION

551.11, Harwell, Didcot, Oxfordshire OX11 0QJ. Telephone 0870 1906465 Fax 0870 1906377



Certificate Number: 01668

AEA Identification Number: ED45077030

Page 9 of 14

0401

| Date Year =2006 | Site | | Analyser number | ¹ Zero output | Uncertainty (ppb) | ² Calibration Factor | Uncertainty (%) | *Max residual (%) | *Converter efficiency (%) |
|-----------------------|---------------------------|-----|--------------------|-----------------------------|----------------------|------------------------------------|--------------------|-------------------------|---------------------------------|
| 25-Jul | High Muffles | NO | M1935- | 18 | 5 | 0.55 | 5 | 1.7 | |
| | | NOx | M784 | 34 | 5.2 | 0.57 | 5 | 1.7 | 99.0 |
| 19-Sep | Hove Roadside | NO | 199 | -5 | 5 | 0.71 | 5 | 1.1 | |
| | | NOx | | -4 | 5.2 | 0.69 | 5 | 1.6 | 99.6 |
| 01-Aug | Hull Freetown | NO | M732 | 248 | 5 | 0.47 | 5 | 0.5 | |
| | | NOx | | 253 | 5.2 | 0.49 | 5 | 0.3 | 100.3 |
| 27-Sep | Ladybower | NO | 189 | 3 | 5 | 0.60 | 5 | 0.7 | |
| | | NOx | | 2 | 5.2 | 0.58 | 5 | 0.2 | 95.9 |
| 23-Aug | Leamington Spa | NO | 1705 | 20 | 5 | 2.68 | 5 | 1.6 | |
| | | NOx | | 21 | 5.8 | 2.64 | 5 | 1.3 | 100.3 |
| 02-Aug | Leeds Centre | NO | 210005 | 1 | 5 | 1.07 | 5 | 2.2 | |
| | | NOx | | 2 | 5.3 | 1.02 | 5 | 0.5 | 97.8 |
| 22-Aug | Leicester Centre | NO | 210004 | 0 | 5 | 1.09 | 5 | 0.7 | |
| | | NOx | | 0 | 5.3 | 1.11 | 5 | 0.3 | 100.0 |
| 24-Jul | Leominster | NO | 14863 | 1 | 5 | 1.04 | 5 | 0.2 | |
| | | NOx | | 4 | 5.4 | 1.05 | 5 | 0.5 | 98.5 |
| 12-Sep | Liverpool Speke | NO | 734 | 244 | 5 | 0.45 | 5 | 1.0 | |
| | | NOx | | 249 | 5.3 | 0.45 | 5.5 | 1.3 | 99.6 |
| 06-Jul | London A3 Roadside | NO | | 65 | 5 | 2.91 | 6.1 | 1.9 | |
| | | NOx | | 68 | 7.1 | 3.12 | 6.3 | 1.8 | 99.7 |
| 21-Aug | London Bexley | NO | 327 | 1 | 5 | 0.81 | 5 | 0.6 | |
| | | NOx | | 3 | 5.3 | 0.79 | 5 | 0.7 | 98.5 |
| 19-Jul | London Bloomsbury | NO | 14328 | 16 | 5 | 0.62 | 5 | 1.9 | |
| | | NOx | | 10 | 5.2 | 0.61 | 6.1 | 2.4 | 97.9 |
| 04-Jul | London Brent | NO | 1852 | 22 | 5 | 2.15 | 5 | 0.5 | |
| | | NOx | | 30 | 6.2 | 2.20 | 5.1 | 0.3 | 98.5 |
| 05-Jul | London Bromley | NO | 10669 | 0 | 5 | 1.14 | 5 | 2.2 | |
| | | NOx | | 0 | 5.3 | 1.18 | 5 | 1.1 | 100.2 |
| 09-Oct | London Cromwell Road 2 | NO | | -1 | 5 | 2.92 | 5 | 0.6 | |
| | | NOx | | 1 | 6.7 | 2.94 | 5 | 0.8 | 99.4 |
| 21-Aug | London Eltham | NO | 307 | 3 | 5 | 1.18 | 5 | 0.6 | |
| | | NOx | | 4 | 5.6 | 1.29 | 6.4 | 1.5 | 98.9 |
| 05-Jul | London Hackney | NO | 532b-234 | 1 | 5 | 0.99 | 5 | 0.5 | |
| | | NOx | | 4 | 5.3 | 1.05 | 5 | 0.9 | 100.9 |
| 31-Aug | London Harlington | NO | 11491 | -3 | 5 | 1.34 | 5 | 1.0 | |
| | | NOx | | -3 | 5.4 | 1.35 | 5 | 1.1 | 98.0 |
| 06-Jul | London Hillingdon | NO | 10 | 24 | 5 | 0.36 | 5.9 | 5.9 | |
| | | NOx | | 28 | 5.2 | 0.37 | 6.3 | 5.8 | 99.1 |
| 12-Sep | London Lewisham | NO | m1231- | 0 | 5 | 1.23 | 5 | 0.7 | |
| | | NOx | m530 | 2 | 5.4 | 1.43 | 5 | 1.0 | 99.9 |
| 05-Sep | London Marylebone Road | NO | 10072 | 2 | 5 | 1.90 | 5 | 1.2 | |
| | | NOx | | 2 | 5.9 | 1.83 | 5.3 | 2.6 | 99.6 |
| 20-Jul | London N. Kensington | NO | 459 | 3 | 5 | 1.15 | 5 | 0.2 | |
| | | NOx | | 7 | 5.3 | 1.14 | 5.4 | 0.8 | 96.3 |
| 14-Aug | London Southwark | NO | 197 | 2 | 5 | 0.96 | 5 | 1.1 | |
| | | NOx | | 3 | 5.3 | 0.96 | 5 | 0.7 | 100 |
| 31-Jul | London Teddington | NO | | -1 | 5 | 1.51 | 6.3 | 3.4 | |
| | | NOx | | -2 | 5.6 | 1.50 | 7 | 3.9 | 100 |
| 31-Aug | London Wandsworth | NO | 378 | 2 | 5 | 1.40 | 5 | 0.7 | |
| | | NOx | | 3 | 5.5 | 1.33 | 5.1 | 0.5 | 103.2 |
| 14-Sep | London Westminster | NO | 573 | 1 | 5 | 2.05 | 5 | 0.3 | |
| | | NOx | | -1 | 5.7 | 2.22 | 5.5 | 1.5 | 98.3 |

CERTIFICATE OF CALIBRATION

551.11, Harwell, Didcot, Oxfordshire OX11 0QJ. Telephone 0870 1906465 Fax 0870 1906377



Certificate Number: 01668

AEA Identification Number: ED45077030

Page 10 of 14

0401

| Date Year =2006 | Site | | Analyser number | ¹ Zero output | Uncertainty (ppb) | ² Calibration Factor | Uncertainty (%) | *Max residual (%) | *Converter efficiency (%) |
|-----------------------|---------------------------|-----------|--------------------|-----------------------------|----------------------|------------------------------------|--------------------|-------------------------|---------------------------------|
| 25-Sep | Lullington Heath | NO NOx | 675 | 101 101 | 5 5.4 | 1.07 1.07 | 5.8 6 | 2.5 3.5 | 99.2 |
| 15-Aug | Manchester Piccadilly | NO NOx | 11 | 2 2 | 5 5.5 | 0.47 0.47 | 5 5 | 2.2 2.0 | 96.9 |
| 14-Aug | Manchester South | NO NOx | 8 | -13 0 | 5 5.2 | 0.57 0.58 | 5 5.1 | 2.7 2.5 | 98.0 |
| 15-Aug | Manchester Town Hall | NO NOx | 846 | 5 6 | 5 5.5 | 1.09 1.11 | 5 5.2 | 0.9 1.0 | 98.0 |
| 18-Jul | Market Harborough | NO NOx | 61963-333 | 8 12 | 5 5.3 | 0.59 0.59 | 5 5 | 2.4 1.4 | 100.4 |
| 13-Sep | Middlesbrough | NO NOx | 2287 | -1 -5 | 5 5.4 | 1.35 1.32 | 5 5 | 0.9 1.2 | 96.6 |
| 11-Sep | Newcastle Centre | NO NOx | m730 | 249 253 | 5 5.6 | 0.50 0.51 | 5.5 5 | 1.2 1.2 | 95.9 |
| 26-Jul | Northampton | NO NOx | 8513180611 | 0 2 | 5 5.3 | 1.08 1.07 | 5 5 | 0 0.3 | 96.8 |
| 25-Sep | Norwich Centre | NO NOx | 211001 | 0 1 | 5 5.3 | 1.10 1.11 | 5 5 | 0.8 0.9 | 100.3 |
| 26-Sep | Norwich Forum Roadside | NO NOx | 10616 | 1 1 | 5 5.3 | 1.09 1.07 | 5 5 | 1.3 0.5 | 100.8 |
| 17-Jul | Nottingham Centre | NO NOx | 0447-009 | -13 -13 | 5 5.2 | 0.59 0.58 | 5 5.1 | 0.9 0.9 | 95.9 |
| 04-Jul | Oxford Centre Roadside | NO NOx | 947 | 98 104 | 5 5.3 | 1.02 1.03 | 5 5 | 1.0 1.1 | 97.3 |
| 19-Jul | Plymouth Centre | NO NOx | | 2 11 | 5 5.2 | 0.17 0.20 | 5 5 | 0.7 0.8 | 100.0 |
| 08-Aug | Portsmouth | NO NOx | 904005 | 0 0 | 5 5.3 | 1.01 1.00 | 5 5 | 0.4 0.3 | 100.7 |
| 13-Sep | Preston | NO NOx | l-ar-013 | 143 142 | 5 5.4 | 1.45 1.42 | 5 5.3 | 1.5 1.1 | 99.3 |
| 11-Jul | Reading New Town | NO NOx | | 5 6 | 5 5.5 | 1.23 1.23 | 5 5.5 | 3.4 3.6 | 99.7 |
| 13-Sep | Redcar | NO NOx | 497 | 0 3 | 5 5.4 | 1.06 1.08 | 5 5 | 1.6 2.0 | 98.3 |
| 13-Oct | Rochester | NO NOx | 95059 | 0 -1 | 5 5.5 | 1.16 1.19 | 5 5 | 0.7 0.8 | 96.5 |
| 09-Aug | Rotherham Centre | NO NOx | 0447-001 | 12 10 | 5 5.3 | 1.14 1.13 | 5 5.1 | 1.4 1.6 | 95.5 |
| 15-Aug | Salford Eccles | NO NOx | 2381 | 1 2 | 5 5.5 | 1.17 1.17 | 5 6.6 | 1.6 3.2 | 98.7 |
| 25-Jul | Sandwell West Bromwich | NO NOx | 93081 | 1 0 | 5 5.3 | 1.01 1.03 | 5 5 | 1.3 1.8 | 100.2 |
| 07-Aug | Sheffield Centre | NO NOx | 0447-008 | 10 5 | 5 5.2 | 0.52 0.53 | 5 5.5 | 0.7 0.5 | 92 |
| 07-Aug | Sheffield Tinsley | NO NOx | 847 | -4 -3 | 5 6 | 2.90 2.96 | 5 5.5 | 0.3 2.9 | 103.3 |
| 20-Jul | Somerton | NO NOx | 12895 | 4 5 | 5 5.2 | 0.45 0.44 | 5 5 | 0.5 0.7 | 99.0 |
| 22-Aug | Southampton Centre | NO NOx | m723 | 210 225 | 5 5.4 | 0.69 0.68 | 5 5.4 | 0.4 1.1 | 96.5 |
| 05-Oct | Southend-on-Sea | NO NOx | | 0 -1 | 5 5.3 | 1.01 1.03 | 5 5.1 | 0.9 1.0 | 98.1 |

CERTIFICATE OF CALIBRATION

551.11, Harwell, Didcot, Oxfordshire OX11 0QJ. Telephone 0870 1906465 Fax 0870 1906377


 Certificate Number: 01668
 AEA Identification Number: ED45077030

Page 11 of 14

0401

| Date Year =2006 | Site | | Analyser number | ¹ Zero output | Uncertainty (ppb) | ² Calibration Factor | Uncertainty (%) | *Max residual (%) | *Converter efficiency (%) |
|-----------------|------------------------|-----------|-----------------|--------------------------|-------------------|---------------------------------|-----------------|-------------------|---------------------------|
| 05-Oct | St Osyth | NO NOx | 60988 | 0 0 | 6.4 8 | 51.6 52.1 | 5.9 6.1 | 3.6 3.2 | 98.0 |
| 02-Aug | Stockport Shaw Heath | NO NOx | 1853 | 18 19 | 5 7 | 2.93 3.08 | 5.4 6.2 | 2.3 2.2 | 103.8 |
| 12-Sep | Stockton-on-Tees Yarm | NO NOx | 118 | 3 -2 | 5 6.8 | 1.37 1.41 | 6.5 5.7 | 4.3 3.7 | 95.8 |
| 14-Aug | Stoke-on-Trent Centre | NO NOx | | 50 51 | 5 5.3 | 1.06 1.15 | 5.2 6.8 | 3.3 2.8 | 95.2 |
| 14-Sep | Sunderland Silksworth | NO NOx | 734B-322 | 0 0 | 5 5.3 | 1.12 1.12 | 5 5.2 | 1.6 1.7 | 99.3 |
| 06-Sep | Thurrock | NO NOx | 920 | 1 3 | 5 5.3 | 1.12 1.10 | 5 5.3 | 1.2 1.3 | 97.7 |
| 31-Jul | Tower Hamlets Roadside | NO NOx | 306 | 3 5 | 5 5.4 | 1.01 0.93 | 5 5.2 | 0.6 0.4 | 100.4 |
| 10-Jul | Walsall Alumwell | NO NOx | 848 | -4 -6 | 5 5.3 | 0.87 0.88 | 5 5.2 | 3.2 3.2 | 98.6 |
| 24-Aug | Walsall Willenhall | NO NOx | 1337 | 0 4 | 5 5.3 | 1.11 1.12 | 5 5 | 0.8 0.4 | 99.6 |
| 09-Oct | West London | NO NOx | | -3 -2 | 5 5.5 | 1.25 1.23 | 5.5 5 | 0.9 0.4 | 99.6 |
| 27-Sep | Wicken Fen | NO NOx | 13069 | 19 21 | 5 5.2 | 0.53 0.56 | 5 5.2 | 1.0 1.4 | 99.8 |
| 01-Aug | Wigan Centre | NO NOx | 805005 | 0 0 | 5 5.3 | 1.08 1.06 | 5 5 | 0.5 0.2 | 98.9 |
| 12-Sep | Wirral Tranmere | NO NOx | | 22 23 | 5 5.7 | 2.24 2.32 | 5.2 5.5 | 2.8 1.3 | 99.8 |
| 30-Aug | Wolverhampton Centre | NO NOx | 7 | 71 62 | 5 5.6 | 0.60 0.61 | 5 5 | 0.6 1.5 | 98.4 |
| 28-Sep | Yarner Wood | NO NOx | 1784 | 31 28 | 5 5.3 | 0.87 0.83 | 5 5 | 1.7 1.3 | 95.4 |

5. Particulate Analysers

| Date Year =2006 | Site | Analyser number | Calculated Spring Constant k_0 | Uncertainty (%) | ⁴ k_0 accuracy (%) | ³ Measured Main Flow (l/min) | Uncertainty (%) | ³ Measured Total Flow Aux Flow (l/min) | Uncertainty (%) |
|-----------------|-----------------------|-----------------|----------------------------------|-----------------|---------------------------------|---|-----------------|---|-----------------|
| | Scottish Sites | | | | | | | | |
| 18-Jul | Aberdeen | 24427 | 11774 | 1 | 1.8 | 2.90 | 2.2 | 13.33 | 2.2 |
| 24-Jul | Dumfries | | | | | | | Not | tested |
| 12-Jul | Edinburgh St Leonards | 21308 | 12907 | 1 | 0.7 | 2.01 | 2.2 | 16.16 | 2.2 |
| 04-Jul | Glasgow Centre | 22980 | 13203 | 1 | 0.5 | 1.95 | 2.2 | 16.18 | 2.2 |
| 04-Jul | Glasgow Kerbside | 24444 | 10635 | 1 | 1.7 | 2.09 | 2.2 | 17.47 | 2.2 |
| 14-Jul | Grangemouth | 22763 | 12518 | 1 | -1.0 | 3.33 | 2.2 | 17.80 | 2.2 |
| 19-Jul | Inverness | 212550003 | | | | | | 16.93 | 2.2 |
| | Welsh Sites | | | | | | | | |
| 12-Jul | Cardiff Centre | 24449 | 14317 | 1 | 0.1 | 2.05 | 2.2 | 14.27 | 2.2 |
| 11-Jul | Cwmbran | 21557 | 12692 | 1 | 1.2 | 2.89 | 2.2 | 13.49 | 2.2 |
| 13-Jul | Narberth | 2000 | 12612 | 1 | 3.6 | 2.99 | 2.2 | 14.27 | 2.2 |
| 10-Jul | Port Talbot | 2000 | 10827 | 1 | 2.2 | 3.08 | 2.2 | 14.87 | 2.2 |

CERTIFICATE OF CALIBRATION

551.11, Harwell, Didcot, Oxfordshire OX11 0QJ. Telephone 0870 1906465 Fax 0870 1906377


 Certificate Number: 01668
 AEA Identification Number: ED45077030

Page 12 of 14

0401

| Date Year =2006 | Site | Analyser number | Calculated Spring Constant k_0 | Uncertainty (%) | 4k_0 accuracy (%) | 3 Measured Main Flow (l/min) | Uncertainty (%) | 3 Measured Total Flow Aux Flow (l/min) | Uncertainty (%) |
|-----------------|--|-----------------|----------------------------------|-----------------|----------------------|---------------------------------|-----------------|---|-----------------|
| 10-Jul | Swansea | 2130 | 14422 | 1 | -1.0 | 2.05 | 2.2 | 14.57 | 2.2 |
| 11-Sep | Wrexham | 21224001 | | | | | | 16.10 | 2.2 |
| | N.Irish Sites | | | | | | | | |
| 14-Aug | Belfast Centre | 24423 | 14297 | 1 | 0.7 | 2.03 | 2.2 | 14.23 | 2.2 |
| 16-Aug | Belfast Clara St | 25456 | 11810 | 1 | -0.7 | 2.04 | 2.2 | 14.10 | 2.2 |
| 30-Aug | Derry | 49608 | 10945 | 1 | 0.5 | 2.10 | 2.2 | 15.06 | 2.2 |
| 22-Aug | Lough Navar | 21196 | 12920 | 1 | 0.8 | 2.89 | 2.2 | Not | tested |
| | English Sites | | | | | | | | |
| 09-Aug | Birmingham Centre | 3297 | 12166 | 1 | 0.7 | 3.02 | 2.2 | 16.66 | 2.2 |
| 06-Sep | Birmingham Tyburn | 24637 | 13735 | 1 | -3.3 | 2.99 | 2.2 | 15.38 | 2.2 |
| 13-Sep | Blackpool Marton | 24424 | 12923 | 1 | 0.2 | 2.02 | 2.2 | 15.64 | 2.2 |
| 01-Aug | Bolton | 21197 | 15242 | 1 | 0.5 | 3.09 | 2.2 | 14.49 | 2.2 |
| 23-Aug | Bournemouth | | | | | | | 16.13 | 2.2 |
| 31-Jul | Bradford Centre | 21494 | 11445 | 1 | 0.8 | 2.00 | 2.2 | 16.05 | 2.2 |
| 18-Sep | Brighton Roadside | | | | | | | 16.82 | 2.2 |
| 17-Jul | Bristol St Paul's | 24426 | 13250 | 1 | 0.5 | 2.00 | 2.2 | 16.27 | 2.2 |
| 02-Aug | Bury Roadside | 658 | 11682 | 1 | 0.7 | 2.04 | 2.2 | 16.77 | 2.2 |
| 15-Aug | Camden Kerbside | 0 | 16402 | 1 | -0.1 | 2.97 | 2.2 | 16.68 | 2.2 |
| 28-Sep | Canterbury | 20931 | 14128 | 1 | 0.7 | 2.98 | 2.2 | 13.62 | 2.2 |
| 02-Aug | Coventry Memorial Park | 25026 | 13225 | 1 | 0.3 | 2.92 | 2.2 | 13.13 | 2.2 |
| 13-Sep | Haringey Roadside | 9407 | 11463 | 1 | 0.1 | 2.62 | 2.2 | 14.45 | 2.2 |
| 13-Jul | Harwell PM ₁₀ | 21489 | 14736 | 1 | -1.2 | 3.05 | 2.2 | 16.45 | 2.2 |
| 13-Jul | Harwell PM _{2.5} | 21490 | 10826 | 1 | -0.5 | 3.06 | 2.2 | 16.85 | 2.2 |
| 01-Aug | Hull Freetown | 24445 | 14287 | 1 | 1.3 | 2.04 | 2.2 | 15.87 | 2.2 |
| 23-Aug | Leamington Spa | 2075 | 11080 | 1 | 1.3 | 3.12 | 2.2 | 17.08 | 2.2 |
| 02-Aug | Leeds Centre | 24451 | 13458 | 1 | 0.5 | 2.85 | 2.2 | 13.44 | 2.2 |
| 22-Aug | Leicester Centre | 24442 | 14073 | 1 | 0.4 | 3.08 | 2.2 | 16.32 | 2.2 |
| 12-Sep | Liverpool Speke | 2445 | 15802 | 1 | -0.1 | 2.00 | 2.2 | 15.88 | 2.2 |
| 06-Jul | London A3 Roadside | 24425 | 12344 | 1 | -0.7 | 1.98 | 2.2 | 16.15 | 2.2 |
| 21-Aug | London Bexley | 2000 | 10531 | 1 | 0.6 | 1.96 | 2.2 | 16.09 | 2.2 |
| 19-Jul | London Bloomsbury PM ₁₀ | 24446 | 13904 | 1 | 1.2 | 3.18 | 2.2 | 15.19 | 2.2 |
| 19-Jul | London Bloomsbury PM _{2.5} | 21492 | 15005 | 1 | 0.4 | 3.01 | 2.2 | 13.02 | 2.2 |
| 04-Jul | London Brent | 21145 | 17636 | 1 | 0.7 | 3.09 | 2.2 | 9.15 | 2.2 |
| 21-Aug | London Eltham | Not | tested | analyser | fault | | | | |
| 31-Aug | London Harlington | 22835 | 14343 | 1 | 1.0 | 2.00 | 2.2 | 16.06 | 2.2 |
| 06-Jul | London Hillingdon | 24422 | 14194 | 1 | -0.3 | 1.96 | 2.2 | 15.23 | 2.2 |
| 05-Sep | London Marylebone Road PM ₁₀ | 21306 | 13378 | 1 | 0.3 | 3.05 | 2.2 | 16.30 | 2.2 |
| 05-Sep | London Marylebone Road PM _{2.5} | 21493 | 14312 | 1 | -1.6 | 3.05 | 2.2 | 16.00 | 2.2 |
| 20-Jul | London N. Kensington | 20715 | 10983 | 1 | 1.5 | 3.04 | 2.2 | 13.43 | 2.2 |
| 14-Sep | London Westminster | 204969902 | | | | | | 16.21 | 2.2 |
| 15-Aug | Manchester Piccadilly | 2000 | 12180 | 1 | 1.1 | 1.99 | 2.2 | 14.19 | 2.2 |
| 13-Sep | Middlesbrough | 24325 | 13867 | 1 | -1.9 | 2.03 | 2.2 | 15.84 | 2.2 |

CERTIFICATE OF CALIBRATION

551.11, Harwell, Didcot, Oxfordshire OX11 0QJ. Telephone 0870 1906465 Fax 0870 1906377


 Certificate Number: 01668
 AEA Identification Number: ED45077030

Page 13 of 14

0401

| Date Year =2006 | Site | Analyser number | Calculated Spring Constant k_0 | Uncertainty (%) | 4k_0 accuracy (%) | 3 Measured Main Flow (l/min) | Uncertainty (%) | 3 Measured Total Flow Aux Flow (l/min) | Uncertainty (%) |
|-----------------|-----------------------------|-----------------|----------------------------------|-----------------|----------------------|---------------------------------|-----------------|---|-----------------|
| 11-Sep | Newcastle Centre | 24448 | 13795 | 1 | -0.2 | 2.98 | 2.2 | 13.27 | 2.2 |
| 26-Jul | Northampton | 21621 | 11266 | 1 | 1.1 | 2.85 | 2.2 | 12.55 | 2.2 |
| 26-Jul | Northampton Partisol | | | | | | | Not | tested |
| 25-Sep | Norwich Centre | 21495 | 11231 | 1 | -8.0 | 2.15 | 2.2 | 14.32 | 2.2 |
| 17-Jul | Nottingham Centre | 20904 | 8876 | 1 | 2.3 | 2.01 | 2.2 | 13.85 | 2.2 |
| 19-Jul | Plymouth Centre | 24428 | 13059 | 1 | 0.9 | 2.02 | 2.2 | 15.15 | 2.2 |
| 08-Aug | Portsmouth | 21578 | 10499 | 1 | -0.7 | 2.93 | 2.2 | 13.81 | 2.2 |
| 13-Sep | Preston | 22881 | 12881 | 1 | -0.6 | 2.02 | 2.2 | 16.29 | 2.2 |
| 11-Jul | Reading New Town | 2000 | 13291 | 1 | 0.7 | 1.81 | 2.2 | 15.67 | 2.2 |
| 13-Sep | Redcar | 21344 | 11831 | 1 | 0.4 | 0.73 | 2.2 | 12.20 | 2.2 |
| 13-Oct | Rochester PM ₁₀ | 24381 | 12032 | 1 | -0.2 | 2.99 | 2.2 | 16.05 | 2.2 |
| 13-Oct | Rochester PM _{2.5} | 21491 | 13602 | 1 | -2.4 | 3.11 | 2.2 | 17.09 | 2.2 |
| 15-Aug | Salford Eccles | 21168 | 14591 | 1 | 1.2 | 2.09 | 2.2 | 16.09 | 2.2 |
| 01-Aug | Scunthorpe Town | 6000 | 12612 | 1 | -0.4 | 3.17 | 2.2 | 14.24 | 2.2 |
| 07-Aug | Sheffield Centre | 25024 | 12249 | 1 | 0.0 | 2.02 | 2.2 | 14.52 | 2.2 |
| 22-Aug | Southampton Centre | 4484 | 14018 | 1 | 1.0 | 1.93 | 2.2 | 16.52 | 2.2 |
| 05-Oct | Southend-on-Sea | 22927 | 13486 | 1 | 0.7 | 1.97 | 2.2 | 14.54 | 2.2 |
| 02-Aug | Stockport Shaw Heath | 2000 | 10614 | 1 | 1.9 | 3.07 | 2.2 | 14.11 | 2.2 |
| 12-Sep | Stockton-on-Tees Yarm | 22885 | 14148 | 1 | -1.0 | 3.02 | 2.2 | 15.79 | 2.2 |
| 14-Aug | Stoke-on-Trent Centre | 25028 | 12419 | 1 | -0.7 | 1.98 | 2.2 | 16.27 | 2.2 |
| 06-Sep | Thurrock | 25039 | 12906 | 1 | -0.5 | 2.98 | 2.2 | 14.10 | 2.2 |
| 01-Aug | Wigan Centre | 22015 | 12090 | 1 | 0.2 | 3.01 | 2.2 | 13.45 | 2.2 |
| 12-Sep | Wirral Tranmere | 22883 | 13204 | 1 | -0.7 | 1.98 | 2.2 | 16.33 | 2.2 |
| 30-Aug | Wolverhampton Centre | 20917 | 13924 | 1 | 1.3 | 2.02 | 2.2 | 16.23 | 2.2 |

CERTIFICATE OF CALIBRATION

551.11, Harwell, Didcot, Oxfordshire OX11 0QJ. Telephone 0870 1906465 Fax 0870 1906377



Certificate Number: 01668
AEA Identification Number: ED45077030

Page 14 of 14

0401

The above factors have been calculated using certified standards. The analysers listed above have been tested for zero response, calibration factor, linearity, converter efficiency (NO_x analysers), m-xylene interference (SO₂ analysers), k₀ / main flow rate (for TEOM analysers) and total flow rate (for particulate analysers), by documented methods. Note that the test results are valid on the day of test only, as analyser drift over time cannot be quantified.

The calibration results for NO_x, NO, CO, SO₂, O₃ and Particulates are those that fall within our scope of accreditation. Results marked with an asterisk (*) on this certificate fall outside our accreditation, but have been included for completeness.

¹ The zero response is the zero reading on the logging system of the analyser when audit zero gas was introduced to the analysers under test.

² The calibration factor is the multiplying factor required to scale the reading on the data logging system into concentration units (ppb for NO, NO_x and SO₂, ppm for CO - 1ppm = 1000 ppb). It should be used in conjunction with the analyser output and the zero response, according to the following equation:

$$\text{Concentration} = (\text{output} - \text{zero response}) \times \text{Calibration factor}$$

The scaling factor for gaseous analysers is calculated using mole fraction concentrations.

³ The measured main flow rate (where this is applicable) is the flow rate through the sensor unit of a TEOM analyser. The measured aux flow rate (where this is applicable) is the flow rate through the bypass tubing of the TEOM particulate analyser under test. The measured total flow rate is the total flow rate through the particulate analyser under test. Units of flow are l.min⁻¹. Measurements shown in **bold** are not made at the normal sample inlet and may not therefore accurately represent the actual flow through the inlet.

⁴ The k₀ accuracy value (specifically for TEOM analysers) indicates the closeness of the calculated result to the manufacturer's specified value of k₀.

* The maximum residual is the percentage maximum deviation of the worst linearity point from the line of best fit

* R² is the correlation coefficient of linearity

* Converter is the measured efficiency of the NO₂ to NO converter in the Nitrogen Oxides analyser

* meta-xylene interference is the response of the SO₂ analyser when supplied with approx 1ppm meta-xylene.

This certificate is an electronic representation of a certificate signed by Stewart Eaton on 23/3/2007 and held by AEA at the above address. Hard copies are available on request.

