



**RICARDO-AEA**

## Assessment of particulate emissions from energy-from-waste plant

National Atmospheric Emissions Inventory

---

Report for Defra

AQ0726

**Customer:****Defra****Customer reference:**

AQ0726

**Confidentiality, copyright & reproduction:**

This report is the Copyright of Defra and has been prepared by Ricardo-AEA Ltd under contract AQ0726 to Defra dated 01/10/2011. The contents of this report may not be reproduced in whole or in part, nor passed to any organisation or person without the specific prior written permission of Lucy Barnard, Defra. Ricardo-AEA Ltd accepts no liability whatsoever to any third party for any loss or damage arising from any interpretation or use of the information contained in this report, or reliance on any views expressed therein.

**Contact:**

Robert Stewart  
Ricardo-AEA Ltd  
Gemini Building, Harwell, Didcot, OX11 0QR, United Kingdom

**t:** +44 (0) 1235 75 3611**e:** Robert.stewart@ricardo-aea.com

Ricardo-AEA is certificated to ISO9001 and ISO14001

**Author:**

Thomas Buckland

**Approved By:**

Robert Stewart

**Date:**

14 October 2015

**Ricardo-AEA reference:**

Ref: ED58429013- Final report - Issue 1

# Table of contents

- 1 Introduction..... 1**
- 2 Installation information ..... 1**
- 3 Assessment..... 2**
  - 3.1 Sampling methodology..... 2
  - 3.2 Deviations..... 3
  - 3.3 Results..... 4
  - 3.4 Particulate emission factors ..... 7
- 4 Comparison with NAEI Emission Factors ..... 9**
- 5 Published PM size fractionation data ..... 12**
  - 5.1 Emission factors ..... 12
  - 5.2 Particle size fractionation measurements ..... 12
- 6 Recommendation..... 13**
- 7 Acknowledgment ..... 14**
- 8 References ..... 14**

**Appendices**

- Appendix 1: Stack emissions monitoring report: Riverside Resource Recovery Ltd
- Appendix 2: Stack emissions monitoring report: Newlincs Development Ltd
- Appendix 3: Stack emissions monitoring report: Lakeside Energy From Waste Ltd
- Appendix 4: Stack emissions monitoring report: Veolia ES South Downs Ltd
- Appendix 5: Stack emissions monitoring report: MES Environmental Ltd

## 1 Introduction

Emissions of particulates from energy from waste (EfW) plant, specifically mass burn incinerators, have attracted growing attention in recent years. Ricardo-AEA completed a measurement programme to provide a study of particulate emissions, including Particulate Matter < 10µm (PM<sub>10</sub>), Particulate Matter < 2.5µm (PM<sub>2.5</sub>) and total particulates (total PM). The measurement programme was completed by accredited emission monitoring contractors (ESG), who used European Standard emission measurement techniques at selected United Kingdom EfW plant.

The work was undertaken to support the UK National Atmospheric Emissions Inventory (NAEI).

## 2 Installation information

Sampling of particulate emissions was undertaken at a selection of municipal solid waste EfW plant operating across the United Kingdom. Table 1 and Table 2 provide details of the selected plant.

**Table 1: Plant details**

Site name	Operator	Site address
<b>“Riverside”</b>	Riverside Resource Recovery Ltd	Norman Road Belvedere Bexley Kent DA17 6JY
<b>“Newlincs”</b>	Newlincs Development Ltd	South Marsh Road Stallingborough Grimsby North East Lincolnshire DN41 BZ
<b>“Lakeside”</b>	Lakeside Energy From Waste Ltd	Lakeside Road Colnbrook Slough Berkshire SL3 0FE
<b>“Newhaven”</b>	Veolia ES South Downs Ltd	Energy Recovery Facility North Quay Road Newhaven East Sussex BN9 0HE
<b>“Stoke-on-Trent”</b>	MES Environmental Ltd	Stoke-on-Trent Energy from Waste Plant Campbell Road Sideway Stoke On Trent ST4 4DX

Table 2: EfW plant specifications

Parameter	Riverside	Newlincs	Lakeside	Newhaven	Stoke-on-Trent
<b>Description of process</b>	Incineration of waste				
<b>Continuous or batch</b>	Continuous				
<b>Normal load, throughput or continuous rating</b>	Approx. 30 tonnes per hour	7.2 - 8 tonnes per hour	88 tonnes per hour	Approx. 28 tonnes per hour	11 - 12.5 tonnes per hour
<b>Fuel used during monitoring</b>	Waste	Waste	Waste	Waste	Waste
<b>Pollution abatement</b>	Bag filtration Cyclone Lime injection Carbon injection Scrubber	Bag filtration Lime injection Powdered activated carbon Urea injection	Bag filtration Lime injection Powdered activated carbon Ammonia injection	Bag filtration Lime injection Powdered activated carbon Ammonia injection	Bag filtration Lime injection Powdered activated carbon Urea injection Semi-dry scrubbing
<b>Number of streams</b>	3	1	2	2	2

Note: the EfW plant incorporate auxiliary burners to support combustion and measurement periods may have included short periods where the auxiliary burners were in use.

## 3 Assessment

### 3.1 Sampling methodology

A consistent sampling methodology was applied at each EfW plant, comprising the following approach:

- Samples of PM<sub>10</sub> and PM<sub>2.5</sub> at all sites were collected using a cascade impactor and sampling protocol meeting the requirements of the EN test Standard (BS EN ISO 23210, 2009). The cascade impactor employs the principle of inertial separation to classify particulates into multiple size ranges.
- Particles are driven toward a collecting surface, consisting of a conditioned and pre-weighed substrate. The size of the particles collected is controlled by the velocity of the sampled flue gas within the impactor.
- The collecting substrates are reconditioned and reweighed following sampling, to determine the mass collected.
- To determine the most representative sampling point in the sampling plane, a homogeneity assessment was undertaken, based on BS EN ISO 23210.

- The velocity measurement at the chosen point was used to determine an appropriate sampling nozzle to provide near isokinetic sample flow rate. The volume of duct gas sampled is measured, allowing the particulate concentration at each cut size to be determined.
- Multiple tests (between four and six) were carried out at a selected unit on each installation.
- Extended sampling periods were used to address, as far as possible, uncertainty in the mass of particulate material collected because the anticipated PM concentrations were low (<1 mg/m<sup>3</sup>).
- The average velocity of the flue gases was determined at each plant prior to and after the PM<sub>10</sub>/PM<sub>2.5</sub> measurements to allow determination of the flue gas flow rate.
- Total PM emission concentrations were determined at two plant.
- Flow measurement and measurement of total PM emission concentrations were determined using an EN Standard (BS EN 13284-1, 2002).

### 3.2 Monitoring deviations

Monitoring deviations from the Standard were necessary at all plant in order to provide the most effective assessment of particulate concentrations whilst allowing for plant-specific variations. The monitoring deviations are detailed in Table 3 below and described in further detail in the test reports which are provided in the Appendices.

**Table 3: Deviations from standard sampling practices used in the assessment of PM emissions from the 5 EfW plants**

Methodological deviation	Riverside	Newlincs	Lakeside	Newhaven	Stoke-on-Trent
<b>Goose-neck nozzle</b> Goose-neck nozzles were used as unable to use vertical entry nozzle as recommended under BS EN 23210.	✓	✓	✓	✓	✓
<b>Sample flow variation</b> The sample flow rate could not be maintained within 5% of the nominal flow throughout testing. As the results are at or very near the LOD this is anticipated to have limited impact on the outcome of the measurements.	✓	✓	✓	✓	✓
<b>Pitot static pressure measurements</b> Readings taken every 10 minutes during six hour runs instead of the recommended 5 minutes. This was a practical constraint arising from the extended sampling periods.			✓	✓	
<b>Total PM nozzle size</b> 5mm nozzle used as it was not possible to achieve isokinetic flow with the minimum (6mm) nozzle specified in EN13284-1. Volume of gas sampled during 6-hour sample run deemed to be acceptable.				✓	
<b>Single point Total PM sampling</b> To provide direct comparison with the particle size measurements.				✓	

<p><b>Flow traverse</b> Monitoring completed at a reduced number of velocity traverse points, due to CEM probes causing obstructions on the same sample plane.</p>					✓
--	--	--	--	--	---

### 3.3 Results

Table 4 and Table 5 provides the results of each PM<sub>10</sub> and PM<sub>2.5</sub> sampling run at all EfW plants, including the measured concentration and uncertainty. Where results were found to be at or below the limit of detection reported by the testhouse the figures have been highlighted in *italics*.

**All concentrations and flowrates are normalised to a dry gas condition at STP (0°C, 101.3 kPa) and at 11% oxygen.**

**Table 4: Emission sampling results for PM<sub>10</sub>**

Run	Parameter	Units	Riverside	Newlincs	Lakeside	Newhaven	Stoke-on-Trent
<b>PM<sub>10</sub></b>							
Run 1	Concentration	mg/m <sup>3</sup>	0.281	<i>0.019</i>	0.008	0.07	<i>0.014</i>
	Uncertainty		0.26	0.04	0.01	0.09	0.01
Run 2	Concentration	mg/m <sup>3</sup>	0.016	0.022	0.042	<i>0.009</i>	0.012
	Uncertainty		0.01	0.04	0.03	0.01	0.01
Run 3	Concentration	mg/m <sup>3</sup>	0.033	<i>0.018</i>	0.027	0.03	<i>0.059</i>
	Uncertainty		0.03	0.03	0.02	0.04	0.06
Run 4	Concentration	mg/m <sup>3</sup>	<i>0.015</i>	0.02	0.034	0.021	0.088
	Uncertainty		0.01	0.04	0.03	0.03	0.1
Run 5	Concentration	mg/m <sup>3</sup>	0.084	0.021			
	Uncertainty		0.08	0.04			
Run 6	Concentration	mg/m <sup>3</sup>	0.081	0.023			
	Uncertainty		0.08	0.04			
Min	Concentration	mg/m <sup>3</sup>	0.015	0.018	0.008	0.009	0.012
Max	Concentration	mg/m <sup>3</sup>	0.281	0.023	0.042	0.07	0.088
Average	Concentration	mg/m <sup>3</sup>	0.085	0.021	0.028	0.033	0.043

Table 5: Emission sampling results for PM<sub>2.5</sub>

Run	Parameter	Units	Riverside	Newlincs	Lakeside	Newhaven	Stoke-on-Trent
<b>PM<sub>2.5</sub></b>							
Run 1	Concentration	mg/m <sup>3</sup>	0.008	0.009	0.005	0.056	0.005
	Uncertainty		0.01	0.02	0.01	0.09	0.01
Run 2	Concentration	mg/m <sup>3</sup>	0.008	0.013	0.006	0.004	0.005
	Uncertainty		0.01	0.02	0.01	0.01	0.01
Run 3	Concentration	mg/m <sup>3</sup>	0.007	0.009	0.003	0.008	0.01
	Uncertainty		0.01	0.02	0.01	0.01	0.02
Run 4	Concentration	mg/m <sup>3</sup>	0.008	0.01	0.006	0.009	0.048
	Uncertainty		0.01	0.02	0.01	0.01	0.08
Run 5	Concentration	mg/m <sup>3</sup>	0.008	0.011			
	Uncertainty		0.01	0.02			
Run 6	Concentration	mg/m <sup>3</sup>	0.029	0.01			
	Uncertainty		0.05	0.02			
Min	Concentration	mg/m <sup>3</sup>	0.007	0.009	0.003	0.004	0.005
Max	Concentration	mg/m <sup>3</sup>	0.029	0.013	0.006	0.056	0.048
Average	Concentration	mg/m <sup>3</sup>	0.011	0.010	0.005	0.019	0.017

Table 6 provides the average emission concentration of all stack emission parameters for each plant. Individual test details are contained within the measurement reports (see Appendices). The minimum, maximum and average emission concentration values derived from the average concentrations from all 5 plant are provided in Table 7.



Table 6: Average emission sampling results summary

Parameter	Units	Riverside	Newlincs	Lakeside	Newhaven	Stoke-on-Trent
<b>Total PM (average result of all runs)</b>	mg/m <sup>3</sup>	<i>Not measured</i>	<i>Not measured</i>	<i>Not measured</i>	0.7	0.47
<b>Uncertainty</b>	mg/m <sup>3</sup>	-	-	-	0.26	0.07
<b>PM<sub>10</sub> (average result of all runs)</b>	mg/m <sup>3</sup>	0.085	0.021	0.028	0.033	0.043
<b>Uncertainty</b>	mg/m <sup>3</sup>	0.08	0.04	0.02	0.04	0.05
<b>PM<sub>2.5</sub> (average result of all runs)</b>	mg/m <sup>3</sup>	0.011	0.010	0.005	0.019	0.017
<b>Uncertainty</b>	mg/m <sup>3</sup>	0.02	0.02	0.01	0.03	0.03
<b>PM<sub>10</sub> (% of total PM)</b>	%	-	-	-	4.6	9.1
<b>PM<sub>2.5</sub> (% of total PM)</b>	%	-	-	-	2.7	3.6
<b>PM<sub>2.5</sub> (% of PM<sub>10</sub>)</b>	%	-	-	-	59	40
<b>Oxygen</b>	% v/v	7	12	5	7	12
<b>Moisture</b>	%	18.6	13.3	12.9	17	16
<b>Stack gas temperature</b>	°C	127	144	146	151	151
<b>Stack gas velocity (actual)</b>	m/s	14.3	22.4	17	18	20.6
<b>Gas volumetric flow rate at reference conditions</b>	m <sup>3</sup> /hour	154,608	39,134	152,825	77,669	69,915

Table 7: Summary of particulate concentrations measured at all EfW plant

Pollutant (sites measured)	Range of average emission concentrations, all EfW plant (mg/m <sup>3</sup> )		
	Min	Max	Average
<b>Total PM (2)</b>	0.47	0.70	0.59
<b>PM<sub>10</sub> (5)</b>	0.021	0.085	0.042
<b>PM<sub>2.5</sub> (5)</b>	0.005	0.019	0.012

## 3.4 Particulate emission factors

### 3.4.1 Flue gas volume factors

Published flue gas volume factors for EfW plant, applicable to those sampled in this study, have been sourced in order to develop emission factors from the average measured particulate concentrations. The flue gas volume factors (Table 8) are summarised in cubic metres per gigajoule (GJ) of net energy consumed and cubic metres per tonne of waste burnt. Unless noted otherwise, an average net calorific value for waste of 10.4 MJ/kg (European IPPC Bureau 2006) has been applied.

**Table 8: Reference flue gas volume factors**

Source	Volume factor (energy input basis) (m <sup>3</sup> /GJ net, dry vol. at 11% O <sub>2</sub> and STP*)	Volume factor (mass basis) (m <sup>3</sup> /tonne, dry volume at 11% O <sub>2</sub> and STP)	Reported flue gas volume	Reported units
<b>JRC report on NO<sub>x</sub> and dioxin emissions</b> (Tzimas E and Peteves SD)	598	6,222	2.96	m <sup>3</sup> /kg, dry volume at 0% O <sub>2</sub> , STP
<b>WI BREF</b> (European IPPC Bureau, 2006)	500	5,200	5200	m <sup>3</sup> /tonne, dry volume, 11% O <sub>2</sub> , STP
<b>World Bank MSW incineration guide</b> (Rand T et al, World Bank, 2000)	525	5,460	0.25	m <sup>3</sup> /MJ, dry volume at 0% O <sub>2</sub> , STP
<b>USEPA Method 19</b> (USEPA)	728	7,567	2.57x10 <sup>-07</sup>	m <sup>3</sup> /J, dry volume at 0% O <sub>2</sub> , NTP and gross energy input
<b>Denmark CHP report</b> (Nielsen, M et al, 2010)	523	5,438	249	m <sup>3</sup> /GJ, dry volume, 0% O <sub>2</sub> , STP
<b>Denmark CHP report</b>	529	5,500	5500	m <sup>3</sup> /tonne, dry volume, 11% O <sub>2</sub> , STP
<b>UK waste model</b> (Ricardo-AEA)	426	3,960	3.96	m <sup>3</sup> /kg, dry volume, 11% O <sub>2</sub> , STP (9.3 GJ/tonne)
<b>KEMA/VGB Table 6.1</b> (Graham, D et al VGB Powertech, 2012)	592	7,161	0.282	m <sup>3</sup> /MJ (net), dry volume at 0% O <sub>2</sub> , STP (12.1 GJ/Tonne)
<b>KEMA/VGB Table 6.6</b>	580	-	0.276	m <sup>3</sup> /MJ (net), dry volume at 0% O <sub>2</sub> , STP
<b>Min</b>	426	3,960		
<b>Max</b>	728	7,567		
<b>Median</b>	529	5,480		
<b>Average</b>	556	5,814		

\*Standard temperature and pressure (0°C, 101.3 kPa).

### 3.4.2 Calculated particulate emission factors

The average measured PM<sub>10</sub> and PM<sub>2.5</sub> concentrations (

Table 7) have been applied to the range of flue gas volume factors (Table 8) to provide a range of emission factors for total particulates, PM<sub>10</sub> and PM<sub>2.5</sub> (Table 9).

**Table 9: Calculated emission factors for PM emissions from EfW plant for different flue gas volume factors**

Pollutant	Units	Minimum	Max	Median
<b>Total PM</b>	<b>g/GJ</b>	0.249	0.426	0.309
<b>PM<sub>10</sub></b>		0.018	0.030	0.022
<b>PM<sub>2.5</sub></b>		0.005	0.009	0.007
<b>Total PM</b>	<b>g/tonne</b>	2.32	4.43	3.21
<b>PM<sub>10</sub></b>		0.17	0.32	0.23
<b>PM<sub>2.5</sub></b>		0.05	0.09	0.07

## 4 Comparison with NAEI Emission Factors

The emission factors (EFs) produced by this study were compared with the emission factors used in recent years to estimate particulate emissions in the NAEI (Table 10). The NAEI calculates both PM<sub>10</sub> and PM<sub>2.5</sub> using the same factor, which is applied each year to the site-specific particulate emissions data. Emissions are calculated on the basis of kilotonnes of particulate per megatonne of waste consumed. This has been compared with the “Max” EF for grams per tonne of waste from this emissions monitoring study, shown in Table 9 (highlighted in yellow), that is – the average emission concentration from the study combined with the maximum gas volume factor. The maximum combined emission factor (from the maximum of the average emission concentrations from each plant and the maximum flue gas volume) is shown in parentheses in Table 10.

**Table 10: Comparison of NAEI particulate EFs and “Max” EFs from emissions monitoring study**

Year	NAEI EF - NFR 1 Public power from municipal waste incineration		EF from this study		Percentage change from NAEI EF	
	PM <sub>10</sub> kt/Mt fuel consumed	PM <sub>2.5</sub> kt/Mt fuel consumed	PM <sub>10</sub> kt/Mt fuel consumed	PM <sub>2.5</sub> kt/Mt fuel consumed	PM <sub>10</sub>	PM <sub>2.5</sub>
2004	0.012	0.012			-97%	-99%
2005	0.013	0.013			-97%	-99%
2006	0.009	0.009			-97%	-99%
2007	0.008	0.008			-96%	-99%
2008	0.008	0.008	0.00032	0.00009	-96%	-99%
2009	0.007	0.007	(0.00064)	(0.00014)	-96%	-99%
2010	0.008	0.008			-96%	-99%
2011	0.009	0.009			-97%	-99%
2012	0.008	0.008			-96%	-99%
2013	0.008	0.009			-96%	-99%

The EFs provided by the monitoring assessment represent a significant reduction from the EFs currently used in the NAEI. Between 2004 and 2013 these EFs would represent a decrease in emission from the EfW sector of between 96-97 % of PM<sub>10</sub> and 99% of PM<sub>2.5</sub>.

**Particulate emissions are reported under “NFR code 1: Energy” in the NAEI. Table 11 and**

Table 12 provide the total emissions of PM<sub>10</sub> and PM<sub>2.5</sub> from all sources and “NFR code 1” sources. Contributions from the incineration of municipal solid waste (MSW) are given as a percentage of the total PM emissions listed under NFR 1, using both the current and proposed EFs.

**Table 11 and**

Table 12 indicate that although the change in EF for particulate emissions from the incineration of MSW in EfW can be considered significant; the impact on total UK PM emissions is minor.

**Table 11: Comparison of PM<sub>10</sub> emissions using the current and new EFs with emissions from all sources and NFR code 1 sources**

Year	Total UK PM <sub>10</sub> emissions	NFR 1 PM <sub>10</sub> emissions	PM <sub>10</sub> emissions from MSW incineration with current EF	PM <sub>10</sub> emissions from MSW incineration with new EF	PM <sub>10</sub> emissions from MSW incineration as a % of total NFR 1 PM <sub>10</sub> emissions with current EF	PM <sub>10</sub> emissions from MSW incineration as a % of total NFR 1 PM <sub>10</sub> emissions with new EF
	kilotonnes					
<b>2004</b>	151	90	0.038	0.001	0.04%	0.001%
<b>2005</b>	147	89	0.040	0.001	0.05%	0.001%
<b>2006</b>	147	88	0.033	0.001	0.04%	0.001%
<b>2007</b>	143	85	0.030	0.001	0.04%	0.001%
<b>2008</b>	138	82	0.029	0.001	0.04%	0.001%
<b>2009</b>	127	77	0.033	0.001	0.04%	0.002%
<b>2010</b>	129	81	0.038	0.002	0.05%	0.002%
<b>2011</b>	123	75	0.046	0.002	0.06%	0.002%
<b>2012</b>	125	77	0.046	0.002	0.06%	0.002%
<b>2013</b>	123	76	0.047	0.002	0.06%	0.002%

Table 12: Comparison of PM<sub>2.5</sub> emissions using the current and new EFs with emissions from all sources and NFR code 1 sources

Year	Total UK PM <sub>2.5</sub> emissions	NFR 1 PM <sub>2.5</sub> emissions	PM <sub>2.5</sub> emissions from MSW incineration with current EF	PM <sub>2.5</sub> emissions from MSW incineration with new EF	PM <sub>2.5</sub> emissions from MSW incineration as a % of total NFR 1 PM <sub>2.5</sub> emissions with current EF	PM <sub>2.5</sub> emissions from MSW incineration as a % of total NFR 1 PM <sub>2.5</sub> emissions with new EF
			kilotonnes			
2004	98	76	0.038	0.0003	0.05%	0.0004%
2005	96	74	0.040	0.0003	0.05%	0.0004%
2006	95	74	0.033	0.0003	0.05%	0.0004%
2007	93	71	0.030	0.0003	0.04%	0.0005%
2008	90	70	0.029	0.0003	0.04%	0.0005%
2009	84	66	0.033	0.0004	0.05%	0.0006%
2010	87	70	0.038	0.0004	0.05%	0.0006%
2011	81	64	0.046	0.0004	0.07%	0.0007%
2012	82	65	0.046	0.0005	0.07%	0.0008%
2013	82	64	0.047	0.0005	0.07%	0.0008%

## 5 Published PM size fractionation data

### 5.1 Emission factors

Default emission factors and size fractionation data for municipal solid waste incineration for development of national emission inventories are published by the US Environmental Protection Agency (USEPA (AP42)) and European Environment Agency (EEA, 2013). Table 13 shows a summary of the size fractionation data from these sources and the results from this measurement programme.

**Table 13 : Comparison of size fractionation with USEPA and EEA data**

Pollutant	Range of average measured emission concentrations, all EfW plants				USEPA	EEA
	Min	Max	Average	Average	Note 1	Note 2
	mg/m <sup>3</sup>	mg/m <sup>3</sup>	mg/m <sup>3</sup>	%	%	%
<b>Total PM</b>	0.47	0.70	0.59	-	-	-
<b>PM<sub>10</sub></b>	0.021	0.085	0.042	7.1	79.0	74.9
<b>PM<sub>2.5</sub></b>	0.005	0.019	0.012	2.0	44.9	49.8

Notes :

1. USEPA size fractionation from USEPA Generalised particle size distributions for mixed fuel combustion (without abatement control) combined with fabric filter abatement technology control efficiencies.
2. EEA size fractionation from EEA Tier 2 factors for uncontrolled (no abatement) MSW incineration combined with control efficiencies for particle and gas abatement.

### 5.2 Particle size fractionation measurements

An emission survey of industrial activities in Germany, including combustion technologies and industrial processes, found that in more than 70% of the individual emission measurement results from industrial plants and domestic stoves the PM<sub>10</sub> portion amounted to more than 90% and the PM<sub>2.5</sub> portion between 50% and 90% of the total particulate emission (Ehrlich, 2007). The measurement programme did not include measurements at EfW facilities but did cover a wide range of combustion plant from domestic wood stoves to large coal-fired power stations.

A study of facilities in Finland and Sweden (VTT, 2007) included measurements of total particulate and PM<sub>2.5</sub> at four EfW plant (one a pilot plant burning refuse derived fuel). Table 14 compares the results from this measurement programme with a summary of the results of the study from Finland and Sweden.

**Table 14 : Comparison with PM<sub>2.5</sub> emission study from Finland and Sweden**

Pollutant (sites measured)	Range of average measured emission concentrations, all EfW plants, mg/m <sup>3</sup>			Range of average measured emission concentrations, all EfW plants VTT study, mg/m <sup>3</sup>			
	Min	Max	Average	1	2	3	4
<b>Total particulates</b>	0.47	0.70	0.59	0.13	0.6	0.3	0.1
<b>PM<sub>10</sub></b>	0.021	0.085	0.042	-	-	-	-
<b>PM<sub>2.5</sub></b>	0.005	0.019	0.012 (2.0%)	<0.1 (<77%)	0.04, 0.08 (7, 13%)	0.04 (13%)	0.02-0.05 (20-50%)



## 6 Recommendation

The measurements indicate low  $PM_{10}$  and  $PM_{2.5}$  emissions from a range of UK EfW plant. Several individual measurements were at or near the limits of detection of the measurement method. This is not unexpected as the total PM emission concentrations were expected to be low – periodic and continuous emission measurements undertaken for regulatory compliance indicated total PM emissions generally below  $1 \text{ mg/m}^3$  for these facilities which all apply fabric filters for PM abatement.

However, notwithstanding issues in comparing measurement methods and the incomplete coverage of total PM measurements, the implied fraction of  $PM_{10}$  and  $PM_{2.5}$  in the total PM is lower than indicated in emission inventory guidance and indicates that most PM emitted from EfW is larger than  $PM_{10}$  which is counterintuitive. A study of  $PM_{2.5}$  emissions from incineration plant in Sweden and Finland found similar concentrations as the average determined at UK plant but the proportion of  $PM_{2.5}$  in the PM was higher. A German study of PM fractionation for combustion and industrial processes (but not EfW plant) found higher fractions of  $PM_{2.5}$  and  $PM_{10}$  than were determined at the UK EfW plant in this study.

This may reflect issues in the  $PM_{10}$  and  $PM_{2.5}$  measurement technique at such low concentrations and, it is noted that a number of deviations from the Standard were reported including use of 'gooseneck' nozzles where material could have been deposited. During this study, it was not possible to validate the use of goose-neck nozzle as required under the Standard.

The sector is not a key category for  $PM_{10}$  and  $PM_{2.5}$  emissions in the UK emission inventory and it is considered that a worst case emission factor could be adopted without impacting overall uncertainty of the NAEI. However, it is recommended that any future investigations should include modification of sampling facilities to allow deployment of sampling equipment with the straight nozzle configuration to allow full compliance with the BS EN ISO 23210 Standard. It is recommended that any future measurement programme adopting a gooseneck nozzle should include validation.

## 7 Acknowledgment

The funding was provided by Defra as part of project AQ0726 (NAEI technical support). The support of the Environment Agency for England and the EfW plant operators is gratefully acknowledged.

## 8 References

- BS EN 13284-1. (2002). *Stationary source emissions. Determination of low range mass concentration of dust. Manual gravimetric method.*
- BS EN ISO 23210. (2009). *Stationary source emissions. Determination of PM10/PM2,5 mass concentration in flue gas. Measurement at low concentrations by use of impactors.*
- EEA. (2013). *EMEP/EEA air pollutant emission inventory guidebook - 2013*. Technical Report 12/2013 available at <http://www.eea.europa.eu/publications/emep-eea-guidebook-2013/#> : European Environment Agency.
- Ehrlich, C. e. (2007). *PM10, PM2.5 and PM1.0—Emissions from industrial plants—Results from measurement programmes in Germany*. Atmospheric Environment 41 (2007) 6236–6254.
- European IPPC Bureau. (2006). *Reference Document on Best Available Techniques for Waste Incineration*. [http://eippcb.jrc.ec.europa.eu/reference/BREF/wi\\_bref\\_0806.pdf](http://eippcb.jrc.ec.europa.eu/reference/BREF/wi_bref_0806.pdf) : European Commission, JRC-IPTS, European IPPC Bureau.
- Graham, D et al VGB Powertech. (2012). *Validated methods for flue gas flow rate calculation with reference to EN 12952-15*. [http://www.vgb.org/vgbmultimedia/rp338\\_flue\\_gas.pdf](http://www.vgb.org/vgbmultimedia/rp338_flue_gas.pdf) : KEMA Nederland BV.
- Nielsen, M et al . (2010). *Emissions from decentralised CHP plants 2007 - Energinet.dk Environmental project no. 07/1882 : Project report 5 - emission factors and emission inventory for decentralised CHP production*. <http://www2.dmu.dk/Pub/FR786.pdf> : National Environmental Research Institute, Aarhus University.
- Rand T et al, World Bank. (2000). *Municipal solid waste incineration : requirements for a successful project*. [http://www-wds.worldbank.org/external/default/WDSContentServer/WDSP/IB/2000/08/14/000094946\\_00072505420045/Rendered/PDF/multi\\_page.pdf](http://www-wds.worldbank.org/external/default/WDSContentServer/WDSP/IB/2000/08/14/000094946_00072505420045/Rendered/PDF/multi_page.pdf): World Bank.
- Ricardo-AEA. (n.d.). *Model used in assessing Waste recovery facilities*.
- Tzimas E and Peteves SD. (n.d.). *NOx and Dioxin emissions from waste incineration plants*. European Commission, Joint Research Centre, Institute for Energy, Energy Technology Observatory.
- USEPA (AP42). (n.d.). *Compilation of Air Pollutant Emission Factors, 5th Edition*. Available at <http://www.epa.gov/ttnchie1/ap42/> : US Environmental Protection Agency.
- USEPA. (n.d.). *Method 19 - Determination of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur dioxide and nitrogen oxide emission rates*. <http://www.epa.gov/ttnemc01/promgate/m-19.pdf> : US Environmental Protection Agency.
- VTT. (2007). *Fine particulate emissions of waste incineration*. Prepared for IEA Bioenergy Agreement Task 36: VTT, Finland.

## Appendices

Appendix 1: Stack emissions monitoring report: Riverside Resource Recovery Ltd

Appendix 2: Stack emissions monitoring report: Newlincs Development Ltd

Appendix 3: Stack emissions monitoring report: Lakeside Energy From Waste td

Appendix 4: Stack emissions monitoring report: Veolia ES South Downs Ltd

Appendix 5: Stack emissions monitoring report: MES Environmental Ltd

## Appendix 1 – Stack emissions monitoring report: Riverside Resource Recovery Ltd

## STACK EMISSIONS MONITORING REPORT



Acacia Building  
Vantage Point Business Village  
Mitcheldean  
GL17 0DD  
Tel: 01594 546 343

Your contact at ESG
Laurence Sharrock Business Manager - South Tel: 01594 546 343 Email: laurence.sharrock@esg.co.uk

Operator & Address:
Riverside Resource Recovery Ltd Norman Road Belvedere Bexley Kent DA17 6JY - -

Permit
N/A - Investigative Monitoring

Release Point:
Stream 3

Sampling Date(s):
27th February to 3rd March 2014

ESG Job Number:	LCH00704
Report Date:	16th Feb 2015
Version:	1
Report By:	Paul Jones
MCERTS Number:	MM 02 044
MCERTS Level:	MCERTS Level 2 - Team Leader
Technical Endorsements:	1, 2, 3 & 4
Report Approved By:	Andy Tiffen
MCERTS Number:	MM 05 640
Business Title:	MCERTS Level 2 - Projects Manager
Technical Endorsements:	1, 2 & 4
Signature:	



## CONTENTS

### EXECUTIVE SUMMARY

#### Stack Emissions Monitoring Objectives

- Plant
- Operator
- Stack Emissions Monitoring Test House

#### Emissions Summary

#### Monitoring Times

#### Process Details

#### Monitoring Methods

#### Analytical Methods

- Sampling Methods with Subsequent Analysis
- On-Site Testing

#### Sampling Location

- Sampling Plane Validation Criteria
- Duct Characteristics
- Sampling Lines & Sample Points
- Sampling Platform
- Sampling Location / Platform Improvement Recommendations

#### Sampling and Analytical Method Deviations

#### Determination of representative sampling location

### APPENDICES

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

APPENDIX 3 - Measurement Uncertainty Budget Calculations

## EXECUTIVE SUMMARY

### MONITORING OBJECTIVES

Riverside Resource Recovery Ltd operates a incineration of waste process at Belvedere

Environmental Scientifics Group Limited were commissioned by Ricardo AEA to carry out stack emissions monitoring to determine the release of PM<sub>10</sub> & PM<sub>2.5</sub> from the following Plant under standard operating conditions.

The measurements were commissioned by Ricardo-AEA on behalf of the Department of Environment, Food and Rural Affairs (Defra) to provide information for the UK National Atmospheric Emissions Inventory (NAEI).

#### **Plant**

Stream 3

#### **Operator**

Riverside Resource Recovery Ltd  
Norman Road  
Belvedere  
Bexley  
Kent  
DA17 6JY  
-

#### **Stack Emissions Monitoring Test House**

Environmental Scientifics Group Limited - Mitcheldean Laboratory  
Acacia Building  
Vantage Point Business Village  
Mitcheldean  
GL17 0DD  
UKAS and MCERTS Accreditation Number: 1015

Opinions and interpretations expressed herein are outside the scope of UKAS accreditation.

MCERTS accredited results will only be claimed where both the sampling and analytical stages are UKAS accredited.

This test report shall not be reproduced, except in full, without written approval of Environmental Scientifics Group Limited.

## EXECUTIVE SUMMARY

EMISSIONS SUMMARY					
Parameter	Units	Result	Calculated Uncertainty +/-	Limit	MCERTS accredited result
PM <sub>10</sub> (Average result of 6 runs)	mg/m <sup>3</sup>	0.085	0.08	-	✓
PM <sub>10</sub> Emission Rate (Average result of 6 runs)	g/hr	13.71	12.9	-	
PM <sub>2.5</sub> (Average result of 6 runs)	mg/m <sup>3</sup>	0.011	0.02	-	✓
PM <sub>2.5</sub> Emission Rate (Average result of 6 runs)	g/hr	1.81	3.17	-	
<b>PM<sub>10</sub> - Runs</b>					
PM <sub>10</sub> - Run 1	mg/m <sup>3</sup>	0.281	0.26	-	✓
PM <sub>10</sub> Emission Rate - Run 1	g/hr	45.14	42.4	-	
PM <sub>10</sub> - Run 2	mg/m <sup>3</sup>	0.016	0.01	-	✓
PM <sub>10</sub> Emission Rate - Run 2	g/hr	2.53	2.4	-	
PM <sub>10</sub> - Run 3	mg/m <sup>3</sup>	0.033	0.03	-	✓
PM <sub>10</sub> Emission Rate - Run 3	g/hr	5.27	5.0	-	
PM <sub>10</sub> - Run 4	mg/m <sup>3</sup>	<b>0.015</b>	0.01	-	✓
PM <sub>10</sub> Emission Rate - Run 4	g/hr	2.53	2.4	-	
PM <sub>10</sub> - Run 5	mg/m <sup>3</sup>	0.084	0.08	-	✓
PM <sub>10</sub> Emission Rate - Run 5	g/hr	13.73	12.9	-	
PM <sub>10</sub> - Run 6	mg/m <sup>3</sup>	0.081	0.08	-	✓
PM <sub>10</sub> Emission Rate - Run 6	g/hr	13.09	12.3	-	
<b>PM<sub>2.5</sub> - Runs</b>					
PM <sub>2.5</sub> - Run 1	mg/m <sup>3</sup>	<b>0.008</b>	0.01	-	✓
PM <sub>2.5</sub> Emission Rate - Run 1	g/hr	45.14	79.0	-	
PM <sub>2.5</sub> - Run 2	mg/m <sup>3</sup>	<b>0.008</b>	0.01	-	✓
PM <sub>2.5</sub> Emission Rate - Run 2	g/hr	1.26	2.2	-	
PM <sub>2.5</sub> - Run 3	mg/m <sup>3</sup>	<b>0.007</b>	0.01	-	✓
PM <sub>2.5</sub> Emission Rate - Run 3	g/hr	1.10	1.92	-	
PM <sub>2.5</sub> - Run 4	mg/m <sup>3</sup>	<b>0.008</b>	0.01	-	✓
PM <sub>2.5</sub> Emission Rate - Run 4	g/hr	1.26	2.21	-	
PM <sub>2.5</sub> - Run 5	mg/m <sup>3</sup>	<b>0.008</b>	0.01	-	✓
PM <sub>2.5</sub> Emission Rate - Run 5	g/hr	1.27	2.23	-	
PM <sub>2.5</sub> - Run 6	mg/m <sup>3</sup>	0.029	0.05	-	✓
PM <sub>2.5</sub> Emission Rate - Run 6	g/hr	4.74	8.29	-	
Oxygen	% v/v	7	1.40	-	✓
Moisture	%	18.6	1.4	-	✓
Stack Gas Temperature	°C	127	-	-	✓
Stack Gas Velocity	m/s	14.3	-	-	
Gas Volumetric Flow Rate (Actual)	m <sup>3</sup> /hr	209054	-	-	
Gas Volumetric Flow Rate (STP, Wet)	m <sup>3</sup> /hr	140320	-	-	
Gas Volumetric Flow Rate (STP, Dry)	m <sup>3</sup> /hr	113683	-	-	
Gas Volumetric Flow Rate at Reference Conditions	m <sup>3</sup> /hr	154608	-	-	

ND = None Detected,

Results at or below the limit of detection are highlighted by bold italic text.

The above volumetric flow rate is calculated using data from test specific flow data. Mass emissions for non isokinetic tests and isokinetic tests are calculated using these values

Reference conditions are 273K, 101.3kPa, dry gas 11% Oxygen.



## EXECUTIVE SUMMARY

MONITORING TIMES			
Parameter	Sampling Date(s)	Sampling Times	Sampling Duration
PM <sub>10</sub> Run 1	27 February 2014	14:59 - 17:59	180 minutes
PM <sub>10</sub> Run 2	28 February 2014	09:40 - 12:40	180 minutes
PM <sub>10</sub> Run 3	28 February 2014	13:03 - 16:03	180 minutes
PM <sub>10</sub> Run 4	03 March 2014	10:23 - 13:23	180 minutes
PM <sub>10</sub> Run 5	03 March 2014	14:19 - 17:19	180 minutes
PM <sub>10</sub> Run 6	04 March 2014	09:48 - 12:48	180 minutes
PM <sub>2.5</sub> Run 1	27 February 2014	14:59 - 17:59	180 minutes
PM <sub>2.5</sub> Run 2	28 February 2014	09:40 - 12:40	180 minutes
PM <sub>2.5</sub> Run 3	28 February 2014	13:03 - 16:03	180 minutes
PM <sub>2.5</sub> Run 4	03 March 2014	10:23 - 13:23	180 minutes
PM <sub>2.5</sub> Run 5	03 March 2014	14:19 - 17:19	180 minutes
PM <sub>2.5</sub> Run 6	04 March 2014	09:48 - 12:48	180 minutes
Stack Gas Flow Rate & Temperature Run 1	27 February 2014	12:30	-
Stack Gas Flow Rate & Temperature Run 2	27 February 2014	18:04	-
Stack Gas Flow Rate & Temperature Run 3	28 February 2014	12:45	-
Stack Gas Flow Rate & Temperature Run 4	28 February 2014	16:15	-
Stack Gas Flow Rate & Temperature Run 5	03 March 2014	10:15	-
Stack Gas Flow Rate & Temperature Run 6	03 March 2014	14:00	-
Stack Gas Flow Rate & Temperature Run 7	03 March 2014	17:30	-
Stack Gas Flow Rate & Temperature Run 8	04 March 2014	09:30	-
Stack Gas Flow Rate & Temperature Run 9	04 March 2014	13:00	-

## EXECUTIVE SUMMARY

PROCESS DETAILS	
Parameter	Process Details
Description of process	Incineration of waste
Continuous or batch	Continuous
Product Details	Energy from waste
Part of batch to be monitored (if applicable)	N/A
Normal load, throughput or continuous rating	approx. 30 tonnes/hr
Fuel used during monitoring	waste/diesel
Abatement	Cyclone, lime and carbon injection, scrubber and bag filter
Plume Appearance	Not visible from monitoring location

## EXECUTIVE SUMMARY

### Monitoring Methods

The selection of standard reference / alternative methods employed by Environmental Scientifics Group Limited is determined, wherever possible by the hierarchy of method selection outlined in Environment Agency Technical Guidance Note (Monitoring) M2. i.e. CEN, ISO, BS, US EPA etc.

MONITORING METHODS						
Species	Method Standard Reference Method / Alternative Method	ESG Technical Procedure	UKAS Lab Number	MCERTS Accredited Method	Limit of Detection (LOD)	Calculated MU +/- %
PM <sub>10</sub>	SRM - BS EN 23210	AE 136	1015	Yes	0.015 mg/m <sup>3</sup>	94 %
PM <sub>2.5</sub>	SRM - BS EN 23210	AE 136	1015	Yes	0.007 mg/m <sup>3</sup>	175 %
O <sub>2</sub>	SRM - BS EN 14789	AE 102	1015	Yes	0.01%	19.3%
H <sub>2</sub> O	AM - M22/FTIR	AE 063	1015	Yes	0.01 %	7.5%
Flow Rate / Temp.	SRM - BS EN 13284-1	AE 122	1015	Yes	5 Pa	-

The measurement uncertainties for the PM<sub>10</sub> and PM<sub>2.5</sub> measurements reflect that measured concentrations were near or below the Limit of Detection.

## EXECUTIVE SUMMARY

### Analytical Methods

The following tables list the analytical methods employed together with the custody and archiving details:

SAMPLING METHODS WITH SUBSEQUENT ANALYSIS							
Species	Analytical Technique	Analytical Procedure	UKAS Lab Number	UKAS Accredited Lab Analysis	Analysis Lab (ESG or Subcontract)	Sample Archive Location	Archive Period
PM <sub>10</sub>	Gravimetric	AE 106	1015	Yes	ESG Mitcheldean	ESG Mitcheldean	1 year
PM <sub>2.5</sub>	Gravimetric	AE 106	1015	Yes	ESG Mitcheldean	ESG Mitcheldean	1 year

ON-SITE TESTING							
Species	Analytical Technique	Analytical Procedure	UKAS Lab Number	MCERTS Accredited Analysis	Laboratory	Data Archive Location	Archive Period
O <sub>2</sub>	Paramagnetism	AE 102	1015	Yes	ESG Mitcheldean	ESG Mitcheldean	5 years
H <sub>2</sub> O	Fourier Transform - Infra Red	AE 063	1015	Yes	ESG Mitcheldean	ESG Mitcheldean	5 years

## EXECUTIVE SUMMARY

SAMPLING LOCATION					
Sampling Plane Validation Criteria	Value	Units	Requirement	Compliant	Method
Lowest Differential Pressure	118	Pa	>= 5 Pa	Yes	BS EN 13284-1
Lowest Gas Velocity	13.46	m/s	-	-	-
Highest Gas Velocity	14.99	m/s	-	-	-
Ratio of Gas Velocities	1.11	-	< 3 : 1	Yes	BS EN 13284-1
Mean Velocity	14.25	m/s	-	-	-
Maximum angle of flow with regard to duct axis	<15	°	< 15°	Yes	BS EN 13284-1
No local negative flow	Yes	-	-	Yes	BS EN 13284-1

DUCT CHARACTERISTICS		
	Value	Units
Shape	Circular	-
Depth	2.27	m
Width	-	m
Area	4.05	m <sup>2</sup>
Port Depth	160	mm

SAMPLING LINES & POINTS			
	Isokinetic (CEN Methods)	Isokinetic (ISO Methods)	Non-Iso & Gases
Sample port size	4.5" flange	-	4.5" flange
Number of lines used	2	-	1
Number of points / line	10	-	1
Duct orientation	Vertical	-	Vertical
Filtration	In Stack	-	In Stack

SAMPLING PLATFORM	
General Platform Information	
Permanent / Temporary Platform / Ground level / Floor Level / Roof Inside / Outside	Permanent (windshield) Inside

M1 Platform requirements	
Is there a sufficient working area so work can be performed in a compliant manner	Yes
Platform has 2 levels of handrails (approximately 0.5 m & 1.0 m high)	N/A
Platform has vertical base boards (approximately 0.25 m high)	N/A
Platform has removable chains / self closing gates at the top of ladders	N/A
Handrail / obstructions do not hamper insertion of sampling equipment	Yes
Depth of Platform = >Stack depth / diameter + wall and port thickness + 1.5m	Yes

### Sampling Platform Improvement Recommendations (if applicable)

The sampling location meets all the requirements as specified in EA Guidance Note M1.

## EXECUTIVE SUMMARY

### Sampling & Analytical Method Deviations

#### **Goose-neck nozzle Validation**

Due to the long port sleeve, it was physically impossible to insert the cascade impactor using the straight entry nozzle setup recommended in BS EN 23210. Therefore the use of a goose-neck setup was used as this was the only feasible method for monitoring. The standard requires that the use of a goose-neck nozzle is validated, however on this occasion it has not been possible to demonstrate that losses in the nozzle meet the criteria in the standard because the measured concentrations were low and the weight of particulate recovered from the nozzle rinses and the filter media were at or near the weighing LoD. In the context of the low emission concentrations determined during the measurements (all less than 0.1 mg/Nm<sup>3</sup>), losses in the sampling nozzle are unlikely to increase the concentrations significantly.

#### **Sample flow variation**

The sample flowrate could not be maintained within 5% of the nominal flow throughout the testing periods (which were over extended periods due to the anticipated low PM emission concentrations). Whilst this will have affected the actual cutpoints achieved by the impactor, the results are all at or very near the LOD for the tests and hence this is anticipated to have limited impact on the outcome of the measurements.

### Determination of representative sampling location

An assessment of temperature homogeneity was performed in accordance with EN 23210 Annex-G on the first day of monitoring.

APPENDICES

**CONTENTS**

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

APPENDIX 3 - Measurement Uncertainty Budget Calculations

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

<b>MONITORING SCHEDULE</b>					
<b>Species</b>	<b>Method</b> Standard Reference Method / Alternative Method	<b>ESG</b> <b>Technical</b> <b>Procedure</b>	<b>UKAS Lab</b> <b>Number</b>	<b>MCERTS</b> <b>Accredited</b> <b>Method</b>	<b>Number of</b> <b>Samples</b>
PM <sub>10</sub>	SRM - BS EN 23210	AE 136	1015	Yes	6
PM <sub>2.5</sub>	SRM - BS EN 23210	AE 136	1015	Yes	6
O <sub>2</sub>	SRM - BS EN 14789	AE 102	1015	Yes	6
H <sub>2</sub> O	AM - M22/FTIR	AE 063	1015	Yes	6
Flow Rate / Temp.	SRM - BS EN 13284-1	AE 122	1015	Yes	9



APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

CALIBRATEABLE EQUIPMENT CHECKLIST					
Extractive Sampling		Instrumental Analyser/s		Miscellaneous	
Equipment	Equipment I.D.	Equipment	Equipment I.D.	Equipment	Equipment I.D.
Control Box DGM	P1799	Horiba PG-250 Analyser	-	Laboratory Balance	-
Box Thermocouples	P1799	FT-IR	P2060	Tape Measure	P1935
Meter In Thermocouple	P1799	FT-IR Oven Box	-	Stopwatch	-
Meter Out Thermocouple	P1799	Bernath 3006 FID	-	Protractor	-
Control Box Timer	P1799	Signal 3030 FID	-	Barometer	P2090
Oven Box	-	Servomex	-	Digital Micromanometer	-
Probe	LSO--11-29	JCT Heated Head Filter	-	Digital Temperature Meter	-
Probe Thermocouple	P1945	Thermo FID	-	Stack Thermocouple	P1947
Probe	-	Stackmaster	-	Mass Flow Controller	-
Probe Thermocouple	-	FTIR Heater Box for Heated Line	-	MFC Display module	-
S-Pitot	P2056	Anemometer	-	1m Heated Line (1)	-
L-Pitot	-	Ecophysics NOx Analyser	-	1m Heated Line (2)	-
Site Balance	-	Chiller (JCT/MAK 10)	-	1m Heated Line (3)	-
Last Impinger Arm	P1967	Heated Line Controller (1)	8414	5m Heated Line (1)	-
Dioxins Cond. Thermocouple	-	Heated Line Controller (2)	-	10m Heated Line (1)	P1930
Callipers	P1805	Impactor 1	NR18706	10m Heated Line (2)	-
Small DGM	-	0	-	15m Heated Line (1)	-
Heater Controller	-		-	20m Heated Line (1)	-
Inclinometer (Swirl Device)	P2094		-	20m Heated Line (2)	-

NOTE: If the equipment I.D is represented by a dash (-), then this piece of equipment has not been used for this test.

CALIBRATION / CHECK GASES					
Gas (traceable to ISO 17025)	Cylinder I.D Number	Supplier	ppm	%	Analytical Tolerance +/- %
Oxygen	DA B2	BOC	-	10.06	2
Methane	DA B2	BOC	87.1	-	2
Carbon Dioxide	DA B2	BOC	-	12	2

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

**STACK EMISSIONS MONITORING TEAM**

Team Leader	Paul Jones MCERTS Level 2, Technical Endorsements 1, 2, 3 & 4 MM 02 044 MCERTS Expiry Date - Mar 2018 H&S Expiry Date - Sep 2015
Team Leader	Dominic Houghton MCERTS Level 2, Technical Endorsements 1, 2, 3 & 4 MM 04 529 MCERTS Expiry Date - Dec 2016 H&S Expiry Date - Sep 2014
Technician	Rad Poremba MCERTS Level 1 MM 10 1069 MCERTS Expiry Date - Jul 2015 H&S Expiry Date - Jul 2015

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

PM <sub>10</sub> SUMMARY					
Test	Sampling Times	Concentration mg/m <sup>3</sup>	LOD mg/m <sup>3</sup>	Limit mg/m <sup>3</sup>	Emission Rate g/hr
Run 1	14:59 - 17:59 27 February 2014	0.281	0.015	-	45.14
Run 2	09:40 - 12:40 28 February 2014	0.016	0.015	-	2.53
Run 3	13:03 - 16:03 28 February 2014	0.033	0.014	-	5.27
Run 4	10:23 - 13:23 03 March 2014	0.015	0.022	-	2.53
Run 5	14:19 - 17:19 03 March 2014	0.084	0.018	-	13.73
Run 6	09:48 - 12:48 04 March 2014	0.081	0.015	-	13.09
Blank 1	-	0.015	-	-	-
Blank 2	-	0.015	-	-	-
Blank 3	-	0.015	-	-	-

Reference conditions are 273K, 101.3kPa, dry gas 11% Oxygen.  
where values are below the LOD the LOD will be reported.

PM <sub>2.5</sub> SUMMARY					
Test	Sampling Times	Concentration mg/m <sup>3</sup>	LOD mg/m <sup>3</sup>	Limit mg/m <sup>3</sup>	Emission Rate g/hr
Run 1	14:59 - 17:59 27 February 2014	0.008	0.008	-	1.24
Run 2	09:40 - 12:40 28 February 2014	0.008	0.008	-	1.26
Run 3	13:03 - 16:03 28 February 2014	0.007	0.007	-	1.10
Run 4	10:23 - 13:23 03 March 2014	0.008	0.011	-	1.26
Run 5	14:19 - 17:19 03 March 2014	0.008	0.009	-	1.27
Run 6	09:48 - 12:48 04 March 2014	0.029	0.008	-	4.74
Blank 1	-	0.007	-	-	-
Blank 2	-	0.007	-	-	-
Blank 3	-	0.007	-	-	-

Reference conditions are 273K, 101.3kPa, dry gas 11% Oxygen.  
where values are below the LOD the LOD will be reported, where this occurs the quoted uncertainties will be relatively high.

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

PM <sub>2.5</sub> (BF) SAMPLES WEIGHTS				
Test	PM <sub>2.5</sub> Filter Number	Filter Start Weight g	Filter End Weight g	PM <sub>2.5</sub> Mass Gained on Filter g
Run 1	QC964	32.91794	32.91788	-0.00006
Run 2	QC995	32.90496	32.90428	-0.00068
Run 3	QC992	32.96615	32.96598	-0.00017
Run 4	QC985	32.81522	32.81481	-0.00041
Run 5	QC977	31.89809	31.89751	-0.00058
Run 6	QC961	32.45560	32.45581	0.00021
Blank 1	QC966	31.64069	31.64038	-0.00031
Blank 2	QC984	32.06282	32.06271	-0.00011
Blank 3	QC976	32.43702	32.43687	-0.00015

PM <sub>10</sub> (CP2) SAMPLES WEIGHTS				
Test	PM <sub>10</sub> Filter Number	Filter Start Weight g	Filter End Weight g	PM <sub>10</sub> Mass Gained on Filter g
Run 1	QC958	15.73756	15.73933	0.00177
Run 2	QC989	15.89540	15.89538	-0.00002
Run 3	QC992	15.18101	15.18120	0.00019
Run 4	QC974	15.94752	15.94710	-0.00042
Run 5	QC991	15.15272	15.15321	0.00049
Run 6	QC957	15.36466	15.36503	0.00037
Blank 1	QC968	15.26944	15.26936	-0.00008
Blank 2	QC990	15.56496	15.56491	-0.00005
Blank 3	QC975	14.63281	14.63223	-0.00058

PM <sub>2.5</sub> & PM <sub>10</sub> (BF & CP2) SAMPLES WEIGHTS COMBINED							
Test	PM <sub>2.5</sub> Filter Number	PM <sub>10</sub> Filter Number	PM <sub>2.5</sub> Mass Gained on Filter g	PM <sub>10</sub> Mass Gained on Filter g	Actual PM <sub>2.5</sub> & PM <sub>10</sub> Combined Total Mass Gained g	PM <sub>2.5</sub> & PM <sub>10</sub> Combined Weighing LOD g	*Reported PM <sub>2.5</sub> & PM <sub>10</sub> Combined Total Mass Gained g
Run 1	QC964	QC958	-0.00006	0.00177	0.00171	0.00010	0.00182
Run 2	QC995	QC989	-0.00068	-0.00002	-0.00070	0.00010	0.00010
Run 3	QC992	QC992	-0.00017	0.00019	0.00002	0.00010	0.00024
Run 4	QC985	QC974	-0.00041	-0.00042	-0.00083	0.00010	0.00010
Run 5	QC977	QC991	-0.00058	0.00049	-0.00009	0.00010	0.00054
Run 6	QC961	QC957	0.00021	0.00037	0.00058	0.00010	0.00058
Blank 1	QC966	QC968	-0.00031	-0.00008	-0.00039	0.00010	0.00010
Blank 2	QC984	QC990	-0.00011	-0.00005	-0.00016	0.00010	0.00010
Blank 3	QC976	QC975	-0.00015	-0.00058	-0.00073	0.00010	0.00010

\* Where weighing values are below the LOD possibly due to loss of filter material, the LOD will be reported.

NOTE - Where the filter weight gain is less than the weighing uncertainty, the weighing uncertainty is used for further calculations. The weighing uncertainty is 0.00005g.

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS RUN 1			PM <sub>10</sub> & PM <sub>2.5</sub>	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	744.8	CO <sub>2</sub>	9.54
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	-1.9	O <sub>2</sub>	7.40
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	744.6	Total	16.94
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			N <sub>2</sub> (100 -Total)	83.06
Moisture trap weight increase, V <sub>lc</sub>	g	H <sub>2</sub> O by FTIR	M <sub>d</sub> = 0.44(%CO <sub>2</sub> )+0.32(%O <sub>2</sub> )+0.28(%N <sub>2</sub> )	29.82
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	<b>Molecular weight of wet gas, M<sub>s</sub></b>	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			M <sub>s</sub> = M <sub>d</sub> (1 - B <sub>wo</sub> ) + 18(B <sub>wo</sub> )	27.58
Volume of gas sample through gas meter, V <sub>m</sub>		5.12	<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Gas meter correction factor, Y <sub>d</sub>		1.06	Area of stack, A <sub>s</sub>	m <sup>2</sup> 4.05
Mean dry gas meter temperature, T <sub>m</sub>		32.71	Q <sub>a</sub> = (60)(A <sub>s</sub> )(V <sub>s</sub> )	m <sup>3</sup> /min 3627.2
Mean pressure drop across orifice, ΔH	mmH <sub>2</sub> O	81.28	<b>Percent isokinetic, %I</b>	
$V_{mstd} = \frac{(0.3592)(V_m)(P_b+(\Delta H/13.6))(Y_d)}{T_m + 273}$		4.770	Required Flow Rate @ DGM	l/min 30.00
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Actual Flow Rate @ DGM	l/min 31.6
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	5.8874	Isokinetic Rate	105.21
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			Acceptable 90% - 130%	Yes
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	<b>Particulate Concentration, C<sub>PM10</sub></b>	
% oxygen measured in gas stream, act%O <sub>2</sub>		7.40	Mass of particulate collected on PM <sub>10</sub> filter, M <sub>f</sub>	0.00177
% oxygen reference condition		11	Mass of particulate collected on PM <sub>2.5</sub> filter, M <sub>f</sub>	0.00005
O <sub>2</sub> Reference	O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>	1.36	$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.30914
Factor	$\frac{21.0 - ref\%O_2}{21.0 - act\%O_2}$		$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.38157
$V_{mstd@X\%oxygen} = (V_{mstd}) (O_2 Ref)$	m <sup>3</sup>	6.487	$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.28057
<b>Moisture content, B<sub>wo</sub></b>			<b>Particulate Emission Rates, E</b>	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	18.98	E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	45.14
<b>Moisture by FTIR</b>	%	18.98	<b>Particulate Concentration, C<sub>PM2.5</sub></b>	
<b>Velocity of stack gas, V<sub>s</sub></b>			Mass of particulate collected on filter, M <sub>f</sub>	0.00005
Pitot tube velocity constant, K <sub>p</sub>		34.97	$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.0085
Velocity pressure coefficient, C <sub>p</sub>		0.83	$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.0105
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	13.64	$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0077
Mean square root of velocity heads, √ΔP		3.7	<b>Particulate Emission Rates, E</b>	
Mean stack gas temperature, T <sub>s</sub>	°C	126	E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	1.24
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{(T_s + 273)})}{(M_s)(P_s)}$	m/s	14.94		

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS RUN 2			PM <sub>10</sub> & PM <sub>2.5</sub>	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	742.5	CO <sub>2</sub>	9.49
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	-1.9	O <sub>2</sub>	7.61
$P_s = P_b + (P_{static})$	mm Hg	742.4	Total	17.10
$\frac{13.6}{13.6}$			N <sub>2</sub> (100 -Total)	82.90
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2)$	
Moisture trap weight increase, V <sub>lc</sub>	g	H <sub>2</sub> O by FTIR	<b>Molecular weight of wet gas, M<sub>s</sub></b>	
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	$M_s = M_d(1 - B_{wo}) + 18(B_{wo})$	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Volume of gas sample through gas meter, V <sub>m</sub>		5.13	Area of stack, A <sub>s</sub>	m <sup>2</sup> 4.05
Gas meter correction factor, Y <sub>d</sub>		1.06	$Q_a = (60)(A_s)(V_s)$	m <sup>3</sup> /min 3671.1
Mean dry gas meter temperature, T <sub>m</sub>		31.64	<b>Percent isokinetic, %I</b>	
Mean pressure drop across orifice, ΔH	mmH <sub>2</sub> O	88.92	Required Flow Rate @ DGM	l/min 31.00
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		4.787	Actual Flow Rate @ DGM	l/min 31.8
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Isokinetic Rate	
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	5.8338	Acceptable 90% - 130%	
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			<b>Particulate Concentration, C<sub>PM10</sub></b>	
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	Mass of particulate collected on PM <sub>10</sub> filter, M <sub>f</sub>	0.00005
% oxygen measured in gas stream, act%O <sub>2</sub>		7.61	Mass of particulate collected on PM <sub>2.5</sub> filter, M <sub>f</sub>	0.00005
% oxygen reference condition		11	$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.0171
O <sub>2</sub> Reference O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>		1.34	$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.0209
Factor 21.0 - ref%O <sub>2</sub>			$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0156
$V_{mstd@X\%oxygen} = (V_{mstd})(O_2\ Ref)$	m <sup>3</sup>	6.412	<b>Particulate Emission Rates, E</b>	
<b>Moisture content, B<sub>wo</sub></b>			$E = [(C_{wet})(Q_{stw})(60)] / 1000$	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	0.1794	2.53	
		17.94	<b>Particulate Concentration, C<sub>PM2.5</sub></b>	
<b>Moisture by FTIR</b>			Mass of particulate collected on filter, M <sub>f</sub>	
	%	17.94	$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.0086
<b>Velocity of stack gas, V<sub>s</sub></b>			$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.0104
Pitot tube velocity constant, K <sub>p</sub>		34.97	$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0078
Velocity pressure coefficient, C <sub>p</sub>		0.83	<b>Particulate Emission Rates, E</b>	
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	13.99	$E = [(C_{wet})(Q_{stw})(60)] / 1000$	
Mean square root of velocity heads, √ΔP		3.74	1.26	
Mean stack gas temperature, T <sub>s</sub>	°C	126		
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	15.12		

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS RUN 3			PM <sub>10</sub> & PM <sub>2.5</sub>	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	742.5	CO <sub>2</sub>	9.54
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	-1.9	O <sub>2</sub>	7.49
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	742.4	Total	17.04
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			N <sub>2</sub> (100 -Total)	
Moisture trap weight increase, V <sub>lc</sub>	g	H <sub>2</sub> O by FTIR	M <sub>d</sub> = 0.44(%CO <sub>2</sub> )+0.32(%O <sub>2</sub> )+0.28(%N <sub>2</sub> )	82.96
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	<b>Molecular weight of wet gas, M<sub>s</sub></b>	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			M <sub>s</sub> = M <sub>d</sub> (1 - B <sub>wo</sub> ) + 18(B <sub>wo</sub> )	
Volume of gas sample through gas meter, V <sub>m</sub>		5.84	27.67	
Gas meter correction factor, Y <sub>d</sub>		1.06	<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Mean dry gas meter temperature, T <sub>m</sub>		36.15	Area of stack, A <sub>s</sub>	m <sup>2</sup> 4.05
Mean pressure drop across orifice, ΔH	mmH <sub>2</sub> O	116.75	Q <sub>a</sub> = (60)(A <sub>s</sub> )(V <sub>s</sub> )	m <sup>3</sup> /min 3602.4
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		5.381	<b>Percent isokinetic, %I</b>	
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Required Flow Rate @ DGM	
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	6.5835	Actual Flow Rate @ DGM	l/min 31.10
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			Isokinetic Rate	
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	Acceptable 90% - 130%	104.33
% oxygen measured in gas stream, act%O <sub>2</sub>		7.49	Yes	
% oxygen reference condition		11	<b>Particulate Concentration, C<sub>PM10</sub></b>	
O <sub>2</sub> Reference Factor	O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub> 21.0 - ref%O <sub>2</sub>	1.35	Mass of particulate collected on PM <sub>10</sub> filter, M <sub>f</sub>	0.00019
$V_{mstd@X\%oxygen} = (V_{mstd}) (O_2 \text{ Ref})$		7.269	Mass of particulate collected on PM <sub>2.5</sub> filter, M <sub>f</sub>	0.00005
<b>Moisture content, B<sub>wo</sub></b>			$C_{wet} = \frac{M_n}{V_{mstw}}$ mg/m <sup>3</sup> 0.0365	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	0.1826	$C_{dry} = \frac{M_n}{V_{mstd}}$ mg/m <sup>3</sup> 0.0446	
<b>Moisture by FTIR</b>			$C_{dry@X\%O2} = \frac{M_n}{V_{mstd@X\%oxygen}}$ mg/m <sup>3</sup> 0.0330	
			0.1826	
<b>Velocity of stack gas, V<sub>s</sub></b>			<b>Particulate Emission Rates, E</b>	
Pitot tube velocity constant, K <sub>p</sub>		34.97	E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	
Velocity pressure coefficient, C <sub>p</sub>		0.83	5.27	
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	13.45	<b>Particulate Concentration, C<sub>PM2.5</sub></b>	
Mean square root of velocity heads, √ΔP		3.67	Mass of particulate collected on filter, M <sub>f</sub>	
Mean stack gas temperature, T <sub>s</sub>	°C	126	$C_{wet} = \frac{M_n}{V_{mstw}}$ mg/m <sup>3</sup>	0.00005
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	14.83	$C_{dry} = \frac{M_n}{V_{mstd}}$ mg/m <sup>3</sup>	0.0076
			$C_{dry@X\%O2} = \frac{M_n}{V_{mstd@X\%oxygen}}$ mg/m <sup>3</sup>	0.0093
			0.0069	
			<b>Particulate Emission Rates, E</b>	
			E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	
			1.10	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS RUN 4			PM <sub>10</sub> & PM <sub>2.5</sub>	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	727.5	CO <sub>2</sub>	9.69
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	-1.9	O <sub>2</sub>	6.91
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	727.4	Total	16.60
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2)$	
Moisture trap weight increase, V <sub>lc</sub>	g	H <sub>2</sub> O by FTIR	<b>Molecular weight of wet gas, M<sub>s</sub></b>	
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	$M_s = M_d(1 - B_{wo}) + 18(B_{wo})$	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Volume of gas sample through gas meter, V <sub>m</sub>		5.02	Area of stack, A <sub>s</sub>	m <sup>2</sup> 4.05
Gas meter correction factor, Y <sub>d</sub>		1.06	$Q_a = (60)(A_s)(V_s)$	m <sup>3</sup> /min 3669.7
Mean dry gas meter temperature, T <sub>m</sub>		30.88	<b>Percent isokinetic, %I</b>	
Mean pressure drop across orifice, ΔH	mmH <sub>2</sub> O	84.39	Required Flow Rate @ DGM	l/min 29.40
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		4.597	Actual Flow Rate @ DGM	l/min 27.9
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Isokinetic Rate	
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	5.6702	Acceptable 90% - 130%	
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			<b>Particulate Concentration, C<sub>PM10</sub></b>	
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	Mass of particulate collected on PM <sub>10</sub> filter, M <sub>f</sub>	0.00005
% oxygen measured in gas stream, act%O <sub>2</sub>		6.91	Mass of particulate collected on PM <sub>2.5</sub> filter, M <sub>f</sub>	0.00005
% oxygen reference condition		11	$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.0176
O <sub>2</sub> Reference O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>		1.41	$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.0218
Factor $\frac{21.0 - ref\%O_2}{21.0 - act\%O_2}$			$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0154
$V_{mstd@X\%oxygen} = (V_{mstd})(O_2 Ref)$	m <sup>3</sup>	6.475	<b>Particulate Emission Rates, E</b>	
<b>Moisture content, B<sub>wo</sub></b>			$E = [(C_{wet})(Q_{stw})(60)] / 1000$	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	18.93	2.53	
<b>Moisture by FTIR</b>			<b>Particulate Concentration, C<sub>PM2.5</sub></b>	
%			Mass of particulate collected on filter, M <sub>f</sub>	
<b>Velocity of stack gas, V<sub>s</sub></b>			$C_{wet} = \frac{M_n}{V_{mstw}}$	
Pitot tube velocity constant, K <sub>p</sub>		34.97	mg/m <sup>3</sup> 0.0088	
Velocity pressure coefficient, C <sub>p</sub>		0.83	$C_{dry} = \frac{M_n}{V_{mstd}}$	
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	13.55	mg/m <sup>3</sup> 0.0109	
Mean square root of velocity heads, √ΔP		3.68	$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	
Mean stack gas temperature, T <sub>s</sub>	°C	128	mg/m <sup>3</sup> 0.0077	
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	15.11	<b>Particulate Emission Rates, E</b>	
			$E = [(C_{wet})(Q_{stw})(60)] / 1000$	
			1.26	



APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS RUN 5			PM <sub>10</sub> & PM <sub>2.5</sub>	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	742.5	CO <sub>2</sub>	9.66
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	-1.9	O <sub>2</sub>	6.91
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	742.4	Total	16.57
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			M <sub>d</sub> = 0.44(%CO <sub>2</sub> )+0.32(%O <sub>2</sub> )+0.28(%N <sub>2</sub> )	
Moisture trap weight increase, V <sub>lc</sub>	g	H <sub>2</sub> O by FTIR	N <sub>2</sub> (100 -Total)	83.43
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	<b>Molecular weight of wet gas, M<sub>s</sub></b>	29.82
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			M <sub>s</sub> = M <sub>d</sub> (1 - B <sub>w0</sub> ) + 18(B <sub>w0</sub> )	
Volume of gas sample through gas meter, V <sub>m</sub>		4.87	<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Gas meter correction factor, Y <sub>d</sub>		1.06	Area of stack, A <sub>s</sub>	m <sup>2</sup> 4.05
Mean dry gas meter temperature, T <sub>m</sub>		30.86	Q <sub>a</sub> = (60)(A <sub>s</sub> )(V <sub>s</sub> )	m <sup>3</sup> /min 3610.7
Mean pressure drop across orifice, ΔH	mmH <sub>2</sub> C	79.00	<b>Percent isokinetic, %I</b>	
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		4.567	Required Flow Rate @ DGM	l/min 29.40
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Actual Flow Rate @ DGM	
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	5.6563	Isokinetic Rate	l/min 27.1
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			Acceptable 90% - 130%	
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	<b>Particulate Concentration, C<sub>PM10</sub></b>	
% oxygen measured in gas stream, act%O <sub>2</sub>		6.91	Mass of particulate collected on PM <sub>10</sub> filter, M <sub>f</sub>	0.00049
% oxygen reference condition		11	Mass of particulate collected on PM <sub>2.5</sub> filter, M <sub>f</sub>	0.00005
O <sub>2</sub> Reference O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>		1.41	C <sub>wet</sub> = $\frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.0955
Factor 21.0 - ref%O <sub>2</sub>			C <sub>dry</sub> = $\frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.1182
$V_{mstd@X\%oxygen} = (V_{mstd}) (O_2 Ref)$	m <sup>3</sup>	6.435	C <sub>dry@X%O2</sub> = $\frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0839
<b>Moisture content, B<sub>w0</sub></b>			<b>Particulate Emission Rates, E</b>	
$B_{w0} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	0.1925	E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	13.73
		19.25	<b>Particulate Concentration, C<sub>PM2.5</sub></b>	
<b>Moisture by FTIR</b>	%	19.25	Mass of particulate collected on filter, M <sub>f</sub>	
<b>Velocity of stack gas, V<sub>s</sub></b>			C <sub>wet</sub> = $\frac{M_n}{V_{mstw}}$	
Pitot tube velocity constant, K <sub>p</sub>		34.97	C <sub>dry</sub> = $\frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.0088
Velocity pressure coefficient, C <sub>p</sub>		0.83	C <sub>dry@X%O2</sub> = $\frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0109
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	13.36	mg/m <sup>3</sup> 0.0078	
Mean square root of velocity heads, √ΔP		3.66	<b>Particulate Emission Rates, E</b>	
Mean stack gas temperature, T <sub>s</sub>	°C	129	E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	14.87	1.27	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS RUN 6			PM <sub>10</sub> & PM <sub>2.5</sub>	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	742.5	CO <sub>2</sub>	9.54
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	-1.9	O <sub>2</sub>	7.20
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	742.4	Total	16.73
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			N <sub>2</sub> (100 - Total)	83.27
			M <sub>d</sub> = 0.44(%CO <sub>2</sub> )+0.32(%O <sub>2</sub> )+0.28(%N <sub>2</sub> )	29.81
Moisture trap weight increase, V <sub>lc</sub>	g	H <sub>2</sub> O by FTIR	<b>Molecular weight of wet gas, M<sub>s</sub></b>	
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	$M_s = M_d(1 - B_{wo}) + 18(B_{wo})$	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Volume of gas sample through gas meter, V <sub>m</sub>		5.47	Area of stack, A <sub>s</sub>	m <sup>2</sup> 4.05
Gas meter correction factor, Y <sub>d</sub>		1.06	Q <sub>a</sub> = (60)(A <sub>s</sub> )(V <sub>s</sub> )	m <sup>3</sup> /min 3577.8
Mean dry gas meter temperature, T <sub>m</sub>		29.38	<b>Percent isokinetic, %I</b>	
Mean pressure drop across orifice, ΔH	mmH <sub>2</sub> O	101.27	Required Flow Rate @ DGM	l/min 29.50
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		5.161	Actual Flow Rate @ DGM	l/min 30.4
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Isokinetic Rate	
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	6.3145	Acceptable 90% - 130%	
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			<b>Particulate Concentration, C<sub>PM10</sub></b>	
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	Mass of particulate collected on PM <sub>10</sub> filter, M <sub>f</sub>	0.00037
% oxygen measured in gas stream, act%O <sub>2</sub>		7.20	Mass of particulate collected on PM <sub>2.5</sub> filter, M <sub>f</sub>	0.00021
% oxygen reference condition		11	$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.0919
O <sub>2</sub> Reference O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>		1.38	$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.1124
Factor 21.0 - ref%O <sub>2</sub>			$C_{dry@X\%O2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0814
$V_{mstd@X\%oxygen} = (V_{mstd}) (O_2 \text{ Ref})$	m <sup>3</sup>	7.123	<b>Particulate Emission Rates, E</b>	
<b>Moisture content, B<sub>wo</sub></b>			E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	0.1827	13.09	
<b>Moisture by FTIR</b>			<b>Particulate Concentration, C<sub>PM2.5</sub></b>	
	%	18.27	Mass of particulate collected on filter, M <sub>f</sub>	
<b>Velocity of stack gas, V<sub>s</sub></b>			$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.0333
Pitot tube velocity constant, K <sub>p</sub>		34.97	$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.0407
Velocity pressure coefficient, C <sub>p</sub>		0.83	$C_{dry@X\%O2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0295
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	13.17	<b>Particulate Emission Rates, E</b>	
Mean square root of velocity heads, √ΔP		3.63	E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	
Mean stack gas temperature, T <sub>s</sub>	°C	129	4.74	
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	14.73		

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PM<sub>10</sub> & PM<sub>2.5</sub> QUALITY ASSURANCE CHECKLIST**

LEAK RATE						
Run	Mean Sampling Rate litre/min	Pre-sampling Leak Rate litre/min	Post-sampling Leak Rate litre/min	Maximum Vacuum mm Hg	Acceptable Leak Rate litre/min	Leak Tests Acceptable?
Run 1	31.56	0.10	0.12	-457	0.63	Yes
Run 2	31.84	0.04	0.1	-508	0.64	Yes
Run 3	32.45	0.2	0.25	-508	0.65	Yes
Run 4	27.89	0.05	0.12	-406	0.56	Yes
Run 5	27.06	0.09	0.14	-432	0.54	Yes
Run 6	30.36	0.1	0.1	-457	0.61	Yes

ISOKINETICITY		
Run	Flow Variation %	Acceptable Variation
Run 1	105.2	Yes
Run 2	102.7	Yes
Run 3	104.3	Yes
Run 4	94.9	Yes
Run 5	92.0	Yes
Run 6	102.9	Yes

Acceptable Flow rate 90 -130%

FILTERS					
Run	Filter Material	Filter Size mm	Max Filtration Temperature °C	Pre-conditioning Filter Temperature °C	Post conditioning Filtration Temperature °C
Run 1	QF	50	127	180	160
Run 2	QF	50	126	180	160
Run 3	QF	50	127	180	160
Run 4	QF	50	130	180	160
Run 5	QF	50	147	180	160
Run 6	QF	50	144	180	160

QF = Quartz Fibre

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**Conformity with relevant aspects of BS EN ISO 23210:2009**

**GENERAL METHODOLOGY**

The equipment employed is a Paul Gothe, Johnas cascade impactor (see pg 13 for serial number) system meeting the requirements of BS EN ISO 23210. The standard cites a two-stage impactor system.

The method for sampling requires the extraction of a representative sample of duct gas isokinetically, into a specially designed in-stack sampling head. The Cascade Impactor is a multi-stage, multi-jet impactor which aerodynamically classifies particulates into multiple size ranges. The cascade impactor uses the principle of inertial separation to size segregate particulate samples from the gas stream. The impactor has two stages for particle size determination. Each stage gives a cut-point based on aerodynamic diameter of the particle.

During sampling, the particles are driven (jetted) toward a collecting surface where they may cling. By changing the velocity (orifice size of the jet), the size of the particles collected is controlled. The size of the jets within each stage is constant, but for each succeeding stage the jets get smaller. Impaction occurs when the particle's inertia overcomes the aerodynamic drag. Otherwise, the particle remains in the air stream and proceeds to the next stage. To keep the cut-point for each stage constant, the impactor is operated at a constant flow rate.

At each stage, the particle impacts on to a conditioned and pre-weighed substrate. Following sampling, the substrates are reconditioned and reweighed to determine the mass collected.

Based on the sampling conditions (sampling rate and gas temperature) the cut size (D50 – diameter of particles having a 50% probability of penetration) associated with each impactor stage may be determined.

An homogeneity assessment based on BS EN ISO 23210, Annex G, is undertaken to determine the most representative sampling point in the sampling plane (temperature, velocity and oxygen are suitable surrogates for particulate matter). The velocity measurement at the chosen point is used to determine an appropriate sampling nozzle/flow rate in order to ensure that isokinetic conditions are maintained throughout sampling to within the 90-130% range allowed in the standard (8.1) and which is consistent with the sampling equipment.

Concurrently, the volume of duct gas sampled is measured. This then enables the particulate concentration at each cut size to be determined.

The outlet gas from the sampling head is passed via a sampling probe through an impinger train with the purpose of removing water prior to entry to the sampling control box. It is not intended that the sampling train be used for additional sampling of condensable determinands and as such the train is unheated.

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**Conformity with relevant aspects of BS EN ISO 23210:2009**

Sampling Plane Validation Criteria				
EA Technical Guidance Note (Monitoring) M1	Result	Units	Requirement	Compliant
Lowest Differential Pressure	118	Pa	>= 5 Pa	Yes
Lowest Gas Velocity	13.46	m/s	-	-
Highest Gas Velocity	14.99	m/s	-	-
Ratio of Gas Velocities	1.11	-	< 3 : 1	Yes
Maximum angle of flow with regard to duct axis	<15	°	< 15°	Yes
No local negative flow	Yes	-	-	Yes

Conformance with BS EN ISO 23210:2009			
Reference	Requirement	Result	Compliant
Section 6.3	Suitable Impactor Used	See statement of conformity for Impactor	Yes
Section 8.1	Sampling position acceptable (as per 13284-1)	As per table "Sampling Plane Validation"	Yes
Section 8.1	Nozzle arrangement	See statement of conformity for Impactor	Yes
Section 8.1	Representative sampling point	See Homogeneity assessment below	Yes
Section 8.1	Constant Sample gas flow, iso-kinetic rate 90% to 130%		
	Run 1 - Required flow 30 (LPM)		-
	Run 1 - Minimum permissible flow 27 (LPM)	27.62	Yes
	Run 1 - Maximum permissible flow 39 (LPM)	36.58	Yes
	Run 2 - Required flow 31 (LPM)		-
	Run 2 - Minimum permissible flow 27.9 (LPM)	29.13	Yes
	Run 2 - Maximum permissible flow 40.3 (LPM)	38.17	Yes
	Run 3 - Required flow 31.1 (LPM)		-
	Run 3 - Minimum permissible flow 27.99 (LPM)	28.60	Yes
	Run 3 - Maximum permissible flow 40.43 (LPM)	36.00	Yes
	Run 4 - Required flow 29.4 (LPM)		-
	Run 4 - Minimum permissible flow 26.46 (LPM)	26.62	Yes
	Run 4 - Maximum permissible flow 38.22 (LPM)	30.84	Yes
	Run 5 - Required flow 29.4 (LPM)		-
	Run 5 - Minimum permissible flow 26.46 (LPM)	26.60	Yes
	Run 5 - Maximum permissible flow 38.22 (LPM)	29.20	Yes
	Run 6 - Required flow 29.5 (LPM)		-
	Run 6 - Minimum permissible flow 26.55 (LPM)	27.60	Yes
	Run 6 - Maximum permissible flow 38.35 (LPM)	33.20	Yes
Section 8.1	Overall blank taken once per day	Yes	Yes
Section 8.2	Impactor cleaned between each measurement	Yes	Yes
Section 8.2	Arrangement of impactor plates	See statement of conformity for Impactor	Yes
Section 8.3.2	Data taken for velocity, composition, temp & pressure	See "Preliminary stack survey" section	Yes
Section 8.3.3	Sampling rate determination in accordance with Annex A	Yes	Yes
Section 8.3.3	Sample flow rate kept +/- 5% of nominal flow rate		
	Run 1 - Max sample flow deviation from nominal (%)	9.7	No
	Run 2 - Max sample flow deviation from nominal (%)	10.0	No
	Run 3 - Max sample flow deviation from nominal (%)	14.3	No
	Run 4 - Max sample flow deviation from nominal (%)	6.2	No
	Run 5 - Max sample flow deviation from nominal (%)	34.2	No
	Run 6 - Max sample flow deviation from nominal (%)	19.0	No
Section 8.3.4	Nozzle selected to allow iso-kinetic rate 90% to 130%	Yes, as above	Yes
Section 8.3.5	Leak check less than 2%		
	Run 1	0.32	Yes
	Run 2	0.13	Yes
	Run 3	0.62	Yes
	Run 4	0.18	Yes
	Run 5	0.33	Yes
	Run 6	0.33	Yes
Section 8.3.6	Impactor at flue gas temperature before sampling	Yes	Yes
Section 8.3.6	Angle of nozzle less than 10 Degrees to flow	Yes	Yes
Section 8.3.6	Flowrate has checked and recorded every 5 mins	Yes	Yes
Section 8.3.6	Dynamic pressure recorded every 5 mins	Yes	Yes

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**Homogeneity assessment**

Assessment 1

Point number (i)	Distance along sample line (mm)	Probe Marking (mm)	O2 % grid	O2 % fixed	$r_i$
1	59	129	8	8	1.002
2	187.8	257.8	9	9	1.001
3	336.8	406.8	9	10	0.993
4	520.1	590.1	10	10	0.990
5	786.3	856.3	10	10	0.982
6	1513.7	1583.7	9	9	1.000
7	1779.9	1849.9	9	9	1.030
8	1963.2	2033.2	9	8	1.045
9	2112.2	2182.2	9	9	1.022
10	2241	2311	9	9	1.003
<b>Second Line</b>					
1	59	129	10	10	0.990
2	187.8	257.8	10	10	1.002
3	336.8	406.8	9	9	1.000
4	520.1	590.1	8	8	1.000
5	786.3	856.3	9	8	1.045
6	1513.7	1583.7	9	9	0.999
7	1779.9	1849.9	9	9	1.003
8	1963.2	2033.2	10	10	1.000
9	2112.2	2182.2	10	10	1.004
10	2241	2311	9	9	0.998

<b>No. of points</b>	20
$S_{grid}$	0.59
$S_{ref}$	0.65
$f$	1.005
Is $S_{grid} \leq S_{ref}$ ?	Yes
<b>F Factor</b>	0.812
$F_{N-1; N-1; 0.95}$	2.17
Is F Factor $< F_{N-1; N-1; 0.95}$ ?	N/A
$S_{pos}$	N/A
$t_{N-1; 0.95}$	2.093
$U_{pos}$	N/A
<b>Permissible Uncertainty</b>	6
Is $U_{pos} < 0.5 * U_{perm}$ ?	N/A

Sample can be taken from any location

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**DAILY OXYGEN SUMMARY**

Run	Sampling Times	Concentration %	LOD %
1	14:59 - 17:59 27 February 2014	7.40	0.01
2	09:40 - 12:40 28 February 2014	7.61	0.01
3	13:03 - 16:03 28 February 2014	7.49	0.01
4	10:23 - 13:23 03 March 2014	6.91	0.01
5	14:19 - 17:19 03 March 2014	6.91	0.01
6	09:48 - 12:48 04 March 2014	7.20	0.01

PRE SAMPLING CALIBRATION DATA								
Date	Time of Analyser	Range (%)	Zero Reading at analyser	Span Reading at analyser	Zero Check at analyser	Zero Check down line	Span Check down line	Leak Rate %
27 February 2014	11:51 - 12:03	20.9	0.00	10.06	0.00	-0.27	10.19	1.28
03 March 2014	09:14 - 09:24	20.9	0.00	10.06	0.00	0.10	9.78	-2.86

POST SAMPLING CALIBRATION DATA					
Date	Time of Analyser	Zero Check down line	Span Check down line	Zero Drift (%)	Span Drift (%)
28 February 2014	15:59 - 16:10	-0.19	10.14	0.38	-1.29
04 March 2014	12:42 - 12:58	0	9.59	-0.48	-0.89

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**COMBUSTION GAS SUMMARY**

Test	Sampling Times	Concentration %	Analysis Areas	Interference (%) *	LOD %
Moisture Run 1	14:59 - 17:59 27 February 2014	19.0	3200 - 3401	0.7	0.01
Moisture Run 2	09:40 - 12:40 28 February 2014	17.9	3200 - 3401	0.97	0.01
Moisture Run 3	13:03 - 16:03 28 February 2014	18.3	3200 - 3401	0.97	0.01
Moisture Run 4	10:23 - 13:23 03 March 2014	18.9	3200 - 3401	0.97	0.01
Moisture Run 5	14:19 - 17:19 03 March 2014	19.3	3200 - 3401	1.68	0.01
Moisture Run 6	09:48 - 12:48 04 March 2014	18.3	3200 - 3401	1.68	0.01
Carbon Dioxide Run 1	14:59 - 17:59 27 February 2014	9.5	2000 - 2223	1.54	0.04
Carbon Dioxide Run 2	09:40 - 12:40 28 February 2014	9.5	2000 - 2223	0.97	0.04
Carbon Dioxide Run 3	13:03 - 16:03 28 February 2014	9.5	2000 - 2223	0.97	0.04
Carbon Dioxide Run 4	10:23 - 13:23 03 March 2014	9.7	2000 - 2223	0.97	0.04
Carbon Dioxide Run 5	14:19 - 17:19 03 March 2014	9.7	2000 - 2223	0.27	0.04
Carbon Dioxide Run 6	09:48 - 12:48 04 March 2014	9.5	2000 - 2223	0.27	0.04

\*M22 Specifies interference must be <5%.

**FTIR CALIBRATION CHECKS**

Pre - Sampling Checks - System			Date of Checks	27 February 2014	Time of Checks			12:49
Post Sampling Checks - System			Date of Checks	28 February 2014	Time of Checks			16:00
Compound	Pre - Test Zero Reading	Post Test Zero Reading	Zero Drift as a % of Range	Span Gas (ppm)	Pre - Test Span Reading	% Variation from Actual	Post Test Span Reading	% Span Drift
H <sub>2</sub> O	0.02	0.01	-0.02	87.1	86.7	-0.45	87.1	0.45
CO <sub>2</sub> (%)	0.00	0.00	0.00	12.0	12.1	0.69	12.1	-0.22

Pre - Sampling Checks - System			Date of Checks	03 March 2014	Time of Checks			08:52
Post Sampling Checks - System			Date of Checks	04 March 2014	Time of Checks			12:50
Compound	Pre - Test Zero Reading	Post Test Zero Reading	Zero Drift as a % of Range	Span Gas (ppm)	Pre - Test Span Reading	% Variation from Actual	Post Test Span Reading	% Span Drift
H <sub>2</sub> O	0.09	0.10	0.02	87.1	85.9	-1.35	85.2	-0.88
CO <sub>2</sub> (%)	0.00	0.00	0.00	12.0	12.1	1.20	12.0	-1.45

Note - Methane was used as a surrogate span check for moisture. All other surrogates are listed in the individual measurement uncertainty budgets. Acceptance criteria for initial span check variation is +/-5% of certified reading for all gases, except HCl and NH<sub>3</sub> which are +/- 10% of certified reading. Acceptance criteria for % zero drift across the test is +/-2% of range for all gases.



### PRELIMINARY STACK SURVEY

Stack Characteristics		
Stack Diameter / Depth, D	2.27	m
Stack Width, W	-	m
Stack Area, A	4.05	m <sup>2</sup>
Average stack gas temperature	127	°C
Stack static pressure	-0.26	kPa
Barometric Pressure	99.13	kPa
Pitot tube calibration coefficient, $K_{pt}$	0.83	-

Stack Gas Composition & Molecular Weights								
Component	Molar Mass M	Density kg/m <sup>3</sup> p	Conc Dry % Vol	Dry Volume Fraction r	Dry Conc kg/m <sup>3</sup> pi	Conc Wet % Vol	Wet Volume Fraction r	Wet Conc kg/m <sup>3</sup> pi
CO <sub>2</sub>	44	1.96	9.50	0.10	0.19	7.73	0.08	0.15
O <sub>2</sub>	32	1.43	7.25	0.07	0.10	5.90	0.06	0.08
N <sub>2</sub>	28	1.25	83.25	0.83	1.04	67.76	0.68	0.85
H <sub>2</sub> O	18	0.80	-	-	-	18.61	0.19	0.15

Where:  $p = M / 22.41$      $pi = r \times p$

Calculation of Stack Gas Densities		
Determinand	Result	Units
Dry Density (STP), $P_{STD}$	1.3300	kg/m <sup>3</sup>
Wet Density (STP), $P_{STW}$	1.2319	kg/m <sup>3</sup>
Dry Density (Actual), $P_{Actual}$	0.8864	kg/m <sup>3</sup>
Average Wet Density (Actual), $P_{ActualW}$	0.821	kg/m <sup>3</sup>

Where:

$P_{STD}$  = sum of component concentrations, kg/m<sup>3</sup> (not including water vapour)

$P_{STW} = (P_{STD} + pi \text{ of H}_2\text{O}) / (1 + (pi \text{ of H}_2\text{O} / 0.8036))$

$P_{Actual} = P_{STD} \times (Ts / Ps) \times (Pa / Ta)$

$P_{ActualW} = P_{STW} \times (Ts / Ps) \times (Pa / Ta)$

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY**

**TRAVERSE 1**

Date of Survey	27 February 2014
Time of Survey	12:30
Velocity Measurement Device:	S-Type Pitot

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.11	14.0	137	124	14.56	-	<15
2	0.34	13.4	131	124	14.24	-	<15
3	0.57	13.8	135	125	14.47	-	<15
4	0.79	13.0	127	125	14.05	-	<15
5	1.02	12.8	125	125	13.94	-	<15
6	1.25	12.4	122	125	13.72	-	<15
7	1.48	13.8	135	125	14.47	-	<15
8	1.70	14.2	139	125	14.68	-	<15
9	1.93	14.8	145	125	14.99	-	<15
10	2.16	12.0	118	123	13.46	-	<15
Mean	-	13.4	132	125	14.26	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.11	13.2	129	125	14.15	-	<15
2	0.34	14.0	137	125	14.58	-	<15
3	0.57	14.0	137	125	14.58	-	<15
4	0.79	13.8	135	125	14.47	-	<15
5	1.02	13.6	133	125	14.37	-	<15
6	1.25	13.6	133	124	14.35	-	<15
7	1.48	14.0	137	124	14.56	-	<15
8	1.70	13.8	135	124	14.45	-	<15
9	1.93	14.2	139	123	14.64	-	<15
10	2.16	13.0	127	123	14.01	-	<15
Mean	-	13.7	134	124	14.42	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

**TRAVERSE 2**

Date of Survey	27 February 2014
Time of Survey	18:04
Velocity Measurement Device:	S-Type Pitot

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.11	13.3	130	125	14.21	-	<15
2	0.34	13.6	133	125	14.37	-	<15
3	0.57	13.8	135	125	14.47	-	<15
4	0.79	13.0	127	125	14.05	-	<15
5	1.02	13.0	127	125	14.05	-	<15
6	1.25	13.0	127	125	14.05	-	<15
7	1.48	13.8	135	125	14.47	-	<15
8	1.70	13.6	133	125	14.37	-	<15
9	1.93	14.0	137	125	14.58	-	<15
10	2.16	13.3	130	123	14.17	-	<15
Mean	-	13.4	132	125	14.28	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.11	13.5	132	126	14.33	-	<15
2	0.34	14.0	137	126	14.60	-	<15
3	0.57	14.0	137	125	14.58	-	<15
4	0.79	14.0	137	125	14.58	-	<15
5	1.02	13.6	133	125	14.37	-	<15
6	1.25	13.8	135	124	14.45	-	<15
7	1.48	14.0	137	124	14.56	-	<15
8	1.70	13.8	135	124	14.45	-	<15
9	1.93	13.6	133	125	14.37	-	<15
10	2.16	13.0	127	125	14.05	-	<15
Mean	-	13.7	135	125	14.43	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY**

**TRAVERSE 3**

Date of Survey	28 February 2014
Time of Survey	12:45
Velocity Measurement Device:	S-Type Pitot

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.11	13.0	127	126	14.06	-	<15
2	0.34	13.2	129	126	14.17	-	<15
3	0.57	13.6	133	126	14.39	-	<15
4	0.79	13.4	131	126	14.28	-	<15
5	1.02	13.6	133	126	14.39	-	<15
6	1.25	13.6	133	126	14.39	-	<15
7	1.48	13.4	131	126	14.28	-	<15
8	1.70	13.2	129	126	14.17	-	<15
9	1.93	13.0	127	126	14.06	-	<15
10	2.16	13.2	129	126	14.17	-	<15
Mean	-	13.32	131	126	14.24	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.11	13.0	127	125	14.05	-	<15
2	0.34	13.2	129	126	14.17	-	<15
3	0.57	13.5	132	126	14.33	-	<15
4	0.79	13.5	132	126	14.33	-	<15
5	1.02	13.2	129	126	14.17	-	<15
6	1.25	13.2	129	126	14.17	-	<15
7	1.48	13.3	130	126	14.23	-	<15
8	1.70	13.5	132	126	14.33	-	<15
9	1.93	13.6	133	126	14.39	-	<15
10	2.16	13.5	132	126	14.33	-	<15
Mean	-	13.4	131	126	14.25	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

**TRAVERSE 4**

Date of Survey	28 February 2014
Time of Survey	16:15
Velocity Measurement Device:	S-Type Pitot

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.11	13.3	130	125	14.21	-	<15
2	0.34	13.6	133	125	14.37	-	<15
3	0.57	13.5	132	125	14.31	-	<15
4	0.79	13.6	133	125	14.37	-	<15
5	1.02	13.4	131	125	14.26	-	<15
6	1.25	13.3	130	125	14.21	-	<15
7	1.48	13.2	129	125	14.15	-	<15
8	1.70	13.3	130	125	14.21	-	<15
9	1.93	13.4	131	125	14.26	-	<15
10	2.16	13.5	132	125	14.31	-	<15
Mean	-	13.4	131	125	14.27	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.11	13.2	129	125	14.15	-	<15
2	0.34	13.4	131	125	14.26	-	<15
3	0.57	13.6	133	125	14.37	-	<15
4	0.79	13.5	132	125	14.31	-	<15
5	1.02	13.4	131	125	14.26	-	<15
6	1.25	13.5	132	125	14.31	-	<15
7	1.48	13.5	132	125	14.31	-	<15
8	1.70	13.4	131	125	14.26	-	<15
9	1.93	13.3	130	125	14.21	-	<15
10	2.16	13.2	129	125	14.15	-	<15
Mean	-	13.4	131	125	14.26	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY**

**TRAVERSE 5**

Date of Survey	03 March 2014
Time of Survey	10:15
Velocity Measurement Device:	S-Type Pitot

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.11	13.6	133	128	14.42	-	<15
2	0.34	13.4	131	128	14.32	-	<15
3	0.57	13.6	133	128	14.42	-	<15
4	0.79	13.2	129	128	14.21	-	<15
5	1.02	13.4	131	128	14.32	-	<15
6	1.25	13.2	129	128	14.21	-	<15
7	1.48	13.4	131	128	14.32	-	<15
8	1.70	13.4	131	128	14.32	-	<15
9	1.93	13.6	133	128	14.42	-	<15
10	2.16	13.0	127	128	14.10	-	<15
Mean	-	13.38	131	128	14.30	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.11	13.2	129	128	14.21	-	<15
2	0.34	13.6	133	128	14.42	-	<15
3	0.57	13.8	135	128	14.53	-	<15
4	0.79	13.6	133	128	14.42	-	<15
5	1.02	13.6	133	128	14.42	-	<15
6	1.25	13.6	133	128	14.42	-	<15
7	1.48	13.4	131	128	14.32	-	<15
8	1.70	13.6	133	128	14.42	-	<15
9	1.93	13.2	129	128	14.21	-	<15
10	2.16	13.0	127	128	14.10	-	<15
Mean	-	13.5	132	128	14.35	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

**TRAVERSE 6**

Date of Survey	03 March 2014
Time of Survey	14:00
Velocity Measurement Device:	S-Type Pitot

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.11	13.2	129	128	14.21	-	<15
2	0.34	13.5	132	128	14.37	-	<15
3	0.57	13.6	133	128	14.42	-	<15
4	0.79	13.5	132	128	14.37	-	<15
5	1.02	13.4	131	128	14.32	-	<15
6	1.25	13.3	130	128	14.26	-	<15
7	1.48	13.5	132	128	14.37	-	<15
8	1.70	13.5	132	128	14.37	-	<15
9	1.93	13.6	133	128	14.42	-	<15
10	2.16	13.2	129	128	14.21	-	<15
Mean	-	13.4	132	128	14.33	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.11	13.4	131	128	14.32	-	<15
2	0.34	13.6	133	128	14.42	-	<15
3	0.57	13.5	132	128	14.37	-	<15
4	0.79	13.6	133	128	14.42	-	<15
5	1.02	13.6	133	128	14.42	-	<15
6	1.25	13.5	132	128	14.37	-	<15
7	1.48	13.6	133	128	14.42	-	<15
8	1.70	13.6	133	128	14.42	-	<15
9	1.93	13.3	130	128	14.26	-	<15
10	2.16	13.0	127	128	14.10	-	<15
Mean	-	13.5	132	128	14.35	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY**

**TRAVERSE 7**

Date of Survey	03 March 2014
Time of Survey	17:30
Velocity Measurement Device:	S-Type Pitot

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.11	13.2	129	128	14.21	-	<15
2	0.34	13.4	131	128	14.32	-	<15
3	0.57	13.6	133	128	14.42	-	<15
4	0.79	13.5	132	128	14.37	-	<15
5	1.02	13.7	134	128	14.47	-	<15
6	1.25	13.8	135	128	14.53	-	<15
7	1.48	13.5	132	128	14.37	-	<15
8	1.70	13.3	130	128	14.26	-	<15
9	1.93	13.3	130	128	14.26	-	<15
10	2.16	13.0	127	128	14.10	-	<15
Mean	-	13.43	132	128	14.33	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.11	13.5	132	128	14.37	-	<15
2	0.34	13.3	130	128	14.26	-	<15
3	0.57	13.7	134	128	14.47	-	<15
4	0.79	13.9	136	128	14.58	-	<15
5	1.02	13.6	133	128	14.42	-	<15
6	1.25	13.4	131	128	14.32	-	<15
7	1.48	13.5	132	128	14.37	-	<15
8	1.70	13.4	131	128	14.32	-	<15
9	1.93	13.3	130	128	14.26	-	<15
10	2.16	13.2	129	128	14.21	-	<15
Mean	-	13.5	132	128	14.36	-	



APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

**TRAVERSE 8**

Date of Survey	04 March 2014
Time of Survey	09:30
Velocity Measurement Device:	S-Type Pitot

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.11	13.0	127	128	14.10	-	<15
2	0.34	13.3	130	128	14.26	-	<15
3	0.57	13.0	127	128	14.10	-	<15
4	0.79	12.9	126	128	14.05	-	<15
5	1.02	13.2	129	128	14.21	-	<15
6	1.25	13.3	130	128	14.26	-	<15
7	1.48	13.2	129	128	14.21	-	<15
8	1.70	13.1	128	128	14.15	-	<15
9	1.93	13.0	127	128	14.10	-	<15
10	2.16	12.8	125	128	13.99	-	<15
Mean	-	13.1	128	128	14.14	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.11	12.8	125	128	13.99	-	<15
2	0.34	12.6	123	128	13.88	-	<15
3	0.57	12.8	125	128	13.99	-	<15
4	0.79	13.0	127	128	14.10	-	<15
5	1.02	13.3	130	128	14.26	-	<15
6	1.25	13.0	127	128	14.10	-	<15
7	1.48	13.0	127	128	14.10	-	<15
8	1.70	13.0	127	128	14.10	-	<15
9	1.93	12.8	125	128	13.99	-	<15
10	2.16	12.8	125	128	13.99	-	<15
Mean	-	12.9	127	128	14.05	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

**TRAVERSE 9**

Date of Survey	04 March 2014
Time of Survey	13:00
Velocity Measurement Device:	S-Type Pitot

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.11	12.7	124	128	13.94	-	<15
2	0.34	12.8	125	128	13.99	-	<15
3	0.57	12.9	126	128	14.05	-	<15
4	0.79	13.1	128	128	14.15	-	<15
5	1.02	13.3	130	128	14.26	-	<15
6	1.25	13.2	129	128	14.21	-	<15
7	1.48	13.3	130	128	14.26	-	<15
8	1.70	13.1	128	128	14.15	-	<15
9	1.93	13.0	127	128	14.10	-	<15
10	2.16	13.0	127	128	14.10	-	<15
Mean	-	13.0	128	128	14.12	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.11	12.6	123	128	13.88	-	<15
2	0.34	12.5	123	128	13.83	-	<15
3	0.57	12.8	125	128	13.99	-	<15
4	0.79	13.0	127	128	14.10	-	<15
5	1.02	13.0	127	128	14.10	-	<15
6	1.25	13.0	127	128	14.10	-	<15
7	1.48	13.4	131	128	14.32	-	<15
8	1.70	13.2	129	128	14.21	-	<15
9	1.93	13.1	128	128	14.15	-	<15
10	2.16	13.0	127	128	14.10	-	<15
Mean	-	13.0	127	128	14.08	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

Sampling Plane Validation Criteria				
EA Technical Guidance Note (Monitoring) M1	Result	Units	Requirement	Compliant
Lowest Differential Pressure	118	Pa	>= 5 Pa	Yes
Lowest Gas Velocity	13.46	m/s	-	-
Highest Gas Velocity	14.99	m/s	-	-
Ratio of Gas Velocities	1.11	-	< 3 : 1	Yes
Maximum angle of flow with regard to duct axis	<15	°	< 15°	Yes
No local negative flow	Yes	-	-	Yes

Calculation of Stack Gas Velocity, V		
Velocity at Traverse Point, $V = K_{pt} \times (1-\epsilon) \times \sqrt{2 * \Delta P_{pt} / \rho_{ActualW}}$		
<b>Where:</b> $K_{pt}$ = Pitot tube calibration coefficient (1- $\epsilon$ ) = Compressibility correction factor, assumed at a constant 0.998		
Average Stack Gas Velocity, $V_a$	14.25	m/s

**Where:**  
 $Q_{Actual} = V_a \times A \times 3600$   
 $Q_{STP} = Q_{Actual} \times (T_s / T_a) \times (P_a / P_s) \times 3600$   
 $Q_{STP,Dry} = Q_{STP} / (100 - (100 / Ma)) \times 3600$   
 $Q_{Ref} = Q_{STP} \times ((100 - Ma) / (100 - Ms)) \times ((20.9 - O_{2a}) / (20.9 - O_{2s}))$

Day 1	27 February 2014
-------	------------------

Calculation of Stack Gas Volumetric Flowrate, Q			
Duct gas flow conditions	Actual	Reference	Units
Temperature	125	0	°C
Total Pressure	99.0	101.3	kPa
Oxygen	7.4	11	%
Moisture	18.98	0.00	%
Gas Volumetric Flowrate		Result	Units
Average Stack Gas Velocity ( $V_a$ )		14.35	m/s
Stack Area (A)		4.05	m <sup>2</sup>
Gas Volumetric Flowrate (Actual), $Q_{Actual}$		209054	m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Wet), $Q_{STP}$		140320	m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Dry), $Q_{STP,Dry}$		113683	m <sup>3</sup> /hr
Gas Volumetric Flowrate (REF), $Q_{Ref}$		154608	m <sup>3</sup> /hr

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

Day 2	28 February 2014		
Calculation of Stack Gas Volumetric Flowrate, Q			
Duct gas flow conditions	Actual	Reference	Units
Temperature	127	0	°C
Total Pressure	98.9	101.3	kPa
Oxygen	7.3	11	%
Moisture	18.38	0.00	%
Gas Volumetric Flowrate	Result		Units
Average Stack Gas Velocity (Va)	14.29		m/s
Stack Area (A)	4.05		m <sup>2</sup>
Gas Volumetric Flowrate (Actual), Q <sub>Actual</sub>	208281		m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Wet), Q <sub>STP</sub>	138861		m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Dry), Q <sub>STP,Dry</sub>	113343		m <sup>3</sup> /hr
Gas Volumetric Flowrate (REF), Q <sub>Ref</sub>	154853		m <sup>3</sup> /hr

Day 3	03 March 2014		
Calculation of Stack Gas Volumetric Flowrate, Q			
Duct gas flow conditions	Actual	Reference	Units
Temperature	128	0	°C
Total Pressure	98.7	101.3	kPa
Oxygen	7.1	11	%
Moisture	18.76	0.00	%
Gas Volumetric Flowrate	Result		Units
Average Stack Gas Velocity (Va)	14.17		m/s
Stack Area (A)	4.05		m <sup>2</sup>
Gas Volumetric Flowrate (Actual), Q <sub>Actual</sub>	206414		m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Wet), Q <sub>STP</sub>	136975		m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Dry), Q <sub>STP,Dry</sub>	111277		m <sup>3</sup> /hr
Gas Volumetric Flowrate (REF), Q <sub>Ref</sub>	155187		m <sup>3</sup> /hr

**Nomenclature:**

Ts = Absolute Temperature, Standard Conditions, 273 K  
 Ps = Absolute Pressure, Standard Conditions, 101.3 kPa  
 Ta = Absolute Temperature, Actual Conditions, K


Pa = Absolute Pressure, Actual Conditions, kPa  
 Ma = Water vapour, Actual Conditions, % Vol  
 Ms = Water vapour, Reference Conditions, % Vol

O<sub>2a</sub> = Oxygen, Actual Conditions, % Vol  
 O<sub>2s</sub> = Oxygen, Reference Conditions, % Vol

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**STACK DIAGRAM**

	Value	Units
Stack Depth	2.27	m
Stack Width	-	m
Area	4.05	m <sup>2</sup>



Non-Isokinetic/Gases Sampling			
Sampling Point	Distance (% of Depth)	Distance into Stack	Units
A	30	0.68	m

Isokinetic Sampling CEN Methods			
Sampling Point	Distance (% of Depth)	Distance into Stack (m)	Swirl °
1	85.0	1.93	<15

- Isokinetic sampling point
- Isokinetic sampling points not used
- ◐ Non Isokinetic/Gases sampling point

**SAMPLING LOCATION**



APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - PM 10**

Run	Sampled Volume m <sup>3</sup>	Sampled Gas K	Sampled Gas kPa	Sampled Gas % by volume	Oxygen % by volume	Limit of % by mass	Leak %
<b>MU required</b>	<b>≤ 2%</b>	<b>≤ 2%</b>	<b>≤ 1%</b>	<b>≤ 1%</b>	<b>≤ 10%</b>	<b>≤ 5% of ELV</b>	<b>≤ 2%</b>
Run 1	0.001	2	0.5	1	0.1	0.10	-
as a %	0.02	0.50	0.50	1.00	1.35	N/A	0.38
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 2	0.001	2	0.5	1.00	0.1	0.10	-
as a %	0.02	0.50	0.51	1.00	1.31	N/A	0.31
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 3	0.001	2	0.5	1	0.1	0.1000	-
as a %	0.01	0.50	0.51	1.00	1.33	N/A	0.77
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 4	0.001	2	0.5	1	0.1	0.10	-
as a %	0.02	0.50	0.52	1.00	1.45	N/A	0.43
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 5	0.001	2	0.5	1	0.1	0.10	-
as a %	0.02	0.50	0.51	1.00	1.45	N/A	0.52
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 6	0.001	2	0.5	1	0.1	0.10	-
as a %	0.07	0.50	0.51	1.00	1.39	N/A	0.33
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>

Run	Volume (STP) m <sup>3</sup>	Mass of particulate mg	O2 Correction -	Leak mg/m <sup>3</sup>	Combined uncertainty
Run 1	0.0644	0.1542	0.382	1.000	-
MU as mg/m <sup>3</sup>	0.0034	0.0154	0.0021	0.00062	<b>5.55</b>
MU as %	0.0531	5.5	0.735	0.220	-
Run 2	0.0036	0.1560	0.021	1.000	-
MU as mg/m <sup>3</sup>	0.0002	0.0156	0.0001	0.00003	<b>100.00</b>
MU as %	0.0030	100.0	0.747	0.181	-
Run 3	0.0068	0.1376	0.045	1.000	-
MU as mg/m <sup>3</sup>	0.0004	0.0138	0.0002	0.00015	<b>41.676</b>
MU as %	0.0062	41.7	0.740	0.445	-
Run 4	0.0037	0.15	0.022	1.00	-
MU as mg/m <sup>3</sup>	0.0002	0.02	0.0001	0.00004	<b>100.00</b>
MU as %	0.0029	100.0	0.710	0.25	-
Run 5	0.0196	0.16	0.118	1.00	-
MU as mg/m <sup>3</sup>	0.0010	0.02	0.0006	0.00025	<b>18.53</b>
MU as %	0.0159	18.5	0.710	0.30	-
Run 6	0.0322	0.05	0.041	1.00	-
MU as mg/m <sup>3</sup>	0.0004	0.01	0.0002	0.00006	<b>17.26</b>
MU as %	0.0056	17.2	0.725	0.19	-

<b>R1 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.03</b>	<b>mg/m<sup>3</sup></b>	<b>11.36</b>	<b>%</b>
<b>R2 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.03</b>	<b>mg/m<sup>3</sup></b>	<b>200.02</b>	<b>%</b>
<b>R3 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.03</b>	<b>mg/m<sup>3</sup></b>	<b>83.39</b>	<b>%</b>
<b>R4 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.03</b>	<b>mg/m<sup>3</sup></b>	<b>200.02</b>	<b>%</b>
<b>R5 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.03</b>	<b>mg/m<sup>3</sup></b>	<b>37.15</b>	<b>%</b>
<b>R6 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.01</b>	<b>mg/m<sup>3</sup></b>	<b>34.60</b>	<b>%</b>

(k is a coverage factor which gives a 95% confidence in the quoted figures)  
Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - PM 2.5**

Run	Sampled m <sup>3</sup>	Sampled Gas K	Sampled Gas kPa	Sampled Gas % by volume	Oxygen % by volume	Limit of % by mass	Leak %
<b>MU required</b>	≤ 2%	≤ 2%	≤ 1%	≤ 1%	≤ 10%	≤ 5% of ELV	≤ 2%
Run 1	0.001	2	0.5	1	0.1	0.05	-
as a %	0.02	0.50	0.50	1.00	1.35	N/A	0.38
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 2	0.001	2	0.5	1.00	0.1	0.05	-
as a %	0.02	0.50	0.51	1.00	1.31	N/A	0.31
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 3	0.001	2	0.5	1.00	0.1	0.05	-
as a %	0.01	0.50	0.51	1.00	1.33	N/A	0.77
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 4	0.001	2	0.5	1.00	0.1	0.05	-
as a %	0.02	0.50	0.52	1.00	1.45	0.00	0.43
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 5	0.001	2	0.5	1	0.1	0.05	-
as a %	0.02	0.50	0.51	1.00	1.45	N/A	0.52
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 6	0.001	2	0.5	1	0.1	0.05	-
as a %	0.07	0.50	0.51	1.00	1.39	N/A	0.33
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>

Run	Volume (STP) m <sup>3</sup>	Mass of particulate mg	O2 Correction -	Leak mg/m <sup>3</sup>	Combined uncertainty
Run 1	0.00	0.1542	0.0105	1.000	-
MU as mg/m <sup>3</sup>	0.0001	0.0077	0.0001	0.00002	<b>100.00</b>
MU as %	0.0015	100.0000	0.7353	0.22	-
Run 2	0.0018	0.1560	0.0104	1.000	-
MU as mg/m <sup>3</sup>	0.0001	0.0078	0.0001	0.00001	<b>100.00</b>
MU as %	0.0015	100.0000	0.7467	0.18	-
Run 3	0.0016	0.1560	0.0105	1.000	-
MU as mg/m <sup>3</sup>	0.0001	0.0078	0.0001	0.00003	<b>100.00</b>
MU as %	0.0015	100.0000	0.7403	0.44	-
Run 4	0.0018	0.1544	0.0109	1.0000	-
MU as mg/m <sup>3</sup>	0.0001	0.0077	0.0001	0.00002	<b>100.00</b>
MU as %	0.0015	100.0000	0.7099	0.25	-
Run 5	0.002	0.155	0.0109	1.000	-
MU as mg/m <sup>3</sup>	0.000	0.008	0.0001	0.00002	<b>100.00</b>
MU as %	0.001	100.000	0.7097	0.30	-
Run 6	0.03	0.14	0.0407	1.00	-
MU as mg/m <sup>3</sup>	0.00	0.01	0.0002	0.00006	<b>23.82</b>
MU as %	0.0	23.8	0.7245	0.19	-

<b>R1 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.015</b>	<b>mg/m<sup>3</sup></b>	<b>200.02</b>	<b>%</b>
<b>R2 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.016</b>	<b>mg/m<sup>3</sup></b>	<b>200.02</b>	<b>%</b>
<b>R3 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.016</b>	<b>mg/m<sup>3</sup></b>	<b>200.02</b>	<b>%</b>
<b>R4 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.015</b>	<b>mg/m<sup>3</sup></b>	<b>200.02</b>	<b>%</b>
<b>R5 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.016</b>	<b>mg/m<sup>3</sup></b>	<b>200.02</b>	<b>%</b>
<b>R6 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.014</b>	<b>mg/m<sup>3</sup></b>	<b>47.71</b>	<b>%</b>

(k is a coverage factor which gives a 95% confidence in the quoted figures)  
Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - CARBON DIOXIDE BY FTIR**

Actual Measured Concentration	9.53	% vol
Measured Concentration at Reference Conditions	9.53	% vol
Emission Limit Value	-	% vol
Instrument Range	20	% vol
Check Gas Concentration	12.00	% vol

Performance Characteristics & Source of Value	Values	Requirement	Compliant
Deviation from linearity as a % of the range (taken from worst case figure in MCERTS certificate)	-1.900	<2%	Yes
Zero drift (calculated from start and end readings)	0.000	<5%	Yes
Span drift (calculated from start and end readings).	-0.219	<5%	Yes
Sensitivity to sample gas pressure: (taken from worst case figure in MCERTS certificate).	0.990	<2%	Yes
Sensitivity to ambient temperature at zero (taken from worst case figure in MCERTS certificate)	0.100	<5%	Yes
Sensitivity to ambient temperature at span (taken from worst case figure in MCERTS certificate)	-1.300	<5%	Yes
Sensitivity to voltage (taken from worst case figure in MCERTS certificate)	1.600	<2%	Yes
Interferents (calculated using M22, Section 8.2, equation 3)	1.544	<5%	Yes
Repeatability / standard deviation (taken from worst figure in MCERTS certificate)	0.080	<2%	Yes
Certified reference material (check gas)	2.000	2% or less	Yes

Uncertainty in Performance Characteristics	% vol
Uncertainty of linearity (lack of fit) $U_{fit}$	-0.220
Uncertainty of zero drift $U_{0,dr}$	0.000
Uncertainty of span drift $U_{s,dr}$	-0.025
Uncertainty of volume or pressure flow dependence $U_{spress}$	0.115
Uncertainty in Ambient Temperature $U_{temp}$	0.151
Uncertainty in Voltage $U_{volt}$	0.186
Uncertainty of interferents $U_i$	0.179
Uncertainty of Repeatability $U_r$	0.016
Uncertainty of Certified Reference Material $U_{cal}$	0.069

Measurement Uncertainty	% vol
Combined uncertainty	0.40
Expanded uncertainty at a 95% Confidence Interval	0.79

Note - The expanded uncertainty uses a coverage factor of  $k = 2$ .

Expanded Measurement Uncertainty at a 95% Confidence Interval	%
Expressed as a % of the Measured Concentration	8.32
Expressed as a % of the Measured Concentration at Reference Conditions	8.32
Expressed as a % of the Emission Limit Value	-



APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - MOISTURE BY FTIR**

Actual Measured Concentration	18.77	% vol
Measured Concentration at Reference Conditions	18.77	% vol
Emission Limit Value	30	% vol
Instrument Range	40	% vol
Check Gas Concentration (Methane was used as a Surrogate)	62.21	mg/m <sup>3</sup>

Performance Characteristics & Source of Value	Values	Requirement	Compliant
Deviation from linearity as a % of the range (taken from worst case figure in MCERTS certificate)	-1.900	<2%	Yes
Zero drift (calculated from start and end readings)	-0.025	<5%	Yes
Span drift (calculated from start and end readings).	0.447	<5%	Yes
Sensitivity to sample gas pressure: (taken from worst case figure in MCERTS certificate).	0.990	<2%	Yes
Sensitivity to ambient temperature at zero (taken from worst case figure in MCERTS certificate)	0.100	<5%	Yes
Sensitivity to ambient temperature at span (taken from worst case figure in MCERTS certificate)	-1.000	<5%	Yes
Sensitivity to voltage (taken from worst case figure in MCERTS certificate)	0.710	<2%	Yes
Interferents (calculated using M22, Section 8.2, equation 3)	0.683	<5%	Yes
Repeatability / standard deviation (taken from worst figure in MCERTS certificate)	0.170	<2%	Yes
Certified reference material (check gas)	2.000	2% or less	Yes

Uncertainty in Performance Characteristics	% vol
Uncertainty of linearity (lack of fit) $U_{fit}$	-0.443
Uncertainty of zero drift $U_{0,dr}$	-0.006
Uncertainty of span drift $U_{s,dr}$	0.104
Uncertainty of volume or pressure flow dependence $U_{spress}$	0.231
Uncertainty in Ambient Temperature $U_{temp}$	0.234
Uncertainty in Voltage $U_{volt}$	0.166
Uncertainty of interferents $U_i$	0.159
Uncertainty of Repeatability $U_r$	0.069
Uncertainty of Certified Reference Material $U_{cal}$	0.359

Measurement Uncertainty	% vol
Combined uncertainty	0.71
Expanded uncertainty at a 95% Confidence Interval	1.42

Note - The expanded uncertainty uses a coverage factor of  $k = 2$ .

Expanded Measurement Uncertainty at a 95% Confidence Interval	%
Expressed as a % of the Measured Concentration	7.55
Expressed as a % of the Measured Concentration at Reference Conditions	7.55
Expressed as a % of the Emission Limit Value	4.72

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - OXYGEN**

DAY 1 - 27 February 2014

Reference	11	%vol
Measured concentration	7.40	%vol
Calibration gas	10.06	%vol
Full Scale	20.9	%vol

Performance characteristics	Value	Units	specification	MU Met?
Response time	120	seconds	< 200 s	Yes
Logger sampling interval	60	seconds	-	-
Measurement period	302	minutes	-	-
Number of readings in measurement	302	-	-	-
Repeatability at zero	0.015	% by volume	<0.2 % range	Yes
Repeatability at span level	0.014	% by volume	<0.4 % range	Yes
Deviation from linearity	0.13	% vol	<0.3 % volume	Yes
Zero drift (during measurement period)	0.38	% vol at zero level	<2% of volume / 24hr	Yes
Span drift (during measurement period)	-1.29	% vol at span level	<2% volume/24hr	Yes
volume or pressure flow dependence	0.02	% of fs / 10l/h	<1% range	Yes
atmospheric pressure dependence	0.8	% of fs/kPa	< 1.5 % range	Yes
ambient temperature dependence	0.01	% by volume /10K	<0.3% volume 10 K	Yes
Combined interference	0.11704	% range	<2% range	Yes
Dependence on voltage	0.1	% by volume /10V	< 0.1%vol /10 volt	Yes
Losses in the line (leak)	1.28	% of value	< 2% of value	Yes
Uncertainty of calibration gas	2	% of value	< 2% of value	Yes

Performance characteristic	Uncertainty	Value of uncertainty quantity
Standard deviation of repeatability at zero	ur0	-
Standard deviation of repeatability at span level	urs	0.001
Lack of fit	ufit	0.075
Drift	u0dr	-0.328
volume or pressure flow dependence	uspres	0.001
atmospheric pressure dependence	uapres	0.097
ambient temperature dependence	utemp	0.003
Combined interference (from mcerts)	-	0.014
dependence on voltage	uvolt	0.029
losses in the line (leak)	uleak	0.055
Uncertainty of calibration gas	ucalib	0.085

Measurement uncertainty (Concentration Measured)	7.40	%vol
Combined uncertainty	0.37	%vol
% of value	4.94	%

<b>Expanded uncertainty expressed with a level of confidence of 95%</b>	<b>9.88</b>	<b>% of value</b>
---	-------------	-------------------

<b>Expanded uncertainty expressed with a level of confidence of 95%</b>	<b>0.73</b>	<b>% vol</b>
---	-------------	--------------

Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - OXYGEN**

DAY 2 - 27 February 2014

Reference	11	%vol
Measured concentration	7.57	%vol
Calibration gas	10.06	%vol
Full Scale	20.9	%vol

Performance characteristics	Value	Units	specification	MU Met?
Response time	120	seconds	< 200 s	Yes
Logger sampling interval	60	seconds	-	-
Measurement period	391	minutes	-	-
Number of readings in measurement	391	-	-	-
Repeatability at zero	0.015	% by volume	<0.2 % range	Yes
Repeatability at span level	0.014	% by volume	<0.4 % range	Yes
Deviation from linearity	0.13	% vol	<0.3 % volume	Yes
Zero drift (during measurement period)	0.38	% vol at zero level	<2% of volume / 24hr	Yes
Span drift (during measurement period)	-1.29	% vol at span level	<2% volume/24hr	Yes
volume or pressure flow dependence	0.02	% of fs / 10l/h	<1% range	Yes
atmospheric pressure dependence	0.8	% of fs/kPa	< 1.5 % range	Yes
ambient temperature dependence	0.01	% by volume /10K	<0.3% volume 10 K	Yes
Combined interference	0.11704	% range	<2% range	Yes
Dependence on voltage	0.1	% by volume /10V	< 0.1%vol /10 volt	Yes
Losses in the line (leak)	1.28	% of value	< 2% of value	Yes
Uncertainty of calibration gas	2	% of value	< 2% of value	Yes

Performance characteristic	Uncertainty	Value of uncertainty quantity
Standard deviation of repeatability at zero	ur0	-
Standard deviation of repeatability at span level	urs	0.001
Lack of fit	ufit	0.075
Drift	u0dr	-0.341
volume or pressure flow dependence	uspres	0.001
atmospheric pressure dependence	uapres	0.097
ambient temperature dependence	utemp	0.003
Combined interference (from mcerts)	-	0.068
dependence on voltage	uvolt	0.029
losses in the line (leak)	uleak	0.056
Uncertainty of calibration gas	ucalib	0.087

Measurement uncertainty (Concentration Measured)	7.57	%vol
Combined uncertainty	0.38	%vol
% of value	5.07	%

<b>Expanded uncertainty expressed with a level of confidence of 95%</b>	<b>10.13</b>	<b>% of value</b>
---	--------------	-------------------

<b>Expanded uncertainty expressed with a level of confidence of 95%</b>	<b>0.77</b>	<b>% vol</b>
---	-------------	--------------

Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - OXYGEN**

DAY 3 - 03 March 2014

Reference	11	%vol
Measured concentration	6.95	%vol
Calibration gas	10.06	%vol
Full Scale	20.9	%vol

Performance characteristics	Value	Units	specification	MU Met?
Response time	120	seconds	< 200 s	Yes
Logger sampling interval	60	seconds	-	-
Measurement period	468	minutes	-	-
Number of readings in measurement	468	-	-	-
Repeatability at zero	0.015	% by volume	<0.2 % range	Yes
Repeatability at span level	0.014	% by volume	<0.4 % range	Yes
Deviation from linearity	0.13	% vol	<0.3 % volume	Yes
Zero drift (during measurement period)	-0.48	% vol at zero level	<2% of volume / 24hr	Yes
Span drift (during measurement period)	-0.89	% vol at span level	<2% volume/24hr	Yes
volume or pressure flow dependence	0.02	% of fs / 10l/h	<1% range	Yes
atmospheric pressure dependence	0.8	% of fs/kPa	< 1.5 % range	Yes
ambient temperature dependence	0.01	% by volume /10K	<0.3% volume 10 K	Yes
Combined interference	0.11704	% range	<2% range	Yes
Dependence on voltage	0.1	% by volume /10V	< 0.1%vol /10 volt	Yes
Losses in the line (leak)	-2.86	% of value	< 2% of value	Yes
Uncertainty of calibration gas	2	% of value	< 2% of value	Yes

Performance characteristic	Uncertainty	Value of uncertainty quantity
Standard deviation of repeatability at zero	ur0	-
Standard deviation of repeatability at span level	urs	0.001
Lack of fit	ufit	0.075
Drift	u0dr	-0.633
volume or pressure flow dependence	uspres	0.001
atmospheric pressure dependence	uapres	0.097
ambient temperature dependence	utemp	0.003
Combined interference (from mcerts)	-	0.068
dependence on voltage	uvolt	0.029
losses in the line (leak)	uleak	-0.115
Uncertainty of calibration gas	ucalib	0.080

Measurement uncertainty (Concentration Measured)	6.95	%vol
Combined uncertainty	0.66	%vol
% of value	9.55	%

<b>Expanded uncertainty expressed with a level of confidence of 95%</b>	<b>19.11</b>	<b>% of value</b>
---	--------------	-------------------

<b>Expanded uncertainty expressed with a level of confidence of 95%</b>	<b>1.33</b>	<b>% vol</b>
---	-------------	--------------

Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - OXYGEN**

DAY 4 - 03 March 2014

Reference	11	%vol
Measured concentration	7.18	%vol
Calibration gas	10.06	%vol
Full Scale	20.9	%vol

Performance characteristics	Value	Units	specification	MU Met?
Response time	120	seconds	< 200 s	Yes
Logger sampling interval	60	seconds	-	-
Measurement period	188	minutes	-	-
Number of readings in measurement	188	-	-	-
Repeatability at zero	0.015	% by volume	<0.2 % range	Yes
Repeatability at span level	0.014	% by volume	<0.4 % range	Yes
Deviation from linearity	0.13	% vol	<0.3 % volume	Yes
Zero drift (during measurement period)	-0.99	% vol at zero level	<2% of volume / 24hr	Yes
Span drift (during measurement period)	-1.89	% vol at span level	<2% volume/24hr	Yes
volume or pressure flow dependence	0.02	% of fs / 10l/h	<1% range	Yes
atmospheric pressure dependence	0.8	% of fs/kPa	< 1.5 % range	Yes
ambient temperature dependence	0.01	% by volume /10K	<0.3% volume 10 K	Yes
Combined interference	0.11704	% range	<2% range	Yes
Dependence on voltage	0.1	% by volume /10V	< 0.1%vol /10 volt	Yes
Losses in the line (leak)	-2.86	% of value	< 2% of value	Yes
Uncertainty of calibration gas	2	% of value	< 2% of value	Yes

Performance characteristic	Uncertainty	Value of uncertainty quantity
Standard deviation of repeatability at zero	ur0	-
Standard deviation of repeatability at span level	urs	0.001
Lack of fit	ufit	0.075
Drift	u0dr	-1.352
volume or pressure flow dependence	uspres	0.001
atmospheric pressure dependence	uapres	0.097
ambient temperature dependence	utemp	0.003
Combined interference (from mcerts)	-	0.068
dependence on voltage	uvolt	0.029
losses in the line (leak)	uleak	-0.119
Uncertainty of calibration gas	ucalib	0.083

Measurement uncertainty (Concentration Measured)	7.18	%vol
Combined uncertainty	1.37	%vol
% of value	19.04	%

Expanded uncertainty expressed with a level of confidence of 95%	38.09	% of value
Standard deviation of repeatability at span level	urs	#DIV/0!

APPENDIX 4 - Summaries, Calculations, Raw Data and Charts

NOTE - The following data is provided for information only and falls outside ESG's scope of accreditation

COMBINED UNCOLLECTED SUMMARY							
Test	Sampling Times	>PM <sub>10</sub> Concentration		Probe Rinse Concentration		Combined Unweighed Concentration	
		Measured mg/m <sup>3</sup>	LOD mg/m <sup>3</sup>	Measured mg/m <sup>3</sup>	LOD mg/m <sup>3</sup>	Measured mg/m <sup>3</sup>	LOD mg/m <sup>3</sup>
Run 1	14:59 - 17:59 27 February 2014	-	-	0.617	0.200	0.617	0.208
Run 2	09:40 - 12:40 28 February 2014	-	-	0.452	0.203	0.452	0.211
Run 3	13:03 - 16:03 28 February 2014	-	-	0.179	0.179	0.186	0.186
Run 4	10:23 - 13:23 03 March 2014	-	-	0.201	0.201	0.208	0.208
Run 5	14:19 - 17:19 03 March 2014	-	-	0.202	0.202	0.210	0.210
Run 6	09:48 - 12:48 04 March 2014	-	-	0.323	0.183	0.323	0.190

Reference conditions are 273K, 101.3kPa, dry gas 11% Oxygen.

Where the result is less than the LOD, the LOD is reported.

SAMPLES									
Test	>PM <sub>10</sub> Filter Number	Filter Start Weight g	Filter End Weight g	Mass Gained on Filter g	Probe Rinse Number g	Probe Rinse Start Weight g	Probe Rinse End Weight g	Mass Gained in Rinse g	Combined Total Mass Gained g
Run 1	-	-	-	-	8268	185.6722	185.6762	0.00400	0.00400
Run 2	-	-	-	-	8270	202.94590	202.94880	0.00290	0.00290
Run 3	-	-	-	-	8311	178.35600	178.35720	0.00120	0.00120
Run 4	-	-	-	-	8312	197.51310	197.51410	0.00100	0.00100
Run 5	-	-	-	-	8313	184.45100	184.45200	0.00100	0.00100
Run 6	-	-	-	-	8314	192.35870	192.36100	0.00230	0.00230
Blank 1	-	-	-	-	8267	193.54890	193.54910	0.00020	0.00020
Blank 2	-	-	-	-	8269	165.16350	165.16410	0.00060	0.00060
Blank 3	-	-	-	-	8309	184.39820	184.39840	0.00020	0.00020
Blank 4	-	-	-	-	8310	186.26920	186.26940	0.00020	0.00020



Paul Gothe GmbH Wittener Str. 82 D-44789 Bochum

To our customers

Wittener Straße 82  
D-44789 Bochum

Phone.: ++49-234 33 51 80  
Fax:++49 234) 30 82 17  
<http://www.paulgothe.de>  
[service@paulgothe.de](mailto:service@paulgothe.de)  
VAT-No.: DE 813078723  
Trade Register Bochum: HRB-6891

Your ref

Your letter

Our ref

Date 14.03.2007

Calibration of the Johnas Impactor according to ISO 23210

#### 6.2 Separation curves and Section 6.3 Verification of the separation curves

The Johnas Impactor from Paul Gothe GmbH was developed before the ISO Guideline was evaluated and after the Germans and the Netherlands Authorities have enough experiences with our impactor. After that the European Delegation creates the ISO Guideline 23210. The section 6.3 is important and was influence by the Germans. They have the experiences and write the rules for the calibration section accordingly it was made for the Johnas-Impactor.

The development from the Johnas impactor starts with a doctoral thesis from Mrs. John at the Gerhard-Mercator-University. She makes the intensive testing and Mr. Geueke from the North Rhine Westphalia State Environment Agency makes additional verifications at the ESA (Emission Simulation Facility) at the Hessian Agency for the Environment and Geology (HLUG).

Most of the literatures and papers are in German, but all well-known:

1. Probenahme und chemische Analytik von Korngrößenfraktionierten Immissions- und Emissionsaerosolen. Von der Fakultät für Naturwissenschaften der Gerhard-Mercator-Universität – Gesamthochschule Duisburg zur Erlangung des akademischen Grades eines Dr. rer. nat. genehmigte Dissertation von ASTRID CHRISTIANE JOHN aus Lichtenfels.
2. Umweltforschungsplan des Bundesministers für Umwelt, Naturschutz und Reaktorsicherheit Luftreinhalte Forschungsbericht 298 44 280, Korngrößenverteilung (PM10 und PM2,5) von Staubemissionen relevanter stationärer Quellen (Teil II zu 297 44 853), von Dipl.-Ing. A. Dreiseidler, Ing. D. Straub, Prof. Dr.-Ing. G. Baumbach, Universität Stuttgart, Institut für Verfahrenstechnik und Dampfkesselwesen (IVD), Abteilung Reinhaltung der Luft (RdL), Institutsleiter: Prof. Dr.-Ing. K.R.G. Hein, IM AUFTRAG DES UMWELTBUNDESAMTES Juni 2001.
3. VDI 2066, part 10
4. Gefahrstoffe-Reinhaltung der Luft 59 (1999), Nr.11/12, S. 449-453

All this papers shows, that the design of the Johnas Impactor is a proved version for the determination of the PM 2.5 and PM 10. The shape of the separation curves is similar to those specified in ISO 7708:1995 and the separation efficiency at 10 µm and 2,5 µm is 50 % according to section 6.3 of the ISO 23210.

What you need more? There is no authority which has more competence as the listed authorities.

If you still in doubt, you maybe get in contact with Mr. Geueke (phone: ++49-201-7995-1263).

Paul Gothe GmbH

Westdeutsche Landesbank for Sparkasse Bochum  
IBAN DE 24 430500 01 000 120 9840 Swift: WELADED1BOC

Companion: Paul Gothe-Stiftung  
Management: Dr. T. Grodten and Th. Hinrichs





Paul Gothe GmbH Wittener Str. 82 D-44789 Bochum

To our customers

Wittener Straße 82  
D-44789 Bochum

Phone.: ++49-234 33 51 80  
Fax:++49 234) 30 82 17  
<http://www.paulgothe.de>  
[service@paulgothe.de](mailto:service@paulgothe.de)  
VAT-No.: DE 813078723  
Trade Register Bochum: HRB-6891

Your ref                                      Your letter                                      Our ref                                      Date 14.03.2007

**Declaration of conformity**


Herewith the company Paul Gothe GmbH in Bochum declare that the manufactured Cascade Impactor Johnas follows the guidelines from the North Rhine Westphalia State Environment Agency according the convention from 24 June 1999 and the PM 4 stage follows the convention of the Federal Environment Agency from 09. March 2005.

Our Cascade Impactor Johnas was developed in cooperation with the North Rhine Westphalia State Environment and the Gerhard-Mercator University Duisburg. This impactor was validated and after that 2004 adopted in the German Standard VDI 2066, part 10 and 2005 in ISO Standard 23210. All sizes of our manufactured impactors are according to these guidelines, individually checked according our strict quality management and named with a specific serial number. Only an impactor with this serial number is according to the Guideline VDI 2066, part 10 and ISO Standard 23210 and can use for the determination of PM 10 and PM 2.5.

Paul Gothe GmbH

A handwritten signature in blue ink, appearing to be 'T. Grodten', written over two horizontal lines.

Dr. Torsten Grodten  
-manager-





**END OF REPORT**

## Appendix 2 – Stack emissions monitoring report: Newlincs Development Ltd

# STACK EMISSIONS MONITORING REPORT



Unit 5 Crown Industrial Estate  
Kenwood Road  
Stockport  
SK5 6PH  
Tel: 0161 443 0980  
Fax: 0161 443 0989

Your contact at ESG
Mark Woodruff Business Manager - North Tel: 0161 443 0982 Email: mark.woodruff@esg.co.uk

Operator & Address:
Newlincs Development Limited South Marsh Road Stallingborough Grimsby North East Lincolnshire DN41 8BZ

Permit
N/A - Investigative Monitoring

Release Point:
A1 - Incinerator Stack

Sampling Date(s):
5th - 7th March 2014

ESG Job Number:	LNO 11737
Report Date:	18th Feb 2015
Version:	1
Report By:	Dominic Houghton
MCERTS Number:	MM 04 529
MCERTS Level:	MCERTS Level 2 - Team Leader
Technical Endorsements:	1, 2, 3 & 4
Report Approved By:	Andy Tiffen
MCERTS Number:	MM 05 640
Business Title:	MCERTS Level 2 - Projects Manager
Technical Endorsements:	1, 2 & 4
Signature:	



## CONTENTS

### EXECUTIVE SUMMARY

#### Stack Emissions Monitoring Objectives

- Plant
- Operator
- Stack Emissions Monitoring Test House

#### Emissions Summary

#### Monitoring Times

#### Process Details

#### Monitoring Methods

#### Analytical Methods

- Sampling Methods with Subsequent Analysis
- On-Site Testing

#### Sampling Location

- Sampling Plane Validation Criteria
- Duct Characteristics
- Sampling Lines & Sample Points
- Sampling Platform
- Sampling Location / Platform Improvement Recommendations

#### Sampling and Analytical Method Deviations

#### Determination of representative sampling location

### APPENDICES

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

APPENDIX 3 - Measurement Uncertainty Budget Calculations

## EXECUTIVE SUMMARY

### MONITORING OBJECTIVES

Newlincs Development Limited operates a waste incineration process at Stallingborough

Environmental Scientifics Group Limited were commissioned by Ricardo AEA to carry out stack emissions monitoring to determine the release of PM<sub>10</sub> & PM<sub>2.5</sub> from the following Plant under standard operating conditions.

The measurements were commissioned by Ricardo-AEA on behalf of the Department of Environment, Food and Rural Affairs (Defra) to provide information for the UK National Atmospheric Emissions Inventory (NAEI).

#### **Plant**

A1 - Incinerator Stack

#### **Operator**

Newlincs Development Limited  
South Marsh Road  
Stallingborough  
Grimsby  
North East Lincolnshire  
DN41 8BZ

#### **Stack Emissions Monitoring Test House**

Environmental Scientifics Group Limited - Stockport Laboratory  
Unit 5 Crown Industrial Estate  
Kenwood Road  
Stockport  
SK5 6PH  
UKAS and MCERTS Accreditation Number: 1015

Opinions and interpretations expressed herein are outside the scope of UKAS accreditation.

MCERTS accredited results will only be claimed where both the sampling and analytical stages are UKAS accredited.

This test report shall not be reproduced, except in full, without written approval of Environmental Scientifics Group Limited.

## EXECUTIVE SUMMARY

EMISSIONS SUMMARY					
Parameter	Units	Result	Calculated Uncertainty +/-	Limit	MCERTS accredited result
PM <sub>10</sub> (Average result of 6 runs)	mg/m <sup>3</sup>	0.021	0.04	-	✓
PM <sub>10</sub> Emission Rate (Average result of 6 runs)	g/hr	0.86	1.6	-	
PM <sub>2.5</sub> (Average result of 6 runs)	mg/m <sup>3</sup>	0.010	0.02	-	✓
PM <sub>2.5</sub> Emission Rate (Average result of 6 runs)	g/hr	0.43	0.82	-	
<b>PM<sub>10</sub> - Runs</b>					
PM <sub>10</sub> - Run 1	mg/m <sup>3</sup>	<b>0.019</b>	0.04	-	✓
PM <sub>10</sub> Emission Rate - Run 1	g/hr	0.82	1.6	-	
PM <sub>10</sub> - Run 2	mg/m <sup>3</sup>	0.022	0.04	-	✓
PM <sub>10</sub> Emission Rate - Run 2	g/hr	0.96	1.8	-	
PM <sub>10</sub> - Run 3	mg/m <sup>3</sup>	<b>0.018</b>	0.03	-	✓
PM <sub>10</sub> Emission Rate - Run 3	g/hr	0.78	1.5	-	
PM <sub>10</sub> - Run 4	mg/m <sup>3</sup>	0.020	0.04	-	✓
PM <sub>10</sub> Emission Rate - Run 4	g/hr	0.87	1.6	-	
PM <sub>10</sub> - Run 5	mg/m <sup>3</sup>	0.021	0.04	-	✓
PM <sub>10</sub> Emission Rate - Run 5	g/hr	0.78	1.5	-	
PM <sub>10</sub> - Run 6	mg/m <sup>3</sup>	0.023	0.04	-	✓
PM <sub>10</sub> Emission Rate - Run 6	g/hr	0.97	1.8	-	
<b>PM<sub>2.5</sub> - Runs</b>					
PM <sub>2.5</sub> - Run 1	mg/m <sup>3</sup>	<b>0.009</b>	0.02	-	✓
PM <sub>2.5</sub> Emission Rate - Run 1	g/hr	0.82	1.6	-	
PM <sub>2.5</sub> - Run 2	mg/m <sup>3</sup>	0.013	0.02	-	✓
PM <sub>2.5</sub> Emission Rate - Run 2	g/hr	0.56	1.1	-	
PM <sub>2.5</sub> - Run 3	mg/m <sup>3</sup>	<b>0.009</b>	0.02	-	✓
PM <sub>2.5</sub> Emission Rate - Run 3	g/hr	0.39	0.75	-	
PM <sub>2.5</sub> - Run 4	mg/m <sup>3</sup>	0.010	0.02	-	✓
PM <sub>2.5</sub> Emission Rate - Run 4	g/hr	0.43	0.83	-	
PM <sub>2.5</sub> - Run 5	mg/m <sup>3</sup>	0.011	0.02	-	✓
PM <sub>2.5</sub> Emission Rate - Run 5	g/hr	0.39	0.74	-	
PM <sub>2.5</sub> - Run 6	mg/m <sup>3</sup>	0.010	0.02	-	✓
PM <sub>2.5</sub> Emission Rate - Run 6	g/hr	0.41	0.78	-	
Oxygen	% v/v	12	0.46	-	✓
Moisture	%	13.3	1.4	-	✓
Stack Gas Temperature	°C	144	-	-	✓
Stack Gas Velocity	m/s	22.4	-	-	
Gas Volumetric Flow Rate (Actual)	m <sup>3</sup> /hr	76122	-	-	
Gas Volumetric Flow Rate (STP, Wet)	m <sup>3</sup> /hr	49758	-	-	
Gas Volumetric Flow Rate (STP, Dry)	m <sup>3</sup> /hr	42683	-	-	
Gas Volumetric Flow Rate at Reference Conditions	m <sup>3</sup> /hr	39134	-	-	

ND = None Detected,

Results at or below the limit of detection are highlighted by bold italic text.

The above volumetric flow rate is calculated using data from test specific flow data. Mass emissions for non isokinetic tests and isokinetic tests are calculated using these values

Reference conditions are 273K, 101.3kPa, dry gas 11% Oxygen.

## EXECUTIVE SUMMARY

MONITORING TIMES			
Parameter	Sampling Date(s)	Sampling Times	Sampling Duration
PM <sub>10</sub> Run 1	05 March 2014	15:06 - 18:06	180 minutes
PM <sub>10</sub> Run 2	06 March 2014	09:03 - 12:03	180 minutes
PM <sub>10</sub> Run 3	06 March 2014	12:35 - 15:35	180 minutes
PM <sub>10</sub> Run 4	06 March 2014	16:09 - 19:09	180 minutes
PM <sub>10</sub> Run 5	07 March 2014	08:49 - 11:49	180 minutes
PM <sub>10</sub> Run 6	07 March 2014	12:55 - 15:55	180 minutes
PM <sub>2.5</sub> Run 1	05 March 2014	15:06 - 18:06	180 minutes
PM <sub>2.5</sub> Run 2	06 March 2014	09:03 - 12:03	180 minutes
PM <sub>2.5</sub> Run 3	06 March 2014	12:35 - 15:35	180 minutes
PM <sub>2.5</sub> Run 4	06 March 2014	16:09 - 19:09	180 minutes
PM <sub>2.5</sub> Run 5	07 March 2014	08:49 - 11:49	180 minutes
PM <sub>2.5</sub> Run 6	07 March 2014	12:55 - 15:55	180 minutes
Stack Gas Flow Rate & Temperature Run 1	05 March 2014	11:00	-
Stack Gas Flow Rate & Temperature Run 2	05 March 2014	18:46	-
Stack Gas Flow Rate & Temperature Run 3	06 March 2014	08:20	-
Stack Gas Flow Rate & Temperature Run 4	06 March 2014	12:08	-
Stack Gas Flow Rate & Temperature Run 5	06 March 2014	15:35	-
Stack Gas Flow Rate & Temperature Run 6	06 March 2014	19:35	-
Stack Gas Flow Rate & Temperature Run 7	07 March 2014	08:25	-
Stack Gas Flow Rate & Temperature Run 8	07 March 2014	11:55	-
Stack Gas Flow Rate & Temperature Run 9	07 March 2014	12:40	-
Stack Gas Flow Rate & Temperature Run 10	07 March 2014	16:00	-

## EXECUTIVE SUMMARY

PROCESS DETAILS	
Parameter	Process Details
Description of process	Waste Incineration
Continuous or batch	Continuous
Product Details	Municipal Waste
Part of batch to be monitored (if applicable)	Stable conditions
Normal load, throughput or continuous rating	7.2 - 8 Tonnes/hour
Fuel used during monitoring	Waste
Abatement	Bag Filter with Lime, PAC and Urea injection
Plume Appearance	Not visible from the sample location during time of testing.



## EXECUTIVE SUMMARY

### Monitoring Methods

The selection of standard reference / alternative methods employed by Environmental Scientifics Group Limited is determined, wherever possible by the hierarchy of method selection outlined in Environment Agency Technical Guidance Note (Monitoring) M2. i.e. CEN, ISO, BS, US EPA etc.

MONITORING METHODS						
Species	Method Standard Reference Method / Alternative Method	ESG Technical Procedure	UKAS Lab Number	MCERTS Accredited Method	Limit of Detection (LOD)	Calculated MU +/- %
PM <sub>10</sub>	SRM - BS EN 23210	AE 136	1015	Yes	0.019 mg/m <sup>3</sup>	189 %
PM <sub>2.5</sub>	SRM - BS EN 23210	AE 136	1015	Yes	0.009 mg/m <sup>3</sup>	191 %
O <sub>2</sub>	SRM - BS EN 14789	AE 102	1015	Yes	0.01%	3.8%
H <sub>2</sub> O	AM - M22/FTIR	AE 063	1015	Yes	0.1 %	10.8%
Flow Rate / Temp.	SRM - BS EN 13284-1	AE 122	1015	Yes	5 Pa	-

The measurement uncertainties for the PM<sub>10</sub> and PM<sub>2.5</sub> measurements reflect that measured concentrations were near or below the Limit of Detection.

## EXECUTIVE SUMMARY

### Analytical Methods

The following tables list the analytical methods employed together with the custody and archiving details:

SAMPLING METHODS WITH SUBSEQUENT ANALYSIS							
Species	Analytical Technique	Analytical Procedure	UKAS Lab Number	UKAS Accredited Lab Analysis	Analysis Lab (ESG or Subcontract)	Sample Archive Location	Archive Period
PM <sub>10</sub>	Gravimetric	AE 106	1015	Yes	ESG Stockport	ESG Stockport	1 year
PM <sub>2.5</sub>	Gravimetric	AE 106	1015	Yes	ESG Stockport	ESG Stockport	1 year

ON-SITE TESTING							
Species	Analytical Technique	Analytical Procedure	UKAS Lab Number	MCERTS Accredited Analysis	Laboratory	Data Archive Location	Archive Period
O <sub>2</sub>	Paramagnetism	AE 102	1015	Yes	ESG Stockport	ESG Stockport	5 years
H <sub>2</sub> O	Fourier Transform - Infra Red	AE 063	1015	Yes	ESG Stockport	ESG Stockport	5 years

## EXECUTIVE SUMMARY

SAMPLING LOCATION					
Sampling Plane Validation Criteria	Value	Units	Requirement	Compliant	Method
Lowest Differential Pressure	255	Pa	>= 5 Pa	Yes	BS EN 13284-1
Lowest Gas Velocity	20.27	m/s	-	-	-
Highest Gas Velocity	24.63	m/s	-	-	-
Ratio of Gas Velocities	1.21	-	< 3 : 1	Yes	BS EN 13284-1
Mean Velocity	22.44	m/s	-	-	-
Maximum angle of flow with regard to duct axis	<15	°	< 15°	Yes	BS EN 13284-1
No local negative flow	Yes	-	-	Yes	BS EN 13284-1

DUCT CHARACTERISTICS		
	Value	Units
Shape	Circular	-
Depth	1.10	m
Width	-	m
Area	0.95	m <sup>2</sup>
Port Depth	490	mm

SAMPLING LINES & POINTS			
	Isokinetic (CEN Methods)	Isokinetic (ISO Methods)	Non-Iso & Gases
Sample port size	5 inch BSP	-	5 inch BSP
Number of lines used	1	-	1
Number of points / line	1	-	1
Duct orientation	Vertical	-	Vertical
Filtration	In Stack	-	In Stack

SAMPLING PLATFORM	
General Platform Information	
Permanent / Temporary Platform / Ground level / Floor Level / Roof Inside / Outside	Permanent Inside

M1 Platform requirements	
Is there a sufficient working area so work can be performed in a compliant manner	Yes
Platform has 2 levels of handrails (approximately 0.5 m & 1.0 m high)	Yes
Platform has vertical base boards (approximately 0.25 m high)	Yes
Platform has removable chains / self closing gates at the top of ladders	N/A
Handrail / obstructions do not hamper insertion of sampling equipment	Yes
Depth of Platform = >Stack depth / diameter + wall and port thickness + 1.5m	Yes

### Sampling Platform Improvement Recommendations (if applicable)

The sampling location meets all the requirements as specified in EA Guidance Note M1.

## EXECUTIVE SUMMARY

### Sampling & Analytical Method Deviations

#### **Goose-neck nozzle Validation**

Due to the long port sleeve, it was physically impossible to insert the cascade impactor using the straight entry nozzle setup recommended in BS EN 23210. Therefore the use of a goose-neck setup was used as this was the only feasible method for monitoring. The standard requires that the use of a goose-neck nozzle is validated, however on this occasion it has not been possible to demonstrate that losses in the nozzle meet the criteria in the standard because the measured concentrations were low and the weight of particulate recovered from the nozzle rinses and the filter media were at or near the weighing LoD. In the context of the low emission concentrations determined during the measurements (all less than 0.1 mg/Nm<sup>3</sup>), losses in the sampling nozzle are unlikely to increase the concentrations significantly.

#### **Sample flow variation**

The sample flowrate could not be maintained within 5% of the nominal flow throughout the testing periods (which were over extended periods due to the anticipated low PM emission concentrations). Whilst this will have affected the actual cutpoints achieved by the impactor, the results are all at or very near the LOD for the tests and hence this is anticipated to have limited impact on the outcome of the measurements.

### Determination of representative sampling location

An assessment of temperature homogeneity was performed in accordance with EN 23210 Annex-G on the first day of monitoring 5th March 2014. There was a feedstock change on the morning of the third day 7th March 2014 from municipal waste to Community Recycling Centre waste. A further homogeneity test was performed on 7th March and the representative sampling point was determined to be at the same location as on 5th March.

APPENDICES

**CONTENTS**

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

APPENDIX 3 - Measurement Uncertainty Budget Calculations

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

<b>MONITORING SCHEDULE</b>					
<b>Species</b>	<b>Method</b> Standard Reference Method / Alternative Method	<b>ESG</b> <b>Technical</b> <b>Procedure</b>	<b>UKAS Lab</b> <b>Number</b>	<b>MCERTS</b> <b>Accredited</b> <b>Method</b>	<b>Number of</b> <b>Samples</b>
PM <sub>10</sub>	SRM - BS EN 23210	AE 136	1015	Yes	6
PM <sub>2.5</sub>	SRM - BS EN 23210	AE 136	1015	Yes	6
O <sub>2</sub>	SRM - BS EN 14789	AE 102	1015	Yes	6
H <sub>2</sub> O	AM - M22/FTIR	AE 063	1015	Yes	6
Flow Rate / Temp.	SRM - BS EN 13284-1	AE 122	1015	Yes	10

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

CALIBRATEABLE EQUIPMENT CHECKLIST					
Extractive Sampling		Instrumental Analyser/s		Miscellaneous	
Equipment	Equipment I.D.	Equipment	Equipment I.D.	Equipment	Equipment I.D.
Control Box DGM	LNO 13-11	Horiba PG-250 Analyser	-	Laboratory Balance	LNO 00-12/00-13
Box Thermocouples	LNO 03-11	FT-IR	LNO 0750	Tape Measure	LNO 24-DJH
Meter In Thermocouple	LNO 03-11	FT-IR Oven Box	LNO 1207	Stopwatch	LNO 17-DJH
Meter Out Thermocouple	LNO 03-11	Bernath 3006 FID	-	Protractor	-
Control Box Timer	LNO 17-11	Signal 3030 FID	-	Barometer	LNO 08-DJH
Oven Box	-	Servomex	LNO 21-22	Digital Micromanometer	LNO 01-DJH
Probe	LNO 11-41	JCT Heated Head Filter	-	Digital Temperature Meter	LNO 03-DJH
Probe Thermocouple	LNO 10-41	Thermo FID	-	Stack Thermocouple	-
Probe	LNO 11-44	Stackmaster	-	Mass Flow Controller	-
Probe Thermocouple	LNO 10-44	FTIR Heater Box for Heated Line	-	MFC Display module	-
S-Pitot	LNO 06-DJH	Anemometer	-	1m Heated Line (1)	LNO 18-05
L-Pitot	-	Ecophysics NOx Analyser	-	1m Heated Line (2)	-
Site Balance	-	Chiller (JCT/MAK 10)	LNO 21-40	1m Heated Line (3)	-
Last Impinger Arm	-	Heated Line Controller (1)	-	5m Heated Line (1)	-
Dioxins Cond. Thermocouple	-	Heated Line Controller (2)	-	10m Heated Line (1)	-
Callipers	LNO 31-DJH	Site temperature Logger	-	10m Heated Line (2)	-
Small DGM	-	Impactor 1	NR 18706	15m Heated Line (1)	-
Heater Controller	-		-	20m Heated Line (1)	LNO 03-84
Inclinometer (Swirl Device)	LNO 23-DJH		-	20m Heated Line (2)	-

NOTE: If the equipment I.D is represented by a dash (-), then this piece of equipment has not been used for this test.

CALIBRATION / CHECK GASES					
Gas (traceable to ISO 17025)	Cylinder I.D Number	Supplier	ppm	%	Analytical Tolerance +/- %
Oxygen	HPC770	BOC	-	10.01	2
Methane	HPC763	BOC	101	-	2
Carbon Dioxide	HPC 751	BOC	-	8.8	2

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

**STACK EMISSIONS MONITORING TEAM**

Team Leader	Dominic Houghton MCERTS Level 2 Te1 Expiry Date - Dec 2016 Te2 Expiry Date - Dec 2016 Te3 Expiry Date - Mar 2018 Te4 Expiry Date - Dec 2016 MM 04 529 MCERTS Expiry Date - Dec 2016 H&S Expiry Date - Sep 2014
Technician	Ryan Murphy MCERTS Level 1 MM 07 826 MCERTS Expiry Date - Mar 2018 H&S Expiry Date - Apr 2017
Technician	Mark Derbyshire MCERTS Level 1 MM 07 824 MCERTS Expiry Date - Dec 2017 H&S Expiry Date - Apr 2017



APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

PM <sub>10</sub> SUMMARY					
Test	Sampling Times	Concentration mg/m <sup>3</sup>	LOD mg/m <sup>3</sup>	Limit mg/m <sup>3</sup>	Emission Rate g/hr
Run 1	15:06 - 18:06 05 March 2014	0.019	0.019	-	0.82
Run 2	09:03 - 12:03 06 March 2014	0.022	0.019	-	0.96
Run 3	12:35 - 15:35 06 March 2014	0.018	0.018	-	0.78
Run 4	16:09 - 19:09 06 March 2014	0.020	0.019	-	0.87
Run 5	08:49 - 11:49 07 March 2014	0.021	0.015	-	0.78
Run 6	12:55 - 15:55 07 March 2014	0.023	0.019	-	0.97
Blank 1	-	0.025	-	-	-
Blank 2	-	0.019	-	-	-
Blank 3	-	0.019	-	-	-

Reference conditions are 273K, 101.3kPa, dry gas 11% Oxygen.  
where values are below the LOD the LOD will be reported.

PM <sub>2.5</sub> SUMMARY					
Test	Sampling Times	Concentration mg/m <sup>3</sup>	LOD mg/m <sup>3</sup>	Limit mg/m <sup>3</sup>	Emission Rate g/hr
Run 1	15:06 - 18:06 05 March 2014	0.009	0.009	-	0.41
Run 2	09:03 - 12:03 06 March 2014	0.013	0.009	-	0.56
Run 3	12:35 - 15:35 06 March 2014	0.009	0.009	-	0.39
Run 4	16:09 - 19:09 06 March 2014	0.010	0.009	-	0.43
Run 5	08:49 - 11:49 07 March 2014	0.011	0.008	-	0.39
Run 6	12:55 - 15:55 07 March 2014	0.010	0.009	-	0.41
Blank 1	-	0.019	-	-	-
Blank 2	-	0.010	-	-	-
Blank 3	-	0.010	-	-	-

Reference conditions are 273K, 101.3kPa, dry gas 11% Oxygen.  
where values are below the LOD the LOD will be reported, where this occurs the quoted uncertainties will be relatively high.

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

PM <sub>2.5</sub> (BF) SAMPLES WEIGHTS				
Test	PM <sub>2.5</sub> Filter Number	Filter Start Weight g	Filter End Weight g	PM <sub>2.5</sub> Mass Gained on Filter g
Run 1	QC980	32.65638	32.65629	-0.00009
Run 2	QC981	31.79779	31.79786	0.00007
Run 3	QC993	31.83096	31.83075	-0.00021
Run 4	QC998	32.04127	32.04118	-0.00009
Run 5	QC999	32.70270	32.70245	-0.00025
Run 6	QC1000	32.91012	32.90998	-0.00014
Blank 1	QC982	32.68564	32.68574	0.00010
Blank 2	QC947	32.73502	32.73488	-0.00014
Blank 3	QC962	32.63680	32.63641	-0.00039

PM <sub>10</sub> (CP2) SAMPLES WEIGHTS				
Test	PM <sub>10</sub> Filter Number	Filter Start Weight g	Filter End Weight g	PM <sub>10</sub> Mass Gained on Filter g
Run 1	QC978	14.98713	14.98711	-0.00002
Run 2	QC979	15.69719	15.69716	-0.00003
Run 3	QC993	15.66026	15.66020	-0.00006
Run 4	QC994	16.11741	16.11722	-0.00019
Run 5	QC1001	15.56659	15.56647	-0.00012
Run 6	QC1002	15.27270	15.27277	0.00007
Blank 1	QC987	15.49893	15.49896	0.00003
Blank 2	QC908	15.95230	15.95219	-0.00011
Blank 3	QC945	16.05912	16.05901	-0.00011

PM <sub>2.5</sub> & PM <sub>10</sub> (BF & CP2) SAMPLES WEIGHTS COMBINED							
Test	PM <sub>2.5</sub> Filter Number	PM <sub>10</sub> Filter Number	PM <sub>2.5</sub> Mass Gained on Filter g	PM <sub>10</sub> Mass Gained on Filter g	Actual PM <sub>2.5</sub> & PM <sub>10</sub> Combined Total Mass Gained g	PM <sub>2.5</sub> & PM <sub>10</sub> Combined Weighing LOD g	*Reported PM <sub>2.5</sub> & PM <sub>10</sub> Combined Total Mass Gained g
Run 1	QC980	QC978	-0.00009	-0.00002	-0.00011	0.00010	0.00010
Run 2	QC981	QC979	0.00007	-0.00003	0.00004	0.00010	0.00012
Run 3	QC993	QC993	-0.00021	-0.00006	-0.00027	0.00010	0.00010
Run 4	QC998	QC994	-0.00009	-0.00019	-0.00028	0.00010	0.00010
Run 5	QC999	QC1001	-0.00025	-0.00012	-0.00037	0.00010	0.00010
Run 6	QC1000	QC1002	-0.00014	0.00007	-0.00007	0.00010	0.00012
Blank 1	QC982	QC987	0.00010	0.00003	0.00013	0.00010	0.00013
Blank 2	QC947	QC908	-0.00014	-0.00011	-0.00025	0.00010	0.00010
Blank 3	QC962	QC945	-0.00039	-0.00011	-0.00050	0.00010	0.00010

\* Where weighing values are below the LOD possibly due to loss of filter material, the LOD will be reported.

NOTE - Where the filter weight gain is less than the weighing uncertainty, the weighing uncertainty is used for further calculations. The weighing uncertainty is 0.00005g.

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS RUN 1			PM <sub>10</sub> & PM <sub>2.5</sub>	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	765.0	CO <sub>2</sub>	7.35
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	-1.7	O <sub>2</sub>	11.83
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	764.9	Total	19.18
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			N <sub>2</sub> (100 -Total)	80.82
Moisture trap weight increase, V <sub>lc</sub>	g	H <sub>2</sub> O by FTIR	M <sub>d</sub> = 0.44(%CO <sub>2</sub> ) + 0.32(%O <sub>2</sub> ) + 0.28(%N <sub>2</sub> )	29.65
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	<b>Molecular weight of wet gas, M<sub>s</sub></b>	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			M <sub>s</sub> = M <sub>d</sub> (1 - B <sub>wo</sub> ) + 18(B <sub>wo</sub> )	27.99
Volume of gas sample through gas meter, V <sub>m</sub>		5.91	<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Gas meter correction factor, Y <sub>d</sub>		1.05	Area of stack, A <sub>s</sub>	m <sup>2</sup> 0.95
Mean dry gas meter temperature, T <sub>m</sub>		23.80	Q <sub>a</sub> = (60)(A <sub>s</sub> )(V <sub>s</sub> )	m <sup>3</sup> /min 1418.6
Mean pressure drop across orifice, ΔH	mmH <sub>2</sub> O	129.19	<b>Percent isokinetic, %I</b>	
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		5.842	Required Flow Rate @ DGM	l/min 32.80
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Actual Flow Rate @ DGM	l/min 35.3
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	6.8102	Isokinetic Rate	107.69
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			Acceptable 90% - 130%	Yes
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	<b>Particulate Concentration, C<sub>PM10</sub></b>	
% oxygen measured in gas stream, act%O <sub>2</sub>		11.83	Mass of particulate collected on PM <sub>10</sub> filter, M <sub>f</sub>	0.00005
% oxygen reference condition		11	Mass of particulate collected on PM <sub>2.5</sub> filter, M <sub>f</sub>	0.00005
O <sub>2</sub> Reference	O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>	0.92	$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.01468
Factor	$\frac{21.0 - ref\%O_2}{21.0 - act\%O_2}$		$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.01712
$V_{mstd@X\%oxygen} = (V_{mstd})(O_2 Ref)$	m <sup>3</sup>	5.357	$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.01867
<b>Moisture content, B<sub>wo</sub></b>			<b>Particulate Emission Rates, E</b>	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	14.22	E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	0.82
<b>Moisture by FTIR</b>	%	14.22	<b>Particulate Concentration, C<sub>PM2.5</sub></b>	
<b>Velocity of stack gas, V<sub>s</sub></b>			Mass of particulate collected on filter, M <sub>f</sub>	0.00005
Pitot tube velocity constant, K <sub>p</sub>		34.97	$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.0073
Velocity pressure coefficient, C <sub>p</sub>		0.84	$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.0086
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	36.70	$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0093
Mean square root of velocity heads, √ΔP		6.1	<b>Particulate Emission Rates, E</b>	
Mean stack gas temperature, T <sub>s</sub>	°C	145	E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	0.41
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	24.88		

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS RUN 2			PM <sub>10</sub> & PM <sub>2.5</sub>	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	765.0	CO <sub>2</sub>	7.52
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	-1.7	O <sub>2</sub>	11.76
$P_s = P_b + (P_{static})$	mm Hg	764.9	Total	19.28
$\frac{13.6}{13.6}$			N <sub>2</sub> (100 -Total)	80.72
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2)$	
Moisture trap weight increase, V <sub>lc</sub>	g	H <sub>2</sub> O by FTIR	<b>Molecular weight of wet gas, M<sub>s</sub></b>	
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	$M_s = M_d(1 - B_{wo}) + 18(B_{wo})$	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Volume of gas sample through gas meter, V <sub>m</sub>		5.96	Area of stack, A <sub>s</sub>	m <sup>2</sup> 0.95
Gas meter correction factor, Y <sub>d</sub>		1.05	$Q_a = (60)(A_s)(V_s)$	m <sup>3</sup> /min 1399.1
Mean dry gas meter temperature, T <sub>m</sub>		24.01	<b>Percent isokinetic, %I</b>	
Mean pressure drop across orifice, ΔH	mmH <sub>2</sub> O	129.46	Required Flow Rate @ DGM	l/min 32.90
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		5.879	Actual Flow Rate @ DGM	l/min 36.0
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Isokinetic Rate	
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	6.9038	Acceptable 90% - 130%	
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			<b>Particulate Concentration, C<sub>PM10</sub></b>	
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	Mass of particulate collected on PM <sub>10</sub> filter, M <sub>f</sub>	0.00005
% oxygen measured in gas stream, act%O <sub>2</sub>		11.76	Mass of particulate collected on PM <sub>2.5</sub> filter, M <sub>f</sub>	0.00007
% oxygen reference condition		11	$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.0174
O <sub>2</sub> Reference O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>		0.92	$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.0204
Factor 21.0 - ref%O <sub>2</sub>			$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0221
$V_{mstd@X\%oxygen} = (V_{mstd})(O_2 Ref)$	m <sup>3</sup>	5.432	<b>Particulate Emission Rates, E</b>	
<b>Moisture content, B<sub>wo</sub></b>			$E = [(C_{wet})(Q_{stw})(60)] / 1000$	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	14.84	0.96	
<b>Moisture by FTIR</b>			<b>Particulate Concentration, C<sub>PM2.5</sub></b>	
	%	14.84	Mass of particulate collected on filter, M <sub>f</sub>	
<b>Velocity of stack gas, V<sub>s</sub></b>			$C_{wet} = \frac{M_n}{V_{mstw}}$	
Pitot tube velocity constant, K <sub>p</sub>		34.97	mg/m <sup>3</sup> 0.0101	
Velocity pressure coefficient, C <sub>p</sub>		0.84	$C_{dry} = \frac{M_n}{V_{mstd}}$	
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	35.70	mg/m <sup>3</sup> 0.0119	
Mean square root of velocity heads, √ΔP		5.98	$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	
Mean stack gas temperature, T <sub>s</sub>	°C	145	mg/m <sup>3</sup> 0.0129	
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	24.53	<b>Particulate Emission Rates, E</b>	
			$E = [(C_{wet})(Q_{stw})(60)] / 1000$	
			0.56	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS RUN 3			PM <sub>10</sub> & PM <sub>2.5</sub>	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	757.5	CO <sub>2</sub>	7.53
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	-1.7	O <sub>2</sub>	11.66
$P_s = P_b + (P_{static})$	mm Hg	757.4	Total	19.19
$\frac{13.6}{13.6}$			N <sub>2</sub> (100 -Total)	80.81
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2)$	
Moisture trap weight increase, V <sub>lc</sub>	g	H <sub>2</sub> O by FTIR	<b>Molecular weight of wet gas, M<sub>s</sub></b>	
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	$M_s = M_d(1 - B_{wo}) + 18(B_{wo})$	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Volume of gas sample through gas meter, V <sub>m</sub>		6.02	Area of stack, A <sub>s</sub>	m <sup>2</sup> 0.95
Gas meter correction factor, Y <sub>d</sub>		1.05	$Q_a = (60)(A_s)(V_s)$	m <sup>3</sup> /min 1355.6
Mean dry gas meter temperature, T <sub>m</sub>		28.12	<b>Percent isokinetic, %I</b>	
Mean pressure drop across orifice, ΔH	mmH <sub>2</sub> O	121.49	Required Flow Rate @ DGM	l/min 31.60
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		5.800	Actual Flow Rate @ DGM	l/min 33.4
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Isokinetic Rate	
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	6.7702	Acceptable 90% - 130%	
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			<b>Particulate Concentration, C<sub>PM10</sub></b>	
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	Mass of particulate collected on PM <sub>10</sub> filter, M <sub>f</sub>	0.00005
% oxygen measured in gas stream, act%O <sub>2</sub>		11.66	Mass of particulate collected on PM <sub>2.5</sub> filter, M <sub>f</sub>	0.00005
% oxygen reference condition		11	$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.0148
O <sub>2</sub> Reference Factor	O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>	0.93	$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.0172
$V_{mstd@X\%oxygen} = (V_{mstd}) (O_2 Ref)$	21.0 - ref%O <sub>2</sub>		$C_{dry@X\%O2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0185
		5.417	<b>Particulate Emission Rates, E</b>	
<b>Moisture content, B<sub>wo</sub></b>			$E = [(C_{wet})(Q_{stw})(60)] / 1000$	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	0.1433	0.78	
		14.33	<b>Particulate Concentration, C<sub>PM2.5</sub></b>	
<b>Moisture by FTIR</b>			Mass of particulate collected on filter, M <sub>f</sub>	
	%	14.33	$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.0074
<b>Velocity of stack gas, V<sub>s</sub></b>			$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.0086
Pitot tube velocity constant, K <sub>p</sub>		34.97	$C_{dry@X\%O2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0092
Velocity pressure coefficient, C <sub>p</sub>		0.84	<b>Particulate Emission Rates, E</b>	
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	33.19	$E = [(C_{wet})(Q_{stw})(60)] / 1000$	
Mean square root of velocity heads, √ΔP		5.76	0.39	
Mean stack gas temperature, T <sub>s</sub>	°C	145		
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	23.77		

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS RUN 4			PM <sub>10</sub> & PM <sub>2.5</sub>	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	757.5	CO <sub>2</sub>	7.44
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	-1.7	O <sub>2</sub>	11.65
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	757.4	Total	19.09
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2)$	
Moisture trap weight increase, V <sub>lc</sub>	g	H <sub>2</sub> O by FTIR	N <sub>2</sub> (100 - Total)	80.91
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	<b>Molecular weight of wet gas, M<sub>s</sub></b>	29.66
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			$M_s = M_d(1 - B_{wo}) + 18(B_{wo})$	
Volume of gas sample through gas meter, V <sub>m</sub>		5.55	<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Gas meter correction factor, Y <sub>d</sub>		1.05	Area of stack, A <sub>s</sub>	m <sup>2</sup> 0.95
Mean dry gas meter temperature, T <sub>m</sub>		25.54	$Q_a = (60)(A_s)(V_s)$	m <sup>3</sup> /min 1397.2
Mean pressure drop across orifice, ΔH	mmH <sub>2</sub> O	111.62	<b>Percent isokinetic, %I</b>	
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		5.388	Required Flow Rate @ DGM	l/min 31.70
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Actual Flow Rate @ DGM	
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	6.2874	Isokinetic Rate	l/min 30.8
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			Acceptable 90% - 130%	
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	Yes	
% oxygen measured in gas stream, act%O <sub>2</sub>		11.65	<b>Particulate Concentration, C<sub>PM10</sub></b>	
% oxygen reference condition		11	Mass of particulate collected on PM <sub>10</sub> filter, M <sub>f</sub>	
O <sub>2</sub> Reference O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>		0.94	0.00005	
Factor 21.0 - ref%O <sub>2</sub>		5.038	Mass of particulate collected on PM <sub>2.5</sub> filter, M <sub>f</sub>	
$V_{mstd@X\%oxygen} = (V_{mstd})(O_2 \text{ Ref})$	m <sup>3</sup>		0.00005	
<b>Moisture content, B<sub>wo</sub></b>			$C_{wet} = \frac{M_n}{V_{mstw}}$	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	0.1430	mg/m <sup>3</sup> 0.0159	
<b>Moisture by FTIR</b>			$C_{dry} = \frac{M_n}{V_{mstd}}$	
			mg/m <sup>3</sup> 0.0186	
<b>Velocity of stack gas, V<sub>s</sub></b>			$C_{dry@X\%O2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	
Pitot tube velocity constant, K <sub>p</sub>		34.97	mg/m <sup>3</sup> 0.0198	
Velocity pressure coefficient, C <sub>p</sub>		0.84	<b>Particulate Emission Rates, E</b>	
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	35.24	$E = [(C_{wet})(Q_{stw})(60)] / 1000$	
Mean square root of velocity heads, √ΔP		5.94	0.87	
Mean stack gas temperature, T <sub>s</sub>	°C	145	<b>Particulate Concentration, C<sub>PM2.5</sub></b>	
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	24.50	Mass of particulate collected on filter, M <sub>f</sub>	
			0.00005	
			$C_{wet} = \frac{M_n}{V_{mstw}}$	
			mg/m <sup>3</sup> 0.0080	
			$C_{dry} = \frac{M_n}{V_{mstd}}$	
			mg/m <sup>3</sup> 0.0093	
			$C_{dry@X\%O2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	
			mg/m <sup>3</sup> 0.0099	
			<b>Particulate Emission Rates, E</b>	
			$E = [(C_{wet})(Q_{stw})(60)] / 1000$	
			0.43	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS RUN 5			PM <sub>10</sub> & PM <sub>2.5</sub>	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	765.0	CO <sub>2</sub>	7.01
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	-1.7	O <sub>2</sub>	13.02
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	764.9	Total	20.03
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			N <sub>2</sub> (100 -Total)	
Moisture trap weight increase, V <sub>lc</sub>	g	H <sub>2</sub> O by FTIR	M <sub>d</sub> = 0.44(%CO <sub>2</sub> )+0.32(%O <sub>2</sub> )+0.28(%N <sub>2</sub> )	
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	<b>Molecular weight of wet gas, M<sub>s</sub></b>	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			M <sub>s</sub> = M <sub>d</sub> (1 - B <sub>wo</sub> ) + 18(B <sub>wo</sub> )	
Volume of gas sample through gas meter, V <sub>m</sub>		6.05	28.65	
Gas meter correction factor, Y <sub>d</sub>		1.05	<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Mean dry gas meter temperature, T <sub>m</sub>		26.04	Area of stack, A <sub>s</sub>	m <sup>2</sup> 0.95
Mean pressure drop across orifice, ΔH	mmH <sub>2</sub> O	122.68	Q <sub>a</sub> = (60)(A <sub>s</sub> )(V <sub>s</sub> )	m <sup>3</sup> /min 1277.3
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		5.932	<b>Percent isokinetic, %I</b>	
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Required Flow Rate @ DGM	
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	6.4826	Actual Flow Rate @ DGM	l/min 33.6
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			Isokinetic Rate	
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	Acceptable 90% - 130%	
% oxygen measured in gas stream, act%O <sub>2</sub>		13.02	<b>Particulate Concentration, C<sub>PM10</sub></b>	
% oxygen reference condition		11	Mass of particulate collected on PM <sub>10</sub> filter, M <sub>f</sub>	
O <sub>2</sub> Reference O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>		0.80	0.00005	
Factor			Mass of particulate collected on PM <sub>2.5</sub> filter, M <sub>f</sub>	
$V_{mstd@X\%oxygen} = (V_{mstd}) (O_2 Ref)$	m <sup>3</sup>	4.733	0.00005	
<b>Moisture content, B<sub>wo</sub></b>			C <sub>wet</sub> = $\frac{M_n}{V_{mstw}}$ mg/m <sup>3</sup> 0.0154	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	0.0850	C <sub>dry</sub> = $\frac{M_n}{V_{mstd}}$ mg/m <sup>3</sup> 0.0169	
		8.50	C <sub>dry@X%O2</sub> = $\frac{M_n}{V_{mstd@X\%oxygen}}$ mg/m <sup>3</sup> 0.0211	
<b>Moisture by FTIR</b>			<b>Particulate Emission Rates, E</b>	
<b>Velocity of stack gas, V<sub>s</sub></b>			E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	
Pitot tube velocity constant, K <sub>p</sub>		34.97	0.78	
Velocity pressure coefficient, C <sub>p</sub>		0.84	<b>Particulate Concentration, C<sub>PM2.5</sub></b>	
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	30.57	Mass of particulate collected on filter, M <sub>f</sub>	
Mean square root of velocity heads, √ΔP		5.53	0.00005	
Mean stack gas temperature, T <sub>s</sub>	°C	144	C <sub>wet</sub> = $\frac{M_n}{V_{mstw}}$ mg/m <sup>3</sup> 0.0077	
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	22.40	C <sub>dry</sub> = $\frac{M_n}{V_{mstd}}$ mg/m <sup>3</sup> 0.0084	
			C <sub>dry@X%O2</sub> = $\frac{M_n}{V_{mstd@X\%oxygen}}$ mg/m <sup>3</sup> 0.0106	
			<b>Particulate Emission Rates, E</b>	
			E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	
			0.39	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS RUN 6			PM <sub>10</sub> & PM <sub>2.5</sub>	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	750.0	CO <sub>2</sub>	7.27
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	-2.1	O <sub>2</sub>	11.80
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	749.9	Total	19.07
			N <sub>2</sub> (100 - Total)	80.93
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2)$	
Moisture trap weight increase, V <sub>lc</sub>	g	H <sub>2</sub> O by FTIR	<b>Molecular weight of wet gas, M<sub>s</sub></b>	
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	$M_s = M_d(1 - B_{wo}) + 18(B_{wo})$	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Volume of gas sample through gas meter, V <sub>m</sub>		5.72	Area of stack, A <sub>s</sub>	m <sup>2</sup> 0.95
Gas meter correction factor, Y <sub>d</sub>		1.05	$Q_a = (60)(A_s)(V_s)$	m <sup>3</sup> /min 1352.0
Mean dry gas meter temperature, T <sub>m</sub>		22.45	<b>Percent isokinetic, %I</b>	
Mean pressure drop across orifice, ΔH	mmH <sub>2</sub> O	120.95	Required Flow Rate @ DGM	l/min 32.70
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		5.561	Actual Flow Rate @ DGM	l/min 31.8
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Isokinetic Rate	
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	6.4359	Acceptable 90% - 130%	
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			<b>Particulate Concentration, C<sub>PM10</sub></b>	
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	Mass of particulate collected on PM <sub>10</sub> filter, M <sub>f</sub>	0.00007
% oxygen measured in gas stream, act%O <sub>2</sub>		11.80	Mass of particulate collected on PM <sub>2.5</sub> filter, M <sub>f</sub>	0.00005
% oxygen reference condition		11	$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.0186
O <sub>2</sub> Reference O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>		0.92	$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.0216
Factor		21.0 - ref%O <sub>2</sub>	$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0235
$V_{mstd@X\%oxygen} = (V_{mstd})(O_2 Ref)$	m <sup>3</sup>	5.116	<b>Particulate Emission Rates, E</b>	
<b>Moisture content, B<sub>wo</sub></b>			$E = [(C_{wet})(Q_{stw})(60)] / 1000$	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	0.1360	0.97	
<b>Moisture by FTIR</b>			<b>Particulate Concentration, C<sub>PM2.5</sub></b>	
	%	13.60	Mass of particulate collected on filter, M <sub>f</sub>	
<b>Velocity of stack gas, V<sub>s</sub></b>			$C_{wet} = \frac{M_n}{V_{mstw}}$	
Pitot tube velocity constant, K <sub>p</sub>		34.97	mg/m <sup>3</sup> 0.0078	
Velocity pressure coefficient, C <sub>p</sub>		0.84	$C_{dry} = \frac{M_n}{V_{mstd}}$	
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	32.76	mg/m <sup>3</sup> 0.0090	
Mean square root of velocity heads, √ΔP		5.72	$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	
Mean stack gas temperature, T <sub>s</sub>	°C	145	mg/m <sup>3</sup> 0.0098	
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	23.71	<b>Particulate Emission Rates, E</b>	
			$E = [(C_{wet})(Q_{stw})(60)] / 1000$	
			0.41	



APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PM<sub>10</sub> & PM<sub>2.5</sub> QUALITY ASSURANCE CHECKLIST**

LEAK RATE						
Run	Mean Sampling Rate litre/min	Pre-sampling Leak Rate litre/min	Post-sampling Leak Rate litre/min	Maximum Vacuum mm Hg	Acceptable Leak Rate litre/min	Leak Tests Acceptable?
Run 1	35.32	0.10	0.14	-305	0.71	Yes
Run 2	36.00	0.16	0.24	-457	0.72	Yes
Run 3	33.44	0.12	0.22	-508	0.67	Yes
Run 4	30.83	0.14	0.13	-508	0.62	Yes
Run 5	33.63	0.12	0.18	-508	0.67	Yes
Run 6	31.77	0.18	0.18	-559	0.64	Yes

ISOKINETICITY		
Run	Flow Variation %	Acceptable Variation
Run 1	107.7	Yes
Run 2	109.4	Yes
Run 3	105.8	Yes
Run 4	97.2	Yes
Run 5	101.0	Yes
Run 6	97.1	Yes

Acceptable Flow rate 90 -130%

FILTERS					
Run	Filter Material	Filter Size mm	Max Filtration Temperature °C	Pre-conditioning Filter Temperature °C	Post conditioning Filtration Temperature °C
Run 1	QF	50	149	180	160
Run 2	QF	50	147	180	160
Run 3	QF	50	147	180	160
Run 4	QF	50	146	180	160
Run 5	QF	50	147	180	160
Run 6	QF	50	148	180	160

QF = Quartz Fibre

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**Conformity with relevant aspects of BS EN ISO 23210:2009**

**GENERAL METHODOLOGY**

The equipment employed is a Paul Gothe, Johnas cascade impactor (see pg 13 for serial number) system meeting the requirements of BS EN ISO 23210. The standard cites a two-stage impactor system.

The method for sampling requires the extraction of a representative sample of duct gas isokinetically, into a specially designed in-stack sampling head. The Cascade Impactor is a multi-stage, multi-jet impactor which aerodynamically classifies particulates into multiple size ranges. The cascade impactor uses the principle of inertial separation to size segregate particulate samples from the gas stream. The impactor has two stages for particle size determination. Each stage gives a cut-point based on aerodynamic diameter of the particle.

During sampling, the particles are driven (jetted) toward a collecting surface where they may cling. By changing the velocity (orifice size of the jet), the size of the particles collected is controlled. The size of the jets within each stage is constant, but for each succeeding stage the jets get smaller. Impaction occurs when the particle's inertia overcomes the aerodynamic drag. Otherwise, the particle remains in the air stream and proceeds to the next stage. To keep the cut-point for each stage constant, the impactor is operated at a constant flow rate.

At each stage, the particle impacts on to a conditioned and pre-weighed substrate. Following sampling, the substrates are reconditioned and reweighed to determine the mass collected.

Based on the sampling conditions (sampling rate and gas temperature) the cut size (D50 – diameter of particles having a 50% probability of penetration) associated with each impactor stage may be determined.

An homogeneity assessment based on BS EN ISO 23210, Annex G, is undertaken to determine the most representative sampling point in the sampling plane (temperature, velocity and oxygen are suitable surrogates for particulate matter). The velocity measurement at the chosen point is used to determine an appropriate sampling nozzle/flow rate in order to ensure that isokinetic conditions are maintained throughout sampling to within the 90-130% range allowed in the standard (8.1) and which is consistent with the sampling equipment.

Concurrently, the volume of duct gas sampled is measured. This then enables the particulate concentration at each cut size to be determined.

The outlet gas from the sampling head is passed via a sampling probe through an impinger train with the purpose of removing water prior to entry to the sampling control box. It is not intended that the sampling train be used for additional sampling of condensable determinands and as such the train is unheated.

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**Conformity with relevant aspects of BS EN ISO 23210:2009**

Sampling Plane Validation Criteria				
EA Technical Guidance Note (Monitoring) M1	Result	Units	Requirement	Compliant
Lowest Differential Pressure	255	Pa	>= 5 Pa	Yes
Lowest Gas Velocity	20.27	m/s	-	-
Highest Gas Velocity	24.63	m/s	-	-
Ratio of Gas Velocities	1.21	-	< 3 : 1	Yes
Maximum angle of flow with regard to duct axis	<15	°	< 15°	Yes
No local negative flow	Yes	-	-	Yes
Conformance with BS EN ISO 23210:2009				
Reference	Requirement	Result	Requirement	Compliant
Section 6.3	Suitable Impactor Used	See statement of conformity for Impactor		Yes
Section 8.1	Sampling position acceptable (as per 13284-1)	As per table "Sampling Plane Validation"		Yes
Section 8.1	Nozzle arrangement	See statement of conformity for Impactor		Yes
Section 8.1	Representative sampling point	See Homogeneity assessment below		Yes
Section 8.1	Constant Sample gas flow, iso-kinetic rate 90% to 130%			
	Run 1 - Required flow 32.8 (LPM)			-
	Run 1 - Minimum permissible flow 29.52 (LPM)	29.79		Yes
	Run 1 - Maximum permissible flow 42.64 (LPM)	41.49		Yes
	Run 2 - Required flow 32.9 (LPM)			-
	Run 2 - Minimum permissible flow 29.61 (LPM)	30.16		Yes
	Run 2 - Maximum permissible flow 42.77 (LPM)	40.49		Yes
	Run 3 - Required flow 31.6 (LPM)			-
	Run 3 - Minimum permissible flow 28.44 (LPM)	31.40		Yes
	Run 3 - Maximum permissible flow 41.08 (LPM)	35.36		Yes
	Run 4 - Required flow 31.7 (LPM)			-
	Run 4 - Minimum permissible flow 28.53 (LPM)	28.60		Yes
	Run 4 - Maximum permissible flow 41.21 (LPM)	33.80		Yes
	Run 5 - Required flow 33.3 (LPM)			-
	Run 5 - Minimum permissible flow 29.97 (LPM)	30.20		Yes
	Run 5 - Maximum permissible flow 43.29 (LPM)	37.60		Yes
	Run 6 - Required flow 32.7 (LPM)			-
	Run 6 - Minimum permissible flow 29.43 (LPM)	29.80		Yes
	Run 6 - Maximum permissible flow 42.51 (LPM)	33.00		Yes
Section 8.1	Overall blank taken once per day	Yes		Yes
Section 8.2	Impactor cleaned between each measurement	Yes		Yes
Section 8.2	Arrangement of impactor plates	See statement of conformity for Impactor		Yes
Section 8.3.2	Data taken for velocity, composition, temp & pressure	See "Preliminary stack survey" section		Yes
Section 8.3.3	Sampling rate determination in accordance with Annex A	Yes		Yes
Section 8.3.3	Sample flow rate kept +/- 5% of nominal flow rate			
	Run 1 - Max sample flow deviation from nominal (%)	7.1		No
	Run 2 - Max sample flow deviation from nominal (%)	7.5		No
	Run 3 - Max sample flow deviation from nominal (%)	6.5		No
	Run 4 - Max sample flow deviation from nominal (%)	7.0		No
	Run 5 - Max sample flow deviation from nominal (%)	11.7		No
	Run 6 - Max sample flow deviation from nominal (%)	9.1		No
Section 8.3.4	Nozzle selected to allow iso-kinetic rate 90% to 130%	Yes, as above		Yes
Section 8.3.5	Leak check less than 2%			
	Run 1	0.28		Yes
	Run 2	0.44		Yes
	Run 3	0.36		Yes
	Run 4	0.45		Yes
	Run 5	0.36		Yes
	Run 6	0.57		Yes
Section 8.3.6	Impactor at flue gas temperature before sampling	Yes		Yes
Section 8.3.6	Angle of nozzle less than 10 Degrees to flow	Yes		Yes
Section 8.3.6	Flowrate has checked and recorded every 5 mins	Yes		Yes
Section 8.3.6	Dynamic pressure recorded every 5 mins	Yes		Yes

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**Homogeneity assessment**

Assessment 1, Municipal waste

Point number (i)	Distance along sample line (mm)	Probe Marking (mm)	Temp Deg C grid	Temp Deg C fixed	$r_i$
1	28.2	518.2	143	145	0.986
2	89.8	579.8	142	145	0.979
3	161.1	651.1	143	146	0.979
4	248.8	738.8	144	144	1.000
5	376.1	866.1	144	145	0.993
6	723.9	1213.9	144	145	0.993
7	851.2	1341.2	144	146	0.986
8	938.9	1428.9	144	146	0.986
9	1010.2	1500.2	145	146	0.993
10	1071.8	1561.8	146	146	1.000
<b>Second Line</b>					
1	28.2	518.2	145	146	0.993
2	89.8	579.8	144	145	0.993
3	161.1	651.1	145	145	1.000
4	248.8	738.8	145	145	1.000
5	376.1	866.1	145	145	1.000
6	723.9	1213.9	145	145	1.000
7	851.2	1341.2	145	145	1.000
8	938.9	1428.9	145	146	0.993
9	1010.2	1500.2	145	145	1.000
10	1071.8	1561.8	145	145	1.000

<b>No. of points</b>	20
$S_{grid}$	0.94
$S_{ref}$	0.571
$f$	0.99
Is $S_{grid} \leq S_{ref}$ ?	No
<b>F Factor</b>	2.71
$F_{N-1; N-1; 0.95}$	2.17
Is F Factor $< F_{N-1; N-1; 0.95}$ ?	No
$S_{pos}$	0.747
$t_{N-1; 0.95}$	2.093
$U_{pos}$	1.563
<b>Permissible Uncertainty</b>	10
Is $U_{pos} < 0.5 * U_{perm}$ ?	Yes

Sample can be taken from a representative location

The best location for SRM probe is Line A, 1010.2 mm along sample line

Assessment 2, CRC waste

Point number (i)	Distance along sample line (mm)	Probe Marking (mm)	Temp Deg C grid	Temp Deg C fixed	$r_i$		
1	28.2	518.2	144	144	1.000	No. of points	20
2	89.8	579.8	144	144	1.000	$S_{grid}$	0.66
3	161.1	651.1	145	144	1.007	$S_{ref}$	0.503
4	248.8	738.8	144	144	1.000	$F$	1.00
5	376.1	866.1	143	144	0.993	Is $S_{grid} \leq S_{ref}$ ?	No
6	723.9	1213.9	143	144	0.993		
7	851.2	1341.2	143	143	1.000	F Factor	1.708
8	938.9	1428.9	143	143	1.000	$F_{N-1; N-1; 0.95}$	2.17
9	1010.2	1500.2	143	143	1.000	Is F Factor < $F_{N-1; N-1; 0.95}$ ?	Yes
10	1071.8	1561.8	143	143	1.000		
<b>Second Line</b>						$S_{pos}$	0.423
1	28.2	518.2	143	143	1.000	$t_{N-1; 0.95}$	2.093
2	89.8	579.8	143	143	1.000	$U_{pos}$	0.885
3	161.1	651.1	144	143	1.007	Permissible Uncertainty	10
4	248.8	738.8	144	143	1.007	Is $U_{pos} < 0.5 * U_{perm}$ ?	N/A
5	376.1	866.1	144	144	1.000		
6	723.9	1213.9	145	144	1.007		
7	851.2	1341.2	144	144	1.000		
8	938.9	1428.9	144	144	1.000		
9	1010.2	1500.2	144	144	1.000		
10	1071.8	1561.8	144	144	1.000		

Sample can be taken from any location

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**DAILY OXYGEN SUMMARY**

Run	Sampling Times	Concentration %	LOD %
1	15:06 - 18:06 05 March 2014	11.83	0.01
2	09:03 - 12:03 06 March 2014	11.76	0.01
3	12:35 - 15:35 06 March 2014	11.66	0.01
4	16:09 - 19:09 06 March 2014	11.65	0.01
5	08:49 - 11:49 07 March 2014	13.02	0.01
6	12:55 - 15:55 07 March 2014	11.80	0.01

PRE SAMPLING CALIBRATION DATA								
Date	Time of Analyser	Range (%)	Zero Reading at analyser	Span Reading at analyser	Zero Check at analyser	Zero Check down line	Span Check down line	Leak Rate %
05 March 2014	10:00 - 10:30	25	0.00	10.01	0.00	0.03	10.02	0.10
06 March 2014	08:30 - 08:50	25	0.00	10.01	0.00	-0.02	10.03	0.20
07 March 2014	08:05 - 08:30	25	0.00	10.01	0.00	0.00	10.03	0.20

POST SAMPLING CALIBRATION DATA					
Date	Time of Analyser	Zero Check down line	Span Check down line	Zero Drift (%)	Span Drift (%)
06 March 2014	08:00 - 08:30	0.05	10.06	0.08	0.20
06 March 2014	19:15 - 19:30	0.06	10.1	0.32	-0.10
07 March 2014	16:05 - 16:15	-0.12	9.9	-0.48	-0.10

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**COMBUSTION GAS SUMMARY**

Test	Sampling Times	Concentration %	Analysis Areas	Interference (%) *	LOD %
Moisture Run 1	15:06 - 18:06 05 March 2014	14.2	3200 - 3401	1.7	0.10
Moisture Run 2	09:03 - 12:03 06 March 2014	14.8	3200 - 3401	0.97	0.10
Moisture Run 3	12:35 - 15:35 06 March 2014	14.3	3200 - 3401	0.97	0.10
Moisture Run 4	16:09 - 19:09 06 March 2014	14.3	3200 - 3401	0.97	0.10
Moisture Run 5	08:49 - 11:49 07 March 2014	8.5	3200 - 3401	1.68	0.00
Moisture Run 6	12:55 - 15:55 07 March 2014	13.6	3200 - 3401	1.68	0.00
Carbon Dioxide Run 1	15:06 - 18:06 05 March 2014	7.3	2000 - 2223	0.27	0.01
Carbon Dioxide Run 2	09:03 - 12:03 06 March 2014	7.5	2000 - 2223	0.97	0.01
Carbon Dioxide Run 3	12:35 - 15:35 06 March 2014	7.1	2000 - 2223	0.97	0.01
Carbon Dioxide Run 4	16:09 - 19:09 06 March 2014	7.1	2000 - 2223	0.97	0.01
Carbon Dioxide Run 6	12:55 - 15:55 07 March 2014	7.1	2000 - 2223	0.27	0.01

\*M22 Specifies interference must be <5%.

### FTIR CALIBRATION CHECKS

<b>Pre - Sampling Checks - System</b>			<b>Date of Checks</b>	05 March 2014	<b>Time of Checks</b>	12:57		
<b>Post Sampling Checks - System</b>			<b>Date of Checks</b>	06 March 2014	<b>Time of Checks</b>	08:49		
<b>Compound</b>	<b>Pre - Test Zero Reading</b>	<b>Post Test Zero Reading</b>	<b>Zero Drift as a % of Range</b>	<b>Span Gas (ppm)</b>	<b>Pre - Test Span Reading</b>	<b>% Variation from Actual</b>	<b>Post Test Span Reading</b>	<b>% Span Drift</b>
H <sub>2</sub> O	0.21	0.49	0.92	101.0	101.7	0.66	99.7	-1.97
CO <sub>2</sub> (%)	0.00	0.00	0.01	8.8	8.6	-2.27	8.7	0.58

<b>Pre - Sampling Checks - System</b>			<b>Date of Checks</b>	06 March 2014	<b>Time of Checks</b>	08:35		
<b>Post Sampling Checks - System</b>			<b>Date of Checks</b>	06 March 2014	<b>Time of Checks</b>	19:14		
<b>Compound</b>	<b>Pre - Test Zero Reading</b>	<b>Post Test Zero Reading</b>	<b>Zero Drift as a % of Range</b>	<b>Span Gas (ppm)</b>	<b>Pre - Test Span Reading</b>	<b>% Variation from Actual</b>	<b>Post Test Span Reading</b>	<b>% Span Drift</b>
H <sub>2</sub> O	0.21	0.01	-0.14	101.0	99.7	-1.32	99.0	-0.67
CO <sub>2</sub> (%)	0.00	0.00	0.01	8.8	8.7	-1.70	8.7	0.19

<b>Pre - Sampling Checks - System</b>			<b>Date of Checks</b>	07 March 2014	<b>Time of Checks</b>	08:17		
<b>Post Sampling Checks - System</b>			<b>Date of Checks</b>	07 March 2014	<b>Time of Checks</b>	16:07		
<b>Compound</b>	<b>Pre - Test Zero Reading</b>	<b>Post Test Zero Reading</b>	<b>Zero Drift as a % of Range</b>	<b>Span Gas (ppm)</b>	<b>Pre - Test Span Reading</b>	<b>% Variation from Actual</b>	<b>Post Test Span Reading</b>	<b>% Span Drift</b>
H <sub>2</sub> O	0.21	0.00	-0.14	101.0	99.4	-1.58	99.0	-0.40
CO <sub>2</sub> (%)	0.00	0.00	0.01	8.8	8.5	-3.41	8.6	1.57

Note - Methane was used as a surrogate span check for moisture. All other surrogates are listed in the individual measurement uncertainty budgets. Acceptance criteria for initial span check variation is +/-5% of certified reading for all gases, except HCl and NH<sub>3</sub> which are +/- 10% of certified reading. Acceptance criteria for % zero drift across the test is +/-2% of range for all gases.



### PRELIMINARY STACK SURVEY

Stack Characteristics		
Stack Diameter / Depth, D	1.10	m
Stack Width, W	-	m
Stack Area, A	0.95	m <sup>2</sup>
Average stack gas temperature	144	°C
Stack static pressure	-0.25	kPa
Barometric Pressure	101.5	kPa
Pitot tube calibration coefficient, $K_{pt}$	0.84	-

Stack Gas Composition & Molecular Weights								
Component	Molar Mass M	Density kg/m <sup>3</sup> p	Conc Dry % Vol	Dry Volume Fraction r	Dry Conc kg/m <sup>3</sup> pi	Conc Wet % Vol	Wet Volume Fraction r	Wet Conc kg/m <sup>3</sup> pi
CO <sub>2</sub>	44	1.96	8.57	0.09	0.17	7.43	0.07	0.15
O <sub>2</sub>	32	1.43	11.95	0.12	0.17	10.36	0.10	0.15
N <sub>2</sub>	28	1.25	79.48	0.79	0.99	68.91	0.69	0.86
H <sub>2</sub> O	18	0.80	-	-	-	13.30	0.13	0.11

Where:  $p = M / 22.41$      $pi = r \times p$

Calculation of Stack Gas Densities		
Determinand	Result	Units
Dry Density (STP), $P_{STD}$	1.3317	kg/m <sup>3</sup>
Wet Density (STP), $P_{STW}$	1.2614	kg/m <sup>3</sup>
Dry Density (Actual), $P_{Actual}$	0.8705	kg/m <sup>3</sup>
Average Wet Density (Actual), $P_{ActualW}$	0.825	kg/m <sup>3</sup>

Where:

$P_{STD}$  = sum of component concentrations, kg/m<sup>3</sup> (not including water vapour)  
 $P_{STW} = (P_{STD} + pi \text{ of H}_2\text{O}) / (1 + (pi \text{ of H}_2\text{O} / 0.8036))$

$P_{Actual} = P_{STD} \times (Ts / Ps) \times (Pa / Ta)$   
 $P_{ActualW} = P_{STW} \times (Ts / Ps) \times (Pa / Ta)$

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY**

**TRAVERSE 1**

Date of Survey	05 March 2014
Time of Survey	11:00
Velocity Measurement Device:	S-Type Pitot

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.06	30.0	294	143	21.80	-	<15
2	0.17	32.0	314	142	22.49	-	<15
3	0.28	32.0	314	143	22.52	-	<15
4	0.39	28.0	274	144	21.09	-	<15
5	0.50	30.0	294	143	21.80	-	<15
6	0.61	30.0	294	144	21.83	-	<15
7	0.72	34.0	333	144	23.24	-	<15
8	0.83	34.0	333	144	23.24	-	<15
9	0.94	32.0	314	146	22.60	-	<15
10	1.05	28.0	274	146	21.14	-	<15
Mean	-	31.0	304	144	22.17	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.06	30.0	294	145	21.86	-	<15
2	0.17	32.0	314	144	22.54	-	<15
3	0.28	32.0	314	145	22.57	-	<15
4	0.39	30.0	294	145	21.86	-	<15
5	0.50	28.0	274	145	21.11	-	<15
6	0.61	28.0	274	145	21.11	-	<15
7	0.72	30.0	294	145	21.86	-	<15
8	0.83	30.0	294	145	21.86	-	<15
9	0.94	30.0	294	145	21.86	-	<15
10	1.05	32.0	314	145	22.57	-	<15
Mean	-	30.2	296	145	21.92	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

**TRAVERSE 2**

Date of Survey	05 March 2014
Time of Survey	18:46
Velocity Measurement Device:	S-Type Pitot

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.06	32.0	314	144	22.54	-	<15
2	0.17	32.0	314	145	22.57	-	<15
3	0.28	36.0	353	145	23.94	-	<15
4	0.39	32.0	314	145	22.57	-	<15
5	0.50	30.0	294	145	21.86	-	<15
6	0.61	28.0	274	144	21.09	-	<15
7	0.72	32.0	314	144	22.54	-	<15
8	0.83	30.0	294	144	21.83	-	<15
9	0.94	30.0	294	144	21.83	-	<15
10	1.05	30.0	294	144	21.83	-	<15
Mean	-	31.2	306	144	22.26	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.06	32.0	314	144	22.54	-	<15
2	0.17	34.0	333	145	23.27	-	<15
3	0.28	34.0	333	145	23.27	-	<15
4	0.39	32.0	314	145	22.57	-	<15
5	0.50	32.0	314	145	22.57	-	<15
6	0.61	30.0	294	145	21.86	-	<15
7	0.72	30.0	294	145	21.86	-	<15
8	0.83	34.0	333	145	23.27	-	<15
9	0.94	32.0	314	145	22.57	-	<15
10	1.05	32.0	314	145	22.57	-	<15
Mean	-	32.2	316	145	22.63	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY**

**TRAVERSE 3**

Date of Survey	06 March 2014
Time of Survey	08:20
Velocity Measurement Device:	S-Type Pitot

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.06	32.0	314	137	22.35	-	<15
2	0.17	28.0	274	142	21.04	-	<15
3	0.28	32.0	314	143	22.52	-	<15
4	0.39	34.0	333	144	23.24	-	<15
5	0.50	32.0	314	143	22.52	-	<15
6	0.61	30.0	294	144	21.83	-	<15
7	0.72	28.0	274	144	21.09	-	<15
8	0.83	34.0	333	144	23.24	-	<15
9	0.94	36.0	353	146	23.97	-	<15
10	1.05	32.0	314	146	22.60	-	<15
Mean	-	31.8	312	143.3	22.44	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.06	30.0	294	145	21.86	-	<15
2	0.17	32.0	314	144	22.54	-	<15
3	0.28	34.0	333	145	23.27	-	<15
4	0.39	36.0	353	145	23.94	-	<15
5	0.50	30.0	294	145	21.86	-	<15
6	0.61	28.0	274	145	21.11	-	<15
7	0.72	30.0	294	145	21.86	-	<15
8	0.83	34.0	333	145	23.27	-	<15
9	0.94	36.0	353	145	23.94	-	<15
10	1.05	32.0	314	145	22.57	-	<15
Mean	-	32.2	316	145	22.62	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

**TRAVERSE 4**

Date of Survey	06 March 2014
Time of Survey	12:08
Velocity Measurement Device:	S-Type Pitot

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.06	34.0	333	145	23.27	-	<15
2	0.17	34.0	333	145	23.27	-	<15
3	0.28	36.0	353	145	23.94	-	<15
4	0.39	36.0	353	145	23.94	-	<15
5	0.50	32.0	314	144	22.54	-	<15
6	0.61	30.0	294	144	21.83	-	<15
7	0.72	30.0	294	146	21.88	-	<15
8	0.83	36.0	353	146	23.97	-	<15
9	0.94	34.0	333	145	23.27	-	<15
10	1.05	32.0	314	145	22.57	-	<15
Mean	-	33.4	327	145	23.05	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.06	32.0	314	146	22.60	-	<15
2	0.17	34.0	333	146	23.29	-	<15
3	0.28	36.0	353	145	23.94	-	<15
4	0.39	34.0	333	145	23.27	-	<15
5	0.50	38.0	372	145	24.60	-	<15
6	0.61	34.0	333	145	23.27	-	<15
7	0.72	36.0	353	144	23.91	-	<15
8	0.83	38.0	372	146	24.63	-	<15
9	0.94	36.0	353	145	23.94	-	<15
10	1.05	36.0	353	145	23.94	-	<15
Mean	-	35.4	347	145	23.74	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY**

**TRAVERSE 5**

Date of Survey	06 March 2014
Time of Survey	15:35
Velocity Measurement Device:	S-Type Pitot

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.06	34.0	333	145	23.27	-	<15
2	0.17	32.0	314	145	22.57	-	<15
3	0.28	32.0	314	145	22.57	-	<15
4	0.39	30.0	294	146	21.88	-	<15
5	0.50	30.0	294	146	21.88	-	<15
6	0.61	28.0	274	146	21.14	-	<15
7	0.72	32.0	314	145	22.57	-	<15
8	0.83	36.0	353	146	23.97	-	<15
9	0.94	36.0	353	146	23.97	-	<15
10	1.05	34.0	333	146	23.29	-	<15
Mean	-	32.4	318	145.6	22.71	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.06	34.0	333	145	23.27	-	<15
2	0.17	34.0	333	145	23.27	-	<15
3	0.28	32.0	314	145	22.57	-	<15
4	0.39	34.0	333	146	23.29	-	<15
5	0.50	32.0	314	146	22.60	-	<15
6	0.61	30.0	294	146	21.88	-	<15
7	0.72	32.0	314	146	22.60	-	<15
8	0.83	36.0	353	146	23.97	-	<15
9	0.94	38.0	372	146	24.63	-	<15
10	1.05	36.0	353	146	23.97	-	<15
Mean	-	33.8	331	146	23.20	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

**TRAVERSE 6**

Date of Survey	06 March 2014
Time of Survey	19:35
Velocity Measurement Device:	S-Type Pitot

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.06	32.0	314	145	22.57	-	<15
2	0.17	34.0	333	145	23.27	-	<15
3	0.28	38.0	372	145	24.60	-	<15
4	0.39	36.0	353	146	23.97	-	<15
5	0.50	32.0	314	146	22.60	-	<15
6	0.61	30.0	294	146	21.88	-	<15
7	0.72	28.0	274	146	21.14	-	<15
8	0.83	30.0	294	146	21.88	-	<15
9	0.94	34.0	333	146	23.29	-	<15
10	1.05	36.0	353	146	23.97	-	<15
Mean	-	33.0	323	146	22.92	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.06	32.0	314	145	22.57	-	<15
2	0.17	34.0	333	145	23.27	-	<15
3	0.28	38.0	372	146	24.63	-	<15
4	0.39	36.0	353	146	23.97	-	<15
5	0.50	32.0	314	145	22.57	-	<15
6	0.61	30.0	294	146	21.88	-	<15
7	0.72	28.0	274	146	21.14	-	<15
8	0.83	30.0	294	146	21.88	-	<15
9	0.94	34.0	333	146	23.29	-	<15
10	1.05	36.0	353	146	23.97	-	<15
Mean	-	33.0	323	146	22.92	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY**

**TRAVERSE 7**

Date of Survey	07 March 2014
Time of Survey	08:25
Velocity Measurement Device:	S-Type Pitot

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.06	32.0	314	144	22.54	-	<15
2	0.17	32.0	314	144	22.54	-	<15
3	0.28	30.0	294	145	21.86	-	<15
4	0.39	30.0	294	144	21.83	-	<15
5	0.50	28.0	274	143	21.06	-	<15
6	0.61	28.0	274	143	21.06	-	<15
7	0.72	28.0	274	143	21.06	-	<15
8	0.83	28.0	274	143	21.06	-	<15
9	0.94	32.0	314	143	22.52	-	<15
10	1.05	34.0	333	143	23.21	-	<15
Mean	-	30.2	296	143.5	21.88	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.06	30.0	294	143	21.80	-	<15
2	0.17	28.0	274	143	21.06	-	<15
3	0.28	28.0	274	144	21.09	-	<15
4	0.39	28.0	274	144	21.09	-	<15
5	0.50	28.0	274	144	21.09	-	<15
6	0.61	26.0	255	145	20.35	-	<15
7	0.72	34.0	333	144	23.24	-	<15
8	0.83	32.0	314	144	22.54	-	<15
9	0.94	32.0	314	144	22.54	-	<15
10	1.05	32.0	314	144	22.54	-	<15
Mean	-	29.8	292	144	21.74	-	



APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

**TRAVERSE 8**

Date of Survey	07 March 2014
Time of Survey	11:55
Velocity Measurement Device:	S-Type Pitot

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.06	30.0	294	144	21.83	-	<15
2	0.17	32.0	314	143	22.52	-	<15
3	0.28	32.0	314	143	22.52	-	<15
4	0.39	30.0	294	143	21.80	-	<15
5	0.50	28.0	274	142	21.04	-	<15
6	0.61	26.0	255	142	20.27	-	<15
7	0.72	28.0	274	142	21.04	-	<15
8	0.83	30.0	294	142	21.78	-	<15
9	0.94	32.0	314	142	22.49	-	<15
10	1.05	32.0	314	142	22.49	-	<15
Mean	-	30.0	294	143	21.78	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.06	32.0	314	143	22.52	-	<15
2	0.17	32.0	314	143	22.52	-	<15
3	0.28	32.0	314	143	22.52	-	<15
4	0.39	28.0	274	143	21.06	-	<15
5	0.50	30.0	294	142	21.78	-	<15
6	0.61	28.0	274	142	21.04	-	<15
7	0.72	26.0	255	142	20.27	-	<15
8	0.83	28.0	274	142	21.04	-	<15
9	0.94	28.0	274	142	21.04	-	<15
10	1.05	26.0	255	142	20.27	-	<15
Mean	-	29.0	284	142	21.41	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

**TRAVERSE 9**

Date of Survey	07 March 2014
Time of Survey	12:40
Velocity Measurement Device:	S-Type Pitot

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.06	32.0	314	145	22.57	-	<15
2	0.17	34.0	333	145	23.27	-	<15
3	0.28	32.0	314	145	22.57	-	<15
4	0.39	34.0	333	146	23.29	-	<15
5	0.50	36.0	353	146	23.97	-	<15
6	0.61	32.0	314	146	22.60	-	<15
7	0.72	32.0	314	146	22.60	-	<15
8	0.83	36.0	353	146	23.97	-	<15
9	0.94	38.0	372	146	24.63	-	<15
10	1.05	32.0	314	146	22.60	-	<15
Mean	-	33.8	331	146	23.21	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.06	34.0	333	146	23.29	-	<15
2	0.17	36.0	353	146	23.97	-	<15
3	0.28	34.0	333	146	23.29	-	<15
4	0.39	32.0	314	146	22.60	-	<15
5	0.50	30.0	294	146	21.88	-	<15
6	0.61	32.0	314	145	22.57	-	<15
7	0.72	34.0	333	145	23.27	-	<15
8	0.83	34.0	333	146	23.29	-	<15
9	0.94	36.0	353	146	23.97	-	<15
10	1.05	34.0	333	146	23.29	-	<15
Mean	-	33.6	329	146	23.14	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

**TRAVERSE 10**

Date of Survey	07 March 2014
Time of Survey	16:00
Velocity Measurement Device:	S-Type Pitot

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.06	32.0	314	145	22.57	-	<15
2	0.17	34.0	333	145	23.27	-	<15
3	0.28	34.0	333	145	23.27	-	<15
4	0.39	34.0	333	146	23.29	-	<15
5	0.50	36.0	353	146	23.97	-	<15
6	0.61	32.0	314	146	22.60	-	<15
7	0.72	30.0	294	145	21.86	-	<15
8	0.83	34.0	333	145	23.27	-	<15
9	0.94	36.0	353	145	23.94	-	<15
10	1.05	34.0	333	145	23.27	-	<15
Mean	-	33.6	329	145	23.13	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.06	34.0	333	145	23.27	-	<15
2	0.17	34.0	333	145	23.27	-	<15
3	0.28	32.0	314	144	22.54	-	<15
4	0.39	32.0	314	144	22.54	-	<15
5	0.50	36.0	353	144	23.91	-	<15
6	0.61	36.0	353	144	23.91	-	<15
7	0.72	34.0	333	144	23.24	-	<15
8	0.83	34.0	333	144	23.24	-	<15
9	0.94	34.0	333	144	23.24	-	<15
10	1.05	32.0	314	144	22.54	-	<15
Mean	-	33.8	331	144	23.17	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

Sampling Plane Validation Criteria				
EA Technical Guidance Note (Monitoring) M1	Result	Units	Requirement	Compliant
Lowest Differential Pressure	255	Pa	>= 5 Pa	Yes
Lowest Gas Velocity	20.27	m/s	-	-
Highest Gas Velocity	24.63	m/s	-	-
Ratio of Gas Velocities	1.21	-	< 3 : 1	Yes
Maximum angle of flow with regard to duct axis	<15	°	< 15°	Yes
No local negative flow	Yes	-	-	Yes

Calculation of Stack Gas Velocity, V		
Velocity at Traverse Point, $V = K_{pt} \times (1-\epsilon) \times \sqrt{2 * \Delta P_{pt} / \rho_{ActualW}}$		
<b>Where:</b> $K_{pt}$ = Pitot tube calibration coefficient (1- $\epsilon$ ) = Compressibility correction factor, assumed at a constant 0.998		
Average Stack Gas Velocity, $V_a$	<b>22.44</b>	m/s

**Where:**  
 $Q_{Actual} = V_a \times A \times 3600$   
 $Q_{STP} = Q (Actual) \times (T_s / T_a) \times (P_a / P_s) \times 3600$   
 $Q_{STP,Dry} = Q (STP) / (100 - (100 / Ma)) \times 3600$   
 $Q_{Ref} = Q (STP) \times ((100 - Ma) / (100 - Ms)) \times ((20.9 - O_{2a}) / (20.9 - O_{2s}))$

Day 1      05 March 2014

Calculation of Stack Gas Volumetric Flowrate, Q			
Duct gas flow conditions	Actual	Reference	Units
Temperature	145	0	°C
Total Pressure	101.3	101.3	kPa
Oxygen	11.8	11	%
Moisture	14.22	0.00	%
Gas Volumetric Flowrate		Result	Units
Average Stack Gas Velocity ( $V_a$ )		22.25	m/s
Stack Area (A)		0.95	m <sup>2</sup>
Gas Volumetric Flowrate (Actual), $Q_{Actual}$		76122	m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Wet), $Q_{STP}$		49758	m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Dry), $Q_{STP,Dry}$		42683	m <sup>3</sup> /hr
Gas Volumetric Flowrate (REF), $Q_{Ref}$		39134	m <sup>3</sup> /hr

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

Day 2	06 March 2014		
Calculation of Stack Gas Volumetric Flowrate, Q			
Duct gas flow conditions	Actual	Reference	Units
Temperature	145	0	°C
Total Pressure	101.3	101.3	kPa
Oxygen	11.7	11	%
Moisture	14.50	0.00	%
Gas Volumetric Flowrate	Result		Units
Average Stack Gas Velocity (Va)	22.95		m/s
Stack Area (A)	0.95		m <sup>2</sup>
Gas Volumetric Flowrate (Actual), Q <sub>Actual</sub>	78525		m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Wet), Q <sub>STP</sub>	51254		m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Dry), Q <sub>STP,Dry</sub>	43821		m <sup>3</sup> /hr
Gas Volumetric Flowrate (REF), Q <sub>Ref</sub>	40783		m <sup>3</sup> /hr

Day 3	07 March 2014		
Calculation of Stack Gas Volumetric Flowrate, Q			
Duct gas flow conditions	Actual	Reference	Units
Temperature	144	0	°C
Total Pressure	101.2	101.3	kPa
Oxygen	12.4	11	%
Moisture	11.08	0.00	%
Gas Volumetric Flowrate	Result		Units
Average Stack Gas Velocity (Va)	22.03		m/s
Stack Area (A)	0.95		m <sup>2</sup>
Gas Volumetric Flowrate (Actual), Q <sub>Actual</sub>	75392		m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Wet), Q <sub>STP</sub>	49356		m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Dry), Q <sub>STP,Dry</sub>	43888		m <sup>3</sup> /hr
Gas Volumetric Flowrate (REF), Q <sub>Ref</sub>	37699		m <sup>3</sup> /hr

**Nomenclature:**

Ts = Absolute Temperature, Standard Conditions, 273 K  
Ps = Absolute Pressure, Standard Conditions, 101.3 kPa  
Ta = Absolute Temperature, Actual Conditions, K


Pa = Absolute Pressure, Actual Conditions, kPa  
Ma = Water vapour, Actual Conditions, % Vol  
Ms = Water vapour, Reference Conditions, % Vol

O<sub>2a</sub> = Oxygen, Actual Conditions, % Vol  
O<sub>2s</sub> = Oxygen, Reference Conditions, % Vol

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**STACK DIAGRAM**

	Value	Units
Stack Depth	1.10	m
Stack Width	-	m
Area	0.95	m <sup>2</sup>



Non-Isokinetic/Gases Sampling			
Sampling Point	Distance (% of Depth)	Distance into Stack	Units
A	40	0.44	m

Isokinetic Sampling CEN Methods			
Sampling Point	Distance (% of Depth)	Distance into Stack (m)	Swirl °
1	85.0	0.94	<15

- Isokinetic sampling point
- Isokinetic sampling points not used
- ◐ Non Isokinetic/Gases sampling point

**SAMPLING LOCATION**



APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - PM 10**

Run	Sampled Volume m <sup>3</sup>	Sampled Gas K	Sampled Gas kPa	Sampled Gas % by volume	Oxygen % by volume	Limit of % by mass	Leak %
<b>MU required</b>	<b>≤ 2%</b>	<b>≤ 2%</b>	<b>≤ 1%</b>	<b>≤ 1%</b>	<b>≤ 10%</b>	<b>≤ 5% of ELV</b>	<b>≤ 2%</b>
Run 1	0.001	2	0.5	1	0.1	0.10	-
as a %	0.02	0.48	0.49	1.00	0.85	N/A	0.40
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 2	0.001	2	0.5	1.00	0.1	0.10	-
as a %	0.02	0.48	0.49	1.00	0.85	N/A	0.67
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 3	0.001	2	0.5	1	0.1	0.1000	-
as a %	0.02	0.48	0.50	1.00	0.86	N/A	0.66
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 4	0.001	2	0.5	1	0.1	0.10	-
as a %	0.02	0.48	0.50	1.00	0.86	N/A	0.42
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 5	0.001	2	0.5	1	0.1	0.10	-
as a %	0.02	0.48	0.49	1.00	0.77	N/A	0.54
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 6	0.001	2	0.5	1	0.1	0.10	-
as a %	0.11	0.48	0.49	1.00	0.85	N/A	0.57
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>

Run	Volume (STP) m <sup>3</sup>	Mass of particulate mg	O2 Correction -	Leak mg/m <sup>3</sup>	Combined uncertainty
Run 1	0.0053	0.1867	0.017	1.000	-
MU as mg/m <sup>3</sup>	0.0002	0.0187	0.0002	0.00004	<b>100.01</b>
MU as %	0.0042	100.0	1.091	0.229	-
Run 2	0.0062	0.1841	0.020	1.000	-
MU as mg/m <sup>3</sup>	0.0003	0.0184	0.0002	0.00009	<b>83.34</b>
MU as %	0.0050	83.3	1.082	0.385	-
Run 3	0.0052	0.1846	0.017	1.000	-
MU as mg/m <sup>3</sup>	0.0002	0.0185	0.0002	0.00007	<b>100.006</b>
MU as %	0.0042	100.0	1.071	0.380	-
Run 4	0.0061	0.20	0.019	1.00	-
MU as mg/m <sup>3</sup>	0.0002	0.02	0.0002	0.00005	<b>100.01</b>
MU as %	0.0045	100.0	1.070	0.24	-
Run 5	0.0068	0.21	0.017	1.00	-
MU as mg/m <sup>3</sup>	0.0003	0.02	0.0003	0.00007	<b>100.01</b>
MU as %	0.0048	100.0	1.253	0.31	-
Run 6	0.0162	0.08	0.009	1.00	-
MU as mg/m <sup>3</sup>	0.0001	0.01	0.0001	0.00003	<b>83.34</b>
MU as %	0.0022	83.3	1.087	0.33	-

<b>R1 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.04</b>	<b>mg/m<sup>3</sup></b>	<b>200.03</b>	<b>%</b>
<b>R2 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.04</b>	<b>mg/m<sup>3</sup></b>	<b>166.70</b>	<b>%</b>
<b>R3 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.04</b>	<b>mg/m<sup>3</sup></b>	<b>200.03</b>	<b>%</b>
<b>R4 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.04</b>	<b>mg/m<sup>3</sup></b>	<b>200.03</b>	<b>%</b>
<b>R5 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.04</b>	<b>mg/m<sup>3</sup></b>	<b>200.03</b>	<b>%</b>
<b>R6 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.02</b>	<b>mg/m<sup>3</sup></b>	<b>166.70</b>	<b>%</b>

(k is a coverage factor which gives a 95% confidence in the quoted figures)  
Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - PM 2.5**

Run	Sampled m <sup>3</sup>	Sampled Gas K	Sampled Gas kPa	Sampled Gas % by volume	Oxygen % by volume	Limit of % by mass	Leak %
<b>MU required</b>	<b>≤ 2%</b>	<b>≤ 2%</b>	<b>≤ 1%</b>	<b>≤ 1%</b>	<b>≤ 10%</b>	<b>≤ 5% of ELV</b>	<b>≤ 2%</b>
Run 1	0.001	2	0.5	1	0.1	0.05	-
as a %	0.02	0.48	0.49	1.00	0.85	N/A	0.40
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 2	0.001	2	0.5	1.00	0.1	0.05	-
as a %	0.02	0.48	0.49	1.00	0.85	N/A	0.67
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 3	0.001	2	0.5	1.00	0.1	0.05	-
as a %	0.02	0.48	0.50	1.00	0.86	N/A	0.66
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 4	0.001	2	0.5	1.00	0.1	0.05	-
as a %	0.02	0.48	0.50	1.00	0.86	0.00	0.42
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 5	0.001	2	0.5	1	0.1	0.05	-
as a %	0.02	0.48	0.49	1.00	0.77	N/A	0.54
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 6	0.001	2	0.5	1	0.1	0.05	-
as a %	0.11	0.48	0.49	1.00	0.85	N/A	0.57
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>

Run	Volume (STP) m <sup>3</sup>	Mass of particulate mg	O2 Correction -	Leak mg/m <sup>3</sup>	Combined uncertainty
Run 1	0.00	0.1867	0.0086	1.000	-
MU as mg/m <sup>3</sup>	0.0001	0.0093	0.0001	0.00002	<b>100.01</b>
MU as %	0.0021	100.0000	1.0905	0.23	-
Run 2	0.0036	0.1841	0.0119	1.000	-
MU as mg/m <sup>3</sup>	0.0002	0.0092	0.0001	0.00005	<b>71.44</b>
MU as %	0.0029	71.4286	1.0823	0.38	-
Run 3	0.0037	0.2577	0.0120	1.000	-
MU as mg/m <sup>3</sup>	0.0002	0.0129	0.0001	0.00005	<b>100.01</b>
MU as %	0.0029	100.0000	1.0707	0.38	-
Run 4	0.0030	0.1985	0.0093	1.0000	-
MU as mg/m <sup>3</sup>	0.0001	0.0099	0.0001	0.00002	<b>100.01</b>
MU as %	0.0022	100.0000	1.0695	0.24	-
Run 5	0.003	0.211	0.0084	1.000	-
MU as mg/m <sup>3</sup>	0.000	0.011	0.0001	0.00003	<b>100.01</b>
MU as %	0.002	100.000	1.2531	0.31	-
Run 6	0.02	0.20	0.0090	1.00	-
MU as mg/m <sup>3</sup>	0.00	0.01	0.0001	0.00003	<b>100.01</b>
MU as %	0.0	100.0	1.0870	0.33	-

<b>R1 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.019</b>	<b>mg/m<sup>3</sup></b>	<b>200.03</b>	<b>%</b>
<b>R2 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.018</b>	<b>mg/m<sup>3</sup></b>	<b>142.90</b>	<b>%</b>
<b>R3 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.026</b>	<b>mg/m<sup>3</sup></b>	<b>200.03</b>	<b>%</b>
<b>R4 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.020</b>	<b>mg/m<sup>3</sup></b>	<b>200.03</b>	<b>%</b>
<b>R5 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.021</b>	<b>mg/m<sup>3</sup></b>	<b>200.03</b>	<b>%</b>
<b>R6 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.020</b>	<b>mg/m<sup>3</sup></b>	<b>200.03</b>	<b>%</b>

(k is a coverage factor which gives a 95% confidence in the quoted figures)  
Developed for the STA by R Robinson, NPL



APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - CARBON DIOXIDE BY FTIR**

Actual Measured Concentration	7.35	% vol
Measured Concentration at Reference Conditions	7.35	% vol
Emission Limit Value	-	% vol
Instrument Range	10	% vol
Check Gas Concentration	8.80	% vol

Performance Characteristics & Source of Value	Values	Requirement	Compliant
Deviation from linearity as a % of the range (taken from worst case figure in MCERTS certificate)	-1.900	<2%	Yes
Zero drift (calculated from start and end readings)	0.010	<5%	Yes
Span drift (calculated from start and end readings).	0.581	<5%	Yes
Sensitivity to sample gas pressure: (taken from worst case figure in MCERTS certificate).	0.990	<2%	Yes
Sensitivity to ambient temperature at zero (taken from worst case figure in MCERTS certificate)	0.100	<5%	Yes
Sensitivity to ambient temperature at span (taken from worst case figure in MCERTS certificate)	-1.300	<5%	Yes
Sensitivity to voltage (taken from worst case figure in MCERTS certificate)	1.600	<2%	Yes
Interferents (calculated using M22, Section 8.2, equation 3)	0.275	<5%	Yes
Repeatability / standard deviation (taken from worst figure in MCERTS certificate)	0.080	<2%	Yes
Certified reference material (check gas)	2.000	2% or less	Yes

Uncertainty in Performance Characteristics	% vol
Uncertainty of linearity (lack of fit) $U_{fit}$	-0.110
Uncertainty of zero drift $U_{0,dr}$	0.001
Uncertainty of span drift $U_{s,dr}$	0.034
Uncertainty of volume or pressure flow dependence $U_{spress}$	0.057
Uncertainty in Ambient Temperature $U_{temp}$	0.075
Uncertainty in Voltage $U_{volt}$	0.092
Uncertainty of interferents $U_i$	0.016
Uncertainty of Repeatability $U_r$	0.008
Uncertainty of Certified Reference Material $U_{cal}$	0.051

Measurement Uncertainty	% vol
Combined uncertainty	0.18
Expanded uncertainty at a 95% Confidence Interval	0.37

Note - The expanded uncertainty uses a coverage factor of  $k = 2$ .

Expanded Measurement Uncertainty at a 95% Confidence Interval	%
Expressed as a % of the Measured Concentration	4.98
Expressed as a % of the Measured Concentration at Reference Conditions	4.98
Expressed as a % of the Emission Limit Value	-

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - MOISTURE BY FTIR**

Actual Measured Concentration	14.22	% vol
Measured Concentration at Reference Conditions	14.22	% vol
Emission Limit Value	30	% vol
Instrument Range	30	% vol
Check Gas Concentration (Methane was used as a Surrogate)	72.14	mg/m <sup>3</sup>

Performance Characteristics & Source of Value	Values	Requirement	Compliant
Deviation from linearity as a % of the range (taken from worst case figure in MCERTS certificate)	-1.900	<2%	Yes
Zero drift (calculated from start and end readings)	0.923	<5%	Yes
Span drift (calculated from start and end readings).	-1.967	<5%	Yes
Sensitivity to sample gas pressure: (taken from worst case figure in MCERTS certificate).	0.990	<2%	Yes
Sensitivity to ambient temperature at zero (taken from worst case figure in MCERTS certificate)	0.100	<5%	Yes
Sensitivity to ambient temperature at span (taken from worst case figure in MCERTS certificate)	-1.000	<5%	Yes
Sensitivity to voltage (taken from worst case figure in MCERTS certificate)	0.710	<2%	Yes
Interferents (calculated using M22, Section 8.2, equation 3)	1.676	<5%	Yes
Repeatability / standard deviation (taken from worst figure in MCERTS certificate)	0.170	<2%	Yes
Certified reference material (check gas)	2.000	2% or less	Yes

Uncertainty in Performance Characteristics	% vol
Uncertainty of linearity (lack of fit) $U_{fit}$	-0.329
Uncertainty of zero drift $U_{0,dr}$	0.160
Uncertainty of span drift $U_{s,dr}$	-0.341
Uncertainty of volume or pressure flow dependence $U_{spress}$	0.171
Uncertainty in Ambient Temperature $U_{temp}$	0.174
Uncertainty in Voltage $U_{volt}$	0.123
Uncertainty of interferents $U_i$	0.290
Uncertainty of Repeatability $U_r$	0.051
Uncertainty of Certified Reference Material $U_{cal}$	0.417

Measurement Uncertainty	% vol
Combined uncertainty	0.76
Expanded uncertainty at a 95% Confidence Interval	1.53

Note - The expanded uncertainty uses a coverage factor of  $k = 2$ .

Expanded Measurement Uncertainty at a 95% Confidence Interval	%
Expressed as a % of the Measured Concentration	10.76
Expressed as a % of the Measured Concentration at Reference Conditions	10.76
Expressed as a % of the Emission Limit Value	5.10

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - OXYGEN**

DAY 1 - 05 March 2014

Reference	11	%vol
Measured concentration	11.83	%vol
Calibration gas	10.01	%vol
Full Scale	25	%vol

Performance characteristics	Value	Units	specification	MU Met?
Response time	30	seconds	< 200 s	Yes
Logger sampling interval	60	seconds	-	-
Measurement period	180	minutes	-	-
Number of readings in measurement	180	-	-	-
Repeatability at zero	0.015	% by volume	<0.2 % range	Yes
Repeatability at span level	0.014	% by volume	<0.4 % range	Yes
Deviation from linearity	0.13	% vol	<0.3 % volume	Yes
Zero drift (during measurement period)	0.08	% vol at zero level	<2% of volume / 24hr	Yes
Span drift (during measurement period)	0.20	% vol at span level	<2% volume/24hr	Yes
volume or pressure flow dependence	0.02	% of fs / 10l/h	<1% range	Yes
atmospheric pressure dependence	0.8	% of fs/kPa	< 1.5 % range	Yes
ambient temperature dependence	0.01	% by volume /10K	<0.3% volume 10 K	Yes
Combined interference	0.14	% range	<2% range	Yes
Dependence on voltage	0.1	% by volume /10V	< 0.1%vol /10 volt	Yes
Losses in the line (leak)	0.10	% of value	< 2% of value	Yes
Uncertainty of calibration gas	2	% of value	< 2% of value	Yes

Performance characteristic	Uncertainty	Value of uncertainty quantity
Standard deviation of repeatability at zero	ur0	-
Standard deviation of repeatability at span level	urs	0.001
Lack of fit	ufit	0.075
Drift	u0dr	0.183
volume or pressure flow dependence	uspres	0.001
atmospheric pressure dependence	uapres	0.115
ambient temperature dependence	utemp	0.003
Combined interference (from mcerts)	-	0.020
dependence on voltage	uvolt	0.029
losses in the line (leak)	uleak	0.007
Uncertainty of calibration gas	ucalib	0.137

Measurement uncertainty (Concentration Measured)	11.83	%vol
Combined uncertainty	0.27	%vol
% of value	2.27	%

<b>Expanded uncertainty expressed with a level of confidence of 95%</b>	<b>4.54</b>	<b>% of value</b>
---	-------------	-------------------

<b>Expanded uncertainty expressed with a level of confidence of 95%</b>	<b>0.54</b>	<b>% vol</b>
---	-------------	--------------

Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - OXYGEN**

DAY 2 - 06 March 2014

Reference	11	%vol
Measured concentration	11.69	%vol
Calibration gas	10.01	%vol
Full Scale	25	%vol

Performance characteristics	Value	Units	specification	MU Met?
Response time	30	seconds	< 200 s	Yes
Logger sampling interval	60	seconds	-	-
Measurement period	606	minutes	-	-
Number of readings in measurement	606	-	-	-
Repeatability at zero	0.015	% by volume	<0.2 % range	Yes
Repeatability at span level	0.014	% by volume	<0.4 % range	Yes
Deviation from linearity	0.13	% vol	<0.3 % volume	Yes
Zero drift (during measurement period)	0.32	% vol at zero level	<2% of volume / 24hr	Yes
Span drift (during measurement period)	-0.10	% vol at span level	<2% volume/24hr	Yes
volume or pressure flow dependence	0.02	% of fs / 10l/h	<1% range	Yes
atmospheric pressure dependence	0.8	% of fs/kPa	< 1.5 % range	Yes
ambient temperature dependence	0.01	% by volume /10K	<0.3% volume 10 K	Yes
Combined interference	0.14	% range	<2% range	Yes
Dependence on voltage	0.1	% by volume /10V	< 0.1%vol /10 volt	Yes
Losses in the line (leak)	0.20	% of value	< 2% of value	Yes
Uncertainty of calibration gas	2	% of value	< 2% of value	Yes

Performance characteristic	Uncertainty	Value of uncertainty quantity
Standard deviation of repeatability at zero	ur0	-
Standard deviation of repeatability at span level	urs	0.001
Lack of fit	ufit	0.075
Drift	u0dr	0.117
volume or pressure flow dependence	uspres	0.001
atmospheric pressure dependence	uapres	0.115
ambient temperature dependence	utemp	0.003
Combined interference (from mcerts)	-	0.081
dependence on voltage	uvolt	0.029
losses in the line (leak)	uleak	0.013
Uncertainty of calibration gas	ucalib	0.135

Measurement uncertainty (Concentration Measured)	11.69	%vol
Combined uncertainty	0.24	%vol
% of value	2.07	%

<b>Expanded uncertainty expressed with a level of confidence of 95%</b>	<b>4.14</b>	<b>% of value</b>
---	-------------	-------------------

<b>Expanded uncertainty expressed with a level of confidence of 95%</b>	<b>0.48</b>	<b>% vol</b>
---	-------------	--------------

Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - OXYGEN**

DAY 3 - 07 March 2014

Reference	11	%vol
Measured concentration	12.41	%vol
Calibration gas	10.01	%vol
Full Scale	25	%vol

Performance characteristics	Value	Units	specification	MU Met?
Response time	30	seconds	< 200 s	Yes
Logger sampling interval	60	seconds	-	-
Measurement period	426	minutes	-	-
Number of readings in measurement	426	-	-	-
Repeatability at zero	0.015	% by volume	<0.2 % range	Yes
Repeatability at span level	0.014	% by volume	<0.4 % range	Yes
Deviation from linearity	0.13	% vol	<0.3 % volume	Yes
Zero drift (during measurement period)	-0.48	% vol at zero level	<2% of volume / 24hr	Yes
Span drift (during measurement period)	-0.10	% vol at span level	<2% volume/24hr	Yes
volume or pressure flow dependence	0.02	% of fs / 10l/h	<1% range	Yes
atmospheric pressure dependence	0.8	% of fs/kPa	< 1.5 % range	Yes
ambient temperature dependence	0.01	% by volume /10K	<0.3% volume 10 K	Yes
Combined interference	0.14	% range	<2% range	Yes
Dependence on voltage	0.1	% by volume /10V	< 0.1%vol /10 volt	Yes
Losses in the line (leak)	0.20	% of value	< 2% of value	Yes
Uncertainty of calibration gas	2	% of value	< 2% of value	Yes

Performance characteristic	Uncertainty	Value of uncertainty quantity
Standard deviation of repeatability at zero	ur0	-
Standard deviation of repeatability at span level	urs	0.001
Lack of fit	ufit	0.075
Drift	u0dr	-0.349
volume or pressure flow dependence	uspres	0.001
atmospheric pressure dependence	uapres	0.115
ambient temperature dependence	utemp	0.003
Combined interference (from mcerts)	-	0.081
dependence on voltage	uvolt	0.029
losses in the line (leak)	uleak	0.014
Uncertainty of calibration gas	ucalib	0.143

Measurement uncertainty (Concentration Measured)	12.41	%vol
Combined uncertainty	0.41	%vol
% of value	3.31	%

<b>Expanded uncertainty expressed with a level of confidence of 95%</b>	<b>6.62</b>	<b>% of value</b>
---	-------------	-------------------

<b>Expanded uncertainty expressed with a level of confidence of 95%</b>	<b>0.82</b>	<b>% vol</b>
---	-------------	--------------

Developed for the STA by R Robinson, NPL

APPENDIX 4 - Summaries, Calculations, Raw Data and Charts

NOTE - The following data is provided for information only and falls outside ESG's scope of accreditation

COMBINED UNCOLLECTED SUMMARY							
Test	Sampling Times	>PM <sub>10</sub> Concentration		Probe Rinse Concentration		Combined Unweighed Concentration	
		Measured	LOD	Measured	LOD	Measured	LOD
		mg/m <sup>3</sup>	mg/m <sup>3</sup>	mg/m <sup>3</sup>	mg/m <sup>3</sup>	mg/m <sup>3</sup>	mg/m <sup>3</sup>
Run 1	15:06 - 18:06 05 March 2014	0.009	0.009	0.243	0.243	0.252	0.252
Run 2	09:03 - 12:03 06 March 2014	0.009	0.009	0.239	0.239	0.249	0.249
Run 3	12:35 - 15:35 06 March 2014	0.009	0.009	0.240	0.240	0.249	0.249
Run 4	16:09 - 19:09 06 March 2014	0.010	0.010	0.258	0.258	0.268	0.268
Run 5	08:49 - 11:49 07 March 2014	0.011	0.011	0.275	0.275	0.285	0.285
Run 6	12:55 - 15:55 07 March 2014	0.010	0.010	0.254	0.254	0.264	0.264

Reference conditions are 273K, 101.3kPa, dry gas 11% Oxygen.

Where the result is less than the LOD, the LOD is reported.

SAMPLES									
Test	>PM <sub>10</sub> Filter Number	Filter Start Weight	Filter End Weight	Mass Gained on Filter	Probe Rinse Number	Probe Rinse Start Weight	Probe Rinse End Weight	Mass Gained in Rinse	Combined Total Mass Gained
		g	g	g		g	g	g	g
Run 1	QC978/QC980	47.6435	47.6434	-0.00011	QC978/QC980	184.4871	184.4874	0.00030	0.00019
Run 2	QC979/QC981	47.4950	47.4950	0.00004	QC979/QC981	188.86250	188.86250	0.00000	0.00004
Run 3	QC993/QC997	47.4912	47.4910	-0.00027	QC993/QC997	160.08390	160.08330	-0.00060	-0.00087
Run 4	QC994/QC998	48.1587	48.1584	-0.00028	QC994/QC998	179.02650	179.02780	0.00130	0.00102
Run 5	QC1001/QC999	48.2693	48.2689	-0.00037	QC1001/QC999	144.96360	144.96450	0.00090	0.00053
Run 6	QC1002/QC1000	48.1828	48.1828	-0.00007	QC1002/QC1000	185.67260	185.67300	0.00040	0.00033
Blank 1	QC987/QC982	48.1846	48.1847	0.00013	QC908/QC947	195.95230	195.95230	0.00000	0.00013
Blank 2	QC908/QC947	48.6873	48.6871	-0.00025	QC908/QC947	183.51920	183.51910	-0.00010	-0.00035
Blank 3	QC945/QC962	48.6959	48.6954	-0.00050	QC945/QC962	190.84600	190.84590	-0.00010	-0.00060



Paul Gothe GmbH Wittener Str. 82 D-44789 Bochum

To our customers

Wittener Straße 82  
D-44789 Bochum

Phone.: ++49-234 33 51 80  
Fax:++49 234) 30 82 17  
<http://www.paulgothe.de>  
[service@paulgothe.de](mailto:service@paulgothe.de)  
VAT-No.: DE 813078723  
Trade Register Bochum: HRB-6891

Your ref

Your letter

Our ref

Date 14.03.2007

Calibration of the Johnas Impactor according to ISO 23210

#### 6.2 Separation curves and Section 6.3 Verification of the separation curves

The Johnas Impactor from Paul Gothe GmbH was developed before the ISO Guideline was evaluated and after the Germans and the Netherlands Authorities have enough experiences with our impactor. After that the European Delegation creates the ISO Guideline 23210. The section 6.3 is important and was influence by the Germans. They have the experiences and write the rules for the calibration section accordingly it was made for the Johnas-Impactor.

The development from the Johnas impactor starts with a doctoral thesis from Mrs. John at the Gerhard-Mercator-University. She makes the intensive testing and Mr. Geueke from the North Rhine Westphalia State Environment Agency makes additional verifications at the ESA (Emission Simulation Facility) at the Hessian Agency for the Environment and Geology (HLUG).

Most of the literatures and papers are in German, but all well-known:

1. Probenahme und chemische Analytik von Korngrößenfraktionierten Immissions- und Emissionsaerosolen. Von der Fakultät für Naturwissenschaften der Gerhard-Mercator-Universität – Gesamthochschule Duisburg zur Erlangung des akademischen Grades eines Dr. rer. nat. genehmigte Dissertation von ASTRID CHRISTIANE JOHN aus Lichtenfels.
2. Umweltforschungsplan des Bundesministers für Umwelt, Naturschutz und Reaktorsicherheit Luftreinhalte Forschungsbericht 298 44 280, Korngrößenverteilung (PM10 und PM2,5) von Staubemissionen relevanter stationärer Quellen (Teil II zu 297 44 853), von Dipl.-Ing. A. Dreiseidler, Ing. D. Straub, Prof. Dr.-Ing. G. Baumbach, Universität Stuttgart, Institut für Verfahrenstechnik und Dampfkesselwesen (IVD), Abteilung Reinhaltung der Luft (RdL), Institutsleiter: Prof. Dr.-Ing. K.R.G. Hein, IM AUFTRAG DES UMWELTBUNDESAMTES Juni 2001.
3. VDI 2066, part 10
4. Gefahrstoffe-Reinhaltung der Luft 59 (1999), Nr.11/12, S. 449-453

All this papers shows, that the design of the Johnas Impactor is a proved version for the determination of the PM 2.5 and PM 10. The shape of the separation curves is similar to those specified in ISO 7708:1995 and the separation efficiency at 10 µm and 2,5 µm is 50 % according to section 6.3 of the ISO 23210.

What you need more? There is no authority which has more competence as the listed authorities.

If you still in doubt, you maybe get in contact with Mr. Geueke (phone: ++49-201-7995-1263).

Paul Gothe GmbH

Westdeutsche Landesbank for Sparkasse Bochum  
IBAN DE 24 430500 01 000 120 9840 Swift: WELADED1BOC

Companion: Paul Gothe-Stiftung  
Management: Dr. T. Grodten and Th. Hinrichs





Paul Gothe GmbH Wittener Str. 82 D-44789 Bochum

To our customers

Wittener Straße 82  
D-44789 Bochum

Phone.: ++49-234 33 51 80  
Fax:++49 234) 30 82 17  
<http://www.paulgothe.de>  
[service@paulgothe.de](mailto:service@paulgothe.de)  
VAT-No.: DE 813078723  
Trade Register Bochum: HRB-6891

Your ref

Your letter

Our ref

Date 14.03.2007

### Declaration of conformity


Herewith the company Paul Gothe GmbH in Bochum declare that the manufactured Cascade Impactor Johnas follows the guidelines from the North Rhine Westphalia State Environment Agency according the convention from 24 June 1999 and the PM 4 stage follows the convention of the Federal Environment Agency from 09. March 2005.

Our Cascade Impactor Johnas was developed in cooperation with the North Rhine Westphalia State Environment and the Gerhard-Mercator University Duisburg. This impactor was validated and after that 2004 adopted in the German Standard VDI 2066, part 10 and 2005 in ISO Standard 23210. All sizes of our manufactured impactors are according to these guidelines, individually checked according our strict quality management and named with a specific serial number. Only an impactor with this serial number is according to the Guideline VDI 2066, part 10 and ISO Standard 23210 and can use for the determination of PM 10 and PM 2.5.

Paul Gothe GmbH

Dr. Torsten Grodten

-manager-





**END OF REPORT**

## Appendix 3 – Stack emissions monitoring report: Lakeside Energy From Waste Ltd

# STACK EMISSIONS MONITORING REPORT



Acacia Building  
Vantage Point Business Village  
Mitcheldean  
GL17 0DD  
Tel: 01594 546 343

Your contact at ESG
Laurence Sharrock Business Manager - South Tel: 01594 546 343 Email: laurence.sharrock@esg.co.uk

Operator & Address:
Lakeside Energy From Waste Limited Lakeside Road Colnbrook Slough Berkshire SL3 0FE - -

Permit
N/A - Investigative Monitoring

Release Point:
A1

Sampling Date(s):
19th to 21st March 2014

ESG Job Number:	LCH00710
Report Date:	16th Feb 2015
Version:	1
Report By:	Chris Houston
MCERTS Number:	MM 11 1135
MCERTS Level:	MCERTS Level 1 - Technician
Technical Endorsements:	
Report Approved By:	Andy Tiffen
MCERTS Number:	MM 05 640
Business Title:	MCERTS Level 2 - Projects Manager
Technical Endorsements:	1, 2 & 4
Signature:	



## CONTENTS

### EXECUTIVE SUMMARY

#### Stack Emissions Monitoring Objectives

- Plant
- Operator
- Stack Emissions Monitoring Test House

#### Emissions Summary

#### Monitoring Times

#### Process Details

#### Monitoring Methods

#### Analytical Methods

- Sampling Methods with Subsequent Analysis
- On-Site Testing

#### Sampling Location

- Sampling Plane Validation Criteria
- Duct Characteristics
- Sampling Lines & Sample Points
- Sampling Platform
- Sampling Location / Platform Improvement Recommendations

#### Sampling and Analytical Method Deviations

#### Determination of representative sampling location

### APPENDICES

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

APPENDIX 3 - Measurement Uncertainty Budget Calculations

## EXECUTIVE SUMMARY

### MONITORING OBJECTIVES

Lakeside Energy From Waste Limited operates a municipal and commercial waste incineration process at Colnbrook

Environmental Scientifics Group Limited were commissioned by Ricardo AEA to carry out stack emissions monitoring to determine the release of PM<sub>10</sub> & PM<sub>2.5</sub> from the following Plant under standard operating conditions.

The measurements were commissioned by Ricardo-AEA on behalf of the Department of Environment, Food and Rural Affairs (Defra) to provide information for the UK National Atmospheric Emissions Inventory (NAEI).

#### **Plant**

A1

#### **Operator**

Lakeside Energy From Waste Limited  
Lakeside Road  
Colnbrook  
Slough  
Berkshire  
SL3 0FE  
-

#### **Stack Emissions Monitoring Test House**

Environmental Scientifics Group Limited - Mitcheldean Laboratory  
Acacia Building  
Vantage Point Business Village  
Mitcheldean  
GL17 0DD  
UKAS and MCERTS Accreditation Number: 1015

Opinions and interpretations expressed herein are outside the scope of UKAS accreditation.

MCERTS accredited results will only be claimed where both the sampling and analytical stages are UKAS accredited.

This test report shall not be reproduced, except in full, without written approval of Environmental Scientifics Group Limited.

## EXECUTIVE SUMMARY

EMISSIONS SUMMARY					
Parameter	Units	Result	Calculated Uncertainty +/-	Limit	MCERTS accredited result
PM <sub>10</sub> (Average result of 4 runs)	mg/m <sup>3</sup>	0.028	0.02	-	✓
PM <sub>10</sub> Emission Rate (Average result of 4 runs)	g/hr	4.20	3.4	-	
PM <sub>2.5</sub> (Average result of 4 runs)	mg/m <sup>3</sup>	0.005	0.01	-	✓
PM <sub>2.5</sub> Emission Rate (Average result of 4 runs)	g/hr	0.77	1.39	-	
<b>PM<sub>10</sub> - Runs</b>					
PM <sub>10</sub> - Run 1	mg/m <sup>3</sup>	0.008	0.01	-	✓
PM <sub>10</sub> Emission Rate - Run 1	g/hr	1.24	1.0	-	
PM <sub>10</sub> - Run 2	mg/m <sup>3</sup>	0.042	0.03	-	✓
PM <sub>10</sub> Emission Rate - Run 2	g/hr	6.50	5.3	-	
PM <sub>10</sub> - Run 3	mg/m <sup>3</sup>	0.027	0.02	-	✓
PM <sub>10</sub> Emission Rate - Run 3	g/hr	4.01	3.3	-	
PM <sub>10</sub> - Run 4	mg/m <sup>3</sup>	0.034	0.03	-	✓
PM <sub>10</sub> Emission Rate - Run 4	g/hr	5.07	4.2	-	
<b>PM<sub>2.5</sub> - Runs</b>					
PM <sub>2.5</sub> - Run 1	mg/m <sup>3</sup>	0.005	0.01	-	✓
PM <sub>2.5</sub> Emission Rate - Run 1	g/hr	1.24	2.2	-	
PM <sub>2.5</sub> - Run 2	mg/m <sup>3</sup>	0.006	0.01	-	✓
PM <sub>2.5</sub> Emission Rate - Run 2	g/hr	0.98	1.8	-	
PM <sub>2.5</sub> - Run 3	mg/m <sup>3</sup>	<b>0.003</b>	0.01	-	✓
PM <sub>2.5</sub> Emission Rate - Run 3	g/hr	0.46	0.83	-	
PM <sub>2.5</sub> - Run 4	mg/m <sup>3</sup>	0.006	0.01	-	✓
PM <sub>2.5</sub> Emission Rate - Run 4	g/hr	0.87	1.58	-	
Carbon Dioxide	% v/v	0.00	0.0	-	✓
Oxygen	% v/v	5	1.01	-	✓
Moisture	%	12.9	0.8	-	✓
Stack Gas Temperature	°C	146	-	-	✓
Stack Gas Velocity	m/s	17.0	-	-	
Gas Volumetric Flow Rate (Actual)	m <sup>3</sup> /hr	211837	-	-	
Gas Volumetric Flow Rate (STP, Wet)	m <sup>3</sup> /hr	134761	-	-	
Gas Volumetric Flow Rate (STP, Dry)	m <sup>3</sup> /hr	107561	-	-	
Gas Volumetric Flow Rate at Reference Conditions	m <sup>3</sup> /hr	152825	-	-	

ND = None Detected,

Results at or below the limit of detection are highlighted by bold italic text.

The above volumetric flow rate is calculated using data from test specific flow data. Mass emissions for non isokinetic tests and isokinetic tests are calculated using these values

Reference conditions are 273K, 101.3kPa, dry gas 11% Oxygen.

## EXECUTIVE SUMMARY

MONITORING TIMES			
Parameter	Sampling Date(s)	Sampling Times	Sampling Duration
PM <sub>10</sub> Run 1	19 March 2014	09:16 - 15:16	360 minutes
PM <sub>10</sub> Run 2	19 March 2014	16:09 - 19:09	180 minutes
PM <sub>10</sub> Run 3	20 March 2014	07:42 - 13:42	360 minutes
PM <sub>10</sub> Run 4	20 March 2014	14:32 - 17:32	175 minutes
PM <sub>2.5</sub> Run 1	19 March 2014	09:16 - 15:16	360 minutes
PM <sub>2.5</sub> Run 2	19 March 2014	16:09 - 19:09	180 minutes
PM <sub>2.5</sub> Run 3	20 March 2014	07:42 - 13:42	360 minutes
PM <sub>2.5</sub> Run 4	20 March 2014	14:32 - 17:32	175 minutes
Stack Gas Flow Rate & Temperature Run 1	19 March 2014	07:45	-
Stack Gas Flow Rate & Temperature Run 2	19 March 2014	19:45	-
Stack Gas Flow Rate & Temperature Run 3	20 March 2014	07:30	-
Stack Gas Flow Rate & Temperature Run 4	20 March 2014	14:15	-
Stack Gas Flow Rate & Temperature Run 5	20 March 2014	17:50	-

## EXECUTIVE SUMMARY

PROCESS DETAILS	
Parameter	Process Details
Description of process	Municipal and commercial waste incineration
Continuous or batch	Continuous
Product Details	Energy from waste
Part of batch to be monitored (if applicable)	N/A
Normal load, throughput or continuous rating	88 tonnes/hr
Fuel used during monitoring	Waste supplemented by gas oil
Abatement	Lime, activated carbon & ammonia injection with bag filters
Plume Appearance	Not visible from monitoring location



## EXECUTIVE SUMMARY

### Monitoring Methods

The selection of standard reference / alternative methods employed by Environmental Scientifics Group Limited is determined, wherever possible by the hierarchy of method selection outlined in Environment Agency Technical Guidance Note (Monitoring) M2. i.e. CEN, ISO, BS, US EPA etc.

MONITORING METHODS						
Species	Method Standard Reference Method / Alternative Method	ESG Technical Procedure	UKAS Lab Number	MCERTS Accredited Method	Limit of Detection (LOD)	Calculated MU +/- %
PM <sub>10</sub>	SRM - BS EN 23210	AE 136	1015	Yes	0.006 mg/m <sup>3</sup>	82 %
PM <sub>2.5</sub>	SRM - BS EN 23210	AE 136	1015	Yes	0.003 mg/m <sup>3</sup>	181 %
CO <sub>2</sub>	AM - M22/FTIR	AE 063	1015	Yes	0 %	9.39%
O <sub>2</sub>	SRM - BS EN 14789	AE 102	1015	Yes	0.01%	20.9%
H <sub>2</sub> O	AM - M22/FTIR	AE 063	1015	Yes	0.09 %	6.4%
Flow Rate / Temp.	SRM - BS EN 13284-1	AE 122	1015	Yes	5 Pa	-

The measurement uncertainties for the PM<sub>10</sub> and PM<sub>2.5</sub> measurements reflect that measured concentrations were near or below the Limit of Detection.

## EXECUTIVE SUMMARY

### Analytical Methods

The following tables list the analytical methods employed together with the custody and archiving details:

SAMPLING METHODS WITH SUBSEQUENT ANALYSIS							
Species	Analytical Technique	Analytical Procedure	UKAS Lab Number	UKAS Accredited Lab Analysis	Analysis Lab (ESG or Subcontract)	Sample Archive Location	Archive Period
PM <sub>10</sub>	Gravimetric	AE 106	1015	Yes	ESG Mitcheldean	ESG Mitcheldean	1 year
PM <sub>2.5</sub>	Gravimetric	AE 106	1015	Yes	ESG Mitcheldean	ESG Mitcheldean	1 year

ON-SITE TESTING							
Species	Analytical Technique	Analytical Procedure	UKAS Lab Number	MCERTS Accredited Analysis	Laboratory	Data Archive Location	Archive Period
CO <sub>2</sub>	Fourier Transform - Infra Red	AE 063	1015	Yes	ESG Mitcheldean	ESG Mitcheldean	5 years
O <sub>2</sub>	Paramagnetism	AE 102	1015	Yes	ESG Mitcheldean	ESG Mitcheldean	5 years
H <sub>2</sub> O	Fourier Transform - Infra Red	AE 063	1015	Yes	ESG Mitcheldean	ESG Mitcheldean	5 years

## EXECUTIVE SUMMARY

SAMPLING LOCATION					
Sampling Plane Validation Criteria	Value	Units	Requirement	Compliant	Method
Lowest Differential Pressure	181	Pa	>= 5 Pa	Yes	BS EN 13284-1
Lowest Gas Velocity	16.69	m/s	-	-	-
Highest Gas Velocity	17.76	m/s	-	-	-
Ratio of Gas Velocities	1.06	-	< 3 : 1	Yes	BS EN 13284-1
Mean Velocity	17.02	m/s	-	-	-
Maximum angle of flow with regard to duct axis	<15	°	< 15°	Yes	BS EN 13284-1
No local negative flow	Yes	-	-	Yes	BS EN 13284-1

DUCT CHARACTERISTICS		
	Value	Units
Shape	Circular	-
Depth	2.08	m
Width	-	m
Area	3.40	m <sup>2</sup>
Port Depth	90	mm

SAMPLING LINES & POINTS			
	Isokinetic (CEN Methods)	Isokinetic (ISO Methods)	Non-Iso & Gases
Sample port size	5" Flange	-	1"
Number of lines used	1	-	1
Number of points / line	1	-	1
Duct orientation	Vertical	-	Vertical
Filtration	In Stack	-	In Stack

SAMPLING PLATFORM	
General Platform Information	
Permanent / Temporary Platform / Ground level / Floor Level / Roof	Permanent
Inside / Outside	Inside

M1 Platform requirements	
Is there a sufficient working area so work can be performed in a compliant manner	Yes
Platform has 2 levels of handrails (approximately 0.5 m & 1.0 m high)	Yes
Platform has vertical base boards (approximately 0.25 m high)	Yes
Platform has removable chains / self closing gates at the top of ladders	Yes
Handrail / obstructions do not hamper insertion of sampling equipment	Yes
Depth of Platform = >Stack depth / diameter + wall and port thickness + 1.5m	Yes

### Sampling Platform Improvement Recommendations (if applicable)

The sampling location meets all the requirements as specified in EA Guidance Note M1.

## EXECUTIVE SUMMARY

### Sampling & Analytical Method Deviations

#### **Pitot static pressure measurements**

During the six hour runs, readings were taken every ten minutes as opposed to the recommended five, however site staff checked settings between this time to ensure continuity.

#### **Sample flow variation**

The sample flowrate could not be maintained within 5% of the nominal flow throughout the testing periods (which were over extended periods due to the anticipated low PM emission concentrations). Whilst this will have affected the actual cutpoints achieved by the impactor, the results are all at or very near the LOD for the tests and hence this is anticipated to have limited impact on the outcome of the measurements.

#### **Goose-neck nozzle Validation**

Due to the long port sleeve, it was physically impossible to insert the cascade impactor using the straight entry nozzle setup recommended in BS EN 23210. Therefore the use of a goose-neck setup was used as this was the only feasible method for monitoring. The standard requires that the use of a goose-neck nozzle is validated, however on this occasion it has not been possible to demonstrate that losses in the nozzle meet the criteria in the standard because the measured concentrations were low and the weight of particulate recovered from the nozzle rinses and the filter media were at or near the weighing LoD. In the context of the low emission concentrations determined during the measurements (all less than 0.1 mg/Nm<sup>3</sup>), losses in the sampling nozzle are unlikely to increase the concentrations significantly.

### Determination of representative sampling location

An assessment of temperature homogeneity was performed in accordance with EN 23210 Annex-G on the first day of monitoring 5th March 2014. There was a feedstock change on the morning of the third day 7th March 2014 from municipal waste to Community Recycling Centre waste. A further homogeneity test was performed on 7th March and the representative sampling point was determined to be at the same location as on 5th March.

APPENDICES

**CONTENTS**

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

APPENDIX 3 - Measurement Uncertainty Budget Calculations

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

<b>MONITORING SCHEDULE</b>					
<b>Species</b>	<b>Method</b> Standard Reference Method / Alternative Method	<b>ESG</b> <b>Technical</b> <b>Procedure</b>	<b>UKAS Lab</b> <b>Number</b>	<b>MCERTS</b> <b>Accredited</b> <b>Method</b>	<b>Number of</b> <b>Samples</b>
PM <sub>10</sub>	SRM - BS EN 23210	AE 136	1015	Yes	4
PM <sub>2.5</sub>	SRM - BS EN 23210	AE 136	1015	Yes	4
CO <sub>2</sub>	AM - M22/FTIR	AE 063	1015	Yes	1
O <sub>2</sub>	SRM - BS EN 14789	AE 102	1015	Yes	4
H <sub>2</sub> O	AM - M22/FTIR	AE 063	1015	Yes	4
Flow Rate / Temp.	SRM - BS EN 13284-1	AE 122	1015	Yes	5

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

CALIBRATEABLE EQUIPMENT CHECKLIST					
Extractive Sampling		Instrumental Analyser/s		Miscellaneous	
Equipment	Equipment I.D.	Equipment	Equipment I.D.	Equipment	Equipment I.D.
Control Box DGM	P2023	Horiba PG-250 Analyser	-	Laboratory Balance	-
Box Thermocouples	P2023	FT-IR	P2060	Tape Measure	P1935
Meter In Thermocouple	P2023	FT-IR Oven Box	-	Stopwatch	-
Meter Out Thermocouple	P2023	Bernath 3006 FID	-	Protractor	-
Control Box Timer	P2023	Signal 3030 FID	-	Barometer	P2090
Oven Box	-	Servomex	-	Digital Micromanometer	P1599
Probe	-	JCT Heated Head Filter	-	Digital Temperature Meter	P2045
Probe Thermocouple	-	Thermo FID	-	Stack Thermocouple	P2254 + P2055
Probe	-	Stackmaster	-	Mass Flow Controller	-
Probe Thermocouple	-	FTIR Heater Box for Heated Line	-	MFC Display module	-
S-Pitot	P2246	Anemometer	-	1m Heated Line (1)	-
L-Pitot	-	Ecophysics NOx Analyser	-	1m Heated Line (2)	-
Site Balance	-	Chiller (JCT/MAK 10)	-	1m Heated Line (3)	-
Last Impinger Arm	P1966	Heated Line Controller (1)	-	5m Heated Line (1)	-
Dioxins Cond. Thermocouple	-	Heated Line Controller (2)	-	10m Heated Line (1)	-
Callipers	-	Site temperature Logger	-	10m Heated Line (2)	-
Small DGM	-	Impactor 1	NR18706	15m Heated Line (1)	-
Heater Controller	-		-	20m Heated Line (1)	-
Inclinometer (Swirl Device)	-		-	20m Heated Line (2)	-

NOTE: If the equipment I.D is represented by a dash (-), then this piece of equipment has not been used for this test.

CALIBRATION / CHECK GASES					
Gas (traceable to ISO 17025)	Cylinder I.D Number	Supplier	ppm	%	Analytical Tolerance +/- %
Oxygen	DA B2	BOC	-	10.06	2
Methane	DA B2	BOC	87.1	-	2
Carbon Dioxide	DA B2	BOC	-	12	2

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

**STACK EMISSIONS MONITORING TEAM**

Team Leader

Paul Jones  
MCERTS Level 2  
Te1 Expiry Date - Dec 2016  
Te2 Expiry Date - Dec 2016  
Te3 Expiry Date - Mar 2018  
Te4 Expiry Date - Dec 2016  
MM 02 044  
MCERTS Expiry Date - Mar 2018  
H&S Expiry Date - Sep 2015

Technician

Rad Poremba  
MCERTS Level 1  
MM 10 1069  
MCERTS Expiry Date - Jul 2015  
H&S Expiry Date - Jul 2015



APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

PM <sub>10</sub> SUMMARY					
Test	Sampling Times	Concentration mg/m <sup>3</sup>	LOD mg/m <sup>3</sup>	Limit mg/m <sup>3</sup>	Emission Rate g/hr
Run 1	09:16 - 15:16 19 March 2014	0.008	0.006	-	1.24
Run 2	16:09 - 19:09 19 March 2014	0.042	0.006	-	6.50
Run 3	07:42 - 13:42 20 March 2014	0.027	0.006	-	4.01
Run 4	14:32 - 17:32 20 March 2014	0.034	0.016	-	5.07
Blank 1	-	0.011	-	-	-
Blank 2	-	0.008	-	-	-

Reference conditions are 273K, 101.3kPa, dry gas 11% Oxygen.  
where values are below the LOD the LOD will be reported.

PM <sub>2.5</sub> SUMMARY					
Test	Sampling Times	Concentration mg/m <sup>3</sup>	LOD mg/m <sup>3</sup>	Limit mg/m <sup>3</sup>	Emission Rate g/hr
Run 1	09:16 - 15:16 19 March 2014	0.005	0.003	-	0.76
Run 2	16:09 - 19:09 19 March 2014	0.006	0.003	-	0.98
Run 3	07:42 - 13:42 20 March 2014	0.003	0.003	-	0.46
Run 4	14:32 - 17:32 20 March 2014	0.006	0.008	-	0.87
Blank 1	-	0.020	-	-	-
Blank 2	-	0.006	-	-	-

Reference conditions are 273K, 101.3kPa, dry gas 11% Oxygen.  
where values are below the LOD the LOD will be reported, where this occurs the quoted uncertainties will be relatively high.

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

PM <sub>2.5</sub> (BF) SAMPLES WEIGHTS				
Test	PM <sub>2.5</sub> Filter Number	Filter Start Weight g	Filter End Weight g	PM <sub>2.5</sub> Mass Gained on Filter g
Run 1	QC955	16.34679	16.34687	0.00008
Run 2	QC1017	32.67253	32.67227	-0.00026
Run 3	QC1025	32.70278	32.70203	-0.00075
Run 4	QC1020	31.96708	31.96685	-0.00023
Blank 1	QC973	31.76137	31.76162	0.00025
Blank 2	QC1019	31.64873	31.64881	0.00008

PM <sub>10</sub> (CP2) SAMPLES WEIGHTS				
Test	PM <sub>10</sub> Filter Number g	Filter Start Weight g	Filter End Weight g	PM <sub>10</sub> Mass Gained on Filter g
Run 1	QC962	32.63680	32.63641	-0.00039
Run 2	QC1004	51.80857	51.80885	0.00028
Run 3	QC1025	15.92885	15.92924	0.00039
Run 4	QC127	15.81262	15.81286	0.00024
Blank 1	QC970	15.77666	15.77655	-0.00011
Blank 2	QC1026	15.50902	15.50888	-0.00014

PM <sub>2.5</sub> & PM <sub>10</sub> (BF & CP2) SAMPLES WEIGHTS COMBINED							
Test	PM <sub>2.5</sub> Filter Number	PM <sub>10</sub> Filter Number	PM <sub>2.5</sub> Mass Gained on Filter g	PM <sub>10</sub> Mass Gained on Filter g	Actual PM <sub>2.5</sub> & PM <sub>10</sub> Combined Total Mass Gained g	PM <sub>2.5</sub> & PM <sub>10</sub> Combined Weighing LOD g	*Reported PM <sub>2.5</sub> & PM <sub>10</sub> Combined Total Mass Gained g
Run 1	QC955	QC962	0.00008	-0.00039	-0.00031	0.00010	0.00013
Run 2	QC1017	QC1004	-0.00026	0.00028	0.00002	0.00010	0.00033
Run 3	QC1025	QC1025	-0.00075	0.00039	-0.00036	0.00010	0.00044
Run 4	QC1020	QC127	-0.00023	0.00024	0.00001	0.00010	0.00029
Blank 1	QC973	QC970	0.00025	-0.00011	0.00014	0.00010	0.00014
Blank 2	QC1019	QC1026	0.00008	-0.00014	-0.00006	0.00010	0.00010

\* Where weighing values are below the LOD possibly due to loss of filter material, the LOD will be reported.

NOTE - Where the filter weight gain is less than the weighing uncertainty, the weighing uncertainty is used for further calculations. The weighing uncertainty is 0.00005g.

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS RUN 1			PM <sub>10</sub> & PM <sub>2.5</sub>	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	739.5	CO <sub>2</sub>	9.63
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	2.2	O <sub>2</sub>	6.79
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	739.7	Total	16.42
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			N <sub>2</sub> (100 -Total)	83.58
Moisture trap weight increase, V <sub>lc</sub>	g	H <sub>2</sub> O by FTIR	M <sub>d</sub> = 0.44(%CO <sub>2</sub> )+0.32(%O <sub>2</sub> )+0.28(%N <sub>2</sub> )	29.81
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	<b>Molecular weight of wet gas, M<sub>s</sub></b>	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			M <sub>s</sub> = M <sub>d</sub> (1 - B <sub>wo</sub> ) + 18(B <sub>wo</sub> )	27.43
Volume of gas sample through gas meter, V <sub>m</sub>		9.80	<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Gas meter correction factor, Y <sub>d</sub>		1.34	Area of stack, A <sub>s</sub>	m <sup>2</sup> 3.40
Mean dry gas meter temperature, T <sub>m</sub>		25.44	Q <sub>a</sub> = (60)(A <sub>s</sub> )(V <sub>s</sub> )	m <sup>3</sup> /min 3703.3
Mean pressure drop across orifice, ΔH	mmH <sub>2</sub> O	90.00	<b>Percent isokinetic, %I</b>	
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		11.819	Required Flow Rate @ DGM	l/min 28.10
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Actual Flow Rate @ DGM	l/min 30.5
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	14.8075	Isokinetic Rate	108.44
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			Acceptable 90% - 130%	Yes
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	<b>Particulate Concentration, C<sub>PM10</sub></b>	
% oxygen measured in gas stream, act%O <sub>2</sub>		6.79	Mass of particulate collected on PM <sub>10</sub> filter, M <sub>f</sub>	0.00005
% oxygen reference condition		11	Mass of particulate collected on PM <sub>2.5</sub> filter, M <sub>f</sub>	0.00008
O <sub>2</sub> Reference	O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>	1.42	$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.00878
Factor	$\frac{21.0 - ref\%O_2}{21.0 - act\%O_2}$		$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.01100
$V_{mstd@X\%oxygen} = (V_{mstd}) (O_2 Ref)$	m <sup>3</sup>	16.795	$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.00774
<b>Moisture content, B<sub>wo</sub></b>			<b>Particulate Emission Rates, E</b>	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	20.18	E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	1.24
<b>Moisture by FTIR</b>	%	20.18	<b>Particulate Concentration, C<sub>PM2.5</sub></b>	
<b>Velocity of stack gas, V<sub>s</sub></b>			Mass of particulate collected on filter, M <sub>f</sub>	0.00008
Pitot tube velocity constant, K <sub>p</sub>		34.97	$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.0054
Velocity pressure coefficient, C <sub>p</sub>		0.81	$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.0068
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	19.89	$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0048
Mean square root of velocity heads, √ΔP		4.5	<b>Particulate Emission Rates, E</b>	
Mean stack gas temperature, T <sub>s</sub>	°C	146	E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	0.76
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	18.16		

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS RUN 2			PM <sub>10</sub> & PM <sub>2.5</sub>	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	748.5	CO <sub>2</sub>	9.28
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	2.2	O <sub>2</sub>	7.64
$P_s = P_b + (P_{static})$	mm Hg	748.7	Total	16.92
$\frac{P_s}{13.6}$			N <sub>2</sub> (100 -Total)	83.08
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2)$	
Moisture trap weight increase, V <sub>lc</sub>	g	H <sub>2</sub> O by FTIR	<b>Molecular weight of wet gas, M<sub>s</sub></b>	
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	$M_s = M_d(1 - B_{wo}) + 18(B_{wo})$	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Volume of gas sample through gas meter, V <sub>m</sub>		4.82	Area of stack, A <sub>s</sub>	m <sup>2</sup> 3.40
Gas meter correction factor, Y <sub>d</sub>		1.34	$Q_a = (60)(A_s)(V_s)$	m <sup>3</sup> /min 3667.4
Mean dry gas meter temperature, T <sub>m</sub>		27.53	<b>Percent isokinetic, %I</b>	
Mean pressure drop across orifice, ΔH	mmH <sub>2</sub> O	87.83	Required Flow Rate @ DGM	l/min 29.90
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		5.839	Actual Flow Rate @ DGM	l/min 30.3
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Isokinetic Rate	
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	7.1670	Acceptable 90% - 130%	
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			<b>Particulate Concentration, C<sub>PM10</sub></b>	
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	Mass of particulate collected on PM <sub>10</sub> filter, M <sub>f</sub>	0.00028
% oxygen measured in gas stream, act%O <sub>2</sub>		7.64	Mass of particulate collected on PM <sub>2.5</sub> filter, M <sub>f</sub>	0.00005
% oxygen reference condition		11	$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.0460
O <sub>2</sub> Reference O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>		1.34	$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.0565
Factor 21.0 - ref%O <sub>2</sub>			$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0423
$V_{mstd@X\%oxygen} = (V_{mstd})(O_2 Ref)$	m <sup>3</sup>	7.801	<b>Particulate Emission Rates, E</b>	
<b>Moisture content, B<sub>wo</sub></b>			$E = [(C_{wet})(Q_{stw})(60)] / 1000$	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	18.53	6.50	
<b>Moisture by FTIR</b>			<b>Particulate Concentration, C<sub>PM2.5</sub></b>	
	%	18.53	Mass of particulate collected on filter, M <sub>f</sub>	0.00005
<b>Velocity of stack gas, V<sub>s</sub></b>			$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.0070
Pitot tube velocity constant, K <sub>p</sub>		34.97	$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.0086
Velocity pressure coefficient, C <sub>p</sub>		0.81	$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0064
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	19.86	<b>Particulate Emission Rates, E</b>	
Mean square root of velocity heads, √ΔP		4.46	$E = [(C_{wet})(Q_{stw})(60)] / 1000$	
Mean stack gas temperature, T <sub>s</sub>	°C	147	0.98	
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	17.99		

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS RUN 3			PM <sub>10</sub> & PM <sub>2.5</sub>	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	747.8	CO <sub>2</sub>	9.42
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	2.2	O <sub>2</sub>	7.39
$P_s = P_b + (P_{static})$	mm Hg	747.9	Total	16.81
$\frac{13.6}{13.6}$			N <sub>2</sub> (100 -Total)	83.19
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2)$	
Moisture trap weight increase, V <sub>lc</sub>	g	H <sub>2</sub> O by FTIR	<b>Molecular weight of wet gas, M<sub>s</sub></b>	
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	$M_s = M_d(1 - B_{wo}) + 18(B_{wo})$	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Volume of gas sample through gas meter, V <sub>m</sub>		9.98	Area of stack, A <sub>s</sub>	m <sup>2</sup> 3.40
Gas meter correction factor, Y <sub>d</sub>		1.34	$Q_a = (60)(A_s)(V_s)$	m <sup>3</sup> /min 3573.0
Mean dry gas meter temperature, T <sub>m</sub>		25.00	<b>Percent isokinetic, %I</b>	
Mean pressure drop across orifice, ΔH	mmH <sub>2</sub> O	99.58	Required Flow Rate @ DGM	l/min 29.30
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		12.195	Actual Flow Rate @ DGM	l/min 28.5
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Isokinetic Rate	
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	15.0598	Acceptable 90% - 130%	
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			<b>Particulate Concentration, C<sub>PM10</sub></b>	
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	Mass of particulate collected on PM <sub>10</sub> filter, M <sub>f</sub>	0.00039
% oxygen measured in gas stream, act%O <sub>2</sub>		7.39	Mass of particulate collected on PM <sub>2.5</sub> filter, M <sub>f</sub>	0.00005
% oxygen reference condition		11	$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.0292
O <sub>2</sub> Reference Factor		1.36	$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.0361
$O_2 \text{ Ref} = 21.0 - \text{act}\%O_2$			$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0265
$V_{mstd@X\%oxygen} = (V_{mstd}) (O_2 \text{ Ref})$	m <sup>3</sup>	16.599	<b>Particulate Emission Rates, E</b>	
<b>Moisture content, B<sub>wo</sub></b>			$E = [(C_{wet})(Q_{stw})(60)] / 1000$	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	19.03	4.01	
<b>Moisture by FTIR</b>			<b>Particulate Concentration, C<sub>PM2.5</sub></b>	
	%	19.03	Mass of particulate collected on filter, M <sub>f</sub>	0.00005
<b>Velocity of stack gas, V<sub>s</sub></b>			$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.0033
Pitot tube velocity constant, K <sub>p</sub>		34.97	$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.0041
Velocity pressure coefficient, C <sub>p</sub>		0.81	$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0030
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	18.82	<b>Particulate Emission Rates, E</b>	
Mean square root of velocity heads, √ΔP		4.34	$E = [(C_{wet})(Q_{stw})(60)] / 1000$	
Mean stack gas temperature, T <sub>s</sub>	°C	146	0.46	
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	17.52		

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS RUN 4			PM <sub>10</sub> & PM <sub>2.5</sub>	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	739.5	CO <sub>2</sub>	9.38
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	2.2	O <sub>2</sub>	7.38
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	739.7	Total	16.76
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			N <sub>2</sub> (100 - Total)	
Moisture trap weight increase, V <sub>lc</sub>	g	H <sub>2</sub> O by FTIR	M <sub>d</sub> = 0.44(%CO <sub>2</sub> )+0.32(%O <sub>2</sub> )+0.28(%N <sub>2</sub> )	83.24
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	<b>Molecular weight of wet gas, M<sub>s</sub></b>	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			M <sub>s</sub> = M <sub>d</sub> (1 - B <sub>wo</sub> ) + 18(B <sub>wo</sub> )	
Volume of gas sample through gas meter, V <sub>m</sub>		5.25	<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Gas meter correction factor, Y <sub>d</sub>		1.34	Area of stack, A <sub>s</sub>	m <sup>2</sup> 3.40
Mean dry gas meter temperature, T <sub>m</sub>		26.38	Q <sub>a</sub> = (60)(A <sub>s</sub> )(V <sub>s</sub> )	m <sup>3</sup> /min 3608.6
Mean pressure drop across orifice, ΔH	mmH <sub>2</sub> O	100.56	<b>Percent isokinetic, %I</b>	
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		6.322	Required Flow Rate @ DGM	l/min 31.70
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Actual Flow Rate @ DGM	
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	7.8411	Isokinetic Rate	l/min 30.0
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			Acceptable 90% - 130%	
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	<b>Particulate Concentration, C<sub>PM10</sub></b>	
% oxygen measured in gas stream, act%O <sub>2</sub>		7.38	Mass of particulate collected on PM <sub>10</sub> filter, M <sub>f</sub>	0.00024
% oxygen reference condition		11	Mass of particulate collected on PM <sub>2.5</sub> filter, M <sub>f</sub>	0.00005
O <sub>2</sub> Reference O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>		1.36	$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.0370
Factor 21.0 - ref%O <sub>2</sub>			$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.0459
$V_{mstd@X\%oxygen} = (V_{mstd})(O_2 Ref)$	m <sup>3</sup>	8.611	$C_{dry@X\%O2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0337
<b>Moisture content, B<sub>wo</sub></b>			<b>Particulate Emission Rates, E</b>	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	0.1937	E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	5.07
		19.37	<b>Particulate Concentration, C<sub>PM2.5</sub></b>	
<b>Moisture by FTIR</b>	%	19.37	Mass of particulate collected on filter, M <sub>f</sub>	0.00005
<b>Velocity of stack gas, V<sub>s</sub></b>			$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.0064
Pitot tube velocity constant, K <sub>p</sub>		34.97	$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.0079
Velocity pressure coefficient, C <sub>p</sub>		0.81	$C_{dry@X\%O2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0058
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	18.94	<b>Particulate Emission Rates, E</b>	
Mean square root of velocity heads, √ΔP		4.35	E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	
Mean stack gas temperature, T <sub>s</sub>	°C	146	0.87	
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	17.70		

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PM<sub>10</sub> & PM<sub>2.5</sub> QUALITY ASSURANCE CHECKLIST**

LEAK RATE						
Run	Mean Sampling Rate litre/min	Pre-sampling Leak Rate litre/min	Post-sampling Leak Rate litre/min	Maximum Vacuum mm Hg	Acceptable Leak Rate litre/min	Leak Tests Acceptable?
Run 1	30.47	0.10	0.05	381	0.61	Yes
Run 2	30.32	0.05	0.1	381	0.61	Yes
Run 3	28.51	0.1	0.1	381	0.57	Yes
Run 4	30.02	0.1	0.05	381	0.60	Yes

ISOKINETICITY		
Run	Flow Variation %	Acceptable Variation
Run 1	108.4	Yes
Run 2	101.4	Yes
Run 3	97.3	Yes
Run 4	94.7	Yes

Acceptable Flow rate 90 -130%

FILTERS					
Run	Filter Material	Filter Size mm	Max Filtration Temperature °C	Pre-conditioning Filter Temperature °C	Post conditioning Filtration Temperature °C
Run 1	QF	50	150	180	160
Run 2	QF	50	148	180	160
Run 3	QF	50	149	180	160
Run 4	QF	50	147	180	160

QF = Quartz Fibre

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**Conformity with relevant aspects of BS EN ISO 23210:2009**

**GENERAL METHODOLOGY**

The equipment employed is a Paul Gothe, Johnas cascade impactor (see pg 13 for serial number) system meeting the requirements of BS EN ISO 23210. The standard cites a two-stage impactor system.

The method for sampling requires the extraction of a representative sample of duct gas isokinetically, into a specially designed in-stack sampling head. The Cascade Impactor is a multi-stage, multi-jet impactor which aerodynamically classifies particulates into multiple size ranges. The cascade impactor uses the principle of inertial separation to size segregate particulate samples from the gas stream. The impactor has two stages for particle size determination. Each stage gives a cut-point based on aerodynamic diameter of the particle.

During sampling, the particles are driven (jetted) toward a collecting surface where they may cling. By changing the velocity (orifice size of the jet), the size of the particles collected is controlled. The size of the jets within each stage is constant, but for each succeeding stage the jets get smaller. Impaction occurs when the particle's inertia overcomes the aerodynamic drag. Otherwise, the particle remains in the air stream and proceeds to the next stage. To keep the cut-point for each stage constant, the impactor is operated at a constant flow rate.

At each stage, the particle impacts on to a conditioned and pre-weighed substrate. Following sampling, the substrates are reconditioned and reweighed to determine the mass collected.

Based on the sampling conditions (sampling rate and gas temperature) the cut size (D50 – diameter of particles having a 50% probability of penetration) associated with each impactor stage may be determined.

An homogeneity assessment based on BS EN ISO 23210, Annex G, is undertaken to determine the most representative sampling point in the sampling plane (temperature, velocity and oxygen are suitable surrogates for particulate matter). The velocity measurement at the chosen point is used to determine an appropriate sampling nozzle/flow rate in order to ensure that isokinetic conditions are maintained throughout sampling to within the 90-130% range allowed in the standard (8.1) and which is consistent with the sampling equipment.

Concurrently, the volume of duct gas sampled is measured. This then enables the particulate concentration at each cut size to be determined.

The outlet gas from the sampling head is passed via a sampling probe through an impinger train with the purpose of removing water prior to entry to the sampling control box. It is not intended that the sampling train be used for additional sampling of condensable determinands and as such the train is unheated.



APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**Conformity with relevant aspects of BS EN ISO 23210:2009**

Sampling Plane Validation Criteria				
EA Technical Guidance Note (Monitoring) M1	Result	Units	Requirement	Compliant
Lowest Differential Pressure	181	Pa	>= 5 Pa	Yes
Lowest Gas Velocity	16.69	m/s	-	-
Highest Gas Velocity	17.76	m/s	-	-
Ratio of Gas Velocities	1.06	-	< 3 : 1	Yes
Maximum angle of flow with regard to duct axis	<15	°	< 15°	Yes
No local negative flow	Yes	-	-	Yes

Conformance with BS EN ISO 23210:2009			
Reference	Requirement	Result	Compliant
Section 6.3	Suitable Impactor Used	See statement of conformity for Impactor	Yes
Section 8.1	Sampling position acceptable (as per 13284-1)	As per table "Sampling Plane Validation"	Yes
Section 8.1	Nozzle arrangement	See statement of conformity for Impactor	Yes
Section 8.1	Representative sampling point	See Homogeneity assessment below	Yes
Section 8.1	Constant Sample gas flow, iso-kinetic rate 90% to 130%		
	Run 1 - Required flow 28.1 (LPM)		-
	Run 1 - Minimum permissible flow 25.29 (LPM)	28.14	Yes
	Run 1 - Maximum permissible flow 36.53 (LPM)	33.28	Yes
	Run 2 - Required flow 29.9 (LPM)		-
	Run 2 - Minimum permissible flow 26.91 (LPM)	27.76	Yes
	Run 2 - Maximum permissible flow 38.87 (LPM)	34.07	Yes
	Run 3 - Required flow 29.3 (LPM)		-
	Run 3 - Minimum permissible flow 26.37 (LPM)	26.40	Yes
	Run 3 - Maximum permissible flow 38.09 (LPM)	30.40	Yes
	Run 4 - Required flow 31.7 (LPM)		-
	Run 4 - Minimum permissible flow 28.53 (LPM)	29.00	Yes
	Run 4 - Maximum permissible flow 41.21 (LPM)	32.20	Yes
Section 8.1	Overall blank taken once per day	Yes	Yes
Section 8.2	Impactor cleaned between each measurement	Yes	Yes
Section 8.2	Arrangement of impactor plates	See statement of conformity for Impactor	Yes
Section 8.3.2	Data taken for velocity, composition, temp & pressure	See "Preliminary stack survey" section	Yes
Section 8.3.3	Sampling rate determination in accordance with Annex A	Yes	Yes
Section 8.3.3	Sample flow rate kept +/- 5% of nominal flow rate		
	Run 1 - Max sample flow deviation from nominal (%)	28.0	No
	Run 2 - Max sample flow deviation from nominal (%)	11.2	No
	Run 3 - Max sample flow deviation from nominal (%)	5.2	No
	Run 4 - Max sample flow deviation from nominal (%)	8.6	No
Section 8.3.4	Nozzle selected to allow iso-kinetic rate 90% to 130%	Yes, as above	Yes
Section 8.3.5	Leak check less than 2%		
	Run 1	0.33	Yes
	Run 2	0.16	Yes
	Run 3	0.35	Yes
	Run 4	0.33	Yes
Section 8.3.6	Impactor at flue gas temperature before sampling	Yes	Yes
Section 8.3.6	Angle of nozzle less than 10 Degrees to flow	Yes	Yes
Section 8.3.6	Flowrate has checked and recorded every 5 mins	Yes	Yes
Section 8.3.6	Dynamic pressure recorded every 5 mins	Yes	Yes

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**Homogeneity assessment**

Assessment 1

Point number (i)	Distance along sample line (mm)	Probe Marking (mm)	Temp Deg C grid	Temp Deg C fixed	$r_i$
1	104	194	145	146	0.993
2	312	402	145	146	0.993
3	520	610	145	146	0.993
4	728	818	145	146	0.993
5	936	1026	145	146	0.993
6	1144	1234	145	146	0.993
7	1352	1442	145	146	0.993
8	1560	1650	145	146	0.993
9	1768	1858	145	146	0.993
10	1976	2066	145	146	0.993
<b>Second Line</b>					
1	104	194	145	146	0.993
2	312	402	145	146	0.993
3	520	610	145	146	0.993
4	728	818	145	146	0.993
5	936	1026	145	146	0.993
6	1144	1234	145	146	0.993
7	1352	1442	145	146	0.993
8	1560	1650	146	147	0.993
9	1768	1858	145	146	0.993
10	1976	2066	145	146	0.993

No. of points	20
$S_{grid}$	0.22
$S_{ref}$	0.223
$f$	0.99
Is $S_{grid} \leq S_{ref}$ ?	No
F Factor	1
$F_{N-1; N-1; 0.95}$	2.17
Is F Factor $< F_{N-1; N-1; 0.95}$ ?	Yes
$S_{pos}$	0
$t_{N-1; 0.95}$	2.093
$U_{pos}$	0
Permissible Uncertainty	10
Is $U_{pos} < 0.5 * U_{perm}$ ?	N/A

Sample can be taken from any location

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**DAILY OXYGEN SUMMARY**

Run	Sampling Times	Concentration %	LOD %
1	09:16 - 15:16 19 March 2014	6.79	0.01
2	16:09 - 19:09 19 March 2014	7.64	0.01
3	07:42 - 13:42 20 March 2014	7.39	0.01
4	14:32 - 17:32 20 March 2014	7.38	0.01

**PRE SAMPLING CALIBRATION DATA**

Date	Time of Analyser Checks	Range (%)	Zero Reading at analyser	Span Reading at analyser	Zero Check at analyser	Zero Check down line	Span Check down line	Leak Rate %
19 March 2014	08:52 - 09:00	25	0.00	10.06	0.00	0.21	9.92	-1.41
20 March 2014	15:13 - 15:31	25	0.00	10.06	0.00	0.59	10.25	1.85

**POST SAMPLING CALIBRATION DATA**

Date	Time of Analyser Checks	Zero Check down line	Span Check down line	Zero Drift (%)	Span Drift (%)
19 March 2014	15:13 - 15:31	0.59	10.25	1.52	-0.50
20 March 2014	17:40 - 17:50	0.2	10.26	-1.56	3.98

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**COMBUSTION GAS SUMMARY**

Test	Sampling Times	Concentration %	Analysis Areas	Interference (%)	LOD %
Moisture Run 1	09:16 - 15:16 19 March 2014	20.2	3200 - 3401	0.7	0.09
Moisture Run 2	16:09 - 19:09 19 March 2014	18.5	3200 - 3401	0.70	0.09
Moisture Run 3	07:42 - 13:42 20 March 2014	19.0	3200 - 3401	0.70	0.09
Moisture Run 4	14:32 - 17:32 20 March 2014	19.4	3200 - 3401	0.70	0.09
Carbon Dioxide Run 1	09:16 - 15:16 19 March 2014	9.6	2000 - 2223	1.31	0.00
Carbon Dioxide Run 2	16:09 - 19:09 19 March 2014	9.3	2000 - 2223	1.31	0.00
Carbon Dioxide Run 3	07:42 - 13:42 20 March 2014	9.4	2000 - 2223	1.31	0.01
Carbon Dioxide Run 4	14:32 - 17:32 20 March 2014	9.4	2000 - 2223	1.31	0.01

\*M22 Specifies interference must be <5%.

**FTIR CALIBRATION CHECKS**

Pre - Sampling Checks - System			Date of Checks	19 March 2014	Time of Checks	08:25		
Post Sampling Checks - System			Date of Checks	19 March 2014	Time of Checks	15:13		
Compound	Pre - Test Zero Reading	Post Test Zero Reading	Zero Drift as a % of Range	Span Gas (ppm)	Pre - Test Span Reading	% Variation from Actual	Post Test Span Reading	% Span Drift
H <sub>2</sub> O	0.04	-0.01	-0.18	87.1	86.9	-0.24	85.6	-1.49
CO <sub>2</sub> (%)	0.00	0.00	0.00	12.0	12.0	-0.11	11.7	-2.06

Pre - Sampling Checks - System			Date of Checks	20 March 2014	Time of Checks	15:52		
Post Sampling Checks - System			Date of Checks	20 March 2014	Time of Checks	17:40		
Compound	Pre - Test Zero Reading	Post Test Zero Reading	Zero Drift as a % of Range	Span Gas (ppm)	Pre - Test Span Reading	% Variation from Actual	Post Test Span Reading	% Span Drift
H <sub>2</sub> O	0.04	0.01	-0.11	101.0	85.6	-15.25	86.0	0.49
CO <sub>2</sub> (%)	0.00	0.00	0.00	8.8	11.7	33.42	11.9	1.75

Note - Methane was used as a surrogate span check for moisture. All other surrogates are listed in the individual measurement uncertainty budgets. Acceptance criteria for initial span check variation is +/-5% of certified reading for all gases, except HCl and NH<sub>3</sub> which are +/- 10% of certified reading. Acceptance criteria for % zero drift across the test is +/-2% of range for all gases.

### PRELIMINARY STACK SURVEY

Stack Characteristics		
Stack Diameter / Depth, D	2.08	m
Stack Width, W	-	m
Stack Area, A	3.40	m <sup>2</sup>
Average stack gas temperature	146	°C
Stack static pressure	0.30	kPa
Barometric Pressure	98.64	kPa
Pitot tube calibration coefficient, $K_{pt}$	0.81	-

Stack Gas Composition & Molecular Weights								
Component	Molar Mass M	Density kg/m <sup>3</sup> p	Conc Dry % Vol	Dry Volume Fraction r	Dry Conc kg/m <sup>3</sup> pi	Conc Wet % Vol	Wet Volume Fraction r	Wet Conc kg/m <sup>3</sup> pi
CO <sub>2</sub>	44	1.96	11.86	0.12	0.23	10.34	0.10	0.20
O <sub>2</sub>	32	1.43	4.87	0.05	0.07	4.24	0.04	0.06
N <sub>2</sub>	28	1.25	83.27	0.83	1.04	72.57	0.73	0.91
H <sub>2</sub> O	18	0.80	-	-	-	12.85	0.13	0.10

Where:  $p = M / 22.41$      $pi = r \times p$

Calculation of Stack Gas Densities		
Determinand	Result	Units
Dry Density (STP), $P_{STD}$	1.3426	kg/m <sup>3</sup>
Wet Density (STP), $P_{STW}$	1.2732	kg/m <sup>3</sup>
Dry Density (Actual), $P_{Actual}$	0.8534	kg/m <sup>3</sup>
Average Wet Density (Actual), $P_{ActualW}$	0.809	kg/m <sup>3</sup>

Where:

$P_{STD}$  = sum of component concentrations, kg/m<sup>3</sup> (not including water vapour)  
 $P_{STW} = (P_{STD} + pi \text{ of H}_2\text{O}) / (1 + (pi \text{ of H}_2\text{O} / 0.8036))$

$P_{Actual} = P_{STD} \times (Ts / Ps) \times (Pa / Ta)$   
 $P_{ActualW} = P_{STW} \times (Ts / Ps) \times (Pa / Ta)$

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY**

**TRAVERSE 1**

Date of Survey	19 March 2014
Time of Survey	07:45
Velocity Measurement Device:	P2246

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.10	20.0	196	145	17.34	-	<15
2	0.31	20.0	196	145	17.34	-	<15
3	0.52	21.0	206	145	17.76	-	<15
4	0.73	20.5	201	145	17.55	-	<15
5	0.94	21.0	206	145	17.76	-	<15
6	1.14	20.5	201	145	17.55	-	<15
7	1.35	20.0	196	145	17.34	-	<15
8	1.56	20.5	201	145	17.55	-	<15
9	1.77	19.5	191	145	17.12	-	<15
10	1.98	20.0	196	145	17.34	-	<15
Mean	-	20.3	199	145	17.46	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.10	19.5	191	145	17.12	-	<15
2	0.31	20.0	196	144	17.32	-	<15
3	0.52	20.5	201	145	17.55	-	<15
4	0.73	21.0	206	145	17.76	-	<15
5	0.94	20.5	201	145	17.55	-	<15
6	1.14	21.0	206	145	17.76	-	<15
7	1.35	21.0	206	145	17.76	-	<15
8	1.56	20.5	201	145	17.55	-	<15
9	1.77	20.0	196	145	17.34	-	<15
10	1.98	19.5	191	145	17.12	-	<15
Mean	-	20.4	199	145	17.48	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

**TRAVERSE 2**

Date of Survey	19 March 2014
Time of Survey	19:45
Velocity Measurement Device:	P2246

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.10	19.5	191	147	17.16	-	<15
2	0.31	19.8	194	147	17.29	-	<15
3	0.52	19.5	191	147	17.16	-	<15
4	0.73	19.8	194	147	17.29	-	<15
5	0.94	20.0	196	147	17.38	-	<15
6	1.14	19.5	191	147	17.16	-	<15
7	1.35	19.5	191	147	17.16	-	<15
8	1.56	19.3	189	147	17.07	-	<15
9	1.77	19.3	189	147	17.07	-	<15
10	1.98	19.3	189	147	17.07	-	<15
Mean	-	19.6	192	147	17.18	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.10	19.0	186	147	16.94	-	<15
2	0.31	19.3	189	147	17.07	-	<15
3	0.52	19.5	191	147	17.16	-	<15
4	0.73	19.4	190	147	17.11	-	<15
5	0.94	19.5	191	147	17.16	-	<15
6	1.14	19.8	194	147	17.29	-	<15
7	1.35	19.8	194	147	17.29	-	<15
8	1.56	19.5	191	147	17.16	-	<15
9	1.77	19.3	189	147	17.07	-	<15
10	1.98	19.3	189	147	17.07	-	<15
Mean	-	19.4	191	147	17.13	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY**

**TRAVERSE 3**

Date of Survey	20 March 2014
Time of Survey	07:30
Velocity Measurement Device:	P2246

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.10	18.8	184	147	16.85	-	<15
2	0.31	19.0	186	147	16.94	-	<15
3	0.52	19.3	189	147	17.07	-	<15
4	0.73	19.4	190	147	17.11	-	<15
5	0.94	19.3	189	147	17.07	-	<15
6	1.14	19.3	189	147	17.07	-	<15
7	1.35	19.0	186	147	16.94	-	<15
8	1.56	19.0	186	147	16.94	-	<15
9	1.77	19.0	186	147	16.94	-	<15
10	1.98	19.0	186	147	16.94	-	<15
Mean	-	19.11	187	147	16.99	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.10	19.0	186	147	16.94	-	<15
2	0.31	18.8	184	147	16.85	-	<15
3	0.52	19.0	186	147	16.94	-	<15
4	0.73	19.3	189	147	17.07	-	<15
5	0.94	19.3	189	147	17.07	-	<15
6	1.14	19.0	186	147	16.94	-	<15
7	1.35	19.0	186	147	16.94	-	<15
8	1.56	18.8	184	147	16.85	-	<15
9	1.77	19.0	186	147	16.94	-	<15
10	1.98	18.8	184	147	16.85	-	<15
Mean	-	19.0	186	147	16.94	-	



APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

**TRAVERSE 4**

Date of Survey	20 March 2014
Time of Survey	14:15
Velocity Measurement Device:	P2246

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.10	18.8	184	146	16.83	-	<15
2	0.31	19.0	186	146	16.92	-	<15
3	0.52	18.8	184	146	16.83	-	<15
4	0.73	18.8	184	146	16.83	-	<15
5	0.94	19.0	186	146	16.92	-	<15
6	1.14	18.8	184	146	16.83	-	<15
7	1.35	18.8	184	146	16.83	-	<15
8	1.56	18.6	182	146	16.74	-	<15
9	1.77	18.6	182	146	16.74	-	<15
10	1.98	18.5	181	146	16.69	-	<15
Mean	-	18.8	184	146	16.81	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.10	18.8	184	146	16.83	-	<15
2	0.31	19.0	186	146	16.92	-	<15
3	0.52	19.0	186	146	16.92	-	<15
4	0.73	19.2	188	146	17.01	-	<15
5	0.94	19.0	186	146	16.92	-	<15
6	1.14	18.8	184	146	16.83	-	<15
7	1.35	18.8	184	146	16.83	-	<15
8	1.56	19.0	186	146	16.92	-	<15
9	1.77	18.8	184	146	16.83	-	<15
10	1.98	18.5	181	146	16.69	-	<15
Mean	-	18.9	185	146	16.87	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY**

**TRAVERSE 5**

Date of Survey	20 March 2014
Time of Survey	17:50
Velocity Measurement Device:	P2246

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.10	18.5	181	147	16.71	-	<15
2	0.31	18.8	184	147	16.85	-	<15
3	0.52	18.8	184	147	16.85	-	<15
4	0.73	18.5	181	147	16.71	-	<15
5	0.94	19.0	186	147	16.94	-	<15
6	1.14	19.0	186	147	16.94	-	<15
7	1.35	19.2	188	147	17.03	-	<15
8	1.56	18.8	184	147	16.85	-	<15
9	1.77	18.6	182	147	16.76	-	<15
10	1.98	18.5	181	147	16.71	-	<15
Mean	-	18.77	184	147	16.83	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.10	18.8	184	147	16.85	-	<15
2	0.31	18.5	181	147	16.71	-	<15
3	0.52	18.8	184	147	16.85	-	<15
4	0.73	19.2	188	147	17.03	-	<15
5	0.94	19.2	188	147	17.03	-	<15
6	1.14	18.8	184	147	16.85	-	<15
7	1.35	18.5	181	147	16.71	-	<15
8	1.56	19.0	186	147	16.94	-	<15
9	1.77	18.5	181	147	16.71	-	<15
10	1.98	18.5	181	147	16.71	-	<15
Mean	-	18.8	184	147	16.84	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

Sampling Plane Validation Criteria				
EA Technical Guidance Note (Monitoring) M1	Result	Units	Requirement	Compliant
Lowest Differential Pressure	181	Pa	>= 5 Pa	Yes
Lowest Gas Velocity	16.69	m/s	-	-
Highest Gas Velocity	17.76	m/s	-	-
Ratio of Gas Velocities	1.06	-	< 3 : 1	Yes
Maximum angle of flow with regard to duct axis	<15	°	< 15°	Yes
No local negative flow	Yes	-	-	Yes

Calculation of Stack Gas Velocity, V		
Velocity at Traverse Point, $V = K_{pt} \times (1-\epsilon) \times \sqrt{2 * \Delta P_{pt} / \rho_{ActualW}}$		
<b>Where:</b> $K_{pt}$ = Pitot tube calibration coefficient (1-ε) = Compressibility correction factor, assumed at a constant 0.998		
Average Stack Gas Velocity, Va	17.02	m/s

**Where:**  
 $Q_{Actual} = Va \times A \times 3600$   
 $Q_{STP} = Q (Actual) \times (Ts / Ta) \times (Pa / Ps) \times 3600$   
 $Q_{STP,Dry} = Q (STP) / (100 - (100 / Ma)) \times 3600$   
 $Q_{Ref} = Q (STP) \times ((100 - Ma) / (100 - Ms)) \times ((20.9 - O_{2a}) / (20.9 - O_{2s}))$

Day 1      19 March 2014

Calculation of Stack Gas Volumetric Flowrate, Q			
Duct gas flow conditions	Actual	Reference	Units
Temperature	146	0	°C
Total Pressure	98.9	101.3	kPa
Oxygen	6.8	11	%
Moisture	20.18	0.00	%
Gas Volumetric Flowrate		Result	Units
Average Stack Gas Velocity (Va)		17.32	m/s
Stack Area (A)		3.40	m <sup>2</sup>
Gas Volumetric Flowrate (Actual), $Q_{Actual}$		211837	m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Wet), $Q_{STP}$		134761	m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Dry), $Q_{STP,Dry}$		107561	m <sup>3</sup> /hr
Gas Volumetric Flowrate (REF), $Q_{Ref}$		152825	m <sup>3</sup> /hr

Day 2      20 March 2014

Calculation of Stack Gas Volumetric Flowrate, Q			
Duct gas flow conditions	Actual	Reference	Units
Temperature	147	0	°C
Total Pressure	99.0	101.3	kPa
Oxygen	7.5	11	%
Moisture	18.97	0.00	%
Gas Volumetric Flowrate		Result	Units
Average Stack Gas Velocity (Va)		16.87	m/s
Stack Area (A)		3.40	m <sup>2</sup>
Gas Volumetric Flowrate (Actual), $Q_{Actual}$		206379	m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Wet), $Q_{STP}$		131134	m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Dry), $Q_{STP,Dry}$		106253	m <sup>3</sup> /hr
Gas Volumetric Flowrate (REF), $Q_{Ref}$		143766	m <sup>3</sup> /hr

**Nomenclature:**

Ts = Absolute Temperature, Standard Conditions, 273 K  
 Ps = Absolute Pressure, Standard Conditions, 101.3 kPa  
 Ta = Absolute Temperature, Actual Conditions, K


Pa = Absolute Pressure, Actual Conditions, kPa  
 Ma = Water vapour, Actual Conditions, % Vol  
 Ms = Water vapour, Reference Conditions, % Vol

O<sub>2a</sub> = Oxygen, Actual Conditions, % Vol  
 O<sub>2s</sub> = Oxygen, Reference Conditions, % Vol

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**STACK DIAGRAM**

	Value	Units
Stack Depth	2.08	m
Stack Width	-	m
Area	3.40	m <sup>2</sup>




Non-Isokinetic/Gases Sampling			
Sampling Point	Distance (% of Depth)	Distance into Stack	Units
A	40	0.83	m

Isokinetic Sampling CEN Methods			
Sampling Point	Distance (% of Depth)	Distance into Stack (m)	Swirl °
1	85.0	1.77	<15

- Isokinetic sampling point
- Isokinetic sampling points not used
- ◐ Non Isokinetic/Gases sampling point

**SAMPLING LOCATION**



APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - PM 10**

Run	Sampled Volume m <sup>3</sup>	Sampled Gas Pressure K	Sampled Gas Pressure kPa	Sampled Gas Flow % by volume	Oxygen Flow % by volume	Limit of Error % by mass	Leak %
<b>MU required</b>	<b>≤ 2%</b>	<b>≤ 2%</b>	<b>≤ 1%</b>	<b>≤ 1%</b>	<b>≤ 10%</b>	<b>≤ 5% of ELV</b>	<b>≤ 2%</b>
Run 1	0.001	2	0.5	1	0.1	0.10	-
as a %	0.01	0.48	0.51	1.00	1.47	N/A	0.16
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 2	0.001	2	0.5	1.00	0.1	0.10	-
as a %	0.01	0.48	0.50	1.00	1.31	N/A	0.33
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 3	0.001	2	0.5	1	0.1	0.1000	-
as a %	0.01	0.48	0.50	1.00	1.35	N/A	0.35
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 4	0.001	2	0.5	1	0.1	0.10	-
as a %	0.01	0.48	0.51	1.00	1.35	N/A	0.17
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>

Run	Volume (STP) m <sup>3</sup>	Mass of particulate mg	O2 Correction -	Leak mg/m <sup>3</sup>	Combined uncertainty
Run 1	0.0007	0.0595	0.011	1.000	-
MU as mg/m <sup>3</sup>	0.0001	0.0060	0.0001	0.00001	<b>76.93</b>
MU as %	0.0006	76.9	0.704	0.095	-
Run 2	0.0085	0.1282	0.057	1.000	-
MU as mg/m <sup>3</sup>	0.0005	0.0128	0.0003	0.00008	<b>30.31</b>
MU as %	0.0031	30.3	0.749	0.190	-
Run 3	0.0025	0.0602	0.036	1.000	-
MU as mg/m <sup>3</sup>	0.0003	0.0060	0.0002	0.00005	<b>22.740</b>
MU as %	0.0019	22.7	0.735	0.203	-
Run 4	0.0062	0.12	0.046	1.00	-
MU as mg/m <sup>3</sup>	0.0004	0.01	0.0002	0.00003	<b>34.49</b>
MU as %	0.0024	34.5	0.734	0.10	-

<b>R1 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.01</b>	<b>mg/m<sup>3</sup></b>	<b>153.87</b>	<b>%</b>
<b>R2 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.03</b>	<b>mg/m<sup>3</sup></b>	<b>60.67</b>	<b>%</b>
<b>R3 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.01</b>	<b>mg/m<sup>3</sup></b>	<b>45.55</b>	<b>%</b>
<b>R4 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.02</b>	<b>mg/m<sup>3</sup></b>	<b>69.02</b>	<b>%</b>

(k is a coverage factor which gives a 95% confidence in the quoted figures)  
Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - PM 2.5**

Run	Sampled m <sup>3</sup>	Sampled Gas K	Sampled Gas kPa	Sampled Gas % by volume	Oxygen % by volume	Limit of % by mass	Leak %
<b>MU required</b>	<b>≤ 2%</b>	<b>≤ 2%</b>	<b>≤ 1%</b>	<b>≤ 1%</b>	<b>≤ 10%</b>	<b>≤ 5% of ELV</b>	<b>≤ 2%</b>
Run 1	0.001	2	0.5	1	0.1	0.05	-
as a %	0.01	0.48	0.51	1.00	1.47	N/A	0.16
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 2	0.001	2	0.5	1.00	0.1	0.05	-
as a %	0.01	0.48	0.50	1.00	1.31	N/A	0.33
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 3	0.001	2	0.5	1.00	0.1	0.05	-
as a %	0.01	0.48	0.50	1.00	1.35	N/A	0.35
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 4	0.001	2	0.5	1.00	0.1	0.05	-
as a %	0.01	0.48	0.51	1.00	1.35	0.00	0.17
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>

Run	Volume (STP) m <sup>3</sup>	Mass of particulate mg	O2 Correction -	Leak mg/m <sup>3</sup>	Combined uncertainty
Run 1	0.00	0.0595	0.0068	1.000	-
MU as mg/m <sup>3</sup>	0.0001	0.0030	0.0000	0.00000	<b>62.50</b>
MU as %	0.0003	62.5000	0.7037	0.09	-
Run 2	0.0013	0.1282	0.0086	1.000	-
MU as mg/m <sup>3</sup>	0.0001	0.0064	0.0000	0.00001	<b>100.00</b>
MU as %	0.0005	100.0000	0.7485	0.19	-
Run 3	0.0006	0.1282	0.0087	1.000	-
MU as mg/m <sup>3</sup>	0.0001	0.0064	0.0000	0.00001	<b>100.00</b>
MU as %	0.0005	100.0000	0.7346	0.20	-
Run 4	0.0011	0.1161	0.0079	1.0000	-
MU as mg/m <sup>3</sup>	0.0001	0.0058	0.0000	0.00001	<b>100.00</b>
MU as %	0.0004	100.0000	0.7342	0.10	-

<b>R1 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.006</b>	<b>mg/m<sup>3</sup></b>	<b>125.03</b>	<b>%</b>
<b>R2 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.013</b>	<b>mg/m<sup>3</sup></b>	<b>200.02</b>	<b>%</b>
<b>R3 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.013</b>	<b>mg/m<sup>3</sup></b>	<b>200.02</b>	<b>%</b>
<b>R4 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.012</b>	<b>mg/m<sup>3</sup></b>	<b>200.02</b>	<b>%</b>

(k is a coverage factor which gives a 95% confidence in the quoted figures)  
Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - CARBON DIOXIDE BY FTIR**

Actual Measured Concentration	9.58	% vol
Measured Concentration at Reference Conditions	9.58	% vol
Emission Limit Value	-	% vol
Instrument Range	20	% vol
Check Gas Concentration	12.00	% vol

Performance Characteristics & Source of Value	Values	Requirement	Compliant
Deviation from linearity as a % of the range (taken from worst case figure in MCERTS certificate)	-1.900	<2%	Yes
Zero drift (calculated from start and end readings)	0.000	<5%	Yes
Span drift (calculated from start and end readings).	-2.058	<5%	Yes
Sensitivity to sample gas pressure: (taken from worst case figure in MCERTS certificate).	0.990	<2%	Yes
Sensitivity to ambient temperature at zero (taken from worst case figure in MCERTS certificate)	0.100	<5%	Yes
Sensitivity to ambient temperature at span (taken from worst case figure in MCERTS certificate)	-1.300	<5%	Yes
Sensitivity to voltage (taken from worst case figure in MCERTS certificate)	1.600	<2%	Yes
Interferents (calculated using M22, Section 8.2, equation 3)	1.308	<5%	Yes
Repeatability / standard deviation (taken from worst figure in MCERTS certificate)	0.080	<2%	Yes
Certified reference material (check gas)	2.000	2% or less	Yes

Uncertainty in Performance Characteristics	% vol
Uncertainty of linearity (lack of fit) $U_{fit}$	-0.219
Uncertainty of zero drift $U_{0,dr}$	0.000
Uncertainty of span drift $U_{s,dr}$	-0.238
Uncertainty of volume or pressure flow dependence $U_{spress}$	0.114
Uncertainty in Ambient Temperature $U_{temp}$	0.151
Uncertainty in Voltage $U_{volt}$	0.185
Uncertainty of interferents $U_i$	0.151
Uncertainty of Repeatability $U_r$	0.016
Uncertainty of Certified Reference Material $U_{cal}$	0.069

Measurement Uncertainty	% vol
Combined uncertainty	0.45
Expanded uncertainty at a 95% Confidence Interval	0.90

Note - The expanded uncertainty uses a coverage factor of  $k = 2$ .

Expanded Measurement Uncertainty at a 95% Confidence Interval	%
Expressed as a % of the Measured Concentration	9.39
Expressed as a % of the Measured Concentration at Reference Conditions	9.39
Expressed as a % of the Emission Limit Value	-

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - MOISTURE BY FTIR**

Actual Measured Concentration	19.63	% vol
Measured Concentration at Reference Conditions	19.63	% vol
Emission Limit Value	30	% vol
Instrument Range	30	% vol
Check Gas Concentration (Methane was used as a Surrogate)	62.21	mg/m <sup>3</sup>

Performance Characteristics & Source of Value	Values	Requirement	Compliant
Deviation from linearity as a % of the range (taken from worst case figure in MCERTS certificate)	-1.900	<2%	Yes
Zero drift (calculated from start and end readings)	-0.180	<5%	Yes
Span drift (calculated from start and end readings).	-1.490	<5%	Yes
Sensitivity to sample gas pressure: (taken from worst case figure in MCERTS certificate).	0.990	<2%	Yes
Sensitivity to ambient temperature at zero (taken from worst case figure in MCERTS certificate)	0.100	<5%	Yes
Sensitivity to ambient temperature at span (taken from worst case figure in MCERTS certificate)	-1.000	<5%	Yes
Sensitivity to voltage (taken from worst case figure in MCERTS certificate)	0.710	<2%	Yes
Interferents (calculated using M22, Section 8.2, equation 3)	0.695	<5%	Yes
Repeatability / standard deviation (taken from worst figure in MCERTS certificate)	0.170	<2%	Yes
Certified reference material (check gas)	2.000	2% or less	Yes

Uncertainty in Performance Characteristics	% vol
Uncertainty of linearity (lack of fit) $U_{fit}$	-0.329
Uncertainty of zero drift $U_{0,dr}$	-0.031
Uncertainty of span drift $U_{s,dr}$	-0.258
Uncertainty of volume or pressure flow dependence $U_{spress}$	0.171
Uncertainty in Ambient Temperature $U_{temp}$	0.174
Uncertainty in Voltage $U_{volt}$	0.123
Uncertainty of interferents $U_i$	0.120
Uncertainty of Repeatability $U_r$	0.051
Uncertainty of Certified Reference Material $U_{cal}$	0.359

Measurement Uncertainty	% vol
Combined uncertainty	0.63
Expanded uncertainty at a 95% Confidence Interval	1.26

Note - The expanded uncertainty uses a coverage factor of  $k = 2$ .

Expanded Measurement Uncertainty at a 95% Confidence Interval	%
Expressed as a % of the Measured Concentration	6.42
Expressed as a % of the Measured Concentration at Reference Conditions	6.42
Expressed as a % of the Emission Limit Value	4.20



APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - OXYGEN**

DAY 1 - 19 March 2014

Reference	11	%vol
Measured concentration	7.07	%vol
Calibration gas	10.06	%vol
Full Scale	25	%vol

Performance characteristics	Value	Units	specification	MU Met?
Response time	90	seconds	< 200 s	Yes
Logger sampling interval	60	seconds	-	-
Measurement period	620	minutes	-	-
Number of readings in measurement	620	-	-	-
Repeatability at zero	0.015	% by volume	<0.2 % range	Yes
Repeatability at span level	0.014	% by volume	<0.4 % range	Yes
Deviation from linearity	0.13	% vol	<0.3 % volume	Yes
Zero drift (during measurement period)	1.52	% vol at zero level	<2% of volume / 24hr	Yes
Span drift (during measurement period)	-0.50	% vol at span level	<2% volume/24hr	Yes
volume or pressure flow dependence	0.02	% of fs / 10l/h	<1% range	Yes
atmospheric pressure dependence	0.8	% of fs/kPa	< 1.5 % range	Yes
ambient temperature dependence	0.01	% by volume /10K	<0.3% volume 10 K	Yes
Combined interference	0.14	% range	<2% range	Yes
Dependence on voltage	0.1	% by volume /10V	< 0.1%vol /10 volt	Yes
Losses in the line (leak)	-1.41	% of value	< 2% of value	Yes
Uncertainty of calibration gas	2	% of value	< 2% of value	Yes

Performance characteristic	Uncertainty	Value of uncertainty quantity
Standard deviation of repeatability at zero	ur0	-
Standard deviation of repeatability at span level	urs	0.001
Lack of fit	ufit	0.075
Drift	u0dr	0.676
volume or pressure flow dependence	uspres	0.001
atmospheric pressure dependence	uapres	0.115
ambient temperature dependence	utemp	0.003
Combined interference (from mcerts)	-	0.020
dependence on voltage	uvolt	0.029
losses in the line (leak)	uleak	-0.058
Uncertainty of calibration gas	ucalib	0.082

Measurement uncertainty (Concentration Measured)	7.07	%vol
Combined uncertainty	0.70	%vol
% of value	9.87	%

<b>Expanded uncertainty expressed with a level of confidence of 95%</b>	<b>19.74</b>	<b>% of value</b>
---	--------------	-------------------

<b>Expanded uncertainty expressed with a level of confidence of 95%</b>	<b>1.40</b>	<b>% vol</b>
---	-------------	--------------

Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - OXYGEN**

DAY 2 - 20 March 2014

Reference	11	%vol
Measured concentration	7.40	%vol
Calibration gas	10.06	%vol
Full Scale	25	%vol

Performance characteristics	Value	Units	specification	MU Met?
Response time	90	seconds	< 200 s	Yes
Logger sampling interval	60	seconds	-	-
Measurement period	574	minutes	-	-
Number of readings in measurement	574	-	-	-
Repeatability at zero	0.015	% by volume	<0.2 % range	Yes
Repeatability at span level	0.014	% by volume	<0.4 % range	Yes
Deviation from linearity	0.13	% vol	<0.3 % volume	Yes
Zero drift (during measurement period)	-1.56	% vol at zero level	<2% of volume / 24hr	Yes
Span drift (during measurement period)	3.98	% vol at span level	<2% volume/24hr	No
volume or pressure flow dependence	0.02	% of fs / 10l/h	<1% range	Yes
atmospheric pressure dependence	0.8	% of fs/kPa	< 1.5 % range	Yes
ambient temperature dependence	0.01	% by volume /10K	<0.3% volume 10 K	Yes
Combined interference	0.14	% range	<2% range	Yes
Dependence on voltage	0.1	% by volume /10V	< 0.1%vol /10 volt	Yes
Losses in the line (leak)	1.85	% of value	< 2% of value	Yes
Uncertainty of calibration gas	2	% of value	< 2% of value	Yes

Performance characteristic	Uncertainty	Value of uncertainty quantity
Standard deviation of repeatability at zero	ur0	-
Standard deviation of repeatability at span level	urs	0.001
Lack of fit	ufit	0.075
Drift	u0dr	0.788
volume or pressure flow dependence	uspres	0.001
atmospheric pressure dependence	uapres	0.115
ambient temperature dependence	utemp	0.003
Combined interference (from mcerts)	-	0.081
dependence on voltage	uvolt	0.029
losses in the line (leak)	uleak	0.079
Uncertainty of calibration gas	ucalib	0.085

Measurement uncertainty (Concentration Measured)	7.40	%vol
Combined uncertainty	0.81	%vol
% of value	10.98	%

<b>Expanded uncertainty expressed with a level of confidence of 95%</b>	<b>21.97</b>	<b>% of value</b>
---	--------------	-------------------

<b>Expanded uncertainty expressed with a level of confidence of 95%</b>	<b>1.63</b>	<b>% vol</b>
---	-------------	--------------

Developed for the STA by R Robinson, NPL

APPENDIX 4 - Summaries, Calculations, Raw Data and Charts

NOTE - The following data is provided for information only and falls outside ESG's scope of accreditation

COMBINED UNCOLLECTED SUMMARY							
Test	Sampling Times	>PM <sub>10</sub> Concentration		Probe Rinse Concentration		Combined Unweighed Concentration	
		Measured	LOD	Measured	LOD	Measured	LOD
		mg/m <sup>3</sup>	mg/m <sup>3</sup>	mg/m <sup>3</sup>	mg/m <sup>3</sup>	mg/m <sup>3</sup>	mg/m <sup>3</sup>
Run 1	09:16 - 15:16 19 March 2014	0.023	0.003	0.077	0.077	0.080	0.080
Run 2	16:09 - 19:09 19 March 2014	0.006	0.006	0.167	0.167	0.173	0.173
Run 3	07:42 - 13:42 20 March 2014	0.003	0.003	0.078	0.078	0.081	0.081
Run 4	14:32 - 17:32 20 March 2014	0.006	0.006	0.151	0.151	0.157	0.157

Reference conditions are 273K, 101.3kPa, dry gas 11% Oxygen.

Where the result is less than the LOD, the LOD is reported.

SAMPLES									
Test	>PM <sub>10</sub> Filter Number	Filter Start Weight	Filter End Weight	Mass Gained on Filter	Probe Rinse Number	Probe Rinse Start Weight	Probe Rinse End Weight	Mass Gained in Rinse	Combined Total Mass Gained
		g	g	g		g	g	g	g
Run 1	TQC1032	15.5892	15.5895	0.00038	8423	144.9653	144.9652	-0.00010	0.00028
Run 2	TQC1033	16.1137	16.1136	-0.00013	8424	182.94980	182.94990	0.00010	-0.00003
Run 3	TQC1034	16.1753	16.0975	-0.07780	8425	185.67310	185.67360	0.00050	-0.07730
Run 4	TQC1031	15.1463	15.1463	-0.00006	8427	185.10960	185.10980	0.00020	0.00014
Blank 1	-	-	-	-	8422	196.58970	196.58960	-0.00010	-0.00010
Blank 2	-	-	-	-	8426	194.45480	194.45470	-0.00010	-0.00010



Paul Gothe GmbH Wittener Str. 82 D-44789 Bochum

To our customers

Wittener Straße 82  
D-44789 Bochum

Phone.: ++49-234 33 51 80  
Fax:++49 234) 30 82 17  
<http://www.paulgothe.de>  
[service@paulgothe.de](mailto:service@paulgothe.de)  
VAT-No.: DE 813078723  
Trade Register Bochum: HRB-6891

Your ref

Your letter

Our ref

Date 14.03.2007

Calibration of the Johnas Impactor according to ISO 23210

#### 6.2 Separation curves and Section 6.3 Verification of the separation curves

The Johnas Impactor from Paul Gothe GmbH was developed before the ISO Guideline was evaluated and after the Germans and the Netherlands Authorities have enough experiences with our impactor. After that the European Delegation creates the ISO Guideline 23210. The section 6.3 is important and was influence by the Germans. They have the experiences and write the rules for the calibration section accordingly it was made for the Johnas-Impactor.

The development from the Johnas impactor starts with a doctoral thesis from Mrs. John at the Gerhard-Mercator-University. She makes the intensive testing and Mr. Geueke from the North Rhine Westphalia State Environment Agency makes additional verifications at the ESA (Emission Simulation Facility) at the Hessian Agency for the Environment and Geology (HLUG).

Most of the literatures and papers are in German, but all well-known:

1. Probenahme und chemische Analytik von Korngrößenfraktionierten Immissions- und Emissionsaerosolen. Von der Fakultät für Naturwissenschaften der Gerhard-Mercator-Universität – Gesamthochschule Duisburg zur Erlangung des akademischen Grades eines Dr. rer. nat. genehmigte Dissertation von ASTRID CHRISTIANE JOHN aus Lichtenfels.
2. Umweltforschungsplan des Bundesministers für Umwelt, Naturschutz und Reaktorsicherheit Luftreinhaltung Forschungsbericht 298 44 280, Korngrößenverteilung (PM10 und PM2,5) von Staubemissionen relevanter stationärer Quellen (Teil II zu 297 44 853), von Dipl.-Ing. A. Dreiseidler, Ing. D. Straub, Prof. Dr.-Ing. G. Baumbach, Universität Stuttgart, Institut für Verfahrenstechnik und Dampfkesselwesen (IVD), Abteilung Reinhaltung der Luft (RdL), Institutsleiter: Prof. Dr.-Ing. K.R.G. Hein, IM AUFTRAG DES UMWELTBUNDESAMTES Juni 2001.
3. VDI 2066, part 10
4. Gefahrstoffe-Reinhaltung der Luft 59 (1999), Nr.11/12, S. 449-453

All this papers shows, that the design of the Johnas Impactor is a proved version for the determination of the PM 2.5 and PM 10. The shape of the separation curves is similar to those specified in ISO 7708:1995 and the separation efficiency at 10 µm and 2,5 µm is 50 % according to section 6.3 of the ISO 23210.

What you need more? There is no authority which has more competence as the listed authorities.

If you still in doubt, you maybe get in contact with Mr. Geueke (phone: ++49-201-7995-1263).

Paul Gothe GmbH



Paul Gothe GmbH Wittener Str. 82 D-44789 Bochum

To our customers

Wittener Straße 82  
D-44789 Bochum

Phone.: ++49-234 33 51 80  
Fax:++49 234) 30 82 17  
<http://www.paulgothe.de>  
service@paulgothe.de  
VAT-No.: DE 813078723  
Trade Register Bochum: HRB-6891

Your ref

Your letter

Our ref

Date 14.03.2007

### Declaration of conformity


Herewith the company Paul Gothe GmbH in Bochum declare that the manufactured Cascade Impactor Johnas follows the guidelines from the North Rhine Westphalia State Environment Agency according the convention from 24 June 1999 and the PM 4 stage follows the convention of the Federal Environment Agency from 09. March 2005.

Our Cascade Impactor Johnas was developed in cooperation with the North Rhine Westphalia State Environment and the Gerhard-Mercator University Duisburg. This impactor was validated and after that 2004 adopted in the German Standard VDI 2066, part 10 and 2005 in ISO Standard 23210. All sizes of our manufactured impactors are according to these guidelines, individually checked according our strict quality management and named with a specific serial number. Only an impactor with this serial number is according to the Guideline VDI 2066, part 10 and ISO Standard 23210 and can use for the determination of PM 10 and PM 2.5.

Paul Gothe GmbH

Dr. Torsten Grodten

-manager-



**END OF REPORT**

## Appendix 4 – Stack emissions monitoring report: Veolia ES South Downs Ltd

## STACK EMISSIONS MONITORING REPORT



Acacia Building  
Vantage Point Business Village  
Mitcheldean  
GL17 0DD  
Tel: 01594 546 343

Your contact at ESG
Laurence Sharrock Business Manager - South Tel: 01594 546 343 Email: laurence.sharrock@esg.co.uk

Operator & Address:
Veolia ES South Downs Ltd Energy Recovery Facility North Quay Road Newhaven East Sussex BN9 0HE - -

Permit
N/A - Investigative Monitoring

Release Point:
Stream 1

Sampling Date(s):
1st and 2nd April 2014

ESG Job Number:	LCH00722
Report Date:	17th Feb 2015
Version:	1
Report By:	Chris Houston
MCERTS Number:	MM 11 1135
MCERTS Level:	MCERTS Level 1 - Technician
Technical Endorsements:	
Report Approved By:	Andy Tiffen
MCERTS Number:	MM 05 640
Business Title:	MCERTS Level 2 - Projects Manager
Technical Endorsements:	1, 2 & 4
Signature:	





## CONTENTS

### EXECUTIVE SUMMARY

#### Stack Emissions Monitoring Objectives

- Plant
- Operator
- Stack Emissions Monitoring Test House

#### Emissions Summary

#### Monitoring Times

#### Process Details

#### Monitoring Methods

#### Analytical Methods

- Sampling Methods with Subsequent Analysis
- On-Site Testing

#### Sampling Location

- Sampling Plane Validation Criteria
- Duct Characteristics
- Sampling Lines & Sample Points
- Sampling Platform
- Sampling Location / Platform Improvement Recommendations

#### Sampling and Analytical Method Deviations

#### Determination of representative sampling location

### APPENDICES

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

APPENDIX 3 - Measurement Uncertainty Budget Calculations

## EXECUTIVE SUMMARY

### MONITORING OBJECTIVES

Veolia ES South Downs Ltd operates a waste incineration process at Veolia South Downs

Environmental Scientifics Group Limited were commissioned by Ricardo AEA to carry out stack emissions monitoring to determine the release of PM<sub>10</sub> & PM<sub>2.5</sub> from the following Plant under standard operating conditions.

The measurements were commissioned by Ricardo-AEA on behalf of the Department of Environment, Food and Rural Affairs (Defra) to provide information for the UK National Atmospheric Emissions Inventory (NAEI).

#### **Plant**

Stream 1

#### **Operator**

Veolia ES South Downs Ltd  
Energy Recovery Facility  
North Quay Road  
Newhaven  
East Sussex  
BN9 0HE  
-

#### **Stack Emissions Monitoring Test House**

Environmental Scientifics Group Limited - Mitcheldean Laboratory  
Acacia Building  
Vantage Point Business Village  
Mitcheldean  
GL17 0DD  
UKAS and MCERTS Accreditation Number: 1015

Opinions and interpretations expressed herein are outside the scope of UKAS accreditation.

MCERTS accredited results will only be claimed where both the sampling and analytical stages are UKAS accredited.

This test report shall not be reproduced, except in full, without written approval of Environmental Scientifics Group Limited.

## EXECUTIVE SUMMARY

EMISSIONS SUMMARY					
Parameter	Units	Result	Calculated Uncertainty +/-	Limit	MCERTS accredited result
Total Particulate Matter	mg/m <sup>3</sup>	0.7	0.26	10	✓
Particulate Emission Rate	g/hr	68	23.6	-	
PM <sub>10</sub> (Average result of 4 runs)	mg/m <sup>3</sup>	0.032	0.04	-	✓
PM <sub>10</sub> Emission Rate (Average result of 4 runs)	g/hr	2.50	3.1	-	
PM <sub>2.5</sub> (Average result of 4 runs)	mg/m <sup>3</sup>	0.019	0.03	-	✓
PM <sub>2.5</sub> Emission Rate (Average result of 4 runs)	g/hr	1.49	2.30	-	
<b>PM<sub>10</sub> - Runs</b>					
PM <sub>10</sub> - Run 1	mg/m <sup>3</sup>	0.070	0.09	-	✓
PM <sub>10</sub> Emission Rate - Run 1	g/hr	5.41	6.8	-	
PM <sub>10</sub> - Run 2	mg/m <sup>3</sup>	<b>0.009</b>	0.01	-	✓
PM <sub>10</sub> Emission Rate - Run 2	g/hr	0.65	0.8	-	
PM <sub>10</sub> - Run 3	mg/m <sup>3</sup>	0.030	0.04	-	✓
PM <sub>10</sub> Emission Rate - Run 3	g/hr	2.34	3.0	-	
PM <sub>10</sub> - Run 4	mg/m <sup>3</sup>	0.021	0.03	-	✓
PM <sub>10</sub> Emission Rate - Run 4	g/hr	1.59	2.0	-	
<b>PM<sub>2.5</sub> - Runs</b>					
PM <sub>2.5</sub> - Run 1	mg/m <sup>3</sup>	0.056	0.09	-	✓
PM <sub>2.5</sub> Emission Rate - Run 1	g/hr	5.41	8.3	-	
PM <sub>2.5</sub> - Run 2	mg/m <sup>3</sup>	<b>0.004</b>	0.01	-	✓
PM <sub>2.5</sub> Emission Rate - Run 2	g/hr	0.33	0.5	-	
PM <sub>2.5</sub> - Run 3	mg/m <sup>3</sup>	<b>0.008</b>	0.01	-	✓
PM <sub>2.5</sub> Emission Rate - Run 3	g/hr	0.65	1.00	-	
PM <sub>2.5</sub> - Run 4	mg/m <sup>3</sup>	0.009	0.01	-	✓
PM <sub>2.5</sub> Emission Rate - Run 4	g/hr	0.66	1.02	-	
Moisture	%	17.0	1.5	-	✓
Stack Gas Temperature	°C	151	-	-	✓
Stack Gas Velocity	m/s	18.0	-	-	
Gas Volumetric Flow Rate (Actual)	m <sup>3</sup> /hr	111599	-	-	
Gas Volumetric Flow Rate (STP, Wet)	m <sup>3</sup> /hr	71782	-	-	
Gas Volumetric Flow Rate (STP, Dry)	m <sup>3</sup> /hr	57736	-	-	
Gas Volumetric Flow Rate at Reference Conditions	m <sup>3</sup> /hr	77669	-	-	

ND = None Detected,

Results at or below the limit of detection are highlighted by bold italic text.

The above volumetric flow rate is calculated using data from test specific flow data. Mass emissions for non isokinetic tests and isokinetic tests are calculated using these values

Reference conditions are 273K, 101.3kPa, dry gas 11% Oxygen.

## EXECUTIVE SUMMARY

MONITORING TIMES			
Parameter	Sampling Date(s)	Sampling Times	Sampling Duration
Total Particulate Matter Run 1	01 April 2014	10:52 - 17:32	360 minutes
Total Particulate Matter Run 2	02 April 2014	08:29 - 15:25	360 minutes
Total Particulate Matter Run 3	02 April 2014	16:21 - 19:21	180 minutes
Total Particulate Matter Run 4	03 April 2014	09:40 - 12:40	180 minutes
PM <sub>10</sub> Run 1	01 April 2014	10:52 - 17:32	360 minutes
PM <sub>10</sub> Run 2	02 April 2014	08:29 - 15:25	360 minutes
PM <sub>10</sub> Run 3	02 April 2014	16:21 - 19:21	180 minutes
PM <sub>10</sub> Run 4	03 April 2014	09:40 - 12:40	180 minutes
PM <sub>2.5</sub> Run 1	01 April 2014	10:52 - 17:32	360 minutes
PM <sub>2.5</sub> Run 2	02 April 2014	08:29 - 15:25	360 minutes
PM <sub>2.5</sub> Run 3	02 April 2014	16:21 - 19:21	180 minutes
PM <sub>2.5</sub> Run 4	03 April 2014	09:40 - 12:40	180 minutes
Stack Gas Flow Rate & Temperature Run 1	31 March 2014	15:00	-
Stack Gas Flow Rate & Temperature Run 2	01 April 2014	08:00	-
Stack Gas Flow Rate & Temperature Run 3	01 April 2014	18:14	-
Stack Gas Flow Rate & Temperature Run 4	02 April 2014	07:35	-
Stack Gas Flow Rate & Temperature Run 5	02 April 2014	16:00	-
Stack Gas Flow Rate & Temperature Run 6	02 April 2014	19:45	-
Stack Gas Flow Rate & Temperature Run 7	03 April 2014	09:00	-
Stack Gas Flow Rate & Temperature Run 8	03 April 2014	12:45	-

## EXECUTIVE SUMMARY

PROCESS DETAILS	
Parameter	Process Details
Description of process	Waste incineration
Continuous or batch	Continuous
Product Details	Energy from waste
Part of batch to be monitored (if applicable)	N/A
Normal load, throughput or continuous rating	Approx 28 tonnes/hr
Fuel used during monitoring	Waste
Abatement	Bag filter, lime injection
Plume Appearance	Not visible from monitoring location

## EXECUTIVE SUMMARY

### Monitoring Methods

The selection of standard reference / alternative methods employed by Environmental Scientifics Group Limited is determined, wherever possible by the hierarchy of method selection outlined in Environment Agency Technical Guidance Note (Monitoring) M2. i.e. CEN, ISO, BS, US EPA etc.

MONITORING METHODS						
Species	Method Standard Reference Method / Alternative Method	ESG Technical Procedure	UKAS Lab Number	MCERTS Accredited Method	Limit of Detection (LOD)	Calculated MU +/- %
TPM	SRM - BS EN 13284-1	AE 104	1015	Yes	0.07 mg/m <sup>3</sup>	34.8 %
PM <sub>10</sub>	SRM - BS EN 23210	AE 136	1015	Yes	0.011 mg/m <sup>3</sup>	126 %
PM <sub>2.5</sub>	SRM - BS EN 23210	AE 136	1015	Yes	0.006 mg/m <sup>3</sup>	154 %
O <sub>2</sub>	SRM - BS EN 14789	AE 102	1015	Yes	0.01%	10.1%
H <sub>2</sub> O	AM - M22/FTIR	AE 063	1015	Yes	0.24 %	8.9%
Flow Rate / Temp.	SRM - BS EN 13284-1	AE 122	1015	Yes	5 Pa	-

The measurement uncertainties for the PM<sub>10</sub> and PM<sub>2.5</sub> measurements reflect that measured concentrations were near or below the Limit of Detection.

## EXECUTIVE SUMMARY

### Analytical Methods

The following tables list the analytical methods employed together with the custody and archiving details:

SAMPLING METHODS WITH SUBSEQUENT ANALYSIS							
Species	Analytical Technique	Analytical Procedure	UKAS Lab Number	UKAS Accredited Lab Analysis	Analysis Lab (ESG or Subcontract)	Sample Archive Location	Archive Period
TPM	Gravimetric	AE 106	1015	Yes	ESG Mitcheldean	ESG Mitcheldean	3 months
PM <sub>10</sub>	Gravimetric	AE 106	1015	Yes	ESG Mitcheldean	ESG Mitcheldean	1 year
PM <sub>2.5</sub>	Gravimetric	AE 106	1015	Yes	ESG Mitcheldean	ESG Mitcheldean	1 year

ON-SITE TESTING							
Species	Analytical Technique	Analytical Procedure	UKAS Lab Number	MCERTS Accredited Analysis	Laboratory	Data Archive Location	Archive Period
-	-	-	-	-	-	-	-
O <sub>2</sub>	Paramagnetism	AE 102	1015	Yes	ESG Mitcheldean	ESG Mitcheldean	5 years
H <sub>2</sub> O	Fourier Transform - Infra Red	AE 063	1015	Yes	ESG Mitcheldean	ESG Mitcheldean	5 years

## EXECUTIVE SUMMARY

SAMPLING LOCATION					
Sampling Plane Validation Criteria	Value	Units	Requirement	Compliant	Method
Lowest Differential Pressure	162	Pa	>= 5 Pa	Yes	BS EN 13284-1
Lowest Gas Velocity	15.70	m/s	-	-	-
Highest Gas Velocity	22.40	m/s	-	-	-
Ratio of Gas Velocities	1.43	-	< 3 : 1	Yes	BS EN 13284-1
Mean Velocity	18.02	m/s	-	-	-
Maximum angle of flow with regard to duct axis	<15	°	< 15°	Yes	BS EN 13284-1
No local negative flow	Yes	-	-	Yes	BS EN 13284-1

DUCT CHARACTERISTICS		
	Value	Units
Shape	Circular	-
Depth	1.44	m
Width	-	m
Area	1.63	m <sup>2</sup>
Port Depth	400	mm

SAMPLING LINES & POINTS			
	Isokinetic (CEN Methods)	Isokinetic (ISO Methods)	Non-Iso & Gases
Sample port size	5 inch BSP	-	5 inch BSP
Number of lines used	1	-	1
Number of points / line	1	-	1
Duct orientation	Vertical	-	Vertical
Filtration	In Stack	-	In Stack
Filtration for TPM	In Stack	-	-

SAMPLING PLATFORM	
General Platform Information	
Permanent / Temporary Platform / Ground level / Floor Level / Roof Inside / Outside	Permanent Inside

M1 Platform requirements	
Is there a sufficient working area so work can be performed in a compliant manner	Yes
Platform has 2 levels of handrails (approximately 0.5 m & 1.0 m high)	Yes
Platform has vertical base boards (approximately 0.25 m high)	Yes
Platform has removable chains / self closing gates at the top of ladders	N/A
Handrail / obstructions do not hamper insertion of sampling equipment	Yes
Depth of Platform = >Stack depth / diameter + wall and port thickness + 1.5m	Yes

### Sampling Platform Improvement Recommendations (if applicable)

The sampling location meets all the requirements as specified in EA Guidance Note M1.



## EXECUTIVE SUMMARY

### Sampling & Analytical Method Deviations

#### **6hr run data collection**

Data was collected every ten minutes during the 6hr runs, instead of every five as per the standard. However all readings were checked at five minute intervals to ensure continuity between points.

#### **TPM nozzle size**

Due to the additional number of impingers required for a 6hr sample run in a 22% moisture stack, it was not possible to achieve isokinetics with a 6mm nozzle therefore a 5mm was used. During the 6hr sample run it was expected that a more than sufficient gas sample volume will be achieved.

#### **Goose-neck nozzle Validation**

Due to the long port sleeve, it was physically impossible to insert the cascade impactor using the straight entry nozzle setup recommended in BS EN 23210. Therefore the use of a goose-neck setup was used as this was the only feasible method for monitoring. The standard requires that the use of a goose-neck nozzle is validated, however on this occasion it has not been possible to demonstrate that losses in the nozzle meet the criteria in the standard because the measured concentrations were low and the weight of particulate recovered from the nozzle rinses and the filter media were at or near the weighing LoD. In the context of the low emission concentrations determined during the measurements (all less than 0.1 mg/Nm<sup>3</sup>), losses in the sampling nozzle are unlikely to increase the concentrations significantly.

#### **Single point TPM sampling**

As the TPM run was for comparison purposes with the particle size run, this was also set in the centre of the duct with the particle size head.

#### **Sample flow variation**

The sample flowrate could not be maintained within 5% of the nominal flow throughout the testing periods (which were over extended periods due to the anticipated low PM emission concentrations). Whilst this will have affected the actual cutpoints achieved by the impactor, the results are all at or very near the LOD for the tests and hence this is anticipated to have limited impact on the outcome of the measurements.

### Determination of representative sampling location

An assessment of temperature homogeneity was performed in accordance with EN 23210 Annex-G on the first day of monitoring 5th March 2014. There was a feedstock change on the morning of the third day 7th March 2014 from municipal waste to Community Recycling Centre waste. A further homogeneity test was performed on 7th March and the representative sampling point was determined to be at the same location as on 5th March.

APPENDICES

**CONTENTS**

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

APPENDIX 3 - Measurement Uncertainty Budget Calculations

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

<b>MONITORING SCHEDULE</b>					
<b>Species</b>	<b>Method</b> Standard Reference Method / Alternative Method	<b>ESG</b> <b>Technical</b> <b>Procedure</b>	<b>UKAS Lab</b> <b>Number</b>	<b>MCERTS</b> <b>Accredited</b> <b>Method</b>	<b>Number of</b> <b>Samples</b>
TPM	SRM - BS EN 13284-1	AE 104	1015	Yes	4
PM <sub>10</sub>	SRM - BS EN 23210	AE 136	1015	Yes	4
PM <sub>2.5</sub>	SRM - BS EN 23210	AE 136	1015	Yes	4
H <sub>2</sub> O	AM - M22/FTIR	AE 063	1015	Yes	6
Flow Rate / Temp.	SRM - BS EN 13284-1	AE 122	1015	Yes	10

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

CALIBRATEABLE EQUIPMENT CHECKLIST					
Extractive Sampling		Instrumental Analyser/s		Miscellaneous	
Equipment	Equipment I.D.	Equipment	Equipment I.D.	Equipment	Equipment I.D.
Control Box DGM	P1760 + P1799	Horiba PG-250 Analyser	-	Laboratory Balance	00-12/00-13
Box Thermocouples	P1760 + P1799	FT-IR	P2060	Tape Measure	24-DJH
Meter In Thermocouple	P1760 + P1799	FT-IR Oven Box	-	Stopwatch	17-DJH
Meter Out Thermocouple	P1760 + P1799	Bernath 3006 FID	-	Protractor	-
Control Box Timer	P1799	Signal 3030 FID	-	Barometer	08-DJH
Oven Box	-	Servomex	-	Digital Micromanometer	01-DJH
Probe	-	JCT Heated Head Filter	-	Digital Temperature Meter	03-DJH
Probe Thermocouple	-	Thermo FID	-	Stack Thermocouple	-
Probe	-	Stackmaster	-	Mass Flow Controller	-
Probe Thermocouple	P2253 + P2160	FTIR Heater Box for Heated Line	-	MFC Display module	-
S-Pitot	P2246 + P2158	Anemometer	-	1m Heated Line (1)	18-05
L-Pitot	-	Ecophysics NOx Analyser	-	1m Heated Line (2)	-
Site Balance	-	Chiller (JCT/MAK 10)	-	1m Heated Line (3)	-
Last Impinger Arm	P1966 + P2049	Heated Line Controller (1)	-	5m Heated Line (1)	-
Dioxins Cond. Thermocouple	-	Heated Line Controller (2)	-	10m Heated Line (1)	-
Callipers	P2178	Site temperature Logger	-	10m Heated Line (2)	-
Small DGM	-	Impactor 1	NR18706	15m Heated Line (1)	-
Heater Controller	-		-	20m Heated Line (1)	03-84
Inclinometer (Swirl Device)	P2094		-	20m Heated Line (2)	-

NOTE: If the equipment I.D is represented by a dash (-), then this piece of equipment has not been used for this test.

CALIBRATION / CHECK GASES					
Gas (traceable to ISO 17025)	Cylinder I.D Number	Supplier	ppm	%	Analytical Tolerance +/- %
Oxygen	DA W1	BOC	-	9.52	2
Methane	DA W1	BOC	162.9	-	2
Carbon Dioxide	DA W1	BOC	-	5.18	2

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

**STACK EMISSIONS MONITORING TEAM**

Team Leader

Paul Jones  
MCERTS Level 2  
Te1 Expiry Date - Dec 2016  
Te2 Expiry Date - Dec 2016  
Te3 Expiry Date - Mar 2018  
Te4 Expiry Date - Dec 2016  
MM 02 044  
MCERTS Expiry Date - Mar 2018  
H&S Expiry Date - Sep 2015

Technician

Rad Poremba  
MCERTS Level 1  
MM 10 1069  
MCERTS Expiry Date - Jul 2015  
H&S Expiry Date - Jul 2015

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

TOTAL PARTICULATE MATTER SUMMARY					
Parameter	Sampling Times	Concentration mg/m <sup>3</sup>	Uncertainty mg/m <sup>3</sup>	Limit mg/m <sup>3</sup>	Emission Rate g/hr
Run 1	10:52 - 17:32 01 April 2014	0.4	0.14	10	32
Run 2	08:29 - 15:25 02 April 2014	1.3	0.15	10	123
Run 3	16:21 - 19:21 02 April 2014	0.6	0.27	10	53
Run 4	09:40 - 12:40 03 April 2014	0.7	0.29	10	63
Blank	-	0.09	-	-	-
Blank 2	-	0.09	-	-	-
Blank 3	-	0.09	-	-	-

Reference conditions are 273K, 101.3kPa, dry gas 11% Oxygen.

Acetone Blank Value mg/l	Acceptable Value mg/l
2.0	10

**FILTER INFORMATION**

SAMPLES								
Test	Filter & Probe Rinse Number	Filter Start Weight g	Filter End Weight g	Mass Gained on Filter g	Probe Rinse Start Weight g	Probe Rinse End Weight g	Mass Gained on Probe g	Combined Total Mass Gained g
Run 1	116150.00	0.15620	0.15480	-0.00140	68.53890	68.54120	0.00230	0.00090
Run 2	116152.00	0.15630	0.16260	0.00630	70.26230	70.26560	0.00330	0.00960
Run 3	116153.00	0.15680	0.15630	-0.00050	74.24400	74.24590	0.00190	0.00140
Run 4	116155.00	0.15790	0.15970	0.00180	72.45760	72.45830	0.00070	0.00250

If total mass gained is less than the LOD then the LOD is reported

BLANKS								
Test	Filter & Probe Number	Filter Start Weight g	Filter End Weight g	Mass Gained Filter g	Probe Start Weight g	Probe End Weight g	Mass Gained Probe g	Combined Total Mass Gained g
Run 1	116151	0.15910	0.15900	-0.00010	71.83610	71.83650	0.00040	0.00050
Run 2	116154	0.15730	0.15730	0.00000	71.29260	71.29250	-0.00010	0.00050
Run 3	116156	0.15440	0.15430	-0.00010	71.29260	71.29250	-0.00010	0.00050

If total mass gained is less than the LOD then the LOD is reported

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS - RUN 1			TPM	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	755.26	CO <sub>2</sub>	% 11.67
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	18.35	O <sub>2</sub>	% 7.55
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	756.61	Total	% 19.22
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			N <sub>2</sub> (100 -Total)	
Moisture trap weight increase, V <sub>lc</sub>	g	-	% 80.78	
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	M <sub>d</sub> = 0.44(%CO <sub>2</sub> )+0.32(%O <sub>2</sub> )+0.28(%N <sub>2</sub> )	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			<b>Molecular weight of wet gas, M<sub>s</sub></b>	
Volume of gas sample through gas meter, V <sub>m</sub>		5.613	M <sub>s</sub> = M <sub>d</sub> (1 - B <sub>wo</sub> ) + 18(B <sub>wo</sub> )	
Gas meter correction factor, Y <sub>d</sub>		1.0558	g/gmol 28.10	
Mean dry gas meter temperature, T <sub>m</sub>		35.472	<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Mean pressure drop across orifice, ΔH mmH <sub>2</sub> O		23.580	Area of stack, A <sub>s</sub>	m <sup>2</sup> 1.63
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		5.224	Q <sub>a</sub> = (60)(A <sub>s</sub> )(V <sub>s</sub> )	m <sup>3</sup> /min 2081.9
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			<b>Total flow of stack gas, Q</b>	
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	6.2930	Conversion factor (K/mm.Hg)	
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			Q <sub>std</sub> = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})}{(T_s) + 273}$ Dry 1107.3	
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	Q <sub>stdO2</sub> = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})(O_2REF)}{(T_s) + 273}$ @O <sub>2</sub> ref 1489.64	
% oxygen measured in gas stream, act%O <sub>2</sub>		7.5	Q <sub>stw</sub> = $\frac{(Q_a)P_s(0.3592)}{(T_s) + 273}$ Wet 1334.02	
% oxygen reference condition		11	<b>Percent isokinetic, %I</b>	
O <sub>2</sub> Reference O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>		1.35	Nozzle diameter, D <sub>n</sub> mm 5.03	
Factor $\frac{21.0 - ref\%O_2}{21.0 - act\%O_2}$		1.35	Nozzle area, A <sub>n</sub> mm <sup>2</sup> 19.87	
$V_{mstd@X\%oxygen} = (V_{mstd}) (O_2 Ref)$	m <sup>3</sup>	7.0272	Total sampling time, θ min 360	
<b>Moisture content, B<sub>wo</sub></b>			%I = $\frac{(4.6398E6)(T_s+273)(V_{mstd})}{(P_s)(V_s)(A_n)(\theta)(1-B_{wo})}$ % 107.4	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	0.1699	Acceptable isokinetic range 95% to 115% Yes	
		16.99	<b>Particulate Concentration, C</b>	
<b>Moisture by FTIR</b>			Mass collected on filter, M <sub>f</sub> g 0.00020	
	%	19.56725315	Mass collected in probe, M <sub>p</sub> g 0.00230	
<b>Velocity of stack gas, V<sub>s</sub></b>			Total mass collected, M <sub>n</sub> g 0.00250	
Pitot tube velocity constant, K <sub>p</sub>		34.97	C <sub>wet</sub> = $\frac{M_n}{V_{mstw}}$ mg/m <sup>3</sup> 0.397	
Velocity pressure coefficient, C <sub>p</sub>		0.82	C <sub>dry</sub> = $\frac{M_n}{V_{mstd}}$ mg/m <sup>3</sup> 0.479	
Mean of velocity heads, ΔP <sub>avg</sub> mm H <sub>2</sub> O		27.67	C <sub>dry@X%O2</sub> = $\frac{M_n}{V_{mstd@X\%oxygen}}$ mg/m <sup>3</sup> 0.356	
Mean square root of velocity heads, √ΔP		5.26	<b>Particulate Emission Rates, E</b>	
Mean stack gas temperature, T <sub>s</sub> °C		151	E = [(C <sub>wet</sub> )/(Q <sub>stw</sub> )(60)] / 1000 31.80	
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	21.30		

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS - RUN 2			TPM	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	755.26	CO <sub>2</sub>	% 11.67
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	18.35	O <sub>2</sub>	% 7.37
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	756.61	Total	% 19.05
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			N <sub>2</sub> (100 -Total)	
Moisture trap weight increase, V <sub>lc</sub>	g	-	% 80.95	
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	M <sub>d</sub> = 0.44(%CO <sub>2</sub> )+0.32(%O <sub>2</sub> )+0.28(%N <sub>2</sub> )	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			<b>Molecular weight of wet gas, M<sub>s</sub></b>	
Volume of gas sample through gas meter, V <sub>m</sub>		5.524	M <sub>s</sub> = M <sub>d</sub> (1 - B <sub>wo</sub> ) + 18(B <sub>wo</sub> )	
Gas meter correction factor, Y <sub>d</sub>		1.0558	g/gmol 28.10	
Mean dry gas meter temperature, T <sub>m</sub>		30.056	<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Mean pressure drop across orifice, ΔH mmH <sub>2</sub> O		23.454	Area of stack, A <sub>s</sub> m <sup>2</sup> 1.63	
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		5.233	Q <sub>a</sub> = (60)(A <sub>s</sub> )(V <sub>s</sub> ) m <sup>3</sup> /min 2096.0	
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			<b>Total flow of stack gas, Q</b>	
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	6.3045	Conversion factor (K/mm.Hg) 0.3592	
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			Q <sub>std</sub> = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})}{(T_s) + 273}$ Dry 1114.5	
Is the process burning hazardous waste? (if yes, no favourable oxygen correction)		No	Q <sub>stdO2</sub> = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})(O_2REF)}{(T_s) + 273}$ @O <sub>2</sub> ref 1516.02	
% oxygen measured in gas stream, act%O <sub>2</sub>		7.372787194	Q <sub>stw</sub> = $\frac{(Q_a)P_s(0.3592)}{(T_s) + 273}$ Wet 1342.62	
% oxygen reference condition		11	<b>Percent isokinetic, %I</b>	
O <sub>2</sub> Reference O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>		1.36	Nozzle diameter, D <sub>n</sub> mm 5.03	
Factor 21.0 - ref%O <sub>2</sub>			Nozzle area, A <sub>n</sub> mm <sup>2</sup> 19.87	
$V_{mstd@X\%oxygen} = (V_{mstd}) (O_2 Ref)$	m <sup>3</sup>	7.1315	Total sampling time, θ min 360	
<b>Moisture content, B<sub>wo</sub></b>			$\%I = \frac{(4.6398E6)(T_s+273)(V_{mstd})}{(P_s)(V_s)(A_n)(\theta)(1-B_{wo})}$ % 106.9	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$		0.1699	Acceptable isokinetic range 95% to 115% Yes	
	%	16.99	<b>Particulate Concentration, C</b>	
<b>Moisture by FTIR</b>			Mass collected on filter, M <sub>f</sub> g 0.00630	
	%	19.56725315	Mass collected in probe, M <sub>p</sub> g 0.00330	
<b>Velocity of stack gas, V<sub>s</sub></b>			Total mass collected, M <sub>n</sub> g 0.00960	
Pitot tube velocity constant, K <sub>p</sub>		34.97	C <sub>wet</sub> = $\frac{M_n}{V_{mstw}}$ mg/m <sup>3</sup> 1.52	
Velocity pressure coefficient, C <sub>p</sub>		0.82	C <sub>dry</sub> = $\frac{M_n}{V_{mstd}}$ mg/m <sup>3</sup> 1.83	
Mean of velocity heads, ΔP <sub>avg</sub> mm H <sub>2</sub> O		28.03	C <sub>dry@X%O2</sub> = $\frac{M_n}{V_{mstd@X\%oxygen}}$ mg/m <sup>3</sup> 1.35	
Mean square root of velocity heads, √ΔP		5.29	<b>Particulate Emission Rates, E</b>	
Mean stack gas temperature, T <sub>s</sub> °C		151	E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000 122.66	
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	21.45		



APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS - RUN 3			TPM	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	755.26	CO <sub>2</sub>	% 11.67
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	18.35	O <sub>2</sub>	% 7.13
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	756.61	Total	% 18.80
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			N <sub>2</sub> (100 -Total)	
Moisture trap weight increase, V <sub>lc</sub>	g	-	%	
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	%	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			M <sub>d</sub> = 0.44(%CO <sub>2</sub> )+0.32(%O <sub>2</sub> )+0.28(%N <sub>2</sub> )	
Volume of gas sample through gas meter, V <sub>m</sub>		2.802	30.15	
Gas meter correction factor, Y <sub>d</sub>		1.0558	<b>Molecular weight of wet gas, M<sub>s</sub></b>	
Mean dry gas meter temperature, T <sub>m</sub>		30.847	M <sub>s</sub> = M <sub>d</sub> (1 - B <sub>wo</sub> ) + 18(B <sub>wo</sub> )	
Mean pressure drop across orifice, ΔH	mmH <sub>2</sub> O	23.832	g/gmol 28.09	
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		2.648	<b>Actual flow of stack gas, Q<sub>a</sub></b>	
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Area of stack, A <sub>s</sub>	
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	3.1898	m <sup>2</sup> 1.63	
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O<sub>2</sub></sub></b>			Q <sub>a</sub> = (60)(A <sub>s</sub> )(V <sub>s</sub> )	
Is the process burning hazardous waste? (if yes, no favourable oxygen correction)		No	m <sup>3</sup> /min 2113.4	
% oxygen measured in gas stream, act%O <sub>2</sub>		7.129864607	<b>Total flow of stack gas, Q</b>	
% oxygen reference condition		11	Conversion factor (K/mm.Hg)	
O <sub>2</sub> Reference	O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>	1.39	0.3592	
Factor	$\frac{21.0 - ref\%O_2}{21.0 - act\%O_2}$		Q <sub>std</sub> = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})}{(T_s) + 273}$	
$V_{mstd@X\%oxygen} = (V_{mstd})(O_2 Ref)$	m <sup>3</sup>	3.6725	Dry 1122.0	
<b>Moisture content, B<sub>wo</sub></b>			Q <sub>stdO<sub>2</sub></sub> = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})(O_2 REF)}{(T_s) + 273}$	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$		0.1699	@O <sub>2</sub> ref 1553.52	
	%	16.99	Q <sub>stw</sub> = $\frac{(Q_a)P_s(0.3592)}{(T_s) + 273}$	
<b>Moisture by FTIR</b>			Wet 1351.73	
	%	19.56725315	<b>Percent isokinetic, %I</b>	
<b>Velocity of stack gas, V<sub>s</sub></b>			Nozzle diameter, D <sub>n</sub>	
Pitot tube velocity constant, K <sub>p</sub>		34.97	mm 5.03	
Velocity pressure coefficient, C <sub>p</sub>		0.82	Nozzle area, A <sub>n</sub>	
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	28.44	mm <sup>2</sup> 19.87	
Mean square root of velocity heads, √ΔP		5.33	Total sampling time, θ	
Mean stack gas temperature, T <sub>s</sub>	°C	152	min 180	
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{(T_s + 273)})}{(M_s)(P_s)}$	m/s	21.63	%I = $\frac{(4.6398E6)(T_s+273)(V_{mstd})}{(P_s)(V_s)(A_n)(\theta)(1-B_{wo})}$	
<b>Moisture content, B<sub>wo</sub></b>			Acceptable isokinetic range 95% to 115%	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$		0.1699	Yes	
	%	16.99	<b>Particulate Concentration, C</b>	
<b>Moisture by FTIR</b>			Mass collected on filter, M <sub>f</sub>	
	%	19.56725315	g 0.00020	
<b>Velocity of stack gas, V<sub>s</sub></b>			Mass collected in probe, M <sub>p</sub>	
Pitot tube velocity constant, K <sub>p</sub>		34.97	g 0.00190	
Velocity pressure coefficient, C <sub>p</sub>		0.82	Total mass collected, M <sub>n</sub>	
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	28.44	g 0.0021	
Mean square root of velocity heads, √ΔP		5.33	C <sub>wet</sub> = $\frac{M_n}{V_{mstw}}$	
Mean stack gas temperature, T <sub>s</sub>	°C	152	mg/m <sup>3</sup> 0.66	
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{(T_s + 273)})}{(M_s)(P_s)}$	m/s	21.63	C <sub>dry</sub> = $\frac{M_n}{V_{mstd}}$	
<b>Moisture content, B<sub>wo</sub></b>			mg/m <sup>3</sup> 0.79	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$		0.1699	C <sub>dry@X%O<sub>2</sub></sub> = $\frac{M_n}{V_{mstd@X\%oxygen}}$	
	%	16.99	mg/m <sup>3</sup> 0.57	
<b>Moisture by FTIR</b>			<b>Particulate Emission Rates, E</b>	
	%	19.56725315	E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	
<b>Velocity of stack gas, V<sub>s</sub></b>			53.40	
Pitot tube velocity constant, K <sub>p</sub>		34.97		
Velocity pressure coefficient, C <sub>p</sub>		0.82		
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	28.44		
Mean square root of velocity heads, √ΔP		5.33		
Mean stack gas temperature, T <sub>s</sub>	°C	152		
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{(T_s + 273)})}{(M_s)(P_s)}$	m/s	21.63		

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS - RUN 4			TPM	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	745.51	CO <sub>2</sub>	% 11.67
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	21.41	O <sub>2</sub>	% 7.22
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	747.08	Total	% 18.89
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			N <sub>2</sub> (100 -Total)	
Moisture trap weight increase, V <sub>lc</sub>	g	-	%	
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	%	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			M <sub>d</sub> = 0.44(%CO <sub>2</sub> )+0.32(%O <sub>2</sub> )+0.28(%N <sub>2</sub> )	
Volume of gas sample through gas meter, V <sub>m</sub>		2.699	30.16	
Gas meter correction factor, Y <sub>d</sub>		1.059	<b>Molecular weight of wet gas, M<sub>s</sub></b>	
Mean dry gas meter temperature, T <sub>m</sub>		29.042	M <sub>s</sub> = M <sub>d</sub> (1 - B <sub>wo</sub> ) + 18(B <sub>wo</sub> )	
Mean pressure drop across orifice, ΔH	mmH <sub>2</sub> O	22.048	g/gmol 28.09	
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		2.539	<b>Actual flow of stack gas, Q<sub>a</sub></b>	
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Area of stack, A <sub>s</sub>	
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	3.0583	m <sup>2</sup> 1.63	
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O<sub>2</sub></sub></b>			Q <sub>a</sub> = (60)(A <sub>s</sub> )(V <sub>s</sub> )	
Is the process burning hazardous waste? (if yes, no favourable oxygen correction)		No	m <sup>3</sup> /min 2045.0	
% oxygen measured in gas stream, act%O <sub>2</sub>		7.222038048	<b>Total flow of stack gas, Q</b>	
% oxygen reference condition		11	Conversion factor (K/mm.Hg) 0.3592	
O <sub>2</sub> Reference O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>		1.38	Q <sub>std</sub> = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})}{(T_s) + 273}$	
Factor $\frac{21.0 - ref\%O_2}{21.0 - act\%O_2}$		1.38	Dry 1074.0	
$V_{mstd@X\%oxygen} = (V_{mstd}) (O_2 Ref)$	m <sup>3</sup>	3.4977	Q <sub>stdO2</sub> = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})(O_2 REF)}{(T_s) + 273}$	
<b>Moisture content, B<sub>wo</sub></b>			@O <sub>2</sub> ref 1476.63	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$		0.1699	Q <sub>stw</sub> = $\frac{(Q_a)P_s(0.3592)}{(T_s) + 273}$	
	%	16.99	Wet 1293.85	
<b>Moisture by FTIR</b>			<b>Percent isokinetic, %I</b>	
	%	19.56725315	Nozzle diameter, D <sub>n</sub>	
<b>Velocity of stack gas, V<sub>s</sub></b>			mm 5.03	
Pitot tube velocity constant, K <sub>p</sub>		34.97	Nozzle area, A <sub>n</sub>	
Velocity pressure coefficient, C <sub>p</sub>		0.82	mm <sup>2</sup> 19.90	
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	0.82	Total sampling time, θ	
Mean square root of velocity heads, √ΔP		26.35	min 180	
Mean stack gas temperature, T <sub>s</sub>	°C	5.13	%I = $\frac{(4.6398E6)(T_s+273)(V_{mstd})}{(P_s)(V_s)(A_n)(\theta)(1-B_{wo})}$	
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	151	%	
		20.92	Acceptable isokinetic range 95% to 115%	
<b>Moisture content, B<sub>wo</sub></b>			Yes	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$		0.1699	<b>Particulate Concentration, C</b>	
	%	16.99	Mass collected on filter, M <sub>f</sub>	
<b>Moisture by FTIR</b>			g 0.00180	
	%	19.56725315	Mass collected in probe, M <sub>p</sub>	
<b>Velocity of stack gas, V<sub>s</sub></b>			g 0.00070	
Pitot tube velocity constant, K <sub>p</sub>		34.97	Total mass collected, M <sub>n</sub>	
Velocity pressure coefficient, C <sub>p</sub>		0.82	g 0.00250	
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	0.82	C <sub>wet</sub> = $\frac{M_n}{V_{mstw}}$	
Mean square root of velocity heads, √ΔP		26.35	mg/m <sup>3</sup> 0.82	
Mean stack gas temperature, T <sub>s</sub>	°C	5.13	C <sub>dry</sub> = $\frac{M_n}{V_{mstd}}$	
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	151	mg/m <sup>3</sup> 0.98	
		20.92	C <sub>dry@X%O2</sub> = $\frac{M_n}{V_{mstd@X\%oxygen}}$	
<b>Moisture content, B<sub>wo</sub></b>			mg/m <sup>3</sup> 0.71	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$		0.1699	<b>Particulate Emission Rates, E</b>	
	%	16.99	E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	
<b>Moisture by FTIR</b>			63.46	
	%	19.56725315		

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**TOTAL PARTICULATE MATTER QUALITY ASSURANCE CHECKLIST**

LEAK RATE						
Run	Mean Sampling Rate litre/min	Pre-sampling Leak Rate litre/min	Post-sampling Leak Rate litre/min	Maximum Vacuum mm Hg	Acceptable Leak Rate litre/min	Leak Tests Acceptable?
Run 1	16.46	0.2	0.3	304.8	0.33	Yes
Run 2	16.20	0.3	0.3	304.8	0.32	Yes
Run 3	16.44	0.2	0.25	304.8	0.33	Yes
Run 4	15.87	0.3	0.3	304.8	0.32	Yes

ISOKINETICITY		
Run	Isokinetic Variation %	Acceptable Isokineticity
Run 1	107.39	Yes
Run 2	106.90	Yes
Run 3	107.44	Yes
Run 4	107.48	Yes

Acceptable isokinetic range 95% to 115%

WEIGHING BALANCE UNCERTAINTY			
Run	Result mg/m <sup>3</sup>	5% ELV mg/m <sup>3</sup>	LOD < 5% ELV
Run 1	0.07	0.5	Yes
Run 2	0.07	0.5	Yes
Run 3	0.14	0.5	Yes
Run 4	0.1	0.5	Yes

The above is based on both the Filter and rinse uncertainty

BLANK VALUE				
Run	Overall Blank Value mg/m <sup>3</sup>	Daily Emission Limit Value mg/m <sup>3</sup>	Acceptable Blank Value mg/m <sup>3</sup>	Overall Blank Acceptable
Blank 1	0.09	10	1.0	Yes
Blank 2	0.09	10	1.0	Yes
Blank 3	0.09	10	1.0	Yes

FILTERS					
Run	Filter Material	Filter Size mm	Max Filtration Temperature °C	Pre-use Filter Conditioning Temperature °C	Post-use Filter Conditioning Temperature °C
Run 1	QF	47	153	180	160
Run 2	QF	47	152	180	160
Run 3	QF	47	153	180	160
Run 4	QF	47	152	180	160

GF = Glass Fibre  
QF = Quartz Fibre

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

PM <sub>10</sub> SUMMARY					
Test	Sampling Times	Concentration mg/m <sup>3</sup>	LOD mg/m <sup>3</sup>	Limit mg/m <sup>3</sup>	Emission Rate g/hr
Run 1	10:52 - 17:32 01 April 2014	0.070	0.009	-	5.41
Run 2	08:29 - 15:25 02 April 2014	0.009	0.009	-	0.65
Run 3	16:21 - 19:21 02 April 2014	0.030	0.017	-	2.34
Run 4	09:40 - 12:40 03 April 2014	0.021	0.023	-	1.59
Blank 1	-	0.011	-	-	-
Blank 2	-	0.011	-	-	-

Reference conditions are 273K, 101.3kPa, dry gas 11% Oxygen.  
where values are below the LOD the LOD will be reported.

PM <sub>2.5</sub> SUMMARY					
Test	Sampling Times	Concentration mg/m <sup>3</sup>	LOD mg/m <sup>3</sup>	Limit mg/m <sup>3</sup>	Emission Rate g/hr
Run 1	10:52 - 17:32 01 April 2014	0.056	0.004	-	4.33
Run 2	08:29 - 15:25 02 April 2014	0.004	0.004	-	0.33
Run 3	16:21 - 19:21 02 April 2014	0.008	0.008	-	0.65
Run 4	09:40 - 12:40 03 April 2014	0.009	0.012	-	0.66
Blank 1	-	0.006	-	-	-
Blank 2	-	0.022	-	-	-

Reference conditions are 273K, 101.3kPa, dry gas 11% Oxygen.  
where values are below the LOD the LOD will be reported, where this occurs the quoted uncertainties will be relatively high.

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

PM <sub>2.5</sub> (BF) SAMPLES WEIGHTS				
Test	PM <sub>2.5</sub> Filter Number	Filter Start Weight g	Filter End Weight g	PM <sub>2.5</sub> Mass Gained on Filter g
Run 1	QC1003	15.82804	15.82868	0.00064
Run 2	QC1010	32.77095	32.77094	-0.00001
Run 3	QC1049	32.06334	32.06302	-0.00032
Run 4	QC1045	32.73710	32.73682	-0.00028
Blank 1	QC1009	32.58576	32.58548	-0.00028
Blank 2	QC1044	31.65517	31.65536	0.00019

PM <sub>10</sub> (CP2) SAMPLES WEIGHTS				
Test	PM <sub>10</sub> Filter Number g	Filter Start Weight g	Filter End Weight g	PM <sub>10</sub> Mass Gained on Filter g
Run 1	QC1028	15.16626	15.16642	0.00016
Run 2	QC1059	15.82759	15.82754	-0.00005
Run 3	QC1049	15.16123	15.16136	0.00013
Run 4	QC1053	15.27576	15.27583	0.00007
Blank 1	QC1060	16.04445	16.04427	-0.00018
Blank 2	QC1052	15.69773	15.69749	-0.00024

PM <sub>2.5</sub> & PM <sub>10</sub> (BF & CP2) SAMPLES WEIGHTS COMBINED							
Test	PM <sub>2.5</sub> Filter Number	PM <sub>10</sub> Filter Number	PM <sub>2.5</sub> Mass Gained on Filter g	PM <sub>10</sub> Mass Gained on Filter g	Actual PM <sub>2.5</sub> & PM <sub>10</sub> Combined Total Mass Gained g	PM <sub>2.5</sub> & PM <sub>10</sub> Combined Weighing LOD g	*Reported PM <sub>2.5</sub> & PM <sub>10</sub> Combined Total Mass Gained g
Run 1	QC1003	QC1028	0.00064	0.00016	0.00080	0.00010	0.00080
Run 2	QC1010	QC1059	-0.00001	-0.00005	-0.00006	0.00010	0.00010
Run 3	QC1049	QC1049	-0.00032	0.00013	-0.00019	0.00010	0.00018
Run 4	QC1045	QC1053	-0.00028	0.00007	-0.00021	0.00010	0.00012
Blank 1	QC1009	QC1060	-0.00028	-0.00018	-0.00046	0.00010	0.00010
Blank 2	QC1044	QC1052	0.00019	-0.00024	-0.00005	0.00010	0.00010

\* Where weighing values are below the LOD possibly due to loss of filter material, the LOD will be reported.

NOTE - Where the filter weight gain is less than the weighing uncertainty, the weighing uncertainty is used for further calculations. The weighing uncertainty is 0.00005g.

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS RUN 1			PM <sub>10</sub> & PM <sub>2.5</sub>	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	755.3	CO <sub>2</sub>	9.39
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	1.3	O <sub>2</sub>	7.55
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	755.4	Total	16.94
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			N <sub>2</sub> (100 -Total)	83.06
Moisture trap weight increase, V <sub>lc</sub>	g	H <sub>2</sub> O by FTIR	M <sub>d</sub> = 0.44(%CO <sub>2</sub> )+0.32(%O <sub>2</sub> )+0.28(%N <sub>2</sub> )	29.80
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	<b>Molecular weight of wet gas, M<sub>s</sub></b>	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			M <sub>s</sub> = M <sub>d</sub> (1 - B <sub>wo</sub> ) + 18(B <sub>wo</sub> )	27.49
Volume of gas sample through gas meter, V <sub>m</sub>		9.91	<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Gas meter correction factor, Y <sub>d</sub>		0.97	Area of stack, A <sub>s</sub>	m <sup>2</sup> 1.63
Mean dry gas meter temperature, T <sub>m</sub>		39.13	Q <sub>a</sub> = (60)(A <sub>s</sub> )(V <sub>s</sub> )	m <sup>3</sup> /min 1848.6
Mean pressure drop across orifice, ΔH	mmH <sub>2</sub> O	71.81	<b>Percent isokinetic, %I</b>	
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		8.442	Required Flow Rate @ DGM	l/min 28.70
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Actual Flow Rate @ DGM	l/min 31.0
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	10.4957	Isokinetic Rate	108.14
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			Acceptable 90% - 130%	Yes
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	<b>Particulate Concentration, C<sub>PM10</sub></b>	
% oxygen measured in gas stream, act%O <sub>2</sub>		7.55	Mass of particulate collected on PM <sub>10</sub> filter, M <sub>f</sub>	0.00016
% oxygen reference condition		11	Mass of particulate collected on PM <sub>2.5</sub> filter, M <sub>f</sub>	0.00064
O <sub>2</sub> Reference	O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>	1.35	$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.07622
Factor	$\frac{21.0 - ref\%O_2}{21.0 - act\%O_2}$		$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.09476
$V_{mstd@X\%oxygen} = (V_{mstd}) (O_2 Ref)$	m <sup>3</sup>	11.356	$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.07044
<b>Moisture content, B<sub>wo</sub></b>			<b>Particulate Emission Rates, E</b>	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	0.1957	E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	5.41
		19.57	<b>Particulate Concentration, C<sub>PM2.5</sub></b>	
<b>Moisture by FTIR</b>			Mass of particulate collected on filter, M <sub>f</sub>	0.00064
	%	19.57	$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.0610
<b>Velocity of stack gas, V<sub>s</sub></b>			$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.0758
Pitot tube velocity constant, K <sub>p</sub>		34.97	$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0564
Velocity pressure coefficient, C <sub>p</sub>		0.81	<b>Particulate Emission Rates, E</b>	
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	21.83	E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	4.33
Mean square root of velocity heads, √ΔP		4.7		
Mean stack gas temperature, T <sub>s</sub>	°C	151		
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{(T_s + 273))}}{(M_s)(P_s)}$	m/s	18.92		

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS RUN 2			PM <sub>10</sub> & PM <sub>2.5</sub>	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	750.0	CO <sub>2</sub>	9.71
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	1.6	O <sub>2</sub>	7.37
$P_s = P_b + (P_{static})$	mm Hg	750.1	Total	17.09
$\frac{13.6}{13.6}$			N <sub>2</sub> (100 -Total)	82.91
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2)$	
Moisture trap weight increase, V <sub>lc</sub>	g	H <sub>2</sub> O by FTIR	<b>Molecular weight of wet gas, M<sub>s</sub></b>	
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	$M_s = M_d(1 - B_{wo}) + 18(B_{wo})$	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Volume of gas sample through gas meter, V <sub>m</sub>		9.93	Area of stack, A <sub>s</sub>	m <sup>2</sup> 1.63
Gas meter correction factor, Y <sub>d</sub>		0.97	$Q_a = (60)(A_s)(V_s)$	m <sup>3</sup> /min 1817.7
Mean dry gas meter temperature, T <sub>m</sub>		33.19	<b>Percent isokinetic, %I</b>	
Mean pressure drop across orifice, ΔH	mmH <sub>2</sub> O	70.00	Required Flow Rate @ DGM	l/min 31.10
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		8.565	Actual Flow Rate @ DGM	l/min 31.0
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Isokinetic Rate	
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	10.6241	Acceptable 90% - 130%	
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			<b>Particulate Concentration, C<sub>PM10</sub></b>	
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	Mass of particulate collected on PM <sub>10</sub> filter, M <sub>f</sub>	0.00005
% oxygen measured in gas stream, act%O <sub>2</sub>		7.37	Mass of particulate collected on PM <sub>2.5</sub> filter, M <sub>f</sub>	0.00005
% oxygen reference condition		11	$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.0094
O <sub>2</sub> Reference O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>		1.36	$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.0117
Factor 21.0 - ref%O <sub>2</sub>			$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0086
$V_{mstd@X\%oxygen} = (V_{mstd})(O_2 Ref)$	m <sup>3</sup>	11.671	<b>Particulate Emission Rates, E</b>	
<b>Moisture content, B<sub>wo</sub></b>			$E = [(C_{wet})(Q_{stw})(60)] / 1000$	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	19.38	0.65	
<b>Moisture by FTIR</b>			<b>Particulate Concentration, C<sub>PM2.5</sub></b>	
	%	19.38	Mass of particulate collected on filter, M <sub>f</sub>	
<b>Velocity of stack gas, V<sub>s</sub></b>			$C_{wet} = \frac{M_n}{V_{mstw}}$	
Pitot tube velocity constant, K <sub>p</sub>		34.97	mg/m <sup>3</sup> 0.0047	
Velocity pressure coefficient, C <sub>p</sub>		0.81	$C_{dry} = \frac{M_n}{V_{mstd}}$	
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	21.01	mg/m <sup>3</sup> 0.0058	
Mean square root of velocity heads, √ΔP		4.58	$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	
Mean stack gas temperature, T <sub>s</sub>	°C	151	mg/m <sup>3</sup> 0.0043	
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	18.60	<b>Particulate Emission Rates, E</b>	
			$E = [(C_{wet})(Q_{stw})(60)] / 1000$	
			0.33	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS RUN 3			PM <sub>10</sub> & PM <sub>2.5</sub>	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	750.0	CO <sub>2</sub>	9.97
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	1.6	O <sub>2</sub>	7.13
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	750.1	Total	17.10
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			N <sub>2</sub> (100 -Total)	
Moisture trap weight increase, V <sub>lc</sub>	g	H <sub>2</sub> O by FTIR	M <sub>d</sub> = 0.44(%CO <sub>2</sub> )+0.32(%O <sub>2</sub> )+0.28(%N <sub>2</sub> )	82.90
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	<b>Molecular weight of wet gas, M<sub>s</sub></b>	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			M <sub>s</sub> = M <sub>d</sub> (1 - B <sub>wo</sub> ) + 18(B <sub>wo</sub> )	
Volume of gas sample through gas meter, V <sub>m</sub>		5.04	27.47	
Gas meter correction factor, Y <sub>d</sub>		0.97	<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Mean dry gas meter temperature, T <sub>m</sub>		34.61	Area of stack, A <sub>s</sub>	m <sup>2</sup> 1.63
Mean pressure drop across orifice, ΔH	mmH <sub>2</sub> O	71.67	Q <sub>a</sub> = (60)(A <sub>s</sub> )(V <sub>s</sub> )	m <sup>3</sup> /min 1856.3
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		4.324	<b>Percent isokinetic, %I</b>	
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Required Flow Rate @ DGM	
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	5.4267	Actual Flow Rate @ DGM	l/min 29.20
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			Isokinetic Rate	
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	Acceptable 90% - 130%	Yes
% oxygen measured in gas stream, act%O <sub>2</sub>		7.13	<b>Particulate Concentration, C<sub>PM10</sub></b>	
% oxygen reference condition		11	Mass of particulate collected on PM <sub>10</sub> filter, M <sub>f</sub>	0.00013
O <sub>2</sub> Reference Factor		1.39	Mass of particulate collected on PM <sub>2.5</sub> filter, M <sub>f</sub>	0.00005
$V_{mstd@X\%O_2} = (V_{mstd})(O_2 \text{ Ref})$	m <sup>3</sup>	5.998	$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.0332
<b>Moisture content, B<sub>wo</sub></b>			$C_{dry} = \frac{M_n}{V_{mstd}}$	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	20.32	mg/m <sup>3</sup> 0.0416	
<b>Moisture by FTIR</b>			$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%O_2}}$	
			mg/m <sup>3</sup> 0.0300	
<b>Velocity of stack gas, V<sub>s</sub></b>			<b>Particulate Emission Rates, E</b>	
Pitot tube velocity constant, K <sub>p</sub>		34.97	E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	
Velocity pressure coefficient, C <sub>p</sub>		0.81	2.34	
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	21.81	<b>Particulate Concentration, C<sub>PM2.5</sub></b>	
Mean square root of velocity heads, √ΔP		4.67	Mass of particulate collected on filter, M <sub>f</sub>	
Mean stack gas temperature, T <sub>s</sub>	°C	152	C <sub>wet</sub> = $\frac{M_n}{V_{mstw}}$	
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	18.99	mg/m <sup>3</sup> 0.0092	
			C <sub>dry</sub> = $\frac{M_n}{V_{mstd}}$	
			mg/m <sup>3</sup> 0.0116	
			C <sub>dry@X%O2</sub> = $\frac{M_n}{V_{mstd@X\%O_2}}$	
			mg/m <sup>3</sup> 0.0083	
			<b>Particulate Emission Rates, E</b>	
			E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	
			0.65	



APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS RUN 4			PM <sub>10</sub> & PM <sub>2.5</sub>	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	745.5	CO <sub>2</sub>	9.56
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	-1.6	O <sub>2</sub>	7.39
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	745.4	Total	16.95
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2)$	
Moisture trap weight increase, V <sub>lc</sub>	g	H <sub>2</sub> O by FTIR	N <sub>2</sub> (100 - Total)	83.05
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	<b>Molecular weight of wet gas, M<sub>s</sub></b>	29.83
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			$M_s = M_d(1 - B_{wo}) + 18(B_{wo})$	
Volume of gas sample through gas meter, V <sub>m</sub>		4.98	<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Gas meter correction factor, Y <sub>d</sub>		0.97	Area of stack, A <sub>s</sub>	m <sup>2</sup> 1.63
Mean dry gas meter temperature, T <sub>m</sub>		33.36	$Q_a = (60)(A_s)(V_s)$	m <sup>3</sup> /min 1873.8
Mean pressure drop across orifice, ΔH	mmH <sub>2</sub> O	70.97	<b>Percent isokinetic, %I</b>	
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		4.265	Required Flow Rate @ DGM	l/min 29.20
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Actual Flow Rate @ DGM	
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	5.3705	Isokinetic Rate	l/min 27.6
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			Acceptable 90% - 130%	
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	<b>Particulate Concentration, C<sub>PM10</sub></b>	
% oxygen measured in gas stream, act%O <sub>2</sub>		7.39	Mass of particulate collected on PM <sub>10</sub> filter, M <sub>f</sub>	0.00007
% oxygen reference condition		11	Mass of particulate collected on PM <sub>2.5</sub> filter, M <sub>f</sub>	0.00005
O <sub>2</sub> Reference O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>		1.36	$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.0223
Factor $\frac{21.0 - ref\%O_2}{21.0 - act\%O_2}$			$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.0281
$V_{mstd@X\%oxygen} = (V_{mstd})(O_2 Ref)$	m <sup>3</sup>	5.805	$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0207
<b>Moisture content, B<sub>wo</sub></b>			<b>Particulate Emission Rates, E</b>	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	20.58	$E = [(C_{wet})(Q_{stw})(60)] / 1000$	1.59
<b>Moisture by FTIR</b>	%	20.58	<b>Particulate Concentration, C<sub>PM2.5</sub></b>	
<b>Velocity of stack gas, V<sub>s</sub></b>			Mass of particulate collected on filter, M <sub>f</sub>	
Pitot tube velocity constant, K <sub>p</sub>		34.97	$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.0093
Velocity pressure coefficient, C <sub>p</sub>		0.81	$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.0117
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	22.06	$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0086
Mean square root of velocity heads, √ΔP		4.70	<b>Particulate Emission Rates, E</b>	
Mean stack gas temperature, T <sub>s</sub>	°C	151	$E = [(C_{wet})(Q_{stw})(60)] / 1000$	0.66
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	19.17		

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PM<sub>10</sub> & PM<sub>2.5</sub> QUALITY ASSURANCE CHECKLIST**

LEAK RATE						
Run	Mean Sampling Rate litre/min	Pre-sampling Leak Rate litre/min	Post-sampling Leak Rate litre/min	Maximum Vacuum mm Hg	Acceptable Leak Rate litre/min	Leak Tests Acceptable?
Run 1	31.04	0.10	0.6	381	0.62	Yes
Run 2	30.99	0.6	0.6	305	0.62	Yes
Run 3	27.97	0.12	0.22	381	0.56	Yes
Run 4	27.65	0.1	0.1	305	0.55	Yes

ISOKINETICITY		
Run	Flow Variation %	Acceptable Variation
Run 1	108.1	Yes
Run 2	99.7	Yes
Run 3	95.8	Yes
Run 4	94.7	Yes

Acceptable Flow rate 90 -130%

FILTERS					
Run	Filter Material	Filter Size mm	Max Filtration Temperature °C	Pre-conditioning Filter Temperature °C	Post conditioning Filtration Temperature °C
Run 1	QF	50	153	180	160
Run 2	QF	50	152	180	160
Run 3	QF	50	153	180	160
Run 4	QF	50	152	180	160

QF = Quartz Fibre

## APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

### Conformity with relevant aspects of BS EN ISO 23210:2009

#### GENERAL METHODOLOGY

The equipment employed is a Paul Gothe, Johnas cascade impactor (see pg 13 for serial number) system meeting the requirements of BS EN ISO 23210. The standard cites a two-stage impactor system.

The method for sampling requires the extraction of a representative sample of duct gas isokinetically, into a specially designed in-stack sampling head. The Cascade Impactor is a multi-stage, multi-jet impactor which aerodynamically classifies particulates into multiple size ranges. The cascade impactor uses the principle of inertial separation to size segregate particulate samples from the gas stream. The impactor has two stages for particle size determination. Each stage gives a cut-point based on aerodynamic diameter of the particle.

During sampling, the particles are driven (jetted) toward a collecting surface where they may cling. By changing the velocity (orifice size of the jet), the size of the particles collected is controlled. The size of the jets within each stage is constant, but for each succeeding stage the jets get smaller. Impaction occurs when the particle's inertia overcomes the aerodynamic drag. Otherwise, the particle remains in the air stream and proceeds to the next stage. To keep the cut-point for each stage constant, the impactor is operated at a constant flow rate.

At each stage, the particle impacts on to a conditioned and pre-weighed substrate. Following sampling, the substrates are reconditioned and reweighed to determine the mass collected.

Based on the sampling conditions (sampling rate and gas temperature) the cut size (D50 – diameter of particles having a 50% probability of penetration) associated with each impactor stage may be determined.

An homogeneity assessment based on BS EN ISO 23210, Annex G, is undertaken to determine the most representative sampling point in the sampling plane (temperature, velocity and oxygen are suitable surrogates for particulate matter). The velocity measurement at the chosen point is used to determine an appropriate sampling nozzle/flow rate in order to ensure that isokinetic conditions are maintained throughout sampling to within the 90-130% range allowed in the standard (8.1) and which is consistent with the sampling equipment.

Concurrently, the volume of duct gas sampled is measured. This then enables the particulate concentration at each cut size to be determined.

The outlet gas from the sampling head is passed via a sampling probe through an impinger train with the purpose of removing water prior to entry to the sampling control box. It is not intended that the sampling train be used for additional sampling of condensable determinands and as such the train is unheated.

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**Conformity with relevant aspects of BS EN ISO 23210:2009**

Sampling Plane Validation Criteria				
EA Technical Guidance Note (Monitoring) M1	Result	Units	Requirement	Compliant
Lowest Differential Pressure	162	Pa	>= 5 Pa	Yes
Lowest Gas Velocity	15.70	m/s	-	-
Highest Gas Velocity	22.40	m/s	-	-
Ratio of Gas Velocities	1.43	-	< 3 : 1	Yes
Maximum angle of flow with regard to duct axis	<15	°	< 15°	Yes
No local negative flow	Yes	-	-	Yes

Conformance with BS EN ISO 23210:2009			
Reference	Requirement	Result	Compliant
Section 6.3	Suitable Impactor Used	See statement of conformity for Impactor	Yes
Section 8.1	Sampling position acceptable (as per 13284-1)	As per table "Sampling Plane Validation"	Yes
Section 8.1	Nozzle arrangement	See statement of conformity for Impactor	Yes
Section 8.1	Representative sampling point	See Homogeneity assessment below	Yes
Section 8.1	Constant Sample gas flow, iso-kinetic rate 90% to 130%		
	Run 1 - Required flow 28.7 (LPM)		-
	Run 1 - Minimum permissible flow 25.83 (LPM)	26.30	Yes
	Run 1 - Maximum permissible flow 37.31 (LPM)	37.19	Yes
	Run 2 - Required flow 31.1 (LPM)		-
	Run 2 - Minimum permissible flow 27.99 (LPM)	28.27	Yes
	Run 2 - Maximum permissible flow 40.43 (LPM)	33.63	Yes
	Run 3 - Required flow 29.2 (LPM)		-
	Run 3 - Minimum permissible flow 26.28 (LPM)	26.40	Yes
	Run 3 - Maximum permissible flow 37.96 (LPM)	29.38	Yes
	Run 4 - Required flow 29.2 (LPM)		-
	Run 4 - Minimum permissible flow 26.28 (LPM)	26.30	Yes
	Run 4 - Maximum permissible flow 37.96 (LPM)	30.88	Yes
Section 8.1	Overall blank taken once per day	Yes	Yes
Section 8.2	Impactor cleaned between each measurement	Yes	Yes
Section 8.2	Arrangement of impactor plates	See statement of conformity for Impactor	Yes
Section 8.3.2	Data taken for velocity, composition, temp & pressure	See "Preliminary stack survey" section	Yes
Section 8.3.3	Sampling rate determination in accordance with Annex A	Yes	Yes
Section 8.3.3	Sample flow rate kept +/- 5% of nominal flow rate		
	Run 1 - Max sample flow deviation from nominal (%)	58.2	No
	Run 2 - Max sample flow deviation from nominal (%)	22.2	No
	Run 3 - Max sample flow deviation from nominal (%)	9.3	No
	Run 4 - Max sample flow deviation from nominal (%)	11.3	No
Section 8.3.4	Nozzle selected to allow iso-kinetic rate 90% to 130%	Yes, as above	Yes
Section 8.3.5	Leak check less than 2%		
	Run 1	0.32	Yes
	Run 2	1.94	Yes
	Run 3	0.43	Yes
	Run 4	0.36	Yes
Section 8.3.6	Impactor at flue gas temperature before sampling	Yes	Yes
Section 8.3.6	Angle of nozzle less than 10 Degrees to flow	Yes	Yes
Section 8.3.6	Flowrate has checked and recorded every 5 mins	Yes	Yes
Section 8.3.6	Dynamic pressure recorded every 5 mins	Yes	Yes

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**Homogeneity assessment**

Assessment 1

Point number (i)	Distance along sample line (mm)	Probe Marking (mm)	Temp Deg C grid	Temp Deg C fixed	$r_i$
1	72	472	150	151	0.993
2	216	616	151	151	1.000
3	360	760	151	151	1.000
4	504	904	151	151	1.000
5	648	1048	151	151	1.000
6	792	1192	151	150	1.007
7	936	1336	151	150	1.007
8	1080	1480	151	150	1.007
9	1224	1624	151	151	1.000
10	1368	1768	151	151	1.000
<b>Second Line</b>					
1	72	472	149	151	0.987
2	216	616	151	151	1.000
3	360	760	151	151	1.000
4	504	904	151	151	1.000
5	648	1048	151	151	1.000
6	792	1192	151	151	1.000
7	936	1336	151	151	1.000
8	1080	1480	151	151	1.000
9	1224	1624	152	150	1.013
10	1368	1768	151	151	1.000

No. of points	20
$S_{grid}$	0.55
$S_{ref}$	0.41
$f$	1
Is $S_{grid} \leq S_{ref}$ ?	No
F Factor	1.812
$F_{N-1; N-1; 0.95}$	2.17
Is F Factor $< F_{N-1; N-1; 0.95}$ ?	Yes
$S_{pos}$	0.369
$t_{N-1; 0.95}$	2.093
$U_{pos}$	0.7742
Permissible Uncertainty	10
Is $U_{pos} < 0.5 * U_{perm}$ ?	N/A

Sample can be taken from any location

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**DAILY OXYGEN SUMMARY**

Run	Sampling Times	Concentration %	LOD %
1	10:52 - 17:32 01 April 2014	7.55	0.01
2	08:29 - 15:25 02 April 2014	7.37	0.01
3	16:21 - 19:21 02 April 2014	7.13	0.01
4	09:40 - 12:40 03 April 2014	7.39	0.01

**PRE SAMPLING CALIBRATION DATA**

Date	Time of Analyser Calibration	Range (%)	Zero Reading at analyser	Span Reading at analyser	Zero Check at analyser	Zero Check down line	Span Check down line	Leak Rate %
31 March 2014	15:34 - 17:13	25	0.00	9.52	0.00	0.01	9.55	0.31
01 April 2014	17:51 - 18:13	25	0.00	9.52	0.00	0.09	9.48	-0.42
02 April 2014	15:36 - 16:00	25	0.00	9.52	0.00	0.05	9.59	0.73

**POST SAMPLING CALIBRATION DATA**

Date	Time of Analyser Calibration	Zero Check down line	Span Check down line	Zero Drift (%)	Span Drift (%)
01 April 2014	17:51 - 18:13	0.09	9.48	0.32	-1.58
02 April 2014	15:36 - 16:00	0.05	9.59	-0.16	1.58
03 April 2014	12:30 - 13:02	0.01	9.52	-0.16	-0.32

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**COMBUSTION GAS SUMMARY**

Test	Sampling Times	Concentration %	Analysis Areas	Interference (%)	LOD %
Moisture Run 1	10:52 - 17:32 01 April 2014	19.6	3200 - 3401	0.6	0.24
Moisture Run 2	08:29 - 15:25 02 April 2014	19.4	3200 - 3401	0.58	0.24
Moisture Run 3	16:21 - 19:21 02 April 2014	20.3	3200 - 3401	0.58	0.24
Moisture Run 4	09:40 - 12:40 03 April 2014	20.6	3200 - 3401	0.58	0.24
Carbon Dioxide Run 1	10:52 - 17:32 01 April 2014	9.4	2000 - 2223	1.33	0.01
Carbon Dioxide Run 2	08:29 - 15:25 02 April 2014	9.7	2000 - 2223	1.33	0.01
Carbon Dioxide Run 3	16:21 - 19:21 02 April 2014	10.0	2000 - 2223	1.33	0.01
Carbon Dioxide Run 4	09:40 - 12:40 03 April 2014	9.6	2000 - 2223	1.33	0.01

\*M22 Specifies interference must be <5%.

**FTIR CALIBRATION CHECKS**

Pre - Sampling Checks - System			Date of Checks	31 March 2014	Time of Checks	16:48		
Post Sampling Checks - System			Date of Checks	01 April 2014	Time of Checks	17:51		
Compound	Pre - Test Zero Reading	Post Test Zero Reading	Zero Drift as a % of Range	Span Gas (ppm)	Pre - Test Span Reading	% Variation from Actual	Post Test Span Reading	% Span Drift
H <sub>2</sub> O	0.26	-0.01	-0.90	162.9	163.5	0.34	166.2	1.65
CO <sub>2</sub> (%)	0.00	0.00	0.00	5.2	5.1	-2.41	5.2	3.20

Pre - Sampling Checks - System			Date of Checks	01 April 2014	Time of Checks	17:51		
Post Sampling Checks - System			Date of Checks	02 April 2014	Time of Checks	15:51		
Compound	Pre - Test Zero Reading	Post Test Zero Reading	Zero Drift as a % of Range	Span Gas (ppm)	Pre - Test Span Reading	% Variation from Actual	Post Test Span Reading	% Span Drift
H <sub>2</sub> O	0.26	0.00	-0.87	162.9	166.2	2.00	169.3	1.89
CO <sub>2</sub> (%)	0.00	0.00	0.00	5.2	5.2	0.72	5.1	-1.59

Pre - Sampling Checks - System			Date of Checks	02 April 2014	Time of Checks	15:51		
Post Sampling Checks - System			Date of Checks	03 April 2014	Time of Checks	12:46		
Compound	Pre - Test Zero Reading	Post Test Zero Reading	Zero Drift as a % of Range	Span Gas (ppm)	Pre - Test Span Reading	% Variation from Actual	Post Test Span Reading	% Span Drift
H <sub>2</sub> O	0.26	0.00	-0.87	162.9	169.3	3.92	166.4	-1.72
CO <sub>2</sub> (%)	0.00	0.00	0.00	5.2	5.1	-0.88	5.0	-1.71

Note - Methane was used as a surrogate span check for moisture. All other surrogates are listed in the individual measurement uncertainty budgets. Acceptance criteria for initial span check variation is +/-5% of certified reading for all gases, except HCl and NH<sub>3</sub> which are +/- 10% of certified reading. Acceptance criteria for % zero drift across the test is +/-2% of range for all gases.

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY**

Stack Characteristics		
Stack Diameter / Depth, D	1.44	m
Stack Width, W	-	m
Stack Area, A	1.63	m <sup>2</sup>
Average stack gas temperature	151	°C
Stack static pressure	0.15	kPa
Barometric Pressure	100.1125	kPa
Pitot tube calibration coefficient, $K_{pt}$	0.81	-

Stack Gas Composition & Molecular Weights								
Component	Molar Mass M	Density kg/m <sup>3</sup> p	Conc Dry % Vol	Dry Volume Fraction r	Dry Conc kg/m <sup>3</sup> pi	Conc Wet % Vol	Wet Volume Fraction r	Wet Conc kg/m <sup>3</sup> pi
CO <sub>2</sub>	44	1.96	11.67	0.12	0.23	9.69	0.10	0.19
O <sub>2</sub>	32	1.43	9.04	0.09	0.13	7.51	0.08	0.11
N <sub>2</sub>	28	1.25	79.28	0.79	0.99	65.81	0.66	0.82
H <sub>2</sub> O	18	0.80	-	-	-	16.99	0.17	0.14

Where:  $p = M / 22.41$      $pi = r \times p$

Calculation of Stack Gas Densities		
Determinand	Result	Units
Dry Density (STP), $P_{STD}$	1.3487	kg/m <sup>3</sup>
Wet Density (STP), $P_{STW}$	1.2560	kg/m <sup>3</sup>
Dry Density (Actual), $P_{Actual}$	0.8598	kg/m <sup>3</sup>
Average Wet Density (Actual), $P_{ActualW}$	0.801	kg/m <sup>3</sup>

Where:

$P_{STD}$  = sum of component concentrations, kg/m<sup>3</sup> (not including water vapour)

$P_{STW} = (P_{STD} + pi \text{ of H}_2\text{O}) / (1 + (pi \text{ of H}_2\text{O} / 0.8036))$

$P_{Actual} = P_{STD} \times (Ts / Ps) \times (Pa / Ta)$

$P_{ActualW} = P_{STW} \times (Ts / Ps) \times (Pa / Ta)$



APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY**

**TRAVERSE 1**

Date of Survey	31 March 2014
Time of Survey	15:00
Velocity Measurement Device:	P2246

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.07	18.2	178	149	16.47	-	<15
2	0.22	22.5	221	151	18.36	-	<15
3	0.36	22.5	221	151	18.36	-	<15
4	0.50	22.0	216	151	18.15	-	<15
5	0.65	21.0	206	151	17.73	-	<15
6	0.79	21.0	206	151	17.73	-	<15
7	0.94	20.0	196	151	17.31	-	<15
8	1.08	21.5	211	151	17.94	-	<15
9	1.22	20.0	196	152	17.33	-	<15
10	1.37	20.0	196	151	17.31	-	<15
Mean	-	20.9	205	151	17.67	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.07	18.2	178	149	16.47	-	<15
2	0.22	22.5	221	151	18.36	-	<15
3	0.36	22.5	221	151	18.36	-	<15
4	0.50	22.0	216	151	18.15	-	<15
5	0.65	21.0	206	151	17.73	-	<15
6	0.79	21.0	206	151	17.73	-	<15
7	0.94	20.0	196	151	17.31	-	<15
8	1.08	21.5	211	151	17.94	-	<15
9	1.22	20.0	196	152	17.33	-	<15
10	1.37	20.0	196	151	17.31	-	<15
Mean	-	20.9	205	151	17.67	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

**TRAVERSE 2**

Date of Survey	01 April 2014
Time of Survey	08:00
Velocity Measurement Device:	P2246

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.07	23.0	225	152	18.58	-	<15
2	0.22	24.0	235	152	18.98	-	<15
3	0.36	25.0	245	152	19.37	-	<15
4	0.50	24.5	240	152	19.18	-	<15
5	0.65	25.5	250	152	19.57	-	<15
6	0.79	26.0	255	152	19.76	-	<15
7	0.94	24.0	235	152	18.98	-	<15
8	1.08	23.0	225	152	18.58	-	<15
9	1.22	23.5	230	152	18.78	-	<15
10	1.37	22.0	216	152	18.17	-	<15
Mean	-	24.1	236	152	19.00	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.07	32.0	314	144	21.71	-	<15
2	0.22	34.0	333	145	22.40	-	<15
3	0.36	34.0	333	145	22.40	-	<15
4	0.50	32.0	314	145	21.74	-	<15
5	0.65	32.0	314	145	21.74	-	<15
6	0.79	30.0	294	145	21.05	-	<15
7	0.94	30.0	294	145	21.05	-	<15
8	1.08	34.0	333	145	22.40	-	<15
9	1.22	32.0	314	145	21.74	-	<15
10	1.37	32.0	314	145	21.74	-	<15
Mean	-	32.2	316	145	21.80	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY**

**TRAVERSE 3**

Date of Survey	01 April 2014
Time of Survey	18:14
Velocity Measurement Device:	P2246

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.07	20.0	196	146	17.20	-	<15
2	0.22	23.0	225	148	18.49	-	<15
3	0.36	23.5	230	150	18.74	-	<15
4	0.50	21.5	211	151	17.94	-	<15
5	0.65	22.0	216	150	18.13	-	<15
6	0.79	20.0	196	151	17.31	-	<15
7	0.94	20.5	201	150	17.50	-	<15
8	1.08	19.0	186	150	16.85	-	<15
9	1.22	19.0	186	150	16.85	-	<15
10	1.37	16.5	162	150	15.70	-	<15
Mean	-	20.5	201	149.6	17.47	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.07	21.5	211	144	17.80	-	<15
2	0.22	23.0	225	150	18.54	-	<15
3	0.36	23.5	230	150	18.74	-	<15
4	0.50	24.0	235	150	18.94	-	<15
5	0.65	20.5	201	150	17.50	-	<15
6	0.79	19.5	191	150	17.07	-	<15
7	0.94	18.0	176	150	16.40	-	<15
8	1.08	18.5	181	151	16.65	-	<15
9	1.22	19.5	191	150	17.07	-	<15
10	1.37	19.0	186	150	16.85	-	<15
Mean	-	20.7	203	150	17.55	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

**TRAVERSE 4**

Date of Survey	02 April 2014
Time of Survey	07:35
Velocity Measurement Device:	P2246

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.07	22.0	216	149	18.11	-	<15
2	0.22	23.0	225	150	18.54	-	<15
3	0.36	22.5	221	151	18.36	-	<15
4	0.50	21.0	206	151	17.73	-	<15
5	0.65	20.0	196	151	17.31	-	<15
6	0.79	19.0	186	151	16.87	-	<15
7	0.94	19.0	186	151	16.87	-	<15
8	1.08	21.0	206	150	17.71	-	<15
9	1.22	19.5	191	150	17.07	-	<15
10	1.37	17.5	172	150	16.17	-	<15
Mean	-	20.5	200	150	17.47	-	
Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.07	22.0	216	153	18.19	-	<15
2	0.22	22.5	221	153	18.40	-	<15
3	0.36	23.5	230	153	18.80	-	<15
4	0.50	21.5	211	153	17.99	-	<15
5	0.65	20.0	196	153	17.35	-	<15
6	0.79	19.0	186	152	16.89	-	<15
7	0.94	18.5	181	152	16.66	-	<15
8	1.08	19.0	186	152	16.89	-	<15
9	1.22	19.5	191	152	17.11	-	<15
10	1.37	19.5	191	152	17.11	-	<15
Mean	-	20.5	201	153	17.54	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY**

**TRAVERSE 5**

Date of Survey	02 April 2014
Time of Survey	16:00
Velocity Measurement Device:	P2246

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.07	18.0	176	151	16.42	-	<15
2	0.22	21.0	206	151	17.73	-	<15
3	0.36	23.0	225	151	18.56	-	<15
4	0.50	22.0	216	151	18.15	-	<15
5	0.65	22.0	216	151	18.15	-	<15
6	0.79	21.0	206	151	17.73	-	<15
7	0.94	19.5	191	151	17.09	-	<15
8	1.08	20.0	196	151	17.31	-	<15
9	1.22	19.0	186	151	16.87	-	<15
10	1.37	19.5	191	151	17.09	-	<15
Mean	-	20.5	201	151	17.51	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.07	19.0	186	150	16.85	-	<15
2	0.22	20.0	196	151	17.31	-	<15
3	0.36	21.0	206	151	17.73	-	<15
4	0.50	22.0	216	151	18.15	-	<15
5	0.65	22.0	216	151	18.15	-	<15
6	0.79	21.0	206	151	17.73	-	<15
7	0.94	22.0	216	151	18.15	-	<15
8	1.08	22.0	216	152	18.17	-	<15
9	1.22	20.0	196	152	17.33	-	<15
10	1.37	20.0	196	152	17.33	-	<15
Mean	-	20.9	205	151	17.69	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

**TRAVERSE 6**

Date of Survey	02 April 2014
Time of Survey	19:45
Velocity Measurement Device:	P2246

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.07	22.0	216	152	18.17	-	<15
2	0.22	21.0	206	152	17.76	-	<15
3	0.36	22.0	216	152	18.17	-	<15
4	0.50	23.0	225	152	18.58	-	<15
5	0.65	22.5	221	152	18.38	-	<15
6	0.79	23.0	225	152	18.58	-	<15
7	0.94	22.0	216	152	18.17	-	<15
8	1.08	23.0	225	152	18.58	-	<15
9	1.22	21.0	206	152	17.76	-	<15
10	1.37	20.0	196	152	17.33	-	<15
Mean	-	22.0	215	152	18.15	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.07	21.0	206	152	17.76	-	<15
2	0.22	22.0	216	152	18.17	-	<15
3	0.36	24.0	235	152	18.98	-	<15
4	0.50	22.0	216	152	18.17	-	<15
5	0.65	22.0	216	152	18.17	-	<15
6	0.79	23.0	225	152	18.58	-	<15
7	0.94	23.0	225	152	18.58	-	<15
8	1.08	23.5	230	152	18.78	-	<15
9	1.22	22.0	216	152	18.17	-	<15
10	1.37	21.0	206	152	17.76	-	<15
Mean	-	22.4	219	152	18.31	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY**

**TRAVERSE 7**

Date of Survey	03 April 2014
Time of Survey	09:00
Velocity Measurement Device:	P2246

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.07	22.0	216	150	18.13	-	<15
2	0.22	23.0	225	150	18.54	-	<15
3	0.36	22.5	221	150	18.33	-	<15
4	0.50	23.0	225	151	18.56	-	<15
5	0.65	23.0	225	150	18.54	-	<15
6	0.79	23.5	230	151	18.76	-	<15
7	0.94	22.0	216	150	18.13	-	<15
8	1.08	22.0	216	150	18.13	-	<15
9	1.22	21.0	206	150	17.71	-	<15
10	1.37	20.0	196	150	17.29	-	<15
Mean	-	22.2	218	150.2	18.21	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.07	21.0	206	149	17.69	-	<15
2	0.22	21.0	206	150	17.71	-	<15
3	0.36	22.0	216	150	18.13	-	<15
4	0.50	23.5	230	150	18.74	-	<15
5	0.65	22.0	216	150	18.13	-	<15
6	0.79	22.5	221	150	18.33	-	<15
7	0.94	23.0	225	150	18.54	-	<15
8	1.08	22.0	216	151	18.15	-	<15
9	1.22	22.0	216	151	18.15	-	<15
10	1.37	21.0	206	151	17.73	-	<15
Mean	-	22.0	216	150	18.13	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

**TRAVERSE 8**

Date of Survey	03 April 2014
Time of Survey	12:45
Velocity Measurement Device:	P2246

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.07	21.0	206	149	17.69	-	<15
2	0.22	23.0	225	150	18.54	-	<15
3	0.36	24.0	235	151	18.96	-	<15
4	0.50	21.0	206	151	17.73	-	<15
5	0.65	22.0	216	151	18.15	-	<15
6	0.79	21.0	206	151	17.73	-	<15
7	0.94	22.0	216	152	18.17	-	<15
8	1.08	21.0	206	152	17.76	-	<15
9	1.22	19.0	186	151	16.87	-	<15
10	1.37	19.0	186	151	16.87	-	<15
Mean	-	21.3	209	151	17.85	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.07	21.0	206	151	17.73	-	<15
2	0.22	21.0	206	152	17.76	-	<15
3	0.36	23.0	225	152	18.58	-	<15
4	0.50	22.0	216	152	18.17	-	<15
5	0.65	21.0	206	152	17.76	-	<15
6	0.79	20.0	196	152	17.33	-	<15
7	0.94	21.0	206	152	17.76	-	<15
8	1.08	21.0	206	152	17.76	-	<15
9	1.22	21.0	206	152	17.76	-	<15
10	1.37	20.0	196	152	17.33	-	<15
Mean	-	21.1	207	152	17.79	-	



APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

Sampling Plane Validation Criteria				
EA Technical Guidance Note (Monitoring) M1	Result	Units	Requirement	Compliant
Lowest Differential Pressure	162	Pa	>= 5 Pa	Yes
Lowest Gas Velocity	15.70	m/s	-	-
Highest Gas Velocity	22.40	m/s	-	-
Ratio of Gas Velocities	1.43	-	< 3 : 1	Yes
Maximum angle of flow with regard to duct axis	<15	°	< 15°	Yes
No local negative flow	Yes	-	-	Yes

Calculation of Stack Gas Velocity, V		
Velocity at Traverse Point, $V = K_{pt} \times (1-\epsilon) \times \sqrt{2 * \Delta P_{pt} / \rho_{ActualW}}$		
<b>Where:</b> $K_{pt}$ = Pitot tube calibration coefficient (1-ε) = Compressibility correction factor, assumed at a constant 0.998		
Average Stack Gas Velocity, $V_a$	18.02	m/s

**Where:**  
 $Q_{Actual} = V_a \times A \times 3600$   
 $Q_{STP} = Q (Actual) \times (T_s / T_a) \times (P_a / P_s) \times 3600$   
 $Q_{STP,Dry} = Q (STP) / (100 - (100 / Ma)) \times 3600$   
 $Q_{Ref} = Q (STP) \times ((100 - Ma) / (100 - Ms)) \times ((20.9 - O_{2a}) / (20.9 - O_{2s}))$

Day 1      01 April 2014

Calculation of Stack Gas Volumetric Flowrate, Q			
Duct gas flow conditions	Actual	Reference	Units
Temperature	150	0	°C
Total Pressure	100.9	101.3	kPa
Oxygen	7.5	11	%
Moisture	19.57	0.00	%
Gas Volumetric Flowrate		Result	Units
Average Stack Gas Velocity ( $V_a$ )		19.03	m/s
Stack Area (A)		1.63	m <sup>2</sup>
Gas Volumetric Flowrate (Actual), $Q_{Actual}$		111599	m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Wet), $Q_{STP}$		71782	m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Dry), $Q_{STP,Dry}$		57736	m <sup>3</sup> /hr
Gas Volumetric Flowrate (REF), $Q_{Ref}$		77669	m <sup>3</sup> /hr

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

Day 2	02 April 2014		
Calculation of Stack Gas Volumetric Flowrate, Q			
Duct gas flow conditions	Actual	Reference	Units
Temperature	151	0	°C
Total Pressure	100.4	101.3	kPa
Oxygen	7.3	11	%
Moisture	20.09	0.00	%
Gas Volumetric Flowrate	Result		Units
Average Stack Gas Velocity (Va)	17.71		m/s
Stack Area (A)	1.63		m <sup>2</sup>
Gas Volumetric Flowrate (Actual), Q <sub>Actual</sub>	103860		m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Wet), Q <sub>STP</sub>	66263		m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Dry), Q <sub>STP,Dry</sub>	52948		m <sup>3</sup> /hr
Gas Volumetric Flowrate (REF), Q <sub>Ref</sub>	72554		m <sup>3</sup> /hr

Day 3	07 March 2014		
Calculation of Stack Gas Volumetric Flowrate, Q			
Duct gas flow conditions	Actual	Reference	Units
Temperature	151	0	°C
Total Pressure	99.4	101.3	kPa
Oxygen	7.4	11	%
Moisture	20.25	0.00	%
Gas Volumetric Flowrate	Result		Units
Average Stack Gas Velocity (Va)	17.83		m/s
Stack Area (A)	1.63		m <sup>2</sup>
Gas Volumetric Flowrate (Actual), Q <sub>Actual</sub>	104529		m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Wet), Q <sub>STP</sub>	66012		m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Dry), Q <sub>STP,Dry</sub>	52646		m <sup>3</sup> /hr
Gas Volumetric Flowrate (REF), Q <sub>Ref</sub>	71392		m <sup>3</sup> /hr

**Nomenclature:**

Ts = Absolute Temperature, Standard Conditions, 273 K  
 Ps = Absolute Pressure, Standard Conditions, 101.3 kPa  
 Ta = Absolute Temperature, Actual Conditions, K


Pa = Absolute Pressure, Actual Conditions, kPa  
 Ma = Water vapour, Actual Conditions, % Vol  
 Ms = Water vapour, Reference Conditions, % Vol

O<sub>2a</sub> = Oxygen, Actual Conditions, % Vol  
 O<sub>2s</sub> = Oxygen, Reference Conditions, % Vol

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**STACK DIAGRAM**

	Value	Units
Stack Depth	1.44	m
Stack Width	-	m
Area	1.63	m <sup>2</sup>



Non-Isokinetic/Gases Sampling			
Sampling Point	Distance (% of Depth)	Distance into Stack	Units
A	40	0.58	m

Isokinetic Sampling CEN Methods			
Sampling Point	Distance (% of Depth)	Distance into Stack (m)	Swirl °
1	85.0	1.22	<15

- Isokinetic sampling point
- Isokinetic sampling points not used
- ◐ Non Isokinetic/Gases sampling point

**SAMPLING LOCATION**



APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - PM 10**

Run	Sampled Volume m <sup>3</sup>	Sampled Gas K	Sampled Gas kPa	Sampled Gas % by volume	Oxygen % by volume	Limit of % by mass	Leak %
<b>MU required</b>	<b>≤ 2%</b>	<b>≤ 2%</b>	<b>≤ 1%</b>	<b>≤ 1%</b>	<b>≤ 10%</b>	<b>≤ 5% of ELV</b>	<b>≤ 2%</b>
Run 1	0.001	2	0.5	1	0.1	0.10	-
as a %	0.01	0.47	0.50	1.00	1.32	N/A	1.93
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 2	0.001	2	0.5	1.00	0.1	0.10	-
as a %	0.01	0.47	0.50	1.00	1.36	N/A	1.94
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 3	0.001	2	0.5	1	0.1	0.1000	-
as a %	0.02	0.47	0.50	1.00	1.40	N/A	0.79
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 4	0.001	2	0.5	1	0.1	0.10	-
as a %	0.02	0.47	0.50	1.00	1.35	N/A	0.36
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>

Run	Volume (STP) m <sup>3</sup>	Mass of particulate mg	O2 Correction -	Leak mg/m <sup>3</sup>	Combined uncertainty
Run 1	0.0097	0.0881	0.095	1.000	-
MU as mg/m <sup>3</sup>	0.0009	0.0088	0.0005	0.00079	<b>12.57</b>
MU as %	0.0075	12.5	0.743	1.116	-
Run 2	0.0012	0.0857	0.012	1.000	-
MU as mg/m <sup>3</sup>	0.0001	0.0086	0.0001	0.00010	<b>100.01</b>
MU as %	0.0009	100.0	0.734	1.118	-
Run 3	0.0079	0.1667	0.042	1.000	-
MU as mg/m <sup>3</sup>	0.0004	0.0167	0.0002	0.00014	<b>55.562</b>
MU as %	0.0032	55.6	0.721	0.454	-
Run 4	0.0056	0.17	0.028	1.00	-
MU as mg/m <sup>3</sup>	0.0003	0.02	0.0002	0.00004	<b>83.34</b>
MU as %	0.0022	83.3	0.735	0.21	-

<b>R1 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.02</b>	<b>mg/m<sup>3</sup></b>	<b>25.26</b>	<b>%</b>
<b>R2 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.02</b>	<b>mg/m<sup>3</sup></b>	<b>200.03</b>	<b>%</b>
<b>R3 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.03</b>	<b>mg/m<sup>3</sup></b>	<b>111.15</b>	<b>%</b>
<b>R4 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.03</b>	<b>mg/m<sup>3</sup></b>	<b>166.69</b>	<b>%</b>

(k is a coverage factor which gives a 95% confidence in the quoted figures)  
Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - PM 2.5**

Run	Sampled m <sup>3</sup>	Sampled Gas K	Sampled Gas kPa	Sampled Gas % by volume	Oxygen % by volume	Limit of % by mass	Leak %
<b>MU required</b>	<b>≤ 2%</b>	<b>≤ 2%</b>	<b>≤ 1%</b>	<b>≤ 1%</b>	<b>≤ 10%</b>	<b>≤ 5% of ELV</b>	<b>≤ 2%</b>
Run 1	0.001	2	0.5	1	0.1	0.05	-
as a %	0.01	0.47	0.50	1.00	1.32	N/A	1.93
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 2	0.001	2	0.5	1.00	0.1	0.05	-
as a %	0.01	0.47	0.50	1.00	1.36	N/A	1.94
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 3	0.001	2	0.5	1.00	0.1	0.05	-
as a %	0.02	0.47	0.50	1.00	1.40	N/A	0.79
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 4	0.001	2	0.5	1.00	0.1	0.05	-
as a %	0.02	0.47	0.50	1.00	1.35	0.00	0.36
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>

Run	Volume (STP) m <sup>3</sup>	Mass of particulate mg	O2 Correction -	Leak mg/m <sup>3</sup>	Combined uncertainty
Run 1	0.01	0.0881	0.0758	1.000	-
MU as mg/m <sup>3</sup>	0.0007	0.0044	0.0004	0.00063	<b>7.93</b>
MU as %	0.0060	7.8125	0.7434	1.12	-
Run 2	0.0006	0.0857	0.0058	1.000	-
MU as mg/m <sup>3</sup>	0.0001	0.0043	0.0000	0.00005	<b>100.01</b>
MU as %	0.0005	100.0000	0.7338	1.12	-
Run 3	0.0011	0.0857	0.0059	1.000	-
MU as mg/m <sup>3</sup>	0.0001	0.0043	0.0000	0.00002	<b>100.00</b>
MU as %	0.0005	100.0000	0.7210	0.45	-
Run 4	0.0023	0.1723	0.0117	1.0000	-
MU as mg/m <sup>3</sup>	0.0001	0.0086	0.0001	0.00002	<b>100.00</b>
MU as %	0.0009	100.0000	0.7347	0.21	-

<b>R1 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.009</b>	<b>mg/m<sup>3</sup></b>	<b>16.04</b>	<b>%</b>
<b>R2 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.009</b>	<b>mg/m<sup>3</sup></b>	<b>200.03</b>	<b>%</b>
<b>R3 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.009</b>	<b>mg/m<sup>3</sup></b>	<b>200.02</b>	<b>%</b>
<b>R4 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.017</b>	<b>mg/m<sup>3</sup></b>	<b>200.02</b>	<b>%</b>

(k is a coverage factor which gives a 95% confidence in the quoted figures)  
Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - CARBON DIOXIDE BY FTIR**

Actual Measured Concentration	9.39	% vol
Measured Concentration at Reference Conditions	9.39	% vol
Emission Limit Value	-	% vol
Instrument Range	20	% vol
Check Gas Concentration	5.18	% vol

Performance Characteristics & Source of Value	Values	Requirement	Compliant
Deviation from linearity as a % of the range (taken from worst case figure in MCERTS certificate)	-1.900	<2%	Yes
Zero drift (calculated from start and end readings)	0.000	<5%	Yes
Span drift (calculated from start and end readings).	3.204	<5%	Yes
Sensitivity to sample gas pressure: (taken from worst case figure in MCERTS certificate).	0.990	<2%	Yes
Sensitivity to ambient temperature at zero (taken from worst case figure in MCERTS certificate)	0.100	<5%	Yes
Sensitivity to ambient temperature at span (taken from worst case figure in MCERTS certificate)	-1.300	<5%	Yes
Sensitivity to voltage (taken from worst case figure in MCERTS certificate)	1.600	<2%	Yes
Interferents (calculated using M22, Section 8.2, equation 3)	1.333	<5%	Yes
Repeatability / standard deviation (taken from worst figure in MCERTS certificate)	0.080	<2%	Yes
Certified reference material (check gas)	2.000	2% or less	Yes

Uncertainty in Performance Characteristics	% vol
Uncertainty of linearity (lack of fit) $U_{fit}$	-0.219
Uncertainty of zero drift $U_{0,dr}$	0.000
Uncertainty of span drift $U_{s,dr}$	0.370
Uncertainty of volume or pressure flow dependence $U_{spress}$	0.114
Uncertainty in Ambient Temperature $U_{temp}$	0.151
Uncertainty in Voltage $U_{volt}$	0.185
Uncertainty of interferents $U_i$	0.154
Uncertainty of Repeatability $U_r$	0.016
Uncertainty of Certified Reference Material $U_{cal}$	0.030

Measurement Uncertainty	% vol
Combined uncertainty	0.53
Expanded uncertainty at a 95% Confidence Interval	1.06

Note - The expanded uncertainty uses a coverage factor of  $k = 2$ .

Expanded Measurement Uncertainty at a 95% Confidence Interval	%
Expressed as a % of the Measured Concentration	11.27
Expressed as a % of the Measured Concentration at Reference Conditions	11.27
Expressed as a % of the Emission Limit Value	-

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - MOISTURE BY FTIR**

Actual Measured Concentration	19.57	% vol
Measured Concentration at Reference Conditions	19.57	% vol
Emission Limit Value	30	% vol
Instrument Range	30	% vol
Check Gas Concentration (Methane was used as a Surrogate)	116.36	mg/m <sup>3</sup>

Performance Characteristics & Source of Value	Values	Requirement	Compliant
Deviation from linearity as a % of the range (taken from worst case figure in MCERTS certificate)	-1.900	<2%	Yes
Zero drift (calculated from start and end readings)	-0.900	<5%	Yes
Span drift (calculated from start and end readings).	1.653	<5%	Yes
Sensitivity to sample gas pressure: (taken from worst case figure in MCERTS certificate).	0.990	<2%	Yes
Sensitivity to ambient temperature at zero (taken from worst case figure in MCERTS certificate)	0.100	<5%	Yes
Sensitivity to ambient temperature at span (taken from worst case figure in MCERTS certificate)	-1.000	<5%	Yes
Sensitivity to voltage (taken from worst case figure in MCERTS certificate)	0.710	<2%	Yes
Interferents (calculated using M22, Section 8.2, equation 3)	0.583	<5%	Yes
Repeatability / standard deviation (taken from worst figure in MCERTS certificate)	0.170	<2%	Yes
Certified reference material (check gas)	2.000	2% or less	Yes

Uncertainty in Performance Characteristics	% vol
Uncertainty of linearity (lack of fit) $U_{fit}$	-0.329
Uncertainty of zero drift $U_{0,dr}$	-0.156
Uncertainty of span drift $U_{s,dr}$	0.286
Uncertainty of volume or pressure flow dependence $U_{spress}$	0.171
Uncertainty in Ambient Temperature $U_{temp}$	0.174
Uncertainty in Voltage $U_{volt}$	0.123
Uncertainty of interferents $U_i$	0.101
Uncertainty of Repeatability $U_r$	0.051
Uncertainty of Certified Reference Material $U_{cal}$	0.672

Measurement Uncertainty	% vol
Combined uncertainty	0.87
Expanded uncertainty at a 95% Confidence Interval	1.74

Note - The expanded uncertainty uses a coverage factor of  $k = 2$ .

Expanded Measurement Uncertainty at a 95% Confidence Interval	%
Expressed as a % of the Measured Concentration	8.87
Expressed as a % of the Measured Concentration at Reference Conditions	8.87
Expressed as a % of the Emission Limit Value	5.79

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - OXYGEN**

DAY 1 - 31 March 2014

Reference	11	%vol
Measured concentration	7.55	%vol
Calibration gas	9.52	%vol
Full Scale	25	%vol

Performance characteristics	Value	Units	specification	MU Met?
Response time	60	seconds	< 200 s	Yes
Logger sampling interval	60	seconds	-	-
Measurement period	399	minutes	-	-
Number of readings in measurement	399	-	-	-
Repeatability at zero	0.015	% by volume	<0.2 % range	Yes
Repeatability at span level	0.014	% by volume	<0.4 % range	Yes
Deviation from linearity	0.13	% vol	<0.3 % volume	Yes
Zero drift (during measurement period)	0.32	% vol at zero level	<2% of volume / 24hr	Yes
Span drift (during measurement period)	-1.58	% vol at span level	<2% volume/24hr	Yes
volume or pressure flow dependence	0.02	% of fs / 10l/h	<1% range	Yes
atmospheric pressure dependence	0.8	% of fs/kPa	< 1.5 % range	Yes
ambient temperature dependence	0.01	% by volume /10K	<0.3% volume 10 K	Yes
Combined interference	0.14	% range	<2% range	Yes
Dependence on voltage	0.1	% by volume /10V	< 0.1%vol /10 volt	Yes
Losses in the line (leak)	0.31	% of value	< 2% of value	Yes
Uncertainty of calibration gas	2	% of value	< 2% of value	Yes

Performance characteristic	Uncertainty	Value of uncertainty quantity
Standard deviation of repeatability at zero	ur0	-
Standard deviation of repeatability at span level	urs	0.001
Lack of fit	ufit	0.075
Drift	u0dr	-0.536
volume or pressure flow dependence	uspres	0.001
atmospheric pressure dependence	uapres	0.115
ambient temperature dependence	utemp	0.003
Combined interference (from mcerts)	-	0.020
dependence on voltage	uvolt	0.029
losses in the line (leak)	uleak	0.014
Uncertainty of calibration gas	ucalib	0.087

Measurement uncertainty (Concentration Measured)	7.55	%vol
Combined uncertainty	0.56	%vol
% of value	7.45	%

<b>Expanded uncertainty expressed with a level of confidence of 95%</b>	<b>14.89</b>	<b>% of value</b>
---	--------------	-------------------

<b>Expanded uncertainty expressed with a level of confidence of 95%</b>	<b>1.12</b>	<b>% vol</b>
---	-------------	--------------

Developed for the STA by R Robinson, NPL



APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - OXYGEN**

DAY 2 - 01 April 2014

Reference	11	%vol
Measured concentration	7.30	%vol
Calibration gas	9.52	%vol
Full Scale	25	%vol

Performance characteristics	Value	Units	specification	MU Met?
Response time	60	seconds	< 200 s	Yes
Logger sampling interval	60	seconds	-	-
Measurement period	652	minutes	-	-
Number of readings in measurement	652	-	-	-
Repeatability at zero	0.015	% by volume	<0.2 % range	Yes
Repeatability at span level	0.014	% by volume	<0.4 % range	Yes
Deviation from linearity	0.13	% vol	<0.3 % volume	Yes
Zero drift (during measurement period)	-0.16	% vol at zero level	<2% of volume / 24hr	Yes
Span drift (during measurement period)	1.58	% vol at span level	<2% volume/24hr	Yes
volume or pressure flow dependence	0.02	% of fs / 10l/h	<1% range	Yes
atmospheric pressure dependence	0.8	% of fs/kPa	< 1.5 % range	Yes
ambient temperature dependence	0.01	% by volume /10K	<0.3% volume 10 K	Yes
Combined interference	0.14	% range	<2% range	Yes
Dependence on voltage	0.1	% by volume /10V	< 0.1%vol /10 volt	Yes
Losses in the line (leak)	-0.42	% of value	< 2% of value	Yes
Uncertainty of calibration gas	2	% of value	< 2% of value	Yes

Performance characteristic	Uncertainty	Value of uncertainty quantity
Standard deviation of repeatability at zero	ur0	-
Standard deviation of repeatability at span level	urs	0.001
Lack of fit	ufit	0.075
Drift	u0dr	0.605
volume or pressure flow dependence	uspres	0.001
atmospheric pressure dependence	uapres	0.115
ambient temperature dependence	utemp	0.003
Combined interference (from mcerts)	-	0.081
dependence on voltage	uvolt	0.029
losses in the line (leak)	uleak	-0.018
Uncertainty of calibration gas	ucalib	0.084

Measurement uncertainty (Concentration Measured)	7.30	%vol
Combined uncertainty	0.63	%vol
% of value	8.66	%

<b>Expanded uncertainty expressed with a level of confidence of 95%</b>	<b>17.33</b>	<b>% of value</b>
---	--------------	-------------------

<b>Expanded uncertainty expressed with a level of confidence of 95%</b>	<b>1.26</b>	<b>% vol</b>
---	-------------	--------------

Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - OXYGEN**

DAY 3 - 02 April 2014

Reference	11	%vol
Measured concentration	7.22	%vol
Calibration gas	9.52	%vol
Full Scale	25	%vol

Performance characteristics	Value	Units	specification	MU Met?
Response time	60	seconds	< 200 s	Yes
Logger sampling interval	60	seconds	-	-
Measurement period	166	minutes	-	-
Number of readings in measurement	166	-	-	-
Repeatability at zero	0.015	% by volume	<0.2 % range	Yes
Repeatability at span level	0.014	% by volume	<0.4 % range	Yes
Deviation from linearity	0.13	% vol	<0.3 % volume	Yes
Zero drift (during measurement period)	-0.16	% vol at zero level	<2% of volume / 24hr	Yes
Span drift (during measurement period)	-0.32	% vol at span level	<2% volume/24hr	Yes
volume or pressure flow dependence	0.02	% of fs / 10l/h	<1% range	Yes
atmospheric pressure dependence	0.8	% of fs/kPa	< 1.5 % range	Yes
ambient temperature dependence	0.01	% by volume /10K	<0.3% volume 10 K	Yes
Combined interference	0.14	% range	<2% range	Yes
Dependence on voltage	0.1	% by volume /10V	< 0.1%vol /10 volt	Yes
Losses in the line (leak)	0.73	% of value	< 2% of value	Yes
Uncertainty of calibration gas	2	% of value	< 2% of value	Yes

Performance characteristic	Uncertainty	Value of uncertainty quantity
Standard deviation of repeatability at zero	ur0	-
Standard deviation of repeatability at span level	urs	0.001
Lack of fit	ufit	0.075
Drift	u0dr	-0.230
volume or pressure flow dependence	uspres	0.001
atmospheric pressure dependence	uapres	0.115
ambient temperature dependence	utemp	0.003
Combined interference (from mcerts)	-	0.081
dependence on voltage	uvolt	0.029
losses in the line (leak)	uleak	0.030
Uncertainty of calibration gas	ucalib	0.083

Measurement uncertainty (Concentration Measured)	7.22	%vol
Combined uncertainty	0.30	%vol
% of value	4.09	%

<b>Expanded uncertainty expressed with a level of confidence of 95%</b>	<b>8.18</b>	<b>% of value</b>
---	-------------	-------------------

<b>Expanded uncertainty expressed with a level of confidence of 95%</b>	<b>0.59</b>	<b>% vol</b>
---	-------------	--------------

Developed for the STA by R Robinson, NPL

Standard deviation of repeatability at span level	urs	#DIV/0!
---	-----	---------

APPENDIX 4 - Summaries, Calculations, Raw Data and Charts

NOTE - The following data is provided for information only and falls outside ESG's scope of accreditation

COMBINED UNCOLLECTED SUMMARY							
Test	Sampling Times	>PM <sub>10</sub> Concentration		Probe Rinse Concentration		Combined Unweighed Concentration	
		Measured	LOD	Measured	LOD	Measured	LOD
		mg/m <sup>3</sup>	mg/m <sup>3</sup>	mg/m <sup>3</sup>	mg/m <sup>3</sup>	mg/m <sup>3</sup>	mg/m <sup>3</sup>
Run 1	10:52 - 17:32 01 April 2014	0.004	0.004	0.150	0.114	0.125	0.119
Run 2	08:29 - 15:25 02 April 2014	0.004	0.004	0.111	0.111	0.116	0.116
Run 3	16:21 - 19:21 02 April 2014	0.018	0.008	0.217	0.217	0.225	0.225
Run 4	09:40 - 12:40 03 April 2014	0.009	0.009	0.224	0.224	0.233	0.233

Reference conditions are 273K, 101.3kPa, dry gas 11% Oxygen.

Where the result is less than the LOD, the LOD is reported.

SAMPLES									
Test	>PM <sub>10</sub> Filter Number	Filter Start Weight	Filter End Weight	Mass Gained on Filter	Probe Rinse Number	Probe Rinse Start Weight	Probe Rinse End Weight	Mass Gained in Rinse	Combined Total Mass Gained
		g	g	g	g	g	g	g	g
Run 1	QC1038	32.6359	32.6356	-0.00028	8530	195.9576	195.9593	0.00170	0.00142
Run 2	QC1058	15.7474	15.7473	-0.00015	8531	155.95760	155.36090	-0.59670	-0.59685
Run 3	QC1050	14.8199	14.8200	0.00011	8532	208.09270	208.09320	0.00050	0.00061
Run 4	QC1054	16.3255	16.3255	-0.00002	8533	184.45290	184.45320	0.00030	0.00028
Blank 1	QC1060	16.0445	16.0443	-0.00018	8527	181.94280	181.94230	-0.00050	-0.00068
Blank 2	QC1051	15.9013	15.9011	-0.00013	8528	151.00140	151.00100	-0.00040	-0.00053
Blank 3	QC1056	15.3566	15.3564	-0.00017	8529	161.85580	161.85570	-0.00010	-0.00027



Paul Gothe GmbH Wittener Str. 82 D-44789 Bochum

To our customers

Wittener Straße 82  
D-44789 Bochum

Phone.: ++49-234 33 51 80  
Fax:++49 234) 30 82 17  
<http://www.paulgothe.de>  
[service@paulgothe.de](mailto:service@paulgothe.de)  
VAT-No.: DE 813078723  
Trade Register Bochum: HRB-6891

Your ref

Your letter

Our ref

Date 14.03.2007

Calibration of the Johnas Impactor according to ISO 23210

#### 6.2 Separation curves and Section 6.3 Verification of the separation curves

The Johnas Impactor from Paul Gothe GmbH was developed before the ISO Guideline was evaluated and after the Germans and the Netherlands Authorities have enough experiences with our impactor. After that the European Delegation creates the ISO Guideline 23210. The section 6.3 is important and was influence by the Germans. They have the experiences and write the rules for the calibration section accordingly it was made for the Johnas-Impactor.

The development from the Johnas impactor starts with a doctoral thesis from Mrs. John at the Gerhard-Mercator-University. She makes the intensive testing and Mr. Geueke from the North Rhine Westphalia State Environment Agency makes additional verifications at the ESA (Emission Simulation Facility) at the Hessian Agency for the Environment and Geology (HLUG).

Most of the literatures and papers are in German, but all well-known:

1. Probenahme und chemische Analytik von Korngrößenfraktionierten Immissions- und Emissionsaerosolen. Von der Fakultät für Naturwissenschaften der Gerhard-Mercator-Universität – Gesamthochschule Duisburg zur Erlangung des akademischen Grades eines Dr. rer. nat. genehmigte Dissertation von ASTRID CHRISTIANE JOHN aus Lichtenfels.
2. Umweltforschungsplan des Bundesministers für Umwelt, Naturschutz und Reaktorsicherheit Luftreinhalte Forschungsbericht 298 44 280, Korngrößenverteilung (PM10 und PM2,5) von Staubemissionen relevanter stationärer Quellen (Teil II zu 297 44 853), von Dipl.-Ing. A. Dreiseidler, Ing. D. Straub, Prof. Dr.-Ing. G. Baumbach, Universität Stuttgart, Institut für Verfahrenstechnik und Dampfkesselwesen (IVD), Abteilung Reinhaltung der Luft (RdL), Institutsleiter: Prof. Dr.-Ing. K.R.G. Hein, IM AUFTRAG DES UMWELTBUNDESAMTES Juni 2001.
3. VDI 2066, part 10
4. Gefahrstoffe-Reinhaltung der Luft 59 (1999), Nr.11/12, S. 449-453

All this papers shows, that the design of the Johnas Impactor is a proved version for the determination of the PM 2.5 and PM 10. The shape of the separation curves is similar to those specified in ISO 7708:1995 and the separation efficiency at 10 µm and 2,5 µm is 50 % according to section 6.3 of the ISO 23210.

What you need more? There is no authority which has more competence as the listed authorities.

If you still in doubt, you maybe get in contact with Mr. Geueke (phone: ++49-201-7995-1263).

Paul Gothe GmbH

Westdeutsche Landesbank for Sparkasse Bochum  
IBAN DE 24 430500 01 000 120 9840 Swift: WELADED1BOC

Companion: Paul Gothe-Stiftung  
Management: Dr. T. Grodten and Th. Hinrichs



# PAUL GOTHE BOCHUM

Manufacturer of Emissions Control Technology  
SEIT 1924



Paul Gothe GmbH Wittener Str. 82 D-44789 Bochum

To our customers

Wittener Straße 82  
D-44789 Bochum

Phone.: ++49-234 33 51 80  
Fax:++49 234) 30 82 17  
<http://www.paulgothe.de>  
[service@paulgothe.de](mailto:service@paulgothe.de)  
VAT-No.: DE 813078723  
Trade Register Bochum: HRB-6891

Your ref

Your letter

Our ref

Date 14.03.2007

## Declaration of conformity


Herewith the company Paul Gothe GmbH in Bochum declare that the manufactured Cascade Impactor Johnas follows the guidelines from the North Rhine Westphalia State Environment Agency according the convention from 24 June 1999 and the PM 4 stage follows the convention of the Federal Environment Agency from 09. March 2005.

Our Cascade Impactor Johnas was developed in cooperation with the North Rhine Westphalia State Environment and the Gerhard-Mercator University Duisburg. This impactor was validated and after that 2004 adopted in the German Standard VDI 2066, part 10 and 2005 in ISO Standard 23210. All sizes of our manufactured impactors are according to these guidelines, individually checked according our strict quality management and named with a specific serial number. Only an impactor with this serial number is according to the Guideline VDI 2066, part 10 and ISO Standard 23210 and can use for the determination of PM 10 and PM 2.5.

Paul Gothe GmbH

Dr. Torsten Grodten

-manager-



**END OF REPORT**

## Appendix 5 – Stack emissions monitoring report: MES Environmental Ltd

# STACK EMISSIONS MONITORING REPORT



Unit 5 Crown Industrial Estate  
Kenwood Road  
Stockport  
SK5 6PH  
Tel: 0161 443 0980  
Fax: 0161 443 0989

Your contact at ESG
Mark Woodruff Business Manager - North Tel: 0161 443 0982 Email: mark.woodruff@esg.co.uk

Operator & Address:
MES Environmental Limited Stoke-on-Trent Energy from Waste Plant Campbell Road Sideway Stoke On trent ST4 4DX

Permit
N/A - Investigative Monitoring

Release Point:
Incinerator Stream 2

Sampling Date(s):
19th - 21st March 2014

ESG Job Number:	LNO 11737
Report Date:	17th Feb 2015
Version:	1
Report By:	Dominic Houghton
MCERTS Number:	MM 04 529
MCERTS Level:	MCERTS Level 2 - Team Leader
Technical Endorsements:	1, 2, 3 & 4
Report Approved By:	Andy Tiffen
MCERTS Number:	MM 05 640
Business Title:	MCERTS Level 2 - Projects Manager
Technical Endorsements:	1, 2 & 4
Signature:	



1015



## CONTENTS

### EXECUTIVE SUMMARY

#### Stack Emissions Monitoring Objectives

- Plant
- Operator
- Stack Emissions Monitoring Test House

#### Emissions Summary

#### Monitoring Times

#### Process Details

#### Monitoring Methods

#### Analytical Methods

- Sampling Methods with Subsequent Analysis
- On-Site Testing

#### Sampling Location

- Sampling Plane Validation Criteria
- Duct Characteristics
- Sampling Lines & Sample Points
- Sampling Platform
- Sampling Location / Platform Improvement Recommendations

#### Sampling and Analytical Method Deviations

#### Determination of representative sampling location

### APPENDICES

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

APPENDIX 3 - Measurement Uncertainty Budget Calculations

## EXECUTIVE SUMMARY

### MONITORING OBJECTIVES

MES Environmental Limited operates a incinerator process at Stoke-on-Trent Energy from Waste Plant

Environmental Scientifics Group Limited were commissioned by Ricardo AEA to carry out stack emissions monitoring to determine the release of PM<sub>10</sub> & PM<sub>2.5</sub> from the following Plant under standard operating conditions.

The measurements were commissioned by Ricardo-AEA on behalf of the Department of Environment, Food and Rural Affairs (Defra) to provide information for the UK National Atmospheric Emissions Inventory (NAEI).

#### **Plant**

Incinerator Stream 2

#### **Operator**

MES Environmental Limited  
Stoke-on-Trent Energy from Waste Plant  
Campbell Road  
Sideway  
Stoke On trent  
ST4 4DX

#### **Stack Emissions Monitoring Test House**

Environmental Scientifics Group Limited - Stockport Laboratory  
Unit 5 Crown Industrial Estate  
Kenwood Road  
Stockport  
SK5 6PH  
UKAS and MCERTS Accreditation Number: 1015

Opinions and interpretations expressed herein are outside the scope of UKAS accreditation.

MCERTS accredited results will only be claimed where both the sampling and analytical stages are UKAS accredited.

This test report shall not be reproduced, except in full, without written approval of Environmental Scientifics Group Limited.

## EXECUTIVE SUMMARY

EMISSIONS SUMMARY					
Parameter	Units	Result	Calculated Uncertainty +/-	Limit	MCERTS accredited result
Total Particulate Matter	mg/m <sup>3</sup>	0.47	0.07	30	✓
Particulate Emission Rate	g/hr	31	4.6	-	
PM <sub>10</sub> (Average result of 4 runs)	mg/m <sup>3</sup>	0.043	0.05	-	✓
PM <sub>10</sub> Emission Rate (Average result of 4 runs)	g/hr	2.62	2.9	-	
PM <sub>2.5</sub> (Average result of 4 runs)	mg/m <sup>3</sup>	0.017	0.03	-	✓
PM <sub>2.5</sub> Emission Rate (Average result of 4 runs)	g/hr	1.04	1.67	-	
<b>PM<sub>10</sub> - Runs</b>					
PM <sub>10</sub> - Run 1	mg/m <sup>3</sup>	<b>0.014</b>	0.01	-	✓
PM <sub>10</sub> Emission Rate - Run 1	g/hr	0.76	0.8	-	
PM <sub>10</sub> - Run 2	mg/m <sup>3</sup>	0.012	0.01	-	✓
PM <sub>10</sub> Emission Rate - Run 2	g/hr	0.77	0.8	-	
PM <sub>10</sub> - Run 3	mg/m <sup>3</sup>	<b>0.059</b>	0.06	-	✓
PM <sub>10</sub> Emission Rate - Run 3	g/hr	3.65	4.0	-	
PM <sub>10</sub> - Run 4	mg/m <sup>3</sup>	0.088	0.10	-	✓
PM <sub>10</sub> Emission Rate - Run 4	g/hr	5.32	5.8	-	
<b>PM<sub>2.5</sub> - Runs</b>					
PM <sub>2.5</sub> - Run 1	mg/m <sup>3</sup>	<b>0.005</b>	0.01	-	✓
PM <sub>2.5</sub> Emission Rate - Run 1	g/hr	0.76	1.2	-	
PM <sub>2.5</sub> - Run 2	mg/m <sup>3</sup>	0.005	0.01	-	✓
PM <sub>2.5</sub> Emission Rate - Run 2	g/hr	0.32	0.5	-	
PM <sub>2.5</sub> - Run 3	mg/m <sup>3</sup>	<b>0.010</b>	0.02	-	✓
PM <sub>2.5</sub> Emission Rate - Run 3	g/hr	0.63	1.01	-	
PM <sub>2.5</sub> - Run 4	mg/m <sup>3</sup>	0.048	0.08	-	✓
PM <sub>2.5</sub> Emission Rate - Run 4	g/hr	2.91	4.69	-	
Oxygen	% v/v	12	0.73	-	✓
Moisture	%	16.0	1.0	-	✓
Stack Gas Temperature	°C	151	-	-	
Stack Gas Velocity	m/s	20.6	-	-	
Gas Volumetric Flow Rate (Actual)	m <sup>3</sup> /hr	120419	-	-	✓
Gas Volumetric Flow Rate (STP, Wet)	m <sup>3</sup> /hr	78080	-	-	
Gas Volumetric Flow Rate (STP, Dry)	m <sup>3</sup> /hr	61073	-	-	
Gas Volumetric Flow Rate at Reference Conditions	m <sup>3</sup> /hr	69915	-	-	

ND = None Detected,

Results at or below the limit of detection are highlighted by bold italic text.

The above volumetric flow rate is calculated using data from test specific flow data. Mass emissions for non isokinetic tests and isokinetic tests are calculated using these values

Reference conditions are 273K, 101.3kPa, dry gas 11% Oxygen.

## EXECUTIVE SUMMARY

MONITORING TIMES			
Parameter	Sampling Date(s)	Sampling Times	Sampling Duration
Total Particulate Matter Run 1	19 March 2014	13:00 - 19:00	360 minutes
Total Particulate Matter Run 2	20 March 2014	09:00 - 15:00	360 minutes
Total Particulate Matter Run 3	20 March 2014	15:46 - 18:46	180 minutes
Total Particulate Matter Run 4	21 March 2014	08:45 - 11:45	180 minutes
PM <sub>10</sub> Run 1	19 March 2014	13:00 - 19:00	360 minutes
PM <sub>10</sub> Run 2	20 March 2014	09:00 - 15:00	360 minutes
PM <sub>10</sub> Run 3	20 March 2014	15:46 - 18:46	180 minutes
PM <sub>10</sub> Run 4	21 March 2014	08:45 - 11:45	180 minutes
PM <sub>2.5</sub> Run 1	19 March 2014	13:00 - 19:00	360 minutes
PM <sub>2.5</sub> Run 2	20 March 2014	09:00 - 15:00	360 minutes
PM <sub>2.5</sub> Run 3	20 March 2014	15:46 - 18:46	180 minutes
PM <sub>2.5</sub> Run 4	21 March 2014	08:45 - 11:45	180 minutes
Stack Gas Flow Rate & Temperature Run 1	19 March 2014	09:00	-
Stack Gas Flow Rate & Temperature Run 2	19 March 2014	19:10	-
Stack Gas Flow Rate & Temperature Run 3	20 March 2014	08:32	-
Stack Gas Flow Rate & Temperature Run 4	20 March 2014	15:10	-
Stack Gas Flow Rate & Temperature Run 5	20 March 2014	18:55	-
Stack Gas Flow Rate & Temperature Run 6	21 March 2014	08:05	-
Stack Gas Flow Rate & Temperature Run 7	21 March 2014	12:00	-

## EXECUTIVE SUMMARY

PROCESS DETAILS	
Parameter	Process Details
Description of process	Incinerator
Continuous or batch	Continuous
Product Details	Waste
Part of batch to be monitored (if applicable)	Steady state
Normal load, throughput or continuous rating	11 - 12.5 Tonnes/Hour
Fuel used during monitoring	Oil / Waste
Abatement	Bag Filtration, activated carbon scrubbing, urea injection, lime semi dry scrubbing
Plume Appearance	Not visible from the sample location during time of testing.

## EXECUTIVE SUMMARY

### Monitoring Methods

The selection of standard reference / alternative methods employed by Environmental Scientifics Group Limited is determined, wherever possible by the hierarchy of method selection outlined in Environment Agency Technical Guidance Note (Monitoring) M2. i.e. CEN, ISO, BS, US EPA etc.

MONITORING METHODS						
Species	Method Standard Reference Method / Alternative Method	ESG Technical Procedure	UKAS Lab Number	MCERTS Accredited Method	Limit of Detection (LOD)	Calculated MU +/- %
TPM	SRM - BS EN 13284-1	AE 104	1015	Yes	0.02 mg/m <sup>3</sup>	14.9 %
PM <sub>10</sub>	SRM - BS EN 23210	AE 136	1015	Yes	0.014 mg/m <sup>3</sup>	109 %
PM <sub>2.5</sub>	SRM - BS EN 23210	AE 136	1015	Yes	0.007 mg/m <sup>3</sup>	161 %
O <sub>2</sub>	SRM - BS EN 14789	AE 102	1015	Yes	0.01%	6.1%
H <sub>2</sub> O	AM - M22/FTIR	AE 063	1015	Yes	0.1 %	6.0%
Flow Rate / Temp.	SRM - BS EN 13284-1	AE 122	1015	Yes	5 Pa	-

The measurement uncertainties for the PM<sub>10</sub> and PM<sub>2.5</sub> measurements reflect that measured concentrations were near or below the Limit of Detection.

## EXECUTIVE SUMMARY

### Analytical Methods

The following tables list the analytical methods employed together with the custody and archiving details:

SAMPLING METHODS WITH SUBSEQUENT ANALYSIS							
Species	Analytical Technique	Analytical Procedure	UKAS Lab Number	UKAS Accredited Lab Analysis	Analysis Lab (ESG or Subcontract)	Sample Archive Location	Archive Period
TPM	Gravimetric	AE 106	1015	Yes	ESG Stockport	ESG Stockport	3 months
PM <sub>10</sub>	Gravimetric	AE 106	1015	Yes	ESG Stockport	ESG Stockport	1 year
PM <sub>2.5</sub>	Gravimetric	AE 106	1015	Yes	ESG Stockport	ESG Stockport	1 year

ON-SITE TESTING							
Species	Analytical Technique	Analytical Procedure	UKAS Lab Number	MCERTS Accredited Analysis	Laboratory	Data Archive Location	Archive Period
O <sub>2</sub>	Paramagnetism	AE 102	1015	Yes	ESG Stockport	ESG Stockport	5 years
H <sub>2</sub> O	Fourier Transform - Infra Red	AE 063	1015	Yes	ESG Stockport	ESG Stockport	5 years

## EXECUTIVE SUMMARY

SAMPLING LOCATION					
Sampling Plane Validation Criteria	Value	Units	Requirement	Compliant	Method
Lowest Differential Pressure	157	Pa	>= 5 Pa	Yes	BS EN 13284-1
Lowest Gas Velocity	16.05	m/s	-	-	-
Highest Gas Velocity	22.99	m/s	-	-	-
Ratio of Gas Velocities	1.43	-	< 3 : 1	Yes	BS EN 13284-1
Mean Velocity	20.56	m/s	-	-	-
Maximum angle of flow with regard to duct axis	<15	°	< 15°	Yes	BS EN 13284-1
No local negative flow	Yes	-	-	Yes	BS EN 13284-1

DUCT CHARACTERISTICS		
	Value	Units
Shape	Circular	-
Depth	1.45	m
Width	-	m
Area	1.65	m <sup>2</sup>
Port Depth	100	mm

SAMPLING LINES & POINTS			
	Isokinetic (CEN Methods)	Isokinetic (ISO Methods)	Non-Iso & Gases
Sample port size	4 inch BSP	-	4 inch BSP
Number of lines used	1	-	1
Number of points / line	1	-	1
Duct orientation	Vertical	-	Vertical
Filtration	In Stack	-	In Stack
Filtration for TPM	In Stack	-	-

SAMPLING PLATFORM	
General Platform Information	
Permanent / Temporary Platform / Ground level / Floor Level / Roof Inside / Outside	Permanent Inside

M1 Platform requirements	
Is there a sufficient working area so work can be performed in a compliant manner	Yes
Platform has 2 levels of handrails (approximately 0.5 m & 1.0 m high)	Yes
Platform has vertical base boards (approximately 0.25 m high)	Yes
Platform has removable chains / self closing gates at the top of ladders	Yes
Handrail / obstructions do not hamper insertion of sampling equipment	No
Depth of Platform = >Stack depth / diameter + wall and port thickness + 1.5m	No

### Sampling Platform Improvement Recommendations (if applicable)

The sampling location ports could ideally be relocated to a different plane to avoid the CEM probes in the stack and to meet all the requirements as specified in EA Guidance Note M1.



## EXECUTIVE SUMMARY

### Sampling & Analytical Method Deviations

#### **Sample Points**

Total particulate and PM10 & 2.5 were performed on 2 separate lines on a single point nearest to each other to achieve the most representative sample.

#### **Flow Traverse**

A reduced number of velocity traverse points could only be monitored, due to various CEM probes causing obstructions on the same sample plane.

#### **Sample flow variation**

The sample flowrate could not be maintained within 5% of the nominal flow throughout the testing periods (which were over extended periods due to the anticipated low PM emission concentrations). Whilst this will have affected the actual cutpoints achieved by the impactor, the results are all at or very near the LOD for the tests and hence this is anticipated to have limited impact on the outcome of the measurements.

#### **Goose-neck nozzle Validation**

Due to the long port sleeve, it was physically impossible to insert the cascade impactor using the straight entry nozzle setup recommended in BS EN 23210. Therefore the use of a goose-neck setup was used as this was the only feasible method for monitoring. The standard requires that the use of a goose-neck nozzle is validated, however on this occasion it has not been possible to demonstrate that losses in the nozzle meet the criteria in the standard because the measured concentrations were low and the weight of particulate recovered from the nozzle rinses and the filter media were at or near the weighing LoD. In the context of the low emission concentrations determined during the measurements (all less than 0.1 mg/Nm<sup>3</sup>), losses in the sampling nozzle are unlikely to increase the concentrations significantly.

### Determination of representative sampling location

An assessment of temperature homogeneity was performed in accordance with EN 23210 Annex-G on the first day of monitoring. A reduced number of points could only be monitored, due to various CEM probes causing obstructions on the same sample plane.

APPENDICES

**CONTENTS**

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

APPENDIX 3 - Measurement Uncertainty Budget Calculations

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

<b>MONITORING SCHEDULE</b>					
<b>Species</b>	<b>Method</b> Standard Reference Method / Alternative Method	<b>ESG</b> <b>Technical</b> <b>Procedure</b>	<b>UKAS Lab</b> <b>Number</b>	<b>MCERTS</b> <b>Accredited</b> <b>Method</b>	<b>Number of</b> <b>Samples</b>
TPM	SRM - BS EN 13284-1	AE 104	1015	Yes	4
PM <sub>10</sub>	SRM - BS EN 23210	AE 136	1015	Yes	4
PM <sub>2.5</sub>	SRM - BS EN 23210	AE 136	1015	Yes	4
O <sub>2</sub>	SRM - BS EN 14789	AE 102	1015	Yes	4
H <sub>2</sub> O	AM - M22/FTIR	AE 063	1015	Yes	4
Flow Rate / Temp.	SRM - BS EN 13284-1	AE 122	1015	Yes	7

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

CALIBRATEABLE EQUIPMENT CHECKLIST PARTICLE SIZING					
Extractive Sampling		Instrumental Analyser/s		Miscellaneous	
Equipment	Equipment I.D.	Equipment	Equipment I.D.	Equipment	Equipment I.D.
Control Box DGM	LNO 13-11, 13-05	Horiba PG-250 Analyser	-	Laboratory Balance	LNO 00-12/00-13
Box Thermocouples	LNO 03-11, 03-05	FT-IR	LNO 0750	Tape Measure	LNO 24-DJH
Meter In Thermocouple	LNO 03-11, 03-05	FT-IR Oven Box	LNO 1207	Stopwatch	LNO 17-DJH
Meter Out Thermocouple	LNO 03-11, 03-05	Bernath 3006 FID	-	Protractor	-
Control Box Timer	LNO 17-11, 17-05	Signal 3030 FID	-	Barometer	LNO 08-DJH
Oven Box	-	Servomex	LNO 21-22	Digital Micromanometer	LNO 01-DJH
Probe	LNO 11-41	JCT Heated Head Filter	-	Digital Temperature Meter	LNO 03-DJH
Probe Thermocouple	LNO 10-41	Thermo FID	-	Stack Thermocouple	-
Probe	LNO 11-44	Stackmaster	-	Mass Flow Controller	-
Probe Thermocouple	LNO 10-44	FTIR Heater Box for Heated Line	-	MFC Display module	-
S-Pitot	LNO 06-DJH, 06-LM	Anemometer	-	1m Heated Line (1)	-
L-Pitot	-	Ecophysics NOx Analyser	-	1m Heated Line (2)	-
Site Balance	-	Chiller (JCT/MAK 10)	LNO 21-40	1m Heated Line (3)	-
Last Impinger Arm	-	Heated Line Controller (1)	-	5m Heated Line (1)	-
Dioxins Cond. Thermocouple	-	Heated Line Controller (2)	-	10m Heated Line (1)	-
Callipers	LNO 31-DJH	Impactor 1	LNO NR18706	10m Heated Line (2)	-
Small DGM	-		-	15m Heated Line (1)	-
Heater Controller	-		-	20m Heated Line (1)	LNO 03-84
Inclinometer (Swirl Device)	LNO 23-DJH		-	20m Heated Line (2)	-

NOTE: If the equipment I.D is represented by a dash (-), then this piece of equipment has not been used for this test.

CALIBRATION / CHECK GASES					
Gas (traceable to ISO 17025)	Cylinder I.D	Supplier	ppm	%	Analytical
Oxygen	HPC770	BOC	-	10.01	2
Methane	HPC763	BOC	101	-	2
Carbon Dioxide	HPC752	BOC	-	8.11	2

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

**STACK EMISSIONS MONITORING TEAM**

Team Leader	Dominic Houghton MCERTS Level 2 MM 04 529 Te1 Expiry Date - Dec 2016 Te2 Expiry Date - Dec 2016 Te3 Expiry Date - Mar 2018 Te4 Expiry Date - Dec 2016 H&S Expiry Date - Jul 2017
Team Leader	Lawrence Mason MCERTS Level 2 MM 07 849 Te1 Expiry Date - Dec 2018 Te2 Expiry Date - Dec 2015 Te3 Expiry Date - Mar 2016 Te4 Expiry Date - Dec 2015 H&S Expiry Date - Jul 2017
Technician	Ryan Murphy MCERTS Level 1 MM 07 826 MCERTS Expiry Date - Mar 2018 H&S Expiry Date - Apr 2017
Technician	Mark Derbyshire MCERTS Level 1 MM 07 824 MCERTS Expiry Date - Dec 2017 H&S Expiry Date - Apr 2017

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

TOTAL PARTICULATE MATTER SUMMARY					
Parameter	Sampling Times	Concentration mg/m <sup>3</sup>	Uncertainty mg/m <sup>3</sup>	Limit mg/m <sup>3</sup>	Emission Rate g/hr
Run 1	13:00 - 19:00 19 March 2014	0.34	0.05	30	21
Run 2	09:00 - 15:00 20 March 2014	0.33	0.04	30	23
Run 3	15:46 - 18:46 20 March 2014	0.75	0.10	30	50
Run 4	08:45 - 11:45 21 March 2014	0.48	0.09	30	31
Blank	-	0.08	-	-	-
Blank 2	-	0.05	-	-	-
Blank 3	-	0.03	-	-	-

Reference conditions are 273K, 101.3kPa, dry gas 11% Oxygen.

Acetone Blank Value mg/l	Acceptable Value mg/l
2.0	10

**FILTER INFORMATION**

SAMPLES								
Test	Filter & Probe Rinse Number	Filter Start Weight g	Filter End Weight g	Mass Gained on Filter g	Probe Rinse Start Weight g	Probe Rinse End Weight g	Mass Gained on Probe g	Combined Total Mass Gained g
Run 1	Q8014	0.14927	0.14865	-0.00062	182.94620	182.94890	0.00270	0.00208
Run 2	Q8016	0.14600	0.14390	-0.00210	168.36350	168.36640	0.00290	0.00080
Run 3	Q8017	0.14952	0.14816	-0.00136	164.53050	164.53340	0.00290	0.00154
Run 4	G8019	0.15307	0.15179	-0.00128	187.22610	187.22800	0.00190	0.00062

If total mass gained is less than the LOD then the LOD is reported

BLANKS								
Test	Filter & Probe Number	Filter Start Weight g	Filter End Weight g	Mass Gained Filter g	Probe Start Weight g	Probe End Weight g	Mass Gained Probe g	Combined Total Mass Gained g
Run 1	Q8013	0.14169	0.14159	-0.00010	135.46830	135.46890	0.00060	0.00050
Run 2	Q8015	0.14638	0.14621	-0.00017	193.54850	193.54900	0.00050	0.00033
Run 3	G8018	0.15247	0.15237	-0.00010	193.54850	193.54900	0.00050	0.00040

If total mass gained is less than the LOD then the LOD is reported

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS - RUN 1			TPM	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	765.01	CO <sub>2</sub>	% 7.10
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	-30.59	O <sub>2</sub>	% 9.59
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	762.76	Total	% 16.69
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			N <sub>2</sub> (100 -Total)	
Moisture trap weight increase, V <sub>lc</sub>	g	-	%	
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	%	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			M <sub>d</sub> = 0.44(%CO <sub>2</sub> )+0.32(%O <sub>2</sub> )+0.28(%N <sub>2</sub> )	
Volume of gas sample through gas meter, V <sub>m</sub>		8.105	29.52	
Gas meter correction factor, Y <sub>d</sub>		0.93249	<b>Molecular weight of wet gas, M<sub>s</sub></b>	
Mean dry gas meter temperature, T <sub>m</sub>		19.375	M <sub>s</sub> = M <sub>d</sub> (1 - B <sub>wo</sub> ) + 18(B <sub>wo</sub> )	
Mean pressure drop across orifice, ΔH mmH <sub>2</sub> O		41.691	g/gmol 27.12	
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		7.131	<b>Actual flow of stack gas, Q<sub>a</sub></b>	
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Area of stack, A <sub>s</sub>	
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	9.0042	m <sup>2</sup> 1.65	
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			Q <sub>a</sub> = (60)(A <sub>s</sub> )(V <sub>s</sub> )	
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	m <sup>3</sup> /min 1706.0	
% oxygen measured in gas stream, act%O <sub>2</sub>		9.6	<b>Total flow of stack gas, Q</b>	
% oxygen reference condition		11	Conversion factor (K/mm.Hg)	
O <sub>2</sub> Reference O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>		1.14	0.3592	
Factor $\frac{21.0 - ref\%O_2}{21.0 - act\%O_2}$			Q <sub>std</sub> = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})}{(T_s) + 273}$ Dry 877.2	
$V_{mstd@X\%oxygen} = (V_{mstd}) (O_2 Ref)$	m <sup>3</sup>	8.1376	Q <sub>stdO2</sub> = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})(O_2 REF)}{(T_s) + 273}$ @O <sub>2</sub> ref 1001.03	
<b>Moisture content, B<sub>wo</sub></b>			Q <sub>stw</sub> = $\frac{(Q_a)P_s(0.3592)}{(T_s) + 273}$ Wet 1107.63	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	20.80	<b>Percent isokinetic, %I</b>	
<b>Moisture by FTIR</b>			Nozzle diameter, D <sub>n</sub>	
	%	20.80	mm 6.44	
<b>Velocity of stack gas, V<sub>s</sub></b>			Nozzle area, A <sub>n</sub>	
Pitot tube velocity constant, K <sub>p</sub>		34.97	mm <sup>2</sup> 32.58	
Velocity pressure coefficient, C <sub>p</sub>		0.85	Total sampling time, θ	
Mean of velocity heads, ΔP <sub>avg</sub> mm H <sub>2</sub> O		16.45	min 360	
Mean square root of velocity heads, √ΔP		4.06	%I = $\frac{(4.6398E6)(T_s+273)(V_{mstd})}{(P_s)(V_s)(A_n)(\theta)(1-B_{wo})}$ % 114.5	
Mean stack gas temperature, T <sub>s</sub> °C		149	Acceptable isokinetic range 95% to 115%	
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	17.22	Yes	
<b>Particulate Concentration, C</b>			<b>Particulate Emission Rates, E</b>	
B <sub>wo</sub> = $\frac{V_{wstd}}{V_{mstd} + V_{wstd}}$ % 20.80			Mass collected on filter, M <sub>f</sub> g 0.00008	
Moisture by FTIR % 20.80			Mass collected in probe, M <sub>p</sub> g 0.00270	
Velocity of stack gas, V <sub>s</sub>			Total mass collected, M <sub>n</sub> g 0.00278	
Pitot tube velocity constant, K <sub>p</sub> 34.97			C <sub>wet</sub> = $\frac{M_n}{V_{mstw}}$ mg/m <sup>3</sup> 0.309	
Velocity pressure coefficient, C <sub>p</sub> 0.85			C <sub>dry</sub> = $\frac{M_n}{V_{mstd}}$ mg/m <sup>3</sup> 0.390	
Mean of velocity heads, ΔP <sub>avg</sub> mm H <sub>2</sub> O 16.45			C <sub>dry@X%O2</sub> = $\frac{M_n}{V_{mstd@X\%oxygen}}$ mg/m <sup>3</sup> 0.342	
Mean square root of velocity heads, √ΔP 4.06			E = [(C <sub>wet</sub> )/(Q <sub>stw</sub> )(60)] / 1000 20.52	
Mean stack gas temperature, T <sub>s</sub> °C 149				
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$ m/s 17.22				

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS - RUN 2				TPM	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>		
Barometric pressure, P <sub>b</sub>	mm Hg	765.01	CO <sub>2</sub>	% 9.03	
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	-30.59	O <sub>2</sub>	% 8.96	
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	762.76	Total	% 17.99	
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			N <sub>2</sub> (100 -Total)	% 82.01	
Moisture trap weight increase, V <sub>lc</sub>	g	-	M <sub>d</sub> = 0.44(%CO <sub>2</sub> )+0.32(%O <sub>2</sub> )+0.28(%N <sub>2</sub> )	29.80	
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	<b>Molecular weight of wet gas, M<sub>s</sub></b>		
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			M <sub>s</sub> = M <sub>d</sub> (1 - B <sub>wo</sub> ) + 18(B <sub>wo</sub> )	g/gmol 27.34	
Volume of gas sample through gas meter, V <sub>m</sub>		8.529	<b>Actual flow of stack gas, Q<sub>a</sub></b>		
Gas meter correction factor, Y <sub>d</sub>		0.93249	Area of stack, A <sub>s</sub>	m <sup>2</sup> 1.65	
Mean dry gas meter temperature, T <sub>m</sub>		19.208	Q <sub>a</sub> = (60)(A <sub>s</sub> )(V <sub>s</sub> )	m <sup>3</sup> /min 1911.3	
Mean pressure drop across orifice, ΔH mmH <sub>2</sub> O		51.952	<b>Total flow of stack gas, Q</b>		
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		7.517	Conversion factor (K/mm.Hg)	0.3592	
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Q <sub>std</sub> = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})}{(T_s) + 273}$	Dry 974.6	
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	9.5018	Q <sub>stdO2</sub> = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})(O_2REF)}{(T_s) + 273}$	@O <sub>2</sub> ref 1177.00	
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			Q <sub>stw</sub> = $\frac{(Q_a)P_s(0.3592)}{(T_s) + 273}$	Wet 1231.96	
Is the process burning hazardous waste? (if yes, no favourable oxygen correction)		No	<b>Percent isokinetic, %I</b>		
% oxygen measured in gas stream, act%O <sub>2</sub>		8.96	Nozzle diameter, D <sub>n</sub>	mm 6.44	
% oxygen reference condition		11	Nozzle area, A <sub>n</sub>	mm <sup>2</sup> 32.58	
O <sub>2</sub> Reference O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>		1.20	Total sampling time, θ	min 360	
Factor 21.0 - ref%O <sub>2</sub>		1.20	%I = $\frac{(4.6398E6)(T_s+273)(V_{mstd})}{(P_s)(V_s)(A_n)(\theta)(1-B_{wo})}$	% 108.6	
$V_{mstd@X\%oxygen} = (V_{mstd}) (O_2 Ref)$	m <sup>3</sup>	9.0512	Acceptable isokinetic range 95% to 115%	Yes	
<b>Moisture content, B<sub>wo</sub></b>			<b>Particulate Concentration, C</b>		
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	0.2089	Mass collected on filter, M <sub>f</sub>	g 0.00008	
		20.89	Mass collected in probe, M <sub>p</sub>	g 0.00290	
<b>Moisture by FTIR</b>		%	20.9	Total mass collected, M <sub>n</sub>	g 0.00298
<b>Velocity of stack gas, V<sub>s</sub></b>			$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.31	
Pitot tube velocity constant, K <sub>p</sub>		34.97	$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.40	
Velocity pressure coefficient, C <sub>p</sub>		0.85	$C_{dry@X\%O2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.33	
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	20.66	<b>Particulate Emission Rates, E</b>		
Mean square root of velocity heads, √ΔP		4.54	E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000		
Mean stack gas temperature, T <sub>s</sub>	°C	152			
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	19.29	23.18		



APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS - RUN 3			TPM	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	765.01	CO <sub>2</sub>	% 9.03
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	-30.59	O <sub>2</sub>	% 8.84
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	762.76	Total	% 17.87
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			N <sub>2</sub> (100 -Total)	
Moisture trap weight increase, V <sub>lc</sub>	g	-	%	
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	%	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			M <sub>d</sub> = 0.44(%CO <sub>2</sub> )+0.32(%O <sub>2</sub> )+0.28(%N <sub>2</sub> )	
Volume of gas sample through gas meter, V <sub>m</sub>		3.719	%	
Gas meter correction factor, Y <sub>d</sub>		0.93249	%	
Mean dry gas meter temperature, T <sub>m</sub>		18.056	%	
Mean pressure drop across orifice, ΔH	mmH <sub>2</sub> O	45.189	%	
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		3.288	%	
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			<b>Molecular weight of wet gas, M<sub>s</sub></b>	
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	4.1565	M <sub>s</sub> = M <sub>d</sub> (1 - B <sub>wo</sub> ) + 18(B <sub>wo</sub> )	
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O<sub>2</sub></sub></b>			g/gmol 27.33	
Is the process burning hazardous waste? (if yes, no favourable oxygen correction)		No	<b>Actual flow of stack gas, Q<sub>a</sub></b>	
% oxygen measured in gas stream, act%O <sub>2</sub>		8.8	Area of stack, A <sub>s</sub>	
% oxygen reference condition		11	m <sup>2</sup> 1.65	
O <sub>2</sub> Reference	O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>	1.22	Q <sub>a</sub> = (60)(A <sub>s</sub> )(V <sub>s</sub> )	
Factor	21.0 - ref%O <sub>2</sub>		m <sup>3</sup> /min 1788.5	
$V_{mstd@X\%oxygen} = (V_{mstd})(O_2 \text{ Ref})$	m <sup>3</sup>	3.9987	<b>Total flow of stack gas, Q</b>	
<b>Moisture content, B<sub>wo</sub></b>			Conversion factor (K/mm.Hg)	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$		0.2089	0.3592	
	%	20.89	Q <sub>std</sub> = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})}{(T_s) + 273}$	
<b>Moisture by FTIR</b>			Dry 910.8	
	%	20.89	Q <sub>stdO<sub>2</sub></sub> = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})(O_2 \text{ REF})}{(T_s) + 273}$	
<b>Velocity of stack gas, V<sub>s</sub></b>			@O <sub>2</sub> ref 1110.87	
Pitot tube velocity constant, K <sub>p</sub>		34.97	Wet 1151.32	
Velocity pressure coefficient, C <sub>p</sub>		0.85	<b>Percent isokinetic, %I</b>	
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	18.06	Nozzle diameter, D <sub>n</sub>	
Mean square root of velocity heads, √ΔP		4.25	mm 6.44	
Mean stack gas temperature, T <sub>s</sub>	°C	153	Nozzle area, A <sub>n</sub>	
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	18.05	mm <sup>2</sup> 32.58	
			Total sampling time, θ	
			min 180	
			%I = $\frac{(4.6398E6)(T_s+273)(V_{mstd})}{(P_s)(V_s)(A_n)(\theta)(1-B_{wo})}$	
			% 101.7	
			Acceptable isokinetic range 95% to 115%	
			Yes	
<b>Particulate Concentration, C</b>			<b>Particulate Emission Rates, E</b>	
Mass collected on filter, M <sub>f</sub>			g 0.00008	
Mass collected in probe, M <sub>p</sub>			g 0.00290	
Total mass collected, M <sub>n</sub>			g 0.0030	
$C_{wet} = \frac{M_n}{V_{mstw}}$			mg/m <sup>3</sup> 0.72	
$C_{dry} = \frac{M_n}{V_{mstd}}$			mg/m <sup>3</sup> 0.91	
$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$			mg/m <sup>3</sup> 0.75	
			E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	
			49.53	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS - RUN 4				TPM	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>		
Barometric pressure, P <sub>b</sub>	mm Hg	765.01	CO <sub>2</sub>	% 8.92	
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	-30.59	O <sub>2</sub>	% 9.23	
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	762.76	Total	% 18.15	
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			N <sub>2</sub> (100 -Total)	% 81.85	
Moisture trap weight increase, V <sub>lc</sub>	g	-	M <sub>d</sub> = 0.44(%CO <sub>2</sub> )+0.32(%O <sub>2</sub> )+0.28(%N <sub>2</sub> )	29.80	
V <sub>wstd</sub> = (0.001246)(V <sub>lc</sub> )	m <sup>3</sup>	-	<b>Molecular weight of wet gas, M<sub>s</sub></b>		
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			M <sub>s</sub> = M <sub>d</sub> (1 - B <sub>wo</sub> ) + 18(B <sub>wo</sub> )	g/gmol 27.47	
Volume of gas sample through gas meter, V <sub>m</sub>		3.902	<b>Actual flow of stack gas, Q<sub>a</sub></b>		
Gas meter correction factor, Y <sub>d</sub>		0.93249	Area of stack, A <sub>s</sub>	m <sup>2</sup> 1.65	
Mean dry gas meter temperature, T <sub>m</sub>		13.361	Q <sub>a</sub> = (60)(A <sub>s</sub> )(V <sub>s</sub> )	m <sup>3</sup> /min 1744.8	
Mean pressure drop across orifice, ΔH mmH <sub>2</sub> O		43.006	<b>Total flow of stack gas, Q</b>		
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		3.506	Conversion factor (K/mm.Hg)	0.3592	
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Q <sub>std</sub> = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})}{(T_s) + 273}$	Dry 906.8	
V <sub>mstw</sub> = V <sub>mstd</sub> + V <sub>wstd</sub>	m <sup>3</sup>	4.3673	Q <sub>stdO2</sub> = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})(O_2REF)}{(T_s) + 273}$	@O <sub>2</sub> ref 1070.61	
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			Q <sub>stw</sub> = $\frac{(Q_a)P_s(0.3592)}{(T_s) + 273}$	Wet 1129.52	
Is the process burning hazardous waste? (if yes, no favourable oxygen correction)		No	<b>Percent isokinetic, %I</b>		
% oxygen measured in gas stream, act%O <sub>2</sub>		9.23	Nozzle diameter, D <sub>n</sub>	mm 6.44	
% oxygen reference condition		11	Nozzle area, A <sub>n</sub>	mm <sup>2</sup> 32.58	
O <sub>2</sub> Reference O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>		1.18	Total sampling time, θ	min 180	
Factor $\frac{21.0 - ref\%O_2}{21.0 - act\%O_2}$			%I = $\frac{(4.6398E6)(T_s+273)(V_{mstd})}{(P_s)(V_s)(A_n)(\theta)(1-B_{wo})}$	% 108.9	
V <sub>mstd@X%oxygen</sub> = (V <sub>mstd</sub> ) (O <sub>2</sub> Ref)	m <sup>3</sup>	4.1273	Acceptable isokinetic range 95% to 115%	Yes	
<b>Moisture content, B<sub>wo</sub></b>			<b>Particulate Concentration, C</b>		
B <sub>wo</sub> = $\frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	19.72	Mass collected on filter, M <sub>f</sub>	g 0.00008	
<b>Moisture by FTIR</b>		%	19.7	Mass collected in probe, M <sub>p</sub>	g 0.00190
<b>Velocity of stack gas, V<sub>s</sub></b>			Total mass collected, M <sub>n</sub>	g 0.00198	
Pitot tube velocity constant, K <sub>p</sub>			C <sub>wet</sub> = $\frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.45	
Velocity pressure coefficient, C <sub>p</sub>		34.97	C <sub>dry</sub> = $\frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.56	
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	0.85	C <sub>dry@X%O2</sub> = $\frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.48	
Mean square root of velocity heads, √ΔP		17.37	<b>Particulate Emission Rates, E</b>		
Mean stack gas temperature, T <sub>s</sub>	°C	4.17	E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	30.73	
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	150			
		17.61			

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**TOTAL PARTICULATE MATTER QUALITY ASSURANCE CHECKLIST**

LEAK RATE						
Run	Mean Sampling Rate litre/min	Pre-sampling Leak Rate litre/min	Post-sampling Leak Rate litre/min	Maximum Vacuum mm Hg	Acceptable Leak Rate litre/min	Leak Tests Acceptable?
Run 1	20.99	0.1	0.1	-406.4	0.42	Yes
Run 2	22.09	0.08	0.1	-406.4	0.44	Yes
Run 3	19.26	0.11	0.12	-381	0.39	Yes
Run 4	20.21	0.12	0.11	-457.2	0.40	Yes

ISOKINETICITY		
Run	Isokinetic Variation %	Acceptable Isokineticity
Run 1	114.47	Yes
Run 2	108.61	Yes
Run 3	101.67	Yes
Run 4	108.89	Yes

Acceptable isokinetic range 95% to 115%

WEIGHING BALANCE UNCERTAINTY			
Run	Result mg/m <sup>3</sup>	5% ELV mg/m <sup>3</sup>	LOD < 5% ELV
Run 1	0.02	1.5	Yes
Run 2	0.02	1.5	Yes
Run 3	0.05	1.5	Yes
Run 4	0.0	1.5	Yes

The above is based on both the Filter and rinse uncertainty

BLANK VALUE				
Run	Overall Blank Value mg/m <sup>3</sup>	Daily Emission Limit Value mg/m <sup>3</sup>	Acceptable Blank Value mg/m <sup>3</sup>	Overall Blank Acceptable
Blank 1	0.08	30	3.0	Yes
Blank 2	0.05	30	3.0	Yes
Blank 3	0.03	30	3.0	Yes

FILTERS					
Run	Filter Material	Filter Size mm	Max Filtration Temperature °C	Pre-use Filter Conditioning Temperature °C	Post-use Filter Conditioning Temperature °C
Run 1	QF	47	151	180	160
Run 2	QF	47	153	180	160
Run 3	QF	47	153	180	160
Run 4	QF	47	151	180	160

GF = Glass Fibre  
QF = Quartz Fibre

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

PM <sub>10</sub> SUMMARY					
Test	Sampling Times	Concentration mg/m <sup>3</sup>	LOD mg/m <sup>3</sup>	Limit mg/m <sup>3</sup>	Emission Rate g/hr
Run 1	13:00 - 19:00 19 March 2014	0.014	0.010	-	0.76
Run 2	09:00 - 15:00 20 March 2014	0.012	0.010	-	0.77
Run 3	15:46 - 18:46 20 March 2014	0.059	0.020	-	3.7
Run 4	08:45 - 11:45 21 March 2014	0.088	0.020	-	5.3
Blank 1	-	0.007	-	-	-
Blank 2	-	0.022	-	-	-
Blank 3	-	0.010	-	-	-

Reference conditions are 273K, 101.3kPa, dry gas 11% Oxygen.  
where values are below the LOD the LOD will be reported.

PM <sub>2.5</sub> SUMMARY					
Test	Sampling Times	Concentration mg/m <sup>3</sup>	LOD mg/m <sup>3</sup>	Limit mg/m <sup>3</sup>	Emission Rate g/hr
Run 1	13:00 - 19:00 19 March 2014	0.005	0.005	-	0.29
Run 2	09:00 - 15:00 20 March 2014	0.005	0.005	-	0.32
Run 3	15:46 - 18:46 20 March 2014	0.010	0.010	-	0.63
Run 4	08:45 - 11:45 21 March 2014	0.048	0.010	-	2.9
Blank 1	-	0.007	-	-	-
Blank 2	-	0.010	-	-	-
Blank 3	-	0.010	-	-	-

Reference conditions are 273K, 101.3kPa, dry gas 11% Oxygen.  
where values are below the LOD the LOD will be reported, where this occurs the quoted uncertainties will be relatively high.

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

PM <sub>2.5</sub> (BF) SAMPLES WEIGHTS				
Test	PM <sub>2.5</sub> Filter Number	Filter Start Weight g	Filter End Weight g	PM <sub>2.5</sub> Mass Gained on Filter g
Run 1	QC1022	32.15592	32.15548	-0.00044
Run 2	QC1023	32.90822	32.90806	-0.00016
Run 3	QC1030	32.64649	32.64619	-0.00030
Run 4	QC1036	31.88521	31.88544	0.00023
Blank 1	QC1015	15.82713	15.82700	-0.00013
Blank 2	QC1035	32.64883	32.64890	0.00007
Blank 3	QC1041	15.30896	15.30903	0.00007

PM <sub>10</sub> (CP2) SAMPLES WEIGHTS				
Test	PM <sub>10</sub> Filter Number	Filter Start Weight g	Filter End Weight g	PM <sub>10</sub> Mass Gained on Filter g
Run 1	QC1016	15.31508	15.31516	0.00008
Run 2	QC1029	15.23483	15.23490	0.00007
Run 3	QC1030	15.57621	15.57645	0.00024
Run 4	QC1040	14.63094	14.63113	0.00019
Blank 1	QC1015	15.82713	15.82700	-0.00013
Blank 2	QC1039	15.81961	15.81970	0.00009
Blank 3	QC1041	15.30896	15.30903	0.00007

PM <sub>2.5</sub> & PM <sub>10</sub> (BF & CP2) SAMPLES WEIGHTS COMBINED							
Test	PM <sub>2.5</sub> Filter Number	PM <sub>10</sub> Filter Number	PM <sub>2.5</sub> Mass Gained on Filter g	PM <sub>10</sub> Mass Gained on Filter g	Actual PM <sub>2.5</sub> & PM <sub>10</sub> Combined Total Mass Gained g	PM <sub>2.5</sub> & PM <sub>10</sub> Combined Weighing LOD g	*Reported PM <sub>2.5</sub> & PM <sub>10</sub> Combined Total Mass Gained g
Run 1	QC1022	QC1016	-0.00044	0.00008	-0.00036	0.00010	0.00013
Run 2	QC1023	QC1029	-0.00016	0.00007	-0.00009	0.00010	0.00012
Run 3	QC1030	QC1030	-0.00030	0.00024	-0.00006	0.00010	0.00029
Run 4	QC1036	QC1040	0.00023	0.00019	0.00042	0.00010	0.00042
Blank 1	QC1015	QC1015	-0.00013	-0.00013	-0.00026	0.00010	0.00010
Blank 2	QC1035	QC1039	0.00007	0.00009	0.00016	0.00010	0.00016
Blank 3	QC1041	QC1041	0.00007	0.00007	0.00014	0.00010	0.00014

\* Where weighing values are below the LOD possibly due to loss of filter material, the LOD will be reported.

NOTE - Where the filter weight gain is less than the weighing uncertainty, the weighing uncertainty is used for further calculations. The weighing uncertainty is 0.00005g.

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS RUN 1			PM <sub>10</sub> & PM <sub>2.5</sub>	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	765.0	CO <sub>2</sub>	7.10
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	-2.2	O <sub>2</sub>	11.83
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	764.8	Total	18.93
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			N <sub>2</sub> (100 -Total)	
Moisture trap weight increase, V <sub>lc</sub>	g	H <sub>2</sub> O by FTIR	M <sub>d</sub> = 0.44(%CO <sub>2</sub> )+0.32(%O <sub>2</sub> )+0.28(%N <sub>2</sub> )	81.07
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	<b>Molecular weight of wet gas, M<sub>s</sub></b>	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			M <sub>s</sub> = M <sub>d</sub> (1 - B <sub>wo</sub> ) + 18(B <sub>wo</sub> )	
Volume of gas sample through gas meter, V <sub>m</sub>		10.70	27.19	
Gas meter correction factor, Y <sub>d</sub>		1.05	<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Mean dry gas meter temperature, T <sub>m</sub>		25.42	Area of stack, A <sub>s</sub>	m <sup>2</sup> 1.65
Mean pressure drop across orifice, ΔH	mmH <sub>2</sub> O	110.62	Q <sub>a</sub> = (60)(A <sub>s</sub> )(V <sub>s</sub> )	m <sup>3</sup> /min 1984.5
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		10.496	<b>Percent isokinetic, %I</b>	
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Required Flow Rate @ DGM	
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	13.2527	Actual Flow Rate @ DGM	l/min 29.10
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			Isokinetic Rate	
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	Acceptable 90% - 130%	
% oxygen measured in gas stream, act%O <sub>2</sub>		11.83	<b>Particulate Concentration, C<sub>PM10</sub></b>	
% oxygen reference condition		11	Mass of particulate collected on PM <sub>10</sub> filter, M <sub>f</sub>	
O <sub>2</sub> Reference	O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>	0.92	0.00008	
Factor	21.0 - ref%O <sub>2</sub>		Mass of particulate collected on PM <sub>2.5</sub> filter, M <sub>f</sub>	
$V_{mstd@X\%oxygen} = (V_{mstd}) (O_2 Ref)$	m <sup>3</sup>	9.625	0.00005	
<b>Moisture content, B<sub>wo</sub></b>			C <sub>wet</sub> = $\frac{M_n}{V_{mstw}}$ mg/m <sup>3</sup> 0.00981	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	20.80	C <sub>dry</sub> = $\frac{M_n}{V_{mstd}}$ mg/m <sup>3</sup> 0.01239	
<b>Moisture by FTIR</b>			C <sub>dry@X%O2</sub> = $\frac{M_n}{V_{mstd@X\%oxygen}}$ mg/m <sup>3</sup> 0.01351	
<b>Velocity of stack gas, V<sub>s</sub></b>			<b>Particulate Emission Rates, E</b>	
Pitot tube velocity constant, K <sub>p</sub>		34.97	E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	
Velocity pressure coefficient, C <sub>p</sub>		0.84	0.76	
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	22.85	<b>Particulate Concentration, C<sub>PM2.5</sub></b>	
Mean square root of velocity heads, √ΔP		4.8	Mass of particulate collected on filter, M <sub>f</sub>	
Mean stack gas temperature, T <sub>s</sub>	°C	150	0.00005	
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{(T_s + 273))}}{(M_s)(P_s)}$	m/s	20.03	C <sub>wet</sub> = $\frac{M_n}{V_{mstw}}$ mg/m <sup>3</sup> 0.0038	
			C <sub>dry</sub> = $\frac{M_n}{V_{mstd}}$ mg/m <sup>3</sup> 0.0048	
			C <sub>dry@X%O2</sub> = $\frac{M_n}{V_{mstd@X\%oxygen}}$ mg/m <sup>3</sup> 0.0052	
			<b>Particulate Emission Rates, E</b>	
			E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	
			0.29	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS RUN 2			PM <sub>10</sub> & PM <sub>2.5</sub>	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	757.5	CO <sub>2</sub>	9.03
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	-2.2	O <sub>2</sub>	11.76
$P_s = P_b + (P_{static})$	mm Hg	757.3	Total	20.79
$\frac{13.6}{13.6}$			N <sub>2</sub> (100 -Total)	79.21
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2)$	
Moisture trap weight increase, V <sub>lc</sub>	g	H <sub>2</sub> O by FTIR	<b>Molecular weight of wet gas, M<sub>s</sub></b>	
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	$M_s = M_d(1 - B_{wo}) + 18(B_{wo})$	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			27.43	
Volume of gas sample through gas meter, V <sub>m</sub>		10.93	<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Gas meter correction factor, Y <sub>d</sub>		1.05	Area of stack, A <sub>s</sub>	m <sup>2</sup> 1.65
Mean dry gas meter temperature, T <sub>m</sub>		24.40	$Q_a = (60)(A_s)(V_s)$	m <sup>3</sup> /min 2251.6
Mean pressure drop across orifice, ΔH	mmH <sub>2</sub> O	109.52	<b>Percent isokinetic, %I</b>	
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		10.650	Required Flow Rate @ DGM	l/min 29.40
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Actual Flow Rate @ DGM	l/min 33.1
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	13.4633	Isokinetic Rate	112.57
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			Acceptable 90% - 130%	Yes
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	<b>Particulate Concentration, C<sub>PM10</sub></b>	
% oxygen measured in gas stream, act%O <sub>2</sub>		11.76	Mass of particulate collected on PM <sub>10</sub> filter, M <sub>f</sub>	0.00007
% oxygen reference condition		11	Mass of particulate collected on PM <sub>2.5</sub> filter, M <sub>f</sub>	0.00005
O <sub>2</sub> Reference O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>		0.92	$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.0089
Factor 21.0 - ref%O <sub>2</sub>			$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.0113
$V_{mstd@X\%oxygen} = (V_{mstd})(O_2 Ref)$	m <sup>3</sup>	9.841	$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0122
<b>Moisture content, B<sub>wo</sub></b>			<b>Particulate Emission Rates, E</b>	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	20.89	$E = [(C_{wet})(Q_{stw})(60)] / 1000$	0.77
Moisture by FTIR	%	20.89	<b>Particulate Concentration, C<sub>PM2.5</sub></b>	
<b>Velocity of stack gas, V<sub>s</sub></b>			Mass of particulate collected on filter, M <sub>f</sub>	0.00005
Pitot tube velocity constant, K <sub>p</sub>		34.97	$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.0037
Velocity pressure coefficient, C <sub>p</sub>		0.84	$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.0047
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	29.17	$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0051
Mean square root of velocity heads, √ΔP		5.40	<b>Particulate Emission Rates, E</b>	
Mean stack gas temperature, T <sub>s</sub>	°C	153	$E = [(C_{wet})(Q_{stw})(60)] / 1000$	0.32
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	22.72		

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS RUN 3			PM <sub>10</sub> & PM <sub>2.5</sub>	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	757.5	CO <sub>2</sub>	9.03
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	-2.2	O <sub>2</sub>	11.66
$P_s = P_b + (P_{static})$	mm Hg	757.3	Total	20.69
$\frac{13.6}{13.6}$			N <sub>2</sub> (100 -Total)	79.31
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2)$	
Moisture trap weight increase, V <sub>lc</sub>	g	H <sub>2</sub> O by FTIR	<b>Molecular weight of wet gas, M<sub>s</sub></b>	
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	$M_s = M_d(1 - B_{wo}) + 18(B_{wo})$	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Volume of gas sample through gas meter, V <sub>m</sub>		5.38	Area of stack, A <sub>s</sub>	m <sup>2</sup> 1.65
Gas meter correction factor, Y <sub>d</sub>		1.05	$Q_a = (60)(A_s)(V_s)$	m <sup>3</sup> /min 2190.5
Mean dry gas meter temperature, T <sub>m</sub>		23.11	<b>Percent isokinetic, %I</b>	
Mean pressure drop across orifice, ΔH	mmH <sub>2</sub> O	110.00	Required Flow Rate @ DGM	l/min 28.70
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		5.263	Actual Flow Rate @ DGM	l/min 29.9
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Isokinetic Rate	
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	6.6530	Acceptable 90% - 130%	
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			<b>Particulate Concentration, C<sub>PM10</sub></b>	
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	Mass of particulate collected on PM <sub>10</sub> filter, M <sub>f</sub>	0.00024
% oxygen measured in gas stream, act%O <sub>2</sub>		11.66	Mass of particulate collected on PM <sub>2.5</sub> filter, M <sub>f</sub>	0.00005
% oxygen reference condition		11	$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.0436
O <sub>2</sub> Reference	O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>	0.93	$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.0551
Factor	$\frac{21.0 - ref\%O_2}{21.0 - act\%O_2}$		$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0590
$V_{mstd@X\%oxygen} = (V_{mstd})(O_2 Ref)$	m <sup>3</sup>	4.916	<b>Particulate Emission Rates, E</b>	
<b>Moisture content, B<sub>wo</sub></b>			$E = [(C_{wet})(Q_{stw})(60)] / 1000$	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	0.2089	3.65	
<b>Moisture by FTIR</b>			<b>Particulate Concentration, C<sub>PM2.5</sub></b>	
	%	20.89	Mass of particulate collected on filter, M <sub>f</sub>	0.00005
<b>Velocity of stack gas, V<sub>s</sub></b>			$C_{wet} = \frac{M_n}{V_{mstw}}$	
Pitot tube velocity constant, K <sub>p</sub>		34.97	mg/m <sup>3</sup>	0.0075
Velocity pressure coefficient, C <sub>p</sub>		0.84	$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.0095
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	27.57	$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0102
Mean square root of velocity heads, √ΔP		5.25	<b>Particulate Emission Rates, E</b>	
Mean stack gas temperature, T <sub>s</sub>	°C	154	$E = [(C_{wet})(Q_{stw})(60)] / 1000$	
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	22.11	0.63	



APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS RUN 4			PM <sub>10</sub> & PM <sub>2.5</sub>	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	738.0	CO <sub>2</sub>	8.92
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	-2.2	O <sub>2</sub>	11.65
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	737.8	Total	20.57
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			N <sub>2</sub> (100 - Total)	
Moisture trap weight increase, V <sub>lc</sub>	g	H <sub>2</sub> O by FTIR	M <sub>d</sub> = 0.44(%CO <sub>2</sub> ) + 0.32(%O <sub>2</sub> ) + 0.28(%N <sub>2</sub> )	
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	<b>Molecular weight of wet gas, M<sub>s</sub></b>	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			M <sub>s</sub> = M <sub>d</sub> (1 - B <sub>wo</sub> ) + 18(B <sub>wo</sub> )	
Volume of gas sample through gas meter, V <sub>m</sub>		5.28	<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Gas meter correction factor, Y <sub>d</sub>		1.05	Area of stack, A <sub>s</sub>	m <sup>2</sup> 1.65
Mean dry gas meter temperature, T <sub>m</sub>		19.09	Q <sub>a</sub> = (60)(A <sub>s</sub> )(V <sub>s</sub> )	m <sup>3</sup> /min 2150.1
Mean pressure drop across orifice, ΔH	mmH <sub>2</sub> O	110.00	<b>Percent isokinetic, %I</b>	
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		5.104	Required Flow Rate @ DGM	l/min 28.80
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Actual Flow Rate @ DGM	
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	6.3582	Isokinetic Rate	l/min 29.3
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			Acceptable 90% - 130%	
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	<b>Particulate Concentration, C<sub>PM10</sub></b>	
% oxygen measured in gas stream, act%O <sub>2</sub>		11.65	Mass of particulate collected on PM <sub>10</sub> filter, M <sub>f</sub>	
% oxygen reference condition		11	Mass of particulate collected on PM <sub>2.5</sub> filter, M <sub>f</sub>	
O <sub>2</sub> Reference O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>		0.94	$C_{wet} = \frac{M_n}{V_{mstw}}$	mg/m <sup>3</sup> 0.00019
Factor $\frac{21.0 - ref\%O_2}{21.0 - act\%O_2}$		0.94	$C_{dry} = \frac{M_n}{V_{mstd}}$	mg/m <sup>3</sup> 0.00023
$V_{mstd@X\%oxygen} = (V_{mstd})(O_2 Ref)$	m <sup>3</sup>	4.772	$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m <sup>3</sup> 0.0661
<b>Moisture content, B<sub>wo</sub></b>			<b>Particulate Emission Rates, E</b>	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	0.1972	E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	
		19.72	5.32	
<b>Moisture by FTIR</b>			<b>Particulate Concentration, C<sub>PM2.5</sub></b>	
	%	19.72	Mass of particulate collected on filter, M <sub>f</sub>	
<b>Velocity of stack gas, V<sub>s</sub></b>			$C_{wet} = \frac{M_n}{V_{mstw}}$	
Pitot tube velocity constant, K <sub>p</sub>		34.97	mg/m <sup>3</sup> 0.0362	
Velocity pressure coefficient, C <sub>p</sub>		0.84	$C_{dry} = \frac{M_n}{V_{mstd}}$	
Mean of velocity heads, ΔP <sub>avg</sub>	mm H <sub>2</sub> O	26.11	mg/m <sup>3</sup> 0.0451	
Mean square root of velocity heads, √ΔP		5.11	$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$	
Mean stack gas temperature, T <sub>s</sub>	°C	152	mg/m <sup>3</sup> 0.0482	
$V_s = \frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	21.70	<b>Particulate Emission Rates, E</b>	
			E = [(C <sub>wet</sub> )(Q <sub>stw</sub> )(60)] / 1000	
			2.91	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PM<sub>10</sub> & PM<sub>2.5</sub> QUALITY ASSURANCE CHECKLIST**

LEAK RATE						
Run	Mean Sampling Rate litre/min	Pre-sampling Leak Rate litre/min	Post-sampling Leak Rate litre/min	Maximum Vacuum mm Hg	Acceptable Leak Rate litre/min	Leak Tests Acceptable?
Run 1	32.35	0.16	0.18	-508	0.65	Yes
Run 2	33.10	0.18	0.2	-508	0.66	Yes
Run 3	29.87	0.14	0.2	-508	0.60	Yes
Run 4	29.32	0.1	0.12	-457	0.59	Yes

ISOKINETICITY		
Run	Flow Variation %	Acceptable Variation
Run 1	111.2	Yes
Run 2	112.6	Yes
Run 3	104.1	Yes
Run 4	101.8	Yes

Acceptable Flow rate 90 -130%

FILTERS					
Run	Filter Material	Filter Size mm	Max Filtration Temperature °C	Pre-conditioning Filter Temperature °C	Post conditioning Filtration Temperature °C
Run 1	QF	50	153	180	160
Run 2	QF	50	154	180	160
Run 3	QF	50	154	180	160
Run 4	QF	50	153	180	160

QF = Quartz Fibre

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**Conformity with relevant aspects of BS EN ISO 23210:2009**

**GENERAL METHODOLOGY**

The equipment employed is a Paul Gothe, Johnas cascade impactor (see pg 13 for serial number) system meeting the requirements of BS EN ISO 23210. The standard cites a two-stage impactor system.

The method for sampling requires the extraction of a representative sample of duct gas isokinetically, into a specially designed in-stack sampling head. The Cascade Impactor is a multi-stage, multi-jet impactor which aerodynamically classifies particulates into multiple size ranges. The cascade impactor uses the principle of inertial separation to size segregate particulate samples from the gas stream. The impactor has two stages for particle size determination. Each stage gives a cut-point based on aerodynamic diameter of the particle.

During sampling, the particles are driven (jetted) toward a collecting surface where they may cling. By changing the velocity (orifice size of the jet), the size of the particles collected is controlled. The size of the jets within each stage is constant, but for each succeeding stage the jets get smaller. Impaction occurs when the particle's inertia overcomes the aerodynamic drag. Otherwise, the particle remains in the air stream and proceeds to the next stage. To keep the cut-point for each stage constant, the impactor is operated at a constant flow rate.

At each stage, the particle impacts on to a conditioned and pre-weighed substrate. Following sampling, the substrates are reconditioned and reweighed to determine the mass collected.

Based on the sampling conditions (sampling rate and gas temperature) the cut size (D50 – diameter of particles having a 50% probability of penetration) associated with each impactor stage may be determined.

An homogeneity assessment based on BS EN ISO 23210, Annex G, is undertaken to determine the most representative sampling point in the sampling plane (temperature, velocity and oxygen are suitable surrogates for particulate matter). The velocity measurement at the chosen point is used to determine an appropriate sampling nozzle/flow rate in order to ensure that isokinetic conditions are maintained throughout sampling to within the 90-130% range allowed in the standard (8.1) and which is consistent with the sampling equipment.

Concurrently, the volume of duct gas sampled is measured. This then enables the particulate concentration at each cut size to be determined.

The outlet gas from the sampling head is passed via a sampling probe through an impinger train with the purpose of removing water prior to entry to the sampling control box. It is not intended that the sampling train be used for additional sampling of condensable determinands and as such the train is unheated.

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**Conformity with relevant aspects of BS EN ISO 23210:2009**

Sampling Plane Validation Criteria				
EA Technical Guidance Note (Monitoring) M1	Result	Units	Requirement	Compliant
Lowest Differential Pressure	157	Pa	>= 5 Pa	Yes
Lowest Gas Velocity	16.05	m/s	-	-
Highest Gas Velocity	22.99	m/s	-	-
Ratio of Gas Velocities	1.43	-	< 3 : 1	Yes
Maximum angle of flow with regard to duct axis	<15	°	< 15°	Yes
No local negative flow	Yes	-	-	Yes

Conformance with BS EN ISO 23210:2009			
Reference	Requirement	Result	Compliant
Section 6.3	Suitable Impactor Used	See statement of conformity for Impactor	Yes
Section 8.1	Sampling position acceptable (as per 13284-1)	refer to page 10	No
Section 8.1	Nozzle arrangement	See statement of conformity for Impactor	Yes
Section 8.1	Representative sampling point	refer to page 10	No
Section 8.1	Constant Sample gas flow, iso-kinetic rate 90% to 130%		
	Run 1 - Required flow 29.1 (LPM)		-
	Run 1 - Minimum permissible flow 26.19 (LPM)	27.06	Yes
	Run 1 - Maximum permissible flow 37.83 (LPM)	36.92	Yes
	Run 2 - Required flow 29.4 (LPM)		-
	Run 2 - Minimum permissible flow 26.46 (LPM)	28.77	Yes
	Run 2 - Maximum permissible flow 38.22 (LPM)	38.16	Yes
	Run 3 - Required flow 28.7 (LPM)		-
	Run 3 - Minimum permissible flow 25.83 (LPM)	25.98	Yes
	Run 3 - Maximum permissible flow 37.31 (LPM)	34.00	Yes
	Run 4 - Required flow 28.8 (LPM)		-
	Run 4 - Minimum permissible flow 25.92 (LPM)	25.94	Yes
	Run 4 - Maximum permissible flow 37.44 (LPM)	34.20	Yes
Section 8.1	Overall blank taken once per day	Yes	Yes
Section 8.2	Impactor cleaned between each measurement	Yes	Yes
Section 8.2	Arrangement of impactor plates	See statement of conformity for Impactor	Yes
Section 8.3.2	Data taken for velocity, composition, temp & pressure	See "Preliminary stack survey" section	Yes
Section 8.3.3	Sampling rate determination in accordance with Annex A	Yes	Yes
Section 8.3.3	Sample flow rate kept +/- 5% of nominal flow rate		
	Run 1 - Max sample flow deviation from nominal (%)	7.8	No
	Run 2 - Max sample flow deviation from nominal (%)	8.7	No
	Run 3 - Max sample flow deviation from nominal (%)	0.0	Yes
	Run 4 - Max sample flow deviation from nominal (%)	0.0	Yes
Section 8.3.4	Nozzle selected to allow iso-kinetic rate 90% to 130%	Yes, as above	Yes
Section 8.3.5	Leak check less than 2%		
	Run 1	0.49	Yes
	Run 2	0.54	Yes
	Run 3	0.47	Yes
	Run 4	0.34	Yes
Section 8.3.6	Impactor at flue gas temperature before sampling	Yes	Yes
Section 8.3.6	Angle of nozzle less than 10 Degrees to flow	Yes	Yes
Section 8.3.6	Flowrate has checked and recorded every 5 mins	Yes	Yes
Section 8.3.6	Dynamic pressure recorded every 5 mins	Yes	Yes

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**Homogeneity assessment**

Assessment 1

Point number (i)	Distance along sample line (mm)	Probe Marking (mm)	Temp Deg C grid	Temp Deg C fixed	$r_i$
1	85.6	185.6	149	150	0.993
2	306.4	406.4	149	150	0.993
3	725	825	149	149	1.000
4	1143.6	1243.6	150	150	1.000
5	1364.4	1464.4	151	149	1.013
6					
7					
8					
9					
10					
<b>Second Line</b>					
1	85.6	185.6	148	148	1.000
2	306.4	406.4	150	148	1.014
3	725	825	150	148	1.014
4	1143.6	1243.6	149	148	1.007
5	1364.4	1464.4	149	148	1.007
6					
7					
8					
9					
10					

No. of points	10
$S_{grid}$	0.84
$S_{ref}$	0.9189
$f$	1
Is $S_{grid} \leq S_{ref}$ ?	Yes
F Factor	0.842
$F_{N-1; N-1; 0.95}$	3.18
Is F Factor $< F_{N-1; N-1; 0.95}$ ?	N/A
$S_{pos}$	N/A
$t_{N-1; 0.95}$	2.262
$U_{pos}$	N/A
Permissible Uncertainty	10
Is $U_{pos} < 0.5 * U_{perm}$ ?	N/A

Sample can be taken from any location

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**DAILY OXYGEN SUMMARY**

Run	Sampling Times	Concentration %	LOD %
1	13:00 - 19:00 19 March 2014	9.55	0.01
2	09:00 - 15:00 20 March 2014	9.13	0.01
3	15:46 - 18:46 20 March 2014	9.18	0.01
4	08:45 - 11:45 21 March 2014	9.45	0.01

**PRE SAMPLING CALIBRATION DATA**

Date	Time of Analyser Start	Range (%)	Zero Reading at analyser	Span Reading at analyser	Zero Check at analyser	Zero Check down line	Span Check down line	Leak Rate %
19 March 2014	08:40 - 09:00	25	0.00	10.01	0.01	0.01	10.02	0.10
20 March 2014	08:20 - 08:50	25	0.00	10.01	-0.01	-0.02	10	-0.10
21 March 2014	08:00 - 08:20	25	0.00	10.01	0.00	-0.01	10.02	0.10

**POST SAMPLING CALIBRATION DATA**

Date	Time of Analyser Start	Zero Check down line	Span Check down line	Zero Drift (%)	Span Drift (%)
19 March 2014	19:10 - 19:25	0.12	10.1	0.44	-0.30
20 March 2014	18:55 - 19:15	0.12	10.08	0.56	-0.60
21 March 2014	12:00 - 12:20	0.03	9.91	0.16	-1.50

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**COMBUSTION GAS SUMMARY**

Test	Sampling Times	Concentration %	Analysis Areas	Interference (%)	LOD %
Moisture Run 1	13:00 - 19:00 19 March 2014	21.8	3200 - 3401	1.4	0.10
Moisture Run 2	09:00 - 15:00 20 March 2014	20.8	3200 - 3401	1.75	0.02
Moisture Run 3	15:46 - 18:46 20 March 2014	20.6	3200 - 3401	1.75	0.02
Moisture Run 4	08:45 - 11:45 21 March 2014	20.6	3200 - 3401	1.75	0.10
Carbon Dioxide Run 1	13:00 - 19:00 19 March 2014	8.8	2000 - 2223	0.28	0.01
Carbon Dioxide Run 2	09:00 - 15:00 20 March 2014	9.0	2000 - 2223	1.75	0.01
Carbon Dioxide Run 3	15:46 - 18:46 20 March 2014	8.1	2000 - 2223	1.75	0.01
Carbon Dioxide Run 4	08:45 - 11:45 21 March 2014	8.1	2000 - 2223	1.75	0.01

\*M22 Specifies interference must be <5%.

**FTIR CALIBRATION CHECKS**

Pre - Sampling Checks - System			Date of Checks	19 March 2014	Time of Checks	09:45		
Post Sampling Checks - System			Date of Checks	19 March 2014	Time of Checks	19:20		
Compound	Pre - Test Zero Reading	Post Test Zero Reading	Zero Drift as a % of Range	Span Gas (ppm)	Pre - Test Span Reading	% Variation from Actual	Post Test Span Reading	% Span Drift
H <sub>2</sub> O	0.13	0.14	0.04	101.0	102.0	0.99	102.7	0.65
CO <sub>2</sub> (%)	0.00	0.00	-0.01	8.1	8.4	3.16	8.5	1.20

Pre - Sampling Checks - System			Date of Checks	20 March 2014	Time of Checks	08:35		
Post Sampling Checks - System			Date of Checks	20 March 2014	Time of Checks	18:55		
Compound	Pre - Test Zero Reading	Post Test Zero Reading	Zero Drift as a % of Range	Span Gas (ppm)	Pre - Test Span Reading	% Variation from Actual	Post Test Span Reading	% Span Drift
H <sub>2</sub> O	-0.02	0.14	0.16	101.0	102.0	0.99	102.7	0.65
CO <sub>2</sub> (%)	0.00	0.40	4.01	8.1	8.3	2.34	8.4	1.61

Pre - Sampling Checks - System			Date of Checks	21 March 2014	Time of Checks	08:17		
Post Sampling Checks - System			Date of Checks	21 March 2014	Time of Checks	12:03		
Compound	Pre - Test Zero Reading	Post Test Zero Reading	Zero Drift as a % of Range	Span Gas (ppm)	Pre - Test Span Reading	% Variation from Actual	Post Test Span Reading	% Span Drift
H <sub>2</sub> O	-0.02	0.13	0.15	101.0	102.3	1.32	101.3	-0.98
CO <sub>2</sub> (%)	0.00	0.01	0.11	8.1	8.4	3.99	8.5	0.79

Note - Methane was used as a surrogate span check for moisture. All other surrogates are listed in the individual measurement uncertainty budgets. Acceptance criteria for initial span check variation is +/-5% of certified reading for all gases, except HCl and NH<sub>3</sub> which are +/- 10% of certified reading. Acceptance criteria for % zero drift across the test is +/-2% of range for all gases.

### PRELIMINARY STACK SURVEY

Stack Characteristics		
Stack Diameter / Depth, D	1.45	m
Stack Width, W	-	m
Stack Area, A	1.65	m <sup>2</sup>
Average stack gas temperature	151	°C
Stack static pressure	-0.30	kPa
Barometric Pressure	100.4285714	kPa
Pitot tube calibration coefficient, $K_{pt}$	0.84	-

Stack Gas Composition & Molecular Weights								
Component	Molar Mass M	Density kg/m <sup>3</sup> p	Conc Dry % Vol	Dry Volume Fraction r	Dry Conc kg/m <sup>3</sup> pi	Conc Wet % Vol	Wet Volume Fraction r	Wet Conc kg/m <sup>3</sup> pi
CO <sub>2</sub>	44	1.96	11.27	0.11	0.22	9.47	0.09	0.19
O <sub>2</sub>	32	1.43	11.95	0.12	0.17	10.04	0.10	0.14
N <sub>2</sub>	28	1.25	76.78	0.77	0.96	64.51	0.65	0.81
H <sub>2</sub> O	18	0.80	-	-	-	15.98	0.16	0.13

Where:  $p = M / 22.41$      $pi = r \times p$

Calculation of Stack Gas Densities		
Determinand	Result	Units
Dry Density (STP), $P_{STD}$	1.3510	kg/m <sup>3</sup>
Wet Density (STP), $P_{STW}$	1.2634	kg/m <sup>3</sup>
Dry Density (Actual), $P_{Actual}$	0.8593	kg/m <sup>3</sup>
Average Wet Density (Actual), $P_{ActualW}$	0.804	kg/m <sup>3</sup>

Where:

$P_{STD}$  = sum of component concentrations, kg/m<sup>3</sup> (not including water vapour)  
 $P_{STW} = (P_{STD} + pi \text{ of H}_2\text{O}) / (1 + (pi \text{ of H}_2\text{O} / 0.8036))$

$P_{Actual} = P_{STD} \times (Ts / Ps) \times (Pa / Ta)$   
 $P_{ActualW} = P_{STW} \times (Ts / Ps) \times (Pa / Ta)$



APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY**

**TRAVERSE 1**

Date of Survey	19 March 2014
Time of Survey	09:00
Velocity Measurement Device:	S-Type Pitot

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.07	32.0	314	149	22.64	-	<15
2	0.22	32.0	314	149	22.64	-	<15
3	0.36	30.0	294	149	21.92	-	<15
4	0.51	24.2	237	150	19.72	-	<15
5	0.65	16.0	157	151	16.05	-	<15
6	-	-	-	-	-	-	-
7	-	-	-	-	-	-	-
8	-	-	-	-	-	-	-
9	-	-	-	-	-	-	-
10	-	-	-	-	-	-	-
Mean	-	26.8	263	150	20.60	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	-	-	-	-	-	-	-
2	-	-	-	-	-	-	-
3	-	-	-	-	-	-	-
4	-	-	-	-	-	-	-
5	-	-	-	-	-	-	-
6	-	-	-	-	-	-	-
7	-	-	-	-	-	-	-
8	-	-	-	-	-	-	-
9	-	-	-	-	-	-	-
10	-	-	-	-	-	-	-
Mean	-	-	-	-	-	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

**TRAVERSE 2**

Date of Survey	19 March 2014
Time of Survey	19:10
Velocity Measurement Device:	S-Type Pitot

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.07	30.0	294	149	21.92	-	<15
2	0.22	28.0	274	150	21.21	-	<15
3	0.36	26.8	263	150	20.75	-	<15
4	0.51	22.4	220	150	18.97	-	<15
5	0.65	17.4	171	150	16.72	-	<15
6	-	-	-	-	-	-	-
7	-	-	-	-	-	-	-
8	-	-	-	-	-	-	-
9	-	-	-	-	-	-	-
10	-	-	-	-	-	-	-
Mean	-	24.9	244	150	19.91	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	-	-	-	-	-	-	-
2	-	-	-	-	-	-	-
3	-	-	-	-	-	-	-
4	-	-	-	-	-	-	-
5	-	-	-	-	-	-	-
6	-	-	-	-	-	-	-
7	-	-	-	-	-	-	-
8	-	-	-	-	-	-	-
9	-	-	-	-	-	-	-
10	-	-	-	-	-	-	-
Mean	-	-	-	-	-	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY**

**TRAVERSE 3**

Date of Survey	20 March 2014
Time of Survey	08:32
Velocity Measurement Device:	S-Type Pitot

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.07	28.0	274	152	21.51	-	<15
2	0.22	30.0	294	152	22.26	-	<15
3	0.36	28.0	274	152	21.51	-	<15
4	0.51	26.0	255	153	20.75	-	<15
5	0.65	19.0	186	153	17.74	-	<15
6	-	-	-	-	-	-	-
7	-	-	-	-	-	-	-
8	-	-	-	-	-	-	-
9	-	-	-	-	-	-	-
10	-	-	-	-	-	-	-
Mean	-	26.2	257	152.4	20.75	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	-	-	-	-	-	-	-
2	-	-	-	-	-	-	-
3	-	-	-	-	-	-	-
4	-	-	-	-	-	-	-
5	-	-	-	-	-	-	-
6	-	-	-	-	-	-	-
7	-	-	-	-	-	-	-
8	-	-	-	-	-	-	-
9	-	-	-	-	-	-	-
10	-	-	-	-	-	-	-
Mean	-	-	-	-	-	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

**TRAVERSE 4**

Date of Survey	20 March 2014
Time of Survey	15:10
Velocity Measurement Device:	S-Type Pitot

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.07	30.0	294	149	22.19	-	<15
2	0.22	28.0	274	150	21.46	-	<15
3	0.36	28.0	274	150	21.46	-	<15
4	0.51	24.0	235	150	19.87	-	<15
5	0.65	20.0	196	150	18.14	-	<15
6	-	-	-	-	-	-	-
7	-	-	-	-	-	-	-
8	-	-	-	-	-	-	-
9	-	-	-	-	-	-	-
10	-	-	-	-	-	-	-
Mean	-	26.0	255	150	20.62	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	-	-	-	-	-	-	-
2	-	-	-	-	-	-	-
3	-	-	-	-	-	-	-
4	-	-	-	-	-	-	-
5	-	-	-	-	-	-	-
6	-	-	-	-	-	-	-
7	-	-	-	-	-	-	-
8	-	-	-	-	-	-	-
9	-	-	-	-	-	-	-
10	-	-	-	-	-	-	-
Mean	-	-	-	-	-	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY**

**TRAVERSE 5**

Date of Survey	20 March 2014
Time of Survey	18:55
Velocity Measurement Device:	S-Type Pitot

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.07	32.0	314	154	22.78	-	<15
2	0.22	30.0	294	154	22.05	-	<15
3	0.36	28.0	274	154	21.31	-	<15
4	0.51	24.0	235	154	19.73	-	<15
5	0.65	18.0	176	154	17.08	-	<15
6	-	-	-	-	-	-	-
7	-	-	-	-	-	-	-
8	-	-	-	-	-	-	-
9	-	-	-	-	-	-	-
10	-	-	-	-	-	-	-
Mean	-	26.4	259	154	20.59	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	-	-	-	-	-	-	-
2	-	-	-	-	-	-	-
3	-	-	-	-	-	-	-
4	-	-	-	-	-	-	-
5	-	-	-	-	-	-	-
6	-	-	-	-	-	-	-
7	-	-	-	-	-	-	-
8	-	-	-	-	-	-	-
9	-	-	-	-	-	-	-
10	-	-	-	-	-	-	-
Mean	-	-	-	-	-	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

**TRAVERSE 6**

Date of Survey	21 March 2014
Time of Survey	08:05
Velocity Measurement Device:	S-Type Pitot

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.07	30.0	294	152	22.00	-	<15
2	0.22	30.0	294	152	22.00	-	<15
3	0.36	28.6	280	153	21.51	-	<15
4	0.51	24.2	237	152	19.76	-	<15
5	0.65	20.0	196	152	17.97	-	<15
6	-	-	-	-	-	-	-
7	-	-	-	-	-	-	-
8	-	-	-	-	-	-	-
9	-	-	-	-	-	-	-
10	-	-	-	-	-	-	-
Mean	-	26.6	-	152	-	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	-	-	-	-	-	-	-
2	-	-	-	-	-	-	-
3	-	-	-	-	-	-	-
4	-	-	-	-	-	-	-
5	-	-	-	-	-	-	-
6	-	-	-	-	-	-	-
7	-	-	-	-	-	-	-
8	-	-	-	-	-	-	-
9	-	-	-	-	-	-	-
10	-	-	-	-	-	-	-
Mean	-	-	-	-	-	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY**

**TRAVERSE 7**

Date of Survey	21 March 2014
Time of Survey	12:00
Velocity Measurement Device:	S-Type Pitot

Sampling Line A							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.07	32.0	314	152	22.99	-	<15
2	0.22	30.0	294	151	22.24	-	<15
3	0.36	26.4	259	151	20.86	-	<15
4	0.51	22.8	223	151	19.39	-	<15
5	0.65	18.8	184	151	17.60	-	<15
6	-	-	-	-	-	-	<15
7	-	-	-	-	-	-	<15
8	-	-	-	-	-	-	<15
9	-	-	-	-	-	-	<15
10	-	-	-	-	-	-	<15
Mean	-	26	255	151.2	20.62	-	

Sampling Line B							
Traverse Point	Distance into duct (m)	$\Delta P_{pt}$ mmH <sub>2</sub> O	$\Delta P_{pt}$ Pa	Temp °C	Velocity m/s	O <sub>2</sub> % Vol	Angle of Swirl °
1	-	-	-	-	-	-	-
2	-	-	-	-	-	-	-
3	-	-	-	-	-	-	-
4	-	-	-	-	-	-	-
5	-	-	-	-	-	-	-
6	-	-	-	-	-	-	-
7	-	-	-	-	-	-	-
8	-	-	-	-	-	-	-
9	-	-	-	-	-	-	-
10	-	-	-	-	-	-	-
Mean	-	-	-	-	-	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

Sampling Plane Validation Criteria				
EA Technical Guidance Note (Monitoring) M1	Result	Units	Requirement	Compliant
Lowest Differential Pressure	157	Pa	>= 5 Pa	Yes
Lowest Gas Velocity	16.05	m/s	-	-
Highest Gas Velocity	22.99	m/s	-	-
Ratio of Gas Velocities	1.43	-	< 3 : 1	Yes
Maximum angle of flow with regard to duct axis	<15	°	< 15°	Yes
No local negative flow	Yes	-	-	Yes

Calculation of Stack Gas Velocity, V		
Velocity at Traverse Point, $V = K_{pt} \times (1-\epsilon) \times \sqrt{2 * \Delta P_{pt} / \rho_{ActualW}}$		
<b>Where:</b> $K_{pt}$ = Pitot tube calibration coefficient (1-ε) = Compressibility correction factor, assumed at a constant 0.998		
Average Stack Gas Velocity, $V_a$	20.56	m/s

**Where:**  
 $Q_{Actual} = V_a \times A \times 3600$   
 $Q_{STP} = Q (Actual) \times (T_s / T_a) \times (P_a / P_s) \times 3600$   
 $Q_{STP,Dry} = Q (STP) / (100 - (100 / Ma)) \times 3600$   
 $Q_{Ref} = Q (STP) \times ((100 - Ma) / (100 - Ms)) \times ((20.9 - O_{2a}) / (20.9 - O_{2s}))$

Day 1      19 March 2014

Calculation of Stack Gas Volumetric Flowrate, Q			
Duct gas flow conditions	Actual	Reference	Units
Temperature	150	0	°C
Total Pressure	101.7	101.3	kPa
Oxygen	9.6	11	%
Moisture	21.78	0.00	%
Gas Volumetric Flowrate		Result	Units
Average Stack Gas Velocity ( $V_a$ )		20.25	m/s
Stack Area (A)		1.65	m <sup>2</sup>
Gas Volumetric Flowrate (Actual), $Q_{Actual}$		120419	m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Wet), $Q_{STP}$		78080	m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Dry), $Q_{STP,Dry}$		61073	m <sup>3</sup> /hr
Gas Volumetric Flowrate (REF), $Q_{Ref}$		69915	m <sup>3</sup> /hr



APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

Day 2	20 March 2014		
Calculation of Stack Gas Volumetric Flowrate, Q			
Duct gas flow conditions	Actual	Reference	Units
Temperature	152	0	°C
Total Pressure	100.0	101.3	kPa
Oxygen	9.3	11	%
Moisture	20.64	0.00	%
Gas Volumetric Flowrate	Result		Units
Average Stack Gas Velocity (Va)	20.65		m/s
Stack Area (A)	1.65		m <sup>2</sup>
Gas Volumetric Flowrate (Actual), Q <sub>Actual</sub>	122794		m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Wet), Q <sub>STP</sub>	77808		m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Dry), Q <sub>STP,Dry</sub>	61749		m <sup>3</sup> /hr
Gas Volumetric Flowrate (REF), Q <sub>Ref</sub>	72548		m <sup>3</sup> /hr

Day 3	21 March 2014		
Calculation of Stack Gas Volumetric Flowrate, Q			
Duct gas flow conditions	Actual	Reference	Units
Temperature	151	0	°C
Total Pressure	97.7	101.3	kPa
Oxygen	9.4	11	%
Moisture	16.67	0.00	%
Gas Volumetric Flowrate	Result		Units
Average Stack Gas Velocity (Va)	20.62		m/s
Stack Area (A)	1.65		m <sup>2</sup>
Gas Volumetric Flowrate (Actual), Q <sub>Actual</sub>	122578		m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Wet), Q <sub>STP</sub>	76084		m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Dry), Q <sub>STP,Dry</sub>	63399		m <sup>3</sup> /hr
Gas Volumetric Flowrate (REF), Q <sub>Ref</sub>	73242		m <sup>3</sup> /hr

**Nomenclature:**

Ts = Absolute Temperature, Standard Conditions, 273 K  
Ps = Absolute Pressure, Standard Conditions, 101.3 kPa  
Ta = Absolute Temperature, Actual Conditions, K


Pa = Absolute Pressure, Actual Conditions, kPa  
Ma = Water vapour, Actual Conditions, % Vol  
Ms = Water vapour, Reference Conditions, % Vol

O<sub>2a</sub> = Oxygen, Actual Conditions, % Vol  
O<sub>2s</sub> = Oxygen, Reference Conditions, % Vol

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**STACK DIAGRAM**

	Value	Units
Stack Depth	1.45	m
Stack Width	-	m
Area	1.65	m <sup>2</sup>




Non-Isokinetic/Gases Sampling			
Sampling Point	Distance (% of Depth)	Distance into Stack	Units
A	30	0.44	m

Isokinetic Sampling CEN Methods			
Sampling Point	Distance (% of Depth)	Distance into Stack (m)	Swirl °
1	85.0	1.23	<15

- Isokinetic sampling point
- Isokinetic sampling points not used
- ◐ Non Isokinetic/Gases sampling point

**SAMPLING LOCATION**



APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - TOTAL PARTICULATE MATTER**

Run	Sampled Volume m <sup>3</sup>	Sampled Gas Temp K	Sampled Gas Pressure kPa	Sampled Gas Humidity % by volume	Oxygen Content % by volume	Limit of Detection % by mass	Leak %	Uncollected Mass mg
<b>MU required</b>	<b>≤ 2%</b>	<b>≤ 2%</b>	<b>≤ 1%</b>	<b>≤ 1%</b>	<b>≤ 10%</b>	<b>≤ 5% of ELV</b>	<b>≤ 2%</b>	<b>≤ 10% of ELV</b>
Run 1	0.001	2	0.5	1	0.1	0.1900	-	-
as a %	0.01	0.68	0.49	1.00	1.04	0.07783	0.48	0.001
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>
Run 2	0.001	2	0.5	1.00	0.1	0.190	-	-
as a %	0.01	0.68	0.49	1.00	1.12	0.070	0.45	0.001
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>
Run 3	0.001	2	0.5	1	0.1	0.1900	-	-
as a %	0.03	0.69	0.49	1.00	1.13	0.15839	0.62	0.001
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>
Run 4	0.001	2	0.5	1.00	0.1	0.190	-	-
as a %	0.02	0.70	0.49	1.00	1.08	0.153	0.54	0.001
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>

Run	Volume (STP) m <sup>3</sup>	Mass of particulate mg	O <sub>2</sub> Correction -	Leak mg/m <sup>3</sup>	Uncollected Mass mg	Combined uncertainty
Run 1	7.63	2.7800	0.88	0.001	0.0002	-
MU as mg/m <sup>3</sup>	0.00	0.0233	0.00	0.001	0.0000	<b>0.02</b>
MU as %	1.31	6.8345	-	0.275	0.0071	-
Run 2	8.49	2.9800	0.83	0.001	0.0002	-
MU as mg/m <sup>3</sup>	0.00	0.0210	0.00	0.001	0.0000	<b>0.02</b>
MU as %	1.3	6.3758	-	0.261	0.0066	-
Run 3	3.77	2.9800	0.82	0.003	0.0002	-
MU as mg/m <sup>3</sup>	0.01	0.0475	0.01	0.003	0.0000	<b>0.05</b>
MU as %	1.31	6.3758	-	0.360	0.0066	-
Run 4	3.95	1.98	0.85	0.002	0.0002	-
MU as mg/m <sup>3</sup>	0.01	0.0460	0.00	0.002	0.0000	<b>0.05</b>
MU as %	1.3	9.5960	-	0.314	0.0099	-

<b>R1 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.05</b>	<b>mg/m<sup>3</sup></b>	<b>14.04</b>	<b>%</b>
---	-------------	-------------------------	--------------	----------

<b>R2 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.04</b>	<b>mg/m<sup>3</sup></b>	<b>13.13</b>	<b>%</b>
---	-------------	-------------------------	--------------	----------

<b>R3 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.10</b>	<b>mg/m<sup>3</sup></b>	<b>13.14</b>	<b>%</b>
---	-------------	-------------------------	--------------	----------

<b>R4 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.09</b>	<b>mg/m<sup>3</sup></b>	<b>19.46</b>	<b>%</b>
---	-------------	-------------------------	--------------	----------

(k is a coverage factor which gives a 95% confidence in the quoted figures)

Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - PM 10**

Run	Sampled Volume m <sup>3</sup>	Sampled Gas K	Sampled Gas kPa	Sampled Gas % by volume	Oxygen % by volume	Limit of % by mass	Leak %
<b>MU required</b>	<b>≤ 2%</b>	<b>≤ 2%</b>	<b>≤ 1%</b>	<b>≤ 1%</b>	<b>≤ 10%</b>	<b>≤ 5% of ELV</b>	<b>≤ 2%</b>
Run 1	0.001	2	0.5	1	0.1	0.10	-
as a %	0.01	0.47	0.49	1.00	0.85	N/A	0.56
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 2	0.001	2	0.5	1.00	0.1	0.10	-
as a %	0.01	0.47	0.50	1.00	0.85	N/A	0.60
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 3	0.001	2	0.5	1	0.1	0.1000	-
as a %	0.02	0.47	0.50	1.00	0.86	N/A	0.67
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 4	0.001	2	0.5	1	0.1	0.10	-
as a %	0.02	0.47	0.51	1.00	0.86	N/A	0.41
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>

Run	Volume (STP) m <sup>3</sup>	Mass of particulate mg	O2 Correction -	Leak mg/m <sup>3</sup>	Combined uncertainty
Run 1	0.0022	0.1039	0.012	1.000	-
MU as mg/m <sup>3</sup>	0.0002	0.0104	0.0001	0.00004	<b>76.93</b>
MU as %	0.0017	76.9	1.091	0.321	-
Run 2	0.0019	0.1016	0.011	1.000	-
MU as mg/m <sup>3</sup>	0.0001	0.0102	0.0001	0.00004	<b>83.34</b>
MU as %	0.0015	83.3	1.082	0.349	-
Run 3	0.0188	0.2034	0.055	1.000	-
MU as mg/m <sup>3</sup>	0.0007	0.0203	0.0006	0.00023	<b>34.502</b>
MU as %	0.0074	34.5	1.071	0.387	-
Run 4	0.0295	0.21	0.082	1.00	-
MU as mg/m <sup>3</sup>	0.0011	0.02	0.0009	0.00021	<b>23.83</b>
MU as %	0.0111	23.8	1.070	0.24	-

<b>R1 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.02</b>	<b>mg/m<sup>3</sup></b>	<b>153.88</b>	<b>%</b>
<b>R2 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.02</b>	<b>mg/m<sup>3</sup></b>	<b>166.70</b>	<b>%</b>
<b>R3 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.04</b>	<b>mg/m<sup>3</sup></b>	<b>69.05</b>	<b>%</b>
<b>R4 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.04</b>	<b>mg/m<sup>3</sup></b>	<b>47.73</b>	<b>%</b>

(k is a coverage factor which gives a 95% confidence in the quoted figures)  
Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - PM 2.5**

Run	Sampled m <sup>3</sup>	Sampled Gas K	Sampled Gas kPa	Sampled Gas % by volume	Oxygen % by volume	Limit of % by mass	Leak %
<b>MU required</b>	<b>≤ 2%</b>	<b>≤ 2%</b>	<b>≤ 1%</b>	<b>≤ 1%</b>	<b>≤ 10%</b>	<b>≤ 5% of ELV</b>	<b>≤ 2%</b>
Run 1	0.001	2	0.5	1	0.1	0.05	-
as a %	0.01	0.47	0.49	1.00	0.85	N/A	0.56
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 2	0.001	2	0.5	1.00	0.1	0.05	-
as a %	0.01	0.47	0.50	1.00	0.85	N/A	0.60
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 3	0.001	2	0.5	1.00	0.1	0.05	-
as a %	0.02	0.47	0.50	1.00	0.86	N/A	0.67
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run 4	0.001	2	0.5	1.00	0.1	0.05	-
as a %	0.02	0.47	0.51	1.00	0.86	0.00	0.41
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>

Run	Volume (STP) m <sup>3</sup>	Mass of particulate mg	O2 Correction -	Leak mg/m <sup>3</sup>	Combined uncertainty
Run 1	0.00	0.1039	0.0048	1.000	-
MU as mg/m <sup>3</sup>	0.0001	0.0052	0.0001	0.00002	<b>100.01</b>
MU as %	0.0007	100.0000	1.0905	0.32	-
Run 2	0.0008	0.1016	0.0047	1.000	-
MU as mg/m <sup>3</sup>	0.0001	0.0051	0.0001	0.00002	<b>100.01</b>
MU as %	0.0006	100.0000	1.0823	0.35	-
Run 3	0.0016	0.1016	0.0047	1.000	-
MU as mg/m <sup>3</sup>	0.0001	0.0051	0.0001	0.00002	<b>100.01</b>
MU as %	0.0006	100.0000	1.0707	0.39	-
Run 4	0.0162	0.2095	0.0451	1.0000	-
MU as mg/m <sup>3</sup>	0.0006	0.0105	0.0005	0.00011	<b>21.77</b>
MU as %	0.0061	21.7391	1.0695	0.24	-

<b>R1 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.010</b>	<b>mg/m<sup>3</sup></b>	<b>200.03</b>	<b>%</b>
<b>R2 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.010</b>	<b>mg/m<sup>3</sup></b>	<b>200.03</b>	<b>%</b>
<b>R3 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.010</b>	<b>mg/m<sup>3</sup></b>	<b>200.03</b>	<b>%</b>
<b>R4 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.021</b>	<b>mg/m<sup>3</sup></b>	<b>43.60</b>	<b>%</b>

(k is a coverage factor which gives a 95% confidence in the quoted figures)  
Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - CARBON DIOXIDE BY FTIR**

Actual Measured Concentration	8.81	% vol
Measured Concentration at Reference Conditions	8.81	% vol
Emission Limit Value	-	% vol
Instrument Range	10	% vol
Check Gas Concentration	8.11	% vol

Performance Characteristics & Source of Value	Values	Requirement	Compliant
Deviation from linearity as a % of the range (taken from worst case figure in MCERTS certificate)	-1.900	<2%	Yes
Zero drift (calculated from start and end readings)	-0.010	<5%	Yes
Span drift (calculated from start and end readings).	1.195	<5%	Yes
Sensitivity to sample gas pressure: (taken from worst case figure in MCERTS certificate).	0.990	<2%	Yes
Sensitivity to ambient temperature at zero (taken from worst case figure in MCERTS certificate)	0.100	<5%	Yes
Sensitivity to ambient temperature at span (taken from worst case figure in MCERTS certificate)	-1.300	<5%	Yes
Sensitivity to voltage (taken from worst case figure in MCERTS certificate)	1.600	<2%	Yes
Interferents (calculated using M22, Section 8.2, equation 3)	0.283	<5%	Yes
Repeatability / standard deviation (taken from worst figure in MCERTS certificate)	0.080	<2%	Yes
Certified reference material (check gas)	2.000	2% or less	Yes

Uncertainty in Performance Characteristics	% vol
Uncertainty of linearity (lack of fit) $U_{fit}$	-0.110
Uncertainty of zero drift $U_{0,dr}$	-0.001
Uncertainty of span drift $U_{s,dr}$	0.069
Uncertainty of volume or pressure flow dependence $U_{spress}$	0.057
Uncertainty in Ambient Temperature $U_{temp}$	0.075
Uncertainty in Voltage $U_{volt}$	0.092
Uncertainty of interferents $U_i$	0.016
Uncertainty of Repeatability $U_r$	0.008
Uncertainty of Certified Reference Material $U_{cal}$	0.047

Measurement Uncertainty	% vol
Combined uncertainty	0.19
Expanded uncertainty at a 95% Confidence Interval	0.38

Note - The expanded uncertainty uses a coverage factor of  $k = 2$ .

Expanded Measurement Uncertainty at a 95% Confidence Interval	%
Expressed as a % of the Measured Concentration	4.35
Expressed as a % of the Measured Concentration at Reference Conditions	4.35
Expressed as a % of the Emission Limit Value	-

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - MOISTURE BY FTIR**

Actual Measured Concentration	21.80	% vol
Measured Concentration at Reference Conditions	21.80	% vol
Emission Limit Value	30	% vol
Instrument Range	30	% vol
Check Gas Concentration (Methane was used as a Surrogate)	72.14	mg/m <sup>3</sup>

Performance Characteristics & Source of Value	Values	Requirement	Compliant
Deviation from linearity as a % of the range (taken from worst case figure in MCERTS certificate)	-1.900	<2%	Yes
Zero drift (calculated from start and end readings)	0.043	<5%	Yes
Span drift (calculated from start and end readings).	0.654	<5%	Yes
Sensitivity to sample gas pressure: (taken from worst case figure in MCERTS certificate).	0.990	<2%	Yes
Sensitivity to ambient temperature at zero (taken from worst case figure in MCERTS certificate)	0.100	<5%	Yes
Sensitivity to ambient temperature at span (taken from worst case figure in MCERTS certificate)	-1.000	<5%	Yes
Sensitivity to voltage (taken from worst case figure in MCERTS certificate)	0.710	<2%	Yes
Interferents (calculated using M22, Section 8.2, equation 3)	1.383	<5%	Yes
Repeatability / standard deviation (taken from worst figure in MCERTS certificate)	0.170	<2%	Yes
Certified reference material (check gas)	2.000	2% or less	Yes

Uncertainty in Performance Characteristics	% vol
Uncertainty of linearity (lack of fit) $U_{fit}$	-0.329
Uncertainty of zero drift $U_{0,dr}$	0.008
Uncertainty of span drift $U_{s,dr}$	0.113
Uncertainty of volume or pressure flow dependence $U_{spress}$	0.171
Uncertainty in Ambient Temperature $U_{temp}$	0.174
Uncertainty in Voltage $U_{volt}$	0.123
Uncertainty of interferents $U_i$	0.239
Uncertainty of Repeatability $U_r$	0.051
Uncertainty of Certified Reference Material $U_{cal}$	0.417

Measurement Uncertainty	% vol
Combined uncertainty	0.66
Expanded uncertainty at a 95% Confidence Interval	1.31

Note - The expanded uncertainty uses a coverage factor of  $k = 2$ .

Expanded Measurement Uncertainty at a 95% Confidence Interval	%
Expressed as a % of the Measured Concentration	6.01
Expressed as a % of the Measured Concentration at Reference Conditions	6.01
Expressed as a % of the Emission Limit Value	4.37

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - OXYGEN**

DAY 1 - 19 March 2014

Reference	11	%vol
Measured concentration	9.55	%vol
Calibration gas	10.01	%vol
Full Scale	25	%vol

Performance characteristics	Value	Units	specification	MU Met?
Response time	40	seconds	< 200 s	Yes
Logger sampling interval	60	seconds	-	-
Measurement period	216	minutes	-	-
Number of readings in measurement	216	-	-	-
Repeatability at zero	0.015	% by volume	<0.2 % range	Yes
Repeatability at span level	0.014	% by volume	<0.4 % range	Yes
Deviation from linearity	0.13	% vol	<0.3 % volume	Yes
Zero drift (during measurement period)	0.44	% vol at zero level	<2% of volume / 24hr	Yes
Span drift (during measurement period)	-0.30	% vol at span level	<2% volume/24hr	Yes
volume or pressure flow dependence	0.02	% of fs / 10l/h	<1% range	Yes
atmospheric pressure dependence	0.8	% of fs/kPa	< 1.5 % range	Yes
ambient temperature dependence	0.01	% by volume /10K	<0.3% volume 10 K	Yes
Combined interference	0.14	% range	<2% range	Yes
Dependence on voltage	0.1	% by volume /10V	< 0.1%vol /10 volt	Yes
Losses in the line (leak)	0.10	% of value	< 2% of value	Yes
Uncertainty of calibration gas	2	% of value	< 2% of value	Yes

Performance characteristic	Uncertainty	Value of uncertainty quantity
Standard deviation of repeatability at zero	ur0	-
Standard deviation of repeatability at span level	urs	0.001
Lack of fit	ufit	0.075
Drift	u0dr	0.089
volume or pressure flow dependence	uspres	0.001
atmospheric pressure dependence	uapres	0.115
ambient temperature dependence	utemp	0.003
Combined interference (from mcerts)	-	0.020
dependence on voltage	uvolt	0.029
losses in the line (leak)	uleak	0.006
Uncertainty of calibration gas	ucalib	0.110

Measurement uncertainty (Concentration Measured)	9.55	%vol
Combined uncertainty	0.20	%vol
% of value	2.10	%

<b>Expanded uncertainty expressed with a level of confidence of 95%</b>	<b>4.20</b>	<b>% of value</b>
---	-------------	-------------------

<b>Expanded uncertainty expressed with a level of confidence of 95%</b>	<b>0.40</b>	<b>% vol</b>
---	-------------	--------------

Developed for the STA by R Robinson, NPL



APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - OXYGEN**

DAY 2 - 20 March 2014

Reference	11	%vol
Measured concentration	9.15	%vol
Calibration gas	10.01	%vol
Full Scale	25	%vol

Performance characteristics	Value	Units	specification	MU Met?
Response time	40	seconds	< 200 s	Yes
Logger sampling interval	60	seconds	-	-
Measurement period	586	minutes	-	-
Number of readings in measurement	586	-	-	-
Repeatability at zero	0.015	% by volume	<0.2 % range	Yes
Repeatability at span level	0.014	% by volume	<0.4 % range	Yes
Deviation from linearity	0.13	% vol	<0.3 % volume	Yes
Zero drift (during measurement period)	0.56	% vol at zero level	<2% of volume / 24hr	Yes
Span drift (during measurement period)	-0.60	% vol at span level	<2% volume/24hr	Yes
volume or pressure flow dependence	0.02	% of fs / 10l/h	<1% range	Yes
atmospheric pressure dependence	0.8	% of fs/kPa	< 1.5 % range	Yes
ambient temperature dependence	0.01	% by volume /10K	<0.3% volume 10 K	Yes
Combined interference	0.14	% range	<2% range	Yes
Dependence on voltage	0.1	% by volume /10V	< 0.1%vol /10 volt	Yes
Losses in the line (leak)	-0.10	% of value	< 2% of value	Yes
Uncertainty of calibration gas	2	% of value	< 2% of value	Yes

Performance characteristic	Uncertainty	Value of uncertainty quantity
Standard deviation of repeatability at zero	ur0	-
Standard deviation of repeatability at span level	urs	0.001
Lack of fit	ufit	0.075
Drift	u0dr	0.007
volume or pressure flow dependence	uspres	0.001
atmospheric pressure dependence	uapres	0.115
ambient temperature dependence	utemp	0.003
Combined interference (from mcerts)	-	0.081
dependence on voltage	uvolt	0.029
losses in the line (leak)	uleak	-0.005
Uncertainty of calibration gas	ucalib	0.106

Measurement uncertainty (Concentration Measured)	9.15	%vol
Combined uncertainty	0.19	%vol
% of value	2.12	%

<b>Expanded uncertainty expressed with a level of confidence of 95%</b>	<b>4.24</b>	<b>% of value</b>
---	-------------	-------------------

<b>Expanded uncertainty expressed with a level of confidence of 95%</b>	<b>0.39</b>	<b>% vol</b>
---	-------------	--------------

Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - OXYGEN**

DAY 3 - 21 March 2014

Reference	11	%vol
Measured concentration	9.45	%vol
Calibration gas	10.01	%vol
Full Scale	25	%vol

Performance characteristics	Value	Units	specification	MU Met?
Response time	40	seconds	< 200 s	Yes
Logger sampling interval	60	seconds	-	-
Measurement period	180	minutes	-	-
Number of readings in measurement	180	-	-	-
Repeatability at zero	0.015	% by volume	<0.2 % range	Yes
Repeatability at span level	0.014	% by volume	<0.4 % range	Yes
Deviation from linearity	0.13	% vol	<0.3 % volume	Yes
Zero drift (during measurement period)	0.16	% vol at zero level	<2% of volume / 24hr	Yes
Span drift (during measurement period)	-1.50	% vol at span level	<2% volume/24hr	Yes
volume or pressure flow dependence	0.02	% of fs / 10l/h	<1% range	Yes
atmospheric pressure dependence	0.8	% of fs/kPa	< 1.5 % range	Yes
ambient temperature dependence	0.01	% by volume /10K	<0.3% volume 10 K	Yes
Combined interference	0.14	% range	<2% range	Yes
Dependence on voltage	0.1	% by volume /10V	< 0.1%vol /10 volt	Yes
Losses in the line (leak)	0.10	% of value	< 2% of value	Yes
Uncertainty of calibration gas	2	% of value	< 2% of value	Yes

Performance characteristic	Uncertainty	Value of uncertainty quantity
Standard deviation of repeatability at zero	ur0	-
Standard deviation of repeatability at span level	urs	0.001
Lack of fit	ufit	0.075
Drift	u0dr	-0.724
volume or pressure flow dependence	uspres	0.001
atmospheric pressure dependence	uapres	0.115
ambient temperature dependence	utemp	0.003
Combined interference (from mcerts)	-	0.081
dependence on voltage	uvolt	0.029
losses in the line (leak)	uleak	0.005
Uncertainty of calibration gas	ucalib	0.109

Measurement uncertainty (Concentration Measured)	9.45	%vol
Combined uncertainty	0.75	%vol
% of value	7.94	%

<b>Expanded uncertainty expressed with a level of confidence of 95%</b>	<b>15.88</b>	<b>% of value</b>
---	--------------	-------------------

<b>Expanded uncertainty expressed with a level of confidence of 95%</b>	<b>1.50</b>	<b>% vol</b>
---	-------------	--------------

Developed for the STA by R Robinson, NPL

Standard deviation of repeatability at span level	urs	#DIV/0!
---	-----	---------

APPENDIX 4 - Summaries, Calculations, Raw Data and Charts

NOTE - The following data is provided for information only and falls outside ESG's scope of accreditation

COMBINED UNCOLLECTED SUMMARY							
Test	Sampling Times	>PM <sub>10</sub> Concentration		Probe Rinse Concentration		Combined Unweighed Concentration	
		Measured	LOD	Measured	LOD	Measured	LOD
		mg/m <sup>3</sup>	mg/m <sup>3</sup>	mg/m <sup>3</sup>	mg/m <sup>3</sup>	mg/m <sup>3</sup>	mg/m <sup>3</sup>
Run 1	13:00 - 19:00 19 March 2014	0.005	0.005	0.083	0.010	0.077	0.016
Run 2	09:00 - 15:00 20 March 2014	0.039	0.005	0.010	0.010	0.028	0.015
Run 3	15:46 - 18:46 20 March 2014	0.010	0.010	0.224	0.020	0.197	0.031
Run 4	08:45 - 11:45 21 March 2014	0.010	0.010	0.105	0.021	0.031	0.031

Reference conditions are 273K, 101.3kPa, dry gas 11% Oxygen.

Where the result is less than the LOD, the LOD is reported.

SAMPLES									
Test	>PM <sub>10</sub> Filter Number	Filter Start Weight	Filter End Weight	Mass Gained on Filter	Probe Rinse Number	Probe Rinse Start Weight	Probe Rinse End Weight	Mass Gained in Rinse	Combined Total Mass Gained
		g	g	g	g	g	g	g	g
Run 1	TQC1031	15.1463	15.1463	-0.00006	QC1016 / QC1022	150.0899	150.0907	0.00080	0.00074
Run 2	TQC1032	15.5892	15.5895	0.00038	QC1029 / QC1023	182.90620	182.90610	-0.00010	0.00028
Run 3	TQC1033	16.1137	16.1136	-0.00013	QC1030 / QC1024	159.87560	159.87670	0.00110	0.00097
Run 4	TQC1034	16.1753	16.0975	-0.07780	QC1040 / QC1036	182.70270	182.70320	0.00050	-0.07730
Blank 1					QC1015 / QC1021	194.78310	194.78380	0.00070	0.00070
Blank 2					QC1039 / QC1035	160.08180	160.08150	-0.00030	-0.00030
Blank 3					QC1041 / QC1037	184.48590	184.48600	0.00010	0.00010



Paul Gothe GmbH Wittener Str. 82 D-44789 Bochum

To our customers

Wittener Straße 82  
D-44789 Bochum

Phone.: ++49-234 33 51 80  
Fax:++49 234) 30 82 17  
<http://www.paulgothe.de>  
[service@paulgothe.de](mailto:service@paulgothe.de)  
VAT-No.: DE 813078723  
Trade Register Bochum: HRB-6891

Your ref

Your letter

Our ref

Date 14.03.2007

Calibration of the Johnas Impactor according to ISO 23210

#### 6.2 Separation curves and Section 6.3 Verification of the separation curves

The Johnas Impactor from Paul Gothe GmbH was developed before the ISO Guideline was evaluated and after the Germans and the Netherlands Authorities have enough experiences with our impactor. After that the European Delegation creates the ISO Guideline 23210. The section 6.3 is important and was influence by the Germans. They have the experiences and write the rules for the calibration section accordingly it was made for the Johnas-Impactor.

The development from the Johnas impactor starts with a doctoral thesis from Mrs. John at the Gerhard-Mercator-University. She makes the intensive testing and Mr. Geueke from the North Rhine Westphalia State Environment Agency makes additional verifications at the ESA (Emission Simulation Facility) at the Hessian Agency for the Environment and Geology (HLUG).

Most of the literatures and papers are in German, but all well-known:

1. Probenahme und chemische Analytik von Korngrößenfraktionierten Immissions- und Emissionsaerosolen. Von der Fakultät für Naturwissenschaften der Gerhard-Mercator-Universität – Gesamthochschule Duisburg zur Erlangung des akademischen Grades eines Dr. rer. nat. genehmigte Dissertation von ASTRID CHRISTIANE JOHN aus Lichtenfels.
2. Umweltforschungsplan des Bundesministers für Umwelt, Naturschutz und Reaktorsicherheit Luftreinhalte Forschungsbericht 298 44 280, Korngrößenverteilung (PM10 und PM2,5) von Staubemissionen relevanter stationärer Quellen (Teil II zu 297 44 853), von Dipl.-Ing. A. Dreiseidler, Ing. D. Straub, Prof. Dr.-Ing. G. Baumbach, Universität Stuttgart, Institut für Verfahrenstechnik und Dampfkesselwesen (IVD), Abteilung Reinhaltung der Luft (RdL), Institutsleiter: Prof. Dr.-Ing. K.R.G. Hein, IM AUFTRAG DES UMWELTBUNDESAMTES Juni 2001.
3. VDI 2066, part 10
4. Gefahrstoffe-Reinhaltung der Luft 59 (1999), Nr.11/12, S. 449-453

All this papers shows, that the design of the Johnas Impactor is a proved version for the determination of the PM 2.5 and PM 10. The shape of the separation curves is similar to those specified in ISO 7708:1995 and the separation efficiency at 10 µm and 2,5 µm is 50 % according to section 6.3 of the ISO 23210.

What you need more? There is no authority which has more competence as the listed authorities.

If you still in doubt, you maybe get in contact with Mr. Geueke (phone: ++49-201-7995-1263).

Paul Gothe GmbH

Westdeutsche Landesbank for Sparkasse Bochum  
IBAN DE 24 430500 01 000 120 9840 Swift: WELADED1BOC

Companion: Paul Gothe-Stiftung  
Management: Dr. T. Grodten and Th. Hinrichs



# PAUL GOTHE BOCHUM

Manufacturer of Emissions Control Technology  
SEIT 1924



Paul Gothe GmbH Wittener Str. 82 D-44789 Bochum

To our customers

Wittener Straße 82  
D-44789 Bochum

Phone.: ++49-234 33 51 80  
Fax:++49 234) 30 82 17  
<http://www.paulgothe.de>  
[service@paulgothe.de](mailto:service@paulgothe.de)  
VAT-No.: DE 813078723  
Trade Register Bochum: HRB-6891

Your ref

Your letter

Our ref

Date 14.03.2007

## Declaration of conformity


Herewith the company Paul Gothe GmbH in Bochum declare that the manufactured Cascade Impactor Johnas follows the guidelines from the North Rhine Westphalia State Environment Agency according the convention from 24 June 1999 and the PM 4 stage follows the convention of the Federal Environment Agency from 09. March 2005.

Our Cascade Impactor Johnas was developed in cooperation with the North Rhine Westphalia State Environment and the Gerhard-Mercator University Duisburg. This impactor was validated and after that 2004 adopted in the German Standard VDI 2066, part 10 and 2005 in ISO Standard 23210. All sizes of our manufactured impactors are according to these guidelines, individually checked according our strict quality management and named with a specific serial number. Only an impactor with this serial number is according to the Guideline VDI 2066, part 10 and ISO Standard 23210 and can use for the determination of PM 10 and PM 2.5.

Paul Gothe GmbH

Dr. Torsten Grodten

-manager-



**END OF REPORT**

# RICARDO-AEA

The Gemini Building  
Fermi Avenue  
Harwell  
Didcot  
Oxfordshire  
OX11 0QR  
United Kingdom

t: +44 (0)1235 753000

e: [enquiry@ricardo-aea.com](mailto:enquiry@ricardo-aea.com)

[www.ricardo-aea.com](http://www.ricardo-aea.com)