

Report

**QA/QC Data Ratification and
Intercalibration Report for the
Automatic Urban and Rural Network,
July – September 2004**

A report produced for the Department for
Environment, Food and Rural Affairs, Scottish
Executive, Welsh Assembly Government and the DoE
in Northern Ireland

AEAT/ENV/R/1878 Issue 1
January 2005

UNRESTRICTED

**QA/QC Data Ratification and
Intercalibration Report for the
Automatic Urban and Rural Network,
July - September 2004**

Jane Vallance-Plews
Brian Stacey

January 2005

UNRESTRICTED

| | |
|--|---|
| Title | QA/QC Data Ratification and Intercalibration Report for the Automatic Urban and Rural Network, July - September 2004 |
| Customer | Department for Environment, Food and Rural Affairs, Scottish Executive, Welsh Assembly Government and the DoE in Northern Ireland |
| Customer reference | |
| Confidentiality, copyright and reproduction | Unrestricted Copyright AEA Technology plc All rights reserved. Enquiries about copyright and reproduction should be addressed to the Commercial Manager, AEA Technology plc. |
| File reference | ENET 45077010 |
| Report number | AEAT/ENV/R/1878 Issue 1 |
| | |

Jane Vallance-Plews
 AEA Technology
 National Environmental Technology Centre
 Building 551
 Harwell
 Didcot
 Oxfordshire
 OX11 0QJ

Tel: 0870 1906587
 Fax: 0870 1906377

AEA Technology is the trading name of AEA Technology plc
 AEA Technology is certificated to BS EN ISO9001 2000

| | Name | Signature | Date |
|--------------------|-------------------------------------|------------------|-------------|
| Authors | Jane Vallance-Plews Brian Stacey | | |
| Reviewed by | Ken Stevenson | | |
| Approved by | Geoff Dollard | | |

PART A: DATA RATIFICATION, JULY – SEPTEMBER 2004

| | | |
|----------|---|-----------|
| 1 | INTRODUCTION | 2 |
| 1.1 | Recent Changes in the Network | 2 |
| 1.2 | Overview of Network Performance | 4 |
| 1.3 | Annual Site Operator’s Meeting | 5 |
| 1.4 | LSO Manual | 6 |
| 1.5 | AURN Hub Updates | 6 |
| 2 | GENERIC DATA QUALITY ISSUES | 7 |
| 2.1 | Progress on Monitoring Requirements of the EU Daughter Directives | 7 |
| 2.2 | PM ₁₀ Episodes | 7 |
| 2.3 | Data Capture for Critical Sites in Zones and Agglomerations | 8 |
| 2.4 | Gravimetric PM ₁₀ Data Ratification | 9 |
| 2.5 | NO ₂ Converter Efficiencies | 11 |
| 2.6 | NO _x Switching Valve Leaks | 12 |
| 2.7 | Ozone Outliers | 12 |
| 2.8 | TEOM k ₀ | 13 |
| 2.9 | Zero Response Truncation | 14 |
| 2.10 | Auto-Calibration Run-ons | 15 |
| 3 | SITE SPECIFIC ISSUES | 18 |
| 3.1 | Wolverhampton NO ₂ | 18 |
| 3.2 | Leeds Centre O ₃ | 18 |
| 3.3 | Manchester Town Hall CO | 19 |
| 3.4 | Southend-on-Sea CO | 20 |
| 3.5 | Aston Hill O ₃ | 21 |
| 3.6 | Glasgow Centre PM ₁₀ | 22 |
| 3.7 | Swansea PM ₁₀ | 23 |
| 4 | SITES WITH DATA CAPTURE BELOW 90% | 24 |
| 4.1 | Gravimetric PM ₁₀ Sites with Data Capture Below 90% | 35 |

5 RATIFIED DATA CAPTURE STATISTICS..... 36

PART B: INTERCALIBRATION RESULTS, JULY - SEPTEMBER 2004

6 INTRODUCTION..... 2

7 RESULTS SUMMARY 4

8 OXIDES OF NITROGEN..... 7

8.1 Intercalibration Outliers..... 7

8.2 Leaking switching valves..... 8

8.3 Converter Tests..... 9

9 CARBON MONOXIDE 10

10 SULPHUR DIOXIDE 11

10.1 Intercalibration Outliers..... 11

10.2 m-xylene tests..... 11

11 OZONE..... 13

12 PARTICULATE ANALYSERS 13

12.1 TEOM k_0 13

12.2 Analyser Flow Rates..... 13

12.3 Analyser Configuration Information..... 14

13 SITE CYLINDER CONCENTRATIONS 16

14 SITE INFORMATION 17

15 CEN..... 21

16 SAFETY 22

17 CERTIFICATION..... 23

18 SUMMARY..... 23

APPENDIX A1 List of recommended equipment for up-grading

APPENDIX A2 Critical Sites in the AURN

APPENDIX B1 Network Certificate of Calibration

PART A: Data Ratification July – September 2004

1 Introduction

This quarterly report covers the Quality Assurance and Control (QA/QC) activities undertaken by **netcen** to ratify automatic monitoring data from Defra and the Devolved Administrations' urban and rural air quality monitoring network (AURN) for the period July to September 2004. During this period there were 121 monitoring sites in the Network of which there are 85 urban sites, 22 rural sites and a further 14 sites in the London Air Quality Monitoring Network (LAQN) which are affiliated into the national network.

Included in this report are the results of QA/QC Unit's 6-monthly intercalibration and audit exercise which was carried out during July to September 2004. The report is therefore divided in to two parts as follows:

PART A: Data Ratification

- Section 1: Introduction including recent changes that have taken place in the network and a general overview of network performance.
- Section 2: Generic data quality issues and recommendations for improving or resolving these issues.
- Section 3: Site specific issues.
- Section 4: Reasons for data loss at sites where data capture falls below 90%.
- Section 5: Data capture statistics for July - September 2004 presented in tables.
- Appendix A1: Recommendations for replacing or up-grading equipment (compiled in conjunction with CMCUs).
- Appendix A2: List of critical sites in the AURN.

Part B: Summer 2004 Intercalibration

- Section 6: Introduction
- Sections 7–18: Results of the Summer 2004 intercalibration exercise
- Appendix B1: Network certificate of calibration

1.1 Recent Changes in the Network

This section gives an overview of the main changes that have recently taken place in the network, including site closures, relocations or the addition of any new sites to the network. A summary of changes in the AURN for the year to date is given in Table 1.1.

QA/QC Unit has been working closely with Casella Stanger and the Local Authorities regarding the following site relocations:

Wigan Leigh

The Wigan Leigh site was closed on 28th September 2004 due to the necessary redevelopment of the Police Station. The Defra and DA's funded instruments were relocated to an existing site at Deanery School and the site renamed "Wigan Centre". The site commissioning audit was carried out on 6th October 2004 and the new site commenced operation on 11th October 2004.

Birmingham East and Centre

The Birmingham East site closed on 4th August 2004 as the school was unable to renew the lease for the site. QA/QC Unit worked closely with Birmingham County Council to identify another suitable site. The new site at Birmingham Tyburn commenced operation on August 16th 2004. The Birmingham Centre site is also scheduled for relocation by the end of March 2005.

Cwmbran

The site at Cwmbran will be temporarily relocated prior to construction activity taking place at the school in January 2005. A suitable site close to the original site and in similar surroundings has been identified.

Blackpool

The site at Blackpool ceased operation on 10th November 2004 due to redevelopment in the area. The housing will be moved to a new location at Stanley school as soon as provision of the electricity supply is sorted out.

Middlesbrough

The site at Middlesbrough needs to be relocated due to redevelopment in the area around the school. Groundwork started in early December 2004, giving rise to elevated PM₁₀ concentrations. Another suitable site, 17 metres from the existing location, has been identified and plans to move the monitoring cabin are in place.

DD3 Requirements

Installation of additional ozone and rural NO_x analysers at existing sites in the network in order to comply with the Third Daughter Directive (DD3) is now complete. The final NO_x analyser was installed at Eskdalemuir on 13th October 2004. There was some initial delay whilst operational problems were resolved and monitoring finally commenced on 9th December 2004.

Brighton Preston Park

A new DD3 (NO_x and O₃) site at Brighton Preston Park commenced monitoring on November 3rd 2004.

Sunderland Silksworth

A new Local Authority site at Sunderland Silksworth measuring NO_x and O₃ (for DD3) was affiliated into the network on 9th December 2004.

Plans are also underway to add a further two new DD3 sites at Fort William and Leominster. Progress on the installation of the new sites is discussed in more detail in Section 2.1

Table 1.1 Changes to the AURN between January to December 2004

| Sites | Date Commenced | Pollutants |
|---|--|---|
| New sites | | |
| London Harlington | 1/01/04 | NO ₂ CO O ₃ PM ₁₀ |
| Brighton Preston Park | 3/11/04 | NO ₂ and O ₃ |
| Sunderland Silksworth | 9/12/04 | NO ₂ and O ₃ |
| Site Relocations | | |
| Scunthorpe relocated to Scunthorpe Town | Scunthorpe closed 18/3/04 Scunthorpe Town started 6 th June 2004 | SO ₂ PM ₁₀ |
| Wigan Leigh relocated to | Wigan Leigh closed on 28 th | NO _x O ₃ CO SO ₂ and |

| Sites | Date Commenced | Pollutants |
|---|--|--|
| Wigan Centre | September 2004. Wigan Centre started on 13 th October 2004 | PM ₁₀ |
| Birmingham East relocated to Birmingham Tyburn | Birmingham East closed on 4 th August 2004. Relocated to Birmingham Tyburn starting on August 16 th 2004 | NO _x O ₃ CO SO ₂ and PM ₁₀ |
| Additional O₃ and/or NO_x (DD3) | | |
| Glazebury | NO _x analyser commissioned on 26 th January 2004 | NO _x |
| Eskdalemuir | NO _x analyser commissioned on 9 th December 2004. | NO _x |

1.2 Overview of Network Performance

Ratified hourly average data capture for the network averaged 94% for all pollutants (O₃, NO₂, SO₂, CO, PM₁₀ and PM_{2.5}) during the 3-month reporting period July to September 2004 (see Table 1.2 below). This has been another very good quarter with average data capture for all the pollutants being above the 90% target level.

Table 1.2 AURN Ratified Data Capture (%) April to June 2004
(Using the start date of any new site)

| Data Capture (%) | CO | NO ₂ | O ₃ | PM ₁₀ | PM _{2.5} | SO ₂ | Network Average |
|----------------------|------|-----------------|----------------|------------------|-------------------|-----------------|-----------------|
| Q1 Jan - March 2004 | 92.0 | 90.3 | 93.1 | 91.1 | 97.9 | 91.7 | 92 |
| Q2 April – June 2004 | 93.2 | 93.6 | 96.2 | 94.7 | 98.1 | 93.1 | 94 |
| Q3 July – Sept 2004 | 93.9 | 91.8 | 94.4 | 93.7 | 95.0 | 93.3 | 94 |

Overall, 351 out of the 420 analysers (84%) achieved data capture levels above the required 90% target during this reporting period (See Table 1.3). This demonstrates that the high level of network performance has been consistently maintained, even during this quarter when more disruption was expected due to the 6-monthly network intercalibration and service exercise. Only a relatively small proportion of analysers (15-20%) failed to meet the 90% data capture target, which is reasonable in a network of this size and complexity.

Table 1.3 Number of Analysers with Data Capture below 90%

| | Total Number of Analysers | Analysers with Data Capture <90% in 2004 | | |
|-------------------|---------------------------|--|---------------|--------------|
| | | Q1 Jan–March | Q2 Apr – June | Q3 July-Sept |
| CO | 79 | 16 (20%) | 13 (16%) | 12 (15%) |
| NO ₂ | 106 | 26 (25%) | 18 (17%) | 24 (23%) |
| O ₃ | 84 | 14 (16%) | 10 (12%) | 11 (13%) |
| PM ₁₀ | 71 | 12 (17%) | 11 (16%) | 10 (14%) |
| PM _{2.5} | 4 | 0 | 0 | 0 |
| SO ₂ | 76 | 16 (21%) | 15 (19%) | 12 (16%) |
| All sites | 420 | 84 (20%) | 67 (16%) | 69 (16%) |

A more detailed breakdown of the hourly data capture statistics for each site is presented in Section 5, Table 5.1 (July – September 2004) and Table 5.2 (January- September 2004). In total, 21 out of the 122 network sites (17%) had an average data capture rate below the required 90% level for the July – September 2004 period. These sites are listed in Table 1.4. The main site operational and QA/QC issues giving rise to data capture below the required 90% level are summarised in Section 4.

Table 1.4 Sites with Average Data Capture < 90%, July -September 2004
(Data capture calculated from site start date)

| Site | Owner | Site Average Data Capture (%) |
|------------------------------------|-----------|-------------------------------|
| England | | |
| Brighton Roadside PM ₁₀ | Affiliate | 83.7 |
| Bristol Old Market | Affiliate | 89.8 |
| Cambridge Roadside | Affiliate | 89.0 |
| High Muffles | Defra | 76.5 |
| Ladybower | Defra | 78.4 |
| Leeds Centre | Defra | 82.2 |
| London Hackney | Affiliate | 87.2 |
| London Westminster | Defra | 84.4 |
| Lullington Heath | Defra | 88.5 |
| Manchester South | Affiliate | 82.5 |
| Manchester Town Hall | Defra | 76.0 |
| Middlesbrough | Affiliate | 78.6 |
| Northampton | Affiliate | 69.3 |
| Northampton PM ₁₀ | Affiliate | 88.0 |
| Rotherham Centre | Affiliate | 86.3 |
| Southend-on-Sea | Defra | 88.2 |
| Stockport Shaw Heath | Affiliate | 43.8 |
| Scotland | | |
| Glasgow Centre | Defra | 79.5 |
| Strath Vaich | Defra | 80.5 |
| Wales | | |
| Aston Hill | Defra | 82.4 |
| Swansea | Affiliate | 77.5 |
| Number of sites < 90% | | 21 |

Netcen carried out the summer intercalibration and site operator audits during July - September 2004. Results from this intercalibration exercise have been used to assess the accuracy and consistency of the data for this reporting period. Details of the Summer 2004 intercalibration are provided in Part B (Sections 6-18) of this report.

1.3 Annual Site Operator's Meeting

The Local Site Operator's annual meeting was held at Birmingham NEC on December 1st 2004. QA/QC Unit gave presentations on recent data ratification and intercalibration issues as well as the role of AURN data in UK modelling assessment. All presentations given at the meeting have been made available on the AURN Hub.

1.4 LSO Manual

Copies of the Local Site Operator's manual on disc (CD) were distributed to the network participants at the annual LSO meeting in December 2004. If LSOs have not received a copy or further copies are required please contact Jane.vallance-plews@aeat.co.uk. The manual is also available electronically on the following web sites:

AURN Hub <http://www.aeat.co.uk/com/AURNHUB/Isoman.html>

Air Quality Archive <http://www.aeat.co.uk/netcen/airqual/reports/Isoman/Isoman.html>

1.5 AURN Hub Updates

The AURN project information hub web is located at¹:

<http://www.aeat.co.uk/com/AURNHUB/index.html>.

The site is regularly up-dated and some of the more recent information includes:

- Up-dated site lists (December 2004)
- Monthly PM₁₀ (Gravimetric) exceedences for December 2004
- QA/QC Unit's Winter 2005 intercalibration and audit schedule
- Equipment Support Units' Winter 2005 service schedules
- QA/QC Unit's data ratification report, April - June 2004
- Recent Management Unit reports (April – June 2004)
- All presentations given at the AURN Site Operator's meeting on Dec 1st 2004
- Edition 8 of the Network Newsletter (issued December 2004)
- Change of address details for QA/QC Unit (Netcen)*

*Please note, as of 1st November 2004, QA/QC Unit (Netcen) has moved to Harwell at the following address:

netcen
Building 551
Harwell
Didcot
Oxfordshire
OX11 0QJ

All phone and fax numbers remain unchanged.

¹ Password protected site: username and password available from Jane.vallance-plews@aeat.co.uk

2 Generic Data Quality Issues

2.1 Progress on Monitoring Requirements of the EU Daughter Directives

Installation of all of the additional NO_x and O₃ analysers required to comply with the Third Daughter Directive has now been completed. The final NO_x analyser was installed at Eskdalemuir on 13th October 2004 and, after further attention to the NO_x analyser, monitoring commenced on 9th December 2004. Further details on the third Daughter Directive can be found at:

<http://www.defra.gov.uk/environment/consult/air-23daughter/index.htm>

In order to satisfy the requirements of DD3, progress is also being made to commission 3 new direct-funded NO_x and O₃ sites and affiliate one Local Authority owned site, at the following locations:

- Brighton Preston Park (Brighton/Worthing/Littlehampton agglomeration)
- Sunderland Silkworth (North East zone) – Sunderland City Council
- Fort William (Highland zone)
- Leominster (Midlands zone).

Two of the four sites are now operational (Brighton Preston Park and Sunderland Silkworth) and progress on the establishment of the remaining sites is given in Table 2.1.

Table 2.1 New DD3 Monitoring Stations, October 2004

| New Site | Pollutants | Progress to date | Expected integration date |
|-----------------------|------------------------------------|--|---------------------------|
| Brighton Preston Park | O ₃ and NO _x | The site commenced operation on November 3 rd 2004. | Completed |
| Sunderland Silkworth | O ₃ and NO _x | Following installation of a new O ₃ analyser, the site was affiliated on 9 th December 2004. | Completed |
| Fort William | O ₃ and NO _x | Planning consent and lease agreement now completed. Site installation underway. | End April 2005 |
| Leominster | O ₃ and NO _x | Planning consent and lease agreement granted. Site installation going ahead. | End March 2005 |

2.2 PM₁₀ Episodes

During December 2004 there were a few periods of poor dispersion which resulted in increased PM₁₀ concentrations from December 1st to 3rd, 7th to 13th and 19th to 21st. A higher number of monitoring stations therefore recorded exceedences in December 2004 than in the previous months. However, overall there have been far fewer exceedences of the daily mean gravimetric PM₁₀ standard recorded this year compared to the same time last year. The sites that have recorded the highest number of days with exceedences of 50µg/m³ during 2004 (January to the end of December 2004) based on **provisional data** are given below:

95 days - London Marylebone Road (Kerbside) – above objective
 40 days - Camden Kerbside (Kerbside) – above objective
 38 days - Port Talbot (Industry) – above objective
 35 days - Glasgow Kerbside (Kerbside)
 30 days - Bury Roadside (Roadside)
 26 days – Scunthorpe (Industrial)

Three of the above sites have exceeded the Air Quality Objective of 35 days > 50µg/m³, to be achieved by 31/12/2004 based on the **provisional** 2004 monitoring results.

Further information on the extent and duration of the episodes and monthly PM₁₀ exceedence statistics are presented on the Air Quality Archive and AURN hub at <http://www.aeat.co.uk/com/AURNHUB/aunhubPUBLIC-399.htm>.

2.3 Data Capture for Critical Sites in Zones and Agglomerations

In order to meet the requirements of the Daughter Directives, any zone or agglomeration² with an exceedence of the limit value must be formally reported to the Commission. The critical sites are those which, if data capture falls below 90%, there will be insufficient data for the whole zone or agglomeration. In most cases the critical sites are those where there is only one site in the zone or agglomeration. However, for some pollutants (especially ozone) monitoring is required at several sites in each zone or agglomeration and hence these may all need to be classified as critical sites for that pollutant. The list of the critical sites in the Network has been revised to reflect the requirements of the First, Second and Third Daughter Directives (see Appendix A2). In total 61 sites have been identified as critical for DD1, DD2 or DD3 (25 sites in agglomerations and 36 in zones).

Critical sites with less than 90% data capture during the 9-month period January to September 2004 are given in Section 5, Table 5.3. Reasons for data loss at these sites are given in Section 4. In total 46 out of the 185 critical site analysers (25%) did not meet the required 90% data capture during the first 9 months of 2004. Note in this period, Scunthorpe was relocated to Scunthorpe Town so both sites now appear in Table 5.3. Any critical site analyser with less than 86.5% data capture during this first 9-month period will not achieve the 90% data capture target for the year. The 27 site analysers that fall into this category are as follows:

- Leicester Centre CO
- Newcastle Centre CO
- Southend on Sea CO
- Grangemouth CO
- Leamington Spa CO

- Glasgow Centre NO₂
- Hull Freetown NO₂
- Leicester Centre NO₂
- Newcastle Centre NO₂
- Aston Hill NO₂
- Glazebury NO₂
- High Muffles NO₂
- Northampton NO₂
- Wicken Fen NO₂

² A definition of zones and agglomerations can be found under "Article 5 Assessment Zones and Agglomerations Monitoring Maps" at <http://www.defra.gov.uk/environment/airquality/index.htm>

- Reading New Town O₃
- Lough Navar O₃
- Northampton O₃

- Stoke-on-Trent PM₁₀
- Scunthorpe/Scunthorpe Town PM₁₀
- Wrexham PM₁₀

- Blackpool SO₂
- Hull Freetown SO₂
- Newcastle Centre SO₂
- Northampton SO₂
- Scunthorpe/Scunthorpe Town SO₂
- Wigan Leigh SO₂
- Wrexham SO₂

Recommendation

Every effort should be made to ensure that data capture is maximised for the critical sites. LSOs and ESUs should undertake call-outs and repair as soon as possible to avoid unnecessary data loss at these sites

2.4 Gravimetric PM₁₀ Data Ratification

Gravimetric PM₁₀ analysers (Partisols) are located at seven sites in the network (Bournemouth, Northampton, Wrexham, Dumfries, Inverness, London Westminster and Brighton Roadside PM₁₀). The gravimetric PM₁₀ analyser at Northampton is also co-located with a TEOM analyser which provides a useful check that both techniques are operating correctly. Gravimetric PM₁₀ concentrations and the daily mean TEOM scaled by 1.3 at Northampton for the 9-month period January-September 2004 are shown in Figure 2.1. In general, the agreement between the analysers is good, although a problem with the site telemetry resulted in an extended period of TEOM data loss during September.




Figure 2.1 Partisol and TEOM (x1.3) Concentrations at Northampton (Jan-June 2004)

Data capture for the gravimetric PM₁₀ (Partisol) analysers for the period July - September 2004 and for the 9-month period January - September 2004 is given in Table 2.2. Three out of the seven operational gravimetric PM₁₀ analysers did not meet the required 90% data capture target for the July-September reporting period. Details of data loss associated with these three sites (Bournemouth, Brighton Roadside and Northampton) are given in Section 4.1. Some data were lost in this period (10 days from Bournemouth, 14 days from Brighton and 1 day from Dumfries) due to a breakdown in the laboratory analysis procedure that occurred when the initial weights were recorded.

Table 2.2 Gravimetric PM₁₀ Data Capture (%) January - September 2004
(Calculated from site start date)

| Site | Data Capture (%) July - Sept 2004 | 9-months Data Capture (%) January - Sept 2004 |
|------------------------------------|--------------------------------------|--|
| Bournemouth | 85.9 | 92.7 |
| Brighton Roadside PM ₁₀ | 83.7 | 91.6 |
| London Westminster | 97.8 | 93.8 |
| Northampton | 88 | 79.6 |
| Dumfries | 98.9 | 89.1 |
| Inverness | 97.8 | 93.8 |
| Wrexham | 98.9 | 92 |
| Average | 93 | 90.4 |

Six out of the seven Partisol sites have now been connected to telemetry. This allows the exposure data and filter numbers to be downloaded automatically and regular checks on the operational status of the analyser can be carried out remotely. The one remaining

Partisol unit at Bournemouth still needs to be connected via a separate mobile phone system, as the existing line is not compatible with the Partisol software.

2.5 NO₂ Converter Efficiencies

Eight converter failures were identified during QA/QC Unit's Summer 2004 intercalibration exercise. This was an improvement from the previous audit when 15 converter faults were reported. Of the eight converter faults identified, three were considered to be borderline cases and there was no resulting effect on data quality or capture. A summary of all the converter faults and the resulting effect on data quality is given in Table 2.3 below. See also Section 8.3 in Part B of this report.

Table 2.3 Converter faults identified at the Summer 2004 Intercalibration Exercise (July-Sept 2004)

| Site | Audit date | Converter Efficiency | Resulting Effect on Data Quality |
|------------------------|------------|----------------------|---|
| Glasgow Kerbside | 19/7 | 90.9% | 1-minute NO ₂ span calibration data were obtained which showed no history of a declining NO ₂ span response. Data were therefore only deleted between the audit on 19 th July to the service on 28 th July when the converter was replaced. (9 days) |
| Manchester South | 24/8 | 91.9% | Repeat offender (93% at previous audit). Data were deleted from the last stable calibration on 27 th July until repair of converter at the service on 2/9/04. (5 weeks) |
| Middlesbrough | 14/9 | 72% | Calibration data from mid May showed a slight divergence in NO ₂ calibration response compared to the NO response, indicating the likely start of the converter fault. Data were therefore deleted from 18 th May until the service on 14 th September 2004. (4 months). |
| Oxford Centre | 7/7 | 89.6% | Data were rejected from the first unstable NO ₂ calibration on 2 nd June until the converter was replaced at the service on 13 th July 2004. (6 weeks) |
| Walsall Alumwell | 22/9 | 86% | The poor converter result was due to water ingress. The sample inlet funnel was not attached and water had entered the sampling system. Data from 23 rd September to the service on 27 th September have been deleted (5 days). The converter was replaced at the service. |
| BORDERLINE FAIL | | | |
| Dumfries | 12/7 | 94.8% | Repeat offender (94.6% at previous audit) Borderline case – no data loss |
| London A3 Roadside | 8/7 | 94.8% | Borderline case - no data loss Converter replaced at service. |
| Yarner Wood | 4/8 | 94.9 | Borderline case - no data loss |

Two sites (Manchester South and Dumfries) were identified as “repeat offenders” because the converters had also failed at the previous 6-month audit. Extra care should be taken

at these sites in order to determine the cause of the repeated converter failures and/or to ensure the converters are replaced.

Recommendations

The ESUs should have already replaced or repaired the faulty converters listed in Table 2.3 during the Summer 2004 service exercise in order to ensure satisfactory performance of the analysers.

It is recommended the ESUs undertake an additional 3-month converter test at Manchester South and Dumfries where the analysers have failed 2 consecutive audits.

The LSOs should continue to pay careful attention to the short-term stability of the NO₂ calibration response and notify CMCU if a declining NO₂ span is recorded during the calibration. (See trouble-shooting section of the LSO manual for further details).

QA/QC Unit has been taking measures to ensure procedures used in the AURN will comply with any CEN requirements before they become mandatory. These requirements are discussed further in Part B, Section 15 of this report. One of the CEN requirements is to ensure that the NO_x converter efficiency is better than 98%. NO₂ data will have to be rescaled for converter efficiencies between 95-98%, but rejected if below 95%. These are tougher requirements than currently used where "borderline failures" are accepted. It is, therefore, especially important that the borderline cases also get adequate attention at the service in order to ensure they are set up to operate satisfactorily for the next 6-month period.

Recommendation

We recommend that all NO_x analysers should be set up after service with converters operating at 98% or above.

2.6 NO_x Switching Valve Leaks

QA/QC Unit now routinely reports potential problems with NO_x switching valve leaks as part of the 6-monthly intercalibration checks. If a significant leak in the NO_x /NO channel switching valve is present it may lead to NO₂ concentrations being under reported. Results of the checks carried out during the summer intercalibration are discussed in Part B, Section 8.2. The Equipment Support Units are notified of any sites with potential switching valve leak problems and it is recommended that the valves are cleaned and checked during each service.

2.7 Ozone Outliers

22 out of 84 ozone analysers (26%) were identified as outliers during QA/QC Unit's Summer 2004 intercalibration exercise (See Table 2.5). This is consistent the previous Winter intercalibration where again 26% of the analysers tested were identified as outliers. Where appropriate, the data from these sites have been rescaled accordingly during the ratification process.

Table 2.5 Ozone outliers identified at the summer 2004 intercalibration

| | Site | Summer 2004 Outlier |
|----|-----------------------|---------------------|
| 1 | Aberdeen | +6% |
| 2 | Barnsley Gawber | -15% |
| 3 | Birmingham East | +6% |
| 4 | Blackpool | -6% |
| 5 | Bristol Centre | -16% |
| 6 | Cwmbran | -10% |
| 7 | Derry | -16% |
| 8 | Exeter Roadside | -12% |
| 9 | Glazebury | +8% |
| 10 | Hull Freetown | +8% |
| 11 | Ladybower | +13% |
| 12 | Leeds Centre | -8% |
| 13 | London Haringey | -12% |
| 14 | London Harlington | +7% |
| 15 | London Teddington | -8% |
| 16 | Lough Navar | +10% |
| 17 | Manchester Piccadilly | -8% |
| 18 | Plymouth Centre | -14% |
| 19 | Reading New Town | -9% |
| 20 | Redcar | +11% |
| 21 | Salford Eccles | -8% |
| 22 | Stoke-on-Trent | -9% |
| 23 | Yarner Wood | +15% |

2.8 TEOM k_0

Two of the TEOM instruments tested during the Summer 2004 intercalibration were found to be operating with a calibration constant (k_0) outside the acceptable $\pm 2.5\%$ deviation. These were at Sheffield Centre and Wigan Leigh. Data from the analyser at Sheffield Centre have been rescaled. However, no data rescaling was required at Wigan Leigh as the k_0 value stored in the control unit agreed with the calculated k_0 at the audit. The results from this instrument were therefore being correctly reported.

In addition a further three TEOM analysers were found to have a k_0 mis-match, where the value of the calibration constant stamped on the sensor unit was found to be different from the value stored in the control unit. (See Table 2.6). At 2 of the sites the difference was small and within the acceptable $\pm 2.5\%$ limit so no data rescaling was necessary. At London A3 Roadside, however, the difference was much larger resulting in ambient data being rescaled by 10%.

Four TEOM analysers were also found to be operating outside of the expected flow rates during the audits. (See Section 12.2 in Part B of this report). Major flow leaks at Glasgow Centre and Swansea resulted in significant data loss during this period. (See Sections 3.6 and 3.7)

As part of the summer intercalibration exercise, QA/QC Unit compiled additional information on the operational configuration of PM₁₀ analysers in the network. Full details are given in Section 12.3 in Part B of this report.

Table 2.6 TEOM k₀ issues identified at the Summer 2004 Intercalibration

| Site | Problems identified at audit | Effect on data quality |
|--------------------|--|--|
| Sheffield Centre | k ₀ outlier (-2.9%) at audit on 9/8/04. This was consistent with the previous Winter audit result (-3.1%). | Data from 1/1/04 have been rescaled by 3%. |
| Wigan Leigh | k ₀ outlier (+10%). The k ₀ value stamped on sensor unit was low by 10%. However, the measured k ₀ determined at audit agreed with the control unit so no data rescaling was necessary. | No data rescaling required. Note: this site has recently been relocated to Wigan Centre. The k ₀ mis-match will still need to be fixed. |
| Portsmouth | k ₀ values were found to be different on sensor unit and in the control unit software at the summer audit on 14/7/04. This agreed with findings at the previous 6-month audit on 16/1/03. | The difference was 1% so within acceptable limit and no data rescaling was necessary. ESU needs to set control unit to agree with sensor. |
| Thurrock | k ₀ values were found to be different on sensor unit and in the control unit software at the summer audit. | The difference was 1.7% so within acceptable limit and no data rescaling was necessary. ESU needs to set the control unit to agree with sensor. |
| London A3 Roadside | k ₀ on sensor and control unit different by 10% at summer audit on 8/7/04. | Data rescaled from when the replacement TEOM was installed on 21 st April until the ESU visit on 23 rd July 2004 to exchange the TEOM. |

Recommendations

The ESUs need to confirm that the necessary changes have been made to re-certify the TEOM k₀ at Sheffield Centre and set the control unit k₀ to agree with the sensor unit at Portsmouth and Thurrock. At Wigan Leigh (now relocated to Wigan Centre) the k₀ value stamped on sensor unit needs to be changed to agree with the value stored in the control unit.

2.9 Zero Response Truncation

There were a few sites where significant periods of data were lost due to zero truncation (or baseline clipping). This occurs when the analyser response drifts downwards until it falls below the minimum response threshold resulting in extended period of 0mV response. This problem can occur if the analyser is not configured to output negative voltages or if the logger cannot record a response below a certain voltage threshold. Cases of zero response truncation were seen at the following sites during this period:

- Leamington Spa CO 25th June- 11 July 2004 (16 days data loss)
- London Westminster SO₂ June/July 2004 – no data loss as levels were very low
- Bristol Old Market CO 27 July – 13th August 2004 (17 days data loss). A new CO analyser has now been installed at this site.

Recommendation

We recommend that, wherever possible, all analysers are routinely set up after the service with zero baseline offsets of 20-50mV. Special attention should be given to the sites mentioned above in order to ensure the baseline response does not drift downwards over time, resulting in further periods of truncation and data loss.

2.10 Auto-Calibration Run-ons

Autocalibration "run-on" is a generic problem affecting many analysers in the network and is due to autocalibration gas leaking into the sampling system during the ambient measurement period immediately after the autocalibration cycle. Invalid measurements (usually between 01:30 and 02:00) have been removed during data ratification. This can be a serious source of data loss resulting in one hour out of twenty four being deleted, which is 4% of the annual data capture. At some sites significantly more data are being lost resulting in data capture below the 90% data capture target for the period.

The problem can be identified by examining the diurnal variation of NO₂ concentrations for the individual sites. An example of a site where there is **no** autocalibration run on problem is shown in Figure 2.2. In contrast, a large NO₂ autocalibration run-on seen at High Muffles (resulting in 11 hours data loss per day) is shown in Figure 2.3.

The ESUs have investigated the autocalibration run-ons at many of the sites and tried different ways to resolve the problem including thorough cleaning of the solenoid valves and installation of permature driers. In most cases this has improved the situation but it has not always eliminated the problem completely. The 37 sites showing continuing problems with the autocalibration run-on during July to September 2004 are given in Table 2.7. Any autocalibration run-on data that look visibly significant have been deleted from these data sets during ratification.

Table 2.7 Estimate of Spike or Dip due to Auto-calibration Run-on (15-minute average) July - September 2004

| Site | Pollutant | Run-on (ppb) | Data loss (Hours per day) | Autocal span concentration (ppb) |
|-----------------------------|-----------------|--------------|---------------------------|----------------------------------|
| Aberdeen | NO ₂ | 5 | 1 | 200 |
| Belfast Centre | NO ₂ | 7 | 1 | 300 |
| Birmingham Centre | NO ₂ | 9 | 1 | 750 |
| Blackpool | NO ₂ | 4 | 1 | 400 |
| Bournemouth | NO ₂ | 5 | 1 | 100 |
| Bury Roadside | NO ₂ | 12 | 1 | 700 |
| Bush Estate | NO ₂ | 2.4 | 1 | 240 |
| Derry | NO ₂ | 3 | 1 | 300 |
| Dumfries | NO ₂ | 7 | 1 | 700 |
| Glazebury | NO ₂ | 3.3 | 1 | 380 |
| High Muffles | NO ₂ | 8 | 11 | 500 |
| Leamington Spa | NO ₂ | 11 | 1 | 1700 |
| London A3 Roadside | NO ₂ | 7 | 1 | 500 |
| Lullington Heath | NO ₂ | 2.4 | 1 | 300 |
| Manchester Town Hall | NO ₂ | 4 | 1 | 450 |
| Market Harborough | NO ₂ | 3.2 | 2 | 350 |

| Site | Pollutant | Run-on (ppb) | Data loss (Hours per day) | Autocal span concentration (ppb) |
|-------------------------|-----------------|--------------|---------------------------|----------------------------------|
| Narberth | NO ₂ | 1.9 | 3 | 150 |
| Newcastle Centre | NO ₂ | 6 | 1 | 300 |
| Norwich Centre | NO ₂ | 3 | 1 | 350 |
| Oxford Centre | NO ₂ | 7 | 1 | 250 |
| Preston | NO ₂ | 5 | 1 | 500 |
| Reading New Town | NO ₂ | 5 | 1 | 250 |
| Rochester | NO ₂ | 3.6 | 1 | 200 |
| Somerton | NO ₂ | 4.1 | 3 | 45 |
| Southend-on-Sea | NO ₂ | 3 | 2 | 200 |
| St Osyth | NO ₂ | 1.9 | 1 | 300 |
| Stoke-on-Trent Centre | NO ₂ | 4 | 1 | 335 |
| Thurrock | NO ₂ | 4 | 1 | 400 |
| Wirral Tranmere | NO ₂ | 4 | 1 | 300 |
| Wrexham | NO ₂ | 3 | 1 | 350 |
| London Brent | SO ₂ | 1 | 1 | 900 |
| London Marylebone Rd | SO ₂ | 0.5 | 1 | 375 |
| Narberth | SO ₂ | 0.3 | 1 | 500 |
| Plymouth Centre | SO ₂ | 0.1 | 1 | 800 |
| Stoke-on-Trent | SO ₂ | 1 | 2 | 650 |
| Wigan Leigh | SO ₂ | 1 | 1 | - |
| Leeds Centre | CO | 0.2 ppm | 1 | 35 ppm |

Recommendations

ESU to investigate and minimise effect where possible, especially at sites with large autocalibration run-ons or where data loss is in excess of 1 hour. These sites are shown in **bold** in Table 2.7.

QA/QC Unit and CMCU are currently arranging meetings with the Equipment Support Units to discuss the autocalibration run-ons and to identify ways to resolve the problem.

In the meantime, we recommend that the autocalibration devices be adjusted at the problem sites to reduce the concentration of the span gas. It is strongly advised that NO₂ autocalibration span concentrations of less than 200ppb (urban sites) and 100ppb (rural sites) are used throughout the network.

At High Muffles where the autocalibration run-on is causing up to 50% data loss at a critical site, we recommend that the autocalibration span is switched off and with just the autocalibration zeros being recorded for data validation purposes, until a satisfactory solution can be found.




Figure 2.2 Example of site with no autocalibration run-on problem




Figure 2.3 Auto calibration run-on seen at High Muffles, October 2004

3 Site Specific Issues

3.1 Wolverhampton NO₂

A spurious drop in ambient NO₂ concentration following the service in September was identified during CMCU's routine data checking. The Equipment Support Unit was called out and found that the analyser had not been connected to the sampling manifold. Following this call-out however, ambient concentrations continued to be lower than expected compared to nearby sites, and further investigation by the ESU in October identified a blockage in the NO_x sampling system. After the blockage was cleared and the reaction chamber cleaned, ambient levels returned to normal (see Figure 3.1). All data from the service on 13th September until repair on 8th October have been deleted during ratification (3 weeks).




Figure 3.1 Wolverhampton NO_x sampling faults, September-October 2004

3.2 Leeds Centre O₃

Three unrelated O₃ sampling faults occurred at Leeds Centre resulting in 6 weeks data loss during July and August. Spurious low ozone levels were recorded immediately after an ESU visit on 22nd July. A faulty scrubber in the ozone analyser was identified and, when replaced, the ambient levels returned to normal. However, shortly after this unusually high ozone levels were recorded. Investigation by QA/QC Unit at the audit on 16th August identified a leak in the ozone sampling system. This problem also coincided

with elevated ozone levels inside the hut arising from a leak in the charcoal scrubber on the exhaust vent of the NO_x analyser. The combination of the analyser sampling leak and high ozone concentrations inside the hut resulted in artificially high ozone levels being recorded. A pump failure resulted in a further period of poor quality data at the end of August. (See Figure 3.2). The pump was repaired at the 6-monthly service on 2nd September. All spurious ozone data from 22nd July until repair of the pump at the service on 2nd September have been deleted during ratification. (Critical site)

Recommendation

LSOs should be aware that high ozone concentrations venting from the exhaust of a NO_x analyser might affect ambient ozone levels being record. If there is an unusually strong smell of ozone inside the hut, CMCU should be notified immediately.




Figure 3.2 Leeds Centre O₃ sampling faults, July – August 2004

3.3 Manchester Town Hall CO

A 2-month period of erratic response and high noise CO data was recorded at Manchester Town Hall from 7th June until 3rd August 2004 (See Figure 3.3). A fault with the infra-red source was rectified on 13th July, but further problems persisted. A sample flow fault and blockage in the 3-way solenoid valve was cleared on 3rd August and satisfactory monitoring was resumed.




Figure 3.3 Manchester Town Hall CO analyser unstable response

3.4 Southend-on-Sea CO

The CO analyser at Southend-on-Sea has shown a history of response instability problems over the last 6-months. (See Figure 3.4) Four months of unacceptable high noise data from February to May 2004 have already been deleted, as reported in the January-March 2004 data ratification report. Repairs to the infra-red lamp and pump were carried out on 19th May however, although the response improved for a few weeks, further problems with negative response spikes and high noise were recorded again in June and July. The analyser was removed for repair and a replacement box installed on 29th July. In view of the long-term response problems, data deletion has been continued resulting in a total of 5.5 months data loss from 10th February until 29th July 2004. (Critical site)




Figure 3.4 Southend-on-Sea CO high noise and negative response, Feb- July 2004

3.5 Aston Hill O₃

Over the 2-month period August-September, the ozone analyser at Aston Hill was replaced six times due to a number of operational faults which are summarised below:

- 12th August: Original O₃ analyser re-installed at service (1)
- 15th August: Analyser fault and response instability
- 19th August: Replacement analyser installed (2)
- 31st August: IZS temperature fault. Analyser replaced (3)
- 7th Sept : Analyser failure. Removed to workshop for repair
- 10th Sept Repaired analyser reinstalled (4) but IZS fault persisted
- 15th Sept Replacement analyser installed (5) but damaged in transit so removed again.
- 20th Sept Replacement analyser installed (6)

This analyser is one of the relatively new instruments that were purchased as part of the recent major equipment up-grading exercise. Although the cost of repairs will have been carried out under warranty, the high number of recurring faults also has a direct impact on the time taken to ratify the data. All periods of unstable response data shown in Figure 3.5 have been deleted resulting in a total of 3 weeks data loss. (Critical site)




Figure 3.5 Astons Hill O₃ recurring response instability problem

3.6 Glasgow Centre PM₁₀

Over 3.5 months of PM₁₀ data have been rejected from Glasgow Centre during ratification due to periods of high noise and negative response (See Figure 3.6). In addition a major sampling leak (total flow 73% low) was identified at the audit in July 2004. All data from April 20th April until 13th August when the TEOM was replaced have been rejected. (Critical site)




Figure 3.6 Glasgow Centre PM₁₀ high noise and flow leak, April – August 2004

3.7 Swansea PM₁₀

Major leaks in the TEOM analyser at Swansea have been identified at the last two successive QA/QC audits on the 16th March 2004 (main flow 60% low) and on the 20th September 2004 (main flow 45% low). The first leak was due to a cracked plastic fitting at the mass flow controller. The second leak was due to a cracked disposable filter unit (DFU). Due to the magnitude of the leaks and resulting effect on sampling efficiency, all poor quality data from January 2004 until repair of the second leak at the service on 4th October 2004 (9 months) have been deleted. (Critical site)

4 Sites with Data Capture Below 90%

The following section provides a summary of the main site operational problems which have resulted in data capture below the required 90% level during the reporting period July to September 2004 (Table 4.1). The number of days and hours of data lost for each cause is also given. In some cases the data gap extends beyond this three-month reporting period.

Table 4.1 Sites with data capture below 90% July to September 2004
(Using the start date of any new site or end date of site closed)

| Data Capture (%) | Start date | End date | Reason | Comments | Days | Hours | |
|--------------------------|------------|-----------|-----------|--|---|-------|------|
| ENGLAND | | | | | | | |
| Barnsley Gawber | | | | | | | |
| O ₃ | 88.8% | 01-Jul-04 | 01-Jul-04 | PC/logger | PC rebooted | 0.3 | 6 |
| | | 21-Jul-04 | 23-Jul-04 | PC/logger | PC unit replaced due to on-going communications fault. | 2 | 47 |
| | | 25-Jul-04 | 28-Jul-04 | Pump fault | Ozone pump failed. Original PC unit reinstated. | 3.2 | 76 |
| | | 14-Aug-04 | 14-Aug-04 | Analyser fault | Recurring lock-up of the O ₃ analyser's processor card. Analyser reset by LSO. | 0.5 | 11 |
| | | 15-Aug-04 | 16-Aug-04 | Analyser fault | As above. | 0.7 | 17 |
| | | 18-Aug-04 | 20-Aug-04 | ESU service | Service | 2 | 49 |
| | | 14-Sep-04 | 14-Sep-04 | Analyser fault | As above. O ₃ processor card replaced on 8 th Oct 2004. | 0.7 | 16 |
| Birmingham Centre | | | | | | | |
| SO ₂ | 68.5% | 14-Jul-04 | 31-Jul-04 | Response instability | Instrument response instability. | 18 | 431 |
| | | 01-Aug-04 | 11-Aug-04 | Response instability and service | Instrument response instability. Pre-amp board replaced at service | 10.5 | 251 |
| | | 04-Sep-04 | 05-Sep-04 | Response instability | Spurious negative data deleted | 0.3 | 8 |
| Birmingham East | | | | | | | |
| General | | | | Site closed on 4 th August 2004. Relocated to Birmingham Tyburn | | | |
| CO | 37.0% | 04-Aug-04 | 30-Sep-04 | Site closed | Site closed for relocation | 56.7 | 1360 |
| NO ₂ | 34.0% | 09-Jul-04 | 12-Jul-04 | Telemetry | Disruption in data polling due to trial of an alternative data management system | 2.8 | 66 |
| | | 04-Aug-04 | 30-Sep-04 | Site closed | Site closed for relocation | 56.7 | 1360 |
| O ₃ | 37.0% | 04-Aug-04 | 30-Sep-04 | Site closed | As above | 56.7 | 1360 |
| PM ₁₀ | 34.1% | 29-Jul-04 | 30-Jul-04 | Unstable response | TEOM filter reseated | 1 | 25 |
| | | 02-Aug-04 | 30-Sep-04 | Site closed | Unstable response after audit on 2/8/04 until site closure. | 58.5 | 1408 |
| SO ₂ | 37.0% | 04-Aug-04 | 30-Sep-04 | Site closed | As above | 56.7 | 1360 |

Blackpool

| | | | | | | | |
|-----------------|-------|-----------|-----------|-------------------|--|------|-----|
| SO ₂ | 81.1% | 03-Jul-04 | 03-Jul-04 | Unstable response | Unstable high response data rejected | 0.5 | 12 |
| | | 07-Jul-04 | 07-Jul-04 | Unstable response | Spurious low data deleted after calibration. | 0.5 | 11 |
| | | 06-Sep-04 | 22-Sep-04 | Pump fault | Pump fault. Pump replaced on 16/8 but unstable response continued until 22/0/04. | 15.6 | 374 |

Bolton

| | | | | | | | |
|-----------------|-------|-----------|-----------|---------------------------------|--|------|-----|
| NO ₂ | 83.6% | 07-Aug-04 | 20-Aug-04 | Power cut and unstable response | Power cut due to air conditioning problems. Low and unstable response data deleted from after power cut on 7/8/04 until repair on 20/8/04. | 13.1 | 314 |
| | | 21-Sep-04 | 22-Sep-04 | ESU service | Service | 1.1 | 27 |
| | | 26-Sep-04 | 26-Sep-04 | Power cut | Power cut | 0.5 | 12 |

Bristol Centre

| | | | | | | | |
|----------------|-------|-----------|-----------|------------------|---|-----|----|
| O ₃ | 88.8% | 20-Jul-04 | 21-Jul-04 | Instrument fault | Spurious high ozone data deleted due to bad connection on IZS lamp. Joint resoldered. | 1.3 | 31 |
| | | 02-Aug-04 | 04-Aug-04 | Instrument fault | Thermistor board fault. Replacement analyser installed. | 2.3 | 55 |
| | | 09-Aug-04 | 11-Aug-04 | ESU service | Service. Original analyser reinstated | 2.3 | 54 |
| | | 02-Sep-04 | 06-Sep-04 | Sampling fault | Leak in sample inlet filter holder | 4 | 97 |

Bristol Old Market

| | | | | | | | |
|----|-------|-----------|-----------|--------------------|---|----|-----|
| CO | 81.4% | 27-Jul-04 | 13-Aug-04 | Baseline truncated | CO zero baseline offset dropped below response threshold. The old CO analyser which was susceptible to zero truncation problems was removed and a new analyser installed on 12 th August 2004. | 17 | 407 |
|----|-------|-----------|-----------|--------------------|---|----|-----|

Bury Roadside

| | | | | | | | |
|-----------------|-------|-----------|-----------|------------------|--|------|------|
| SO ₂ | 83.3% | 01-Jun-04 | 14-Jul-04 | Instrument fault | UV lamp fault. Lamp driver board replaced on 14 th July 2004. | 43.8 | 1050 |
| | | 17-Aug-04 | 17-Aug-04 | QA/QC audit | QA/QC audit | 0.3 | 6 |
| | | 25-Aug-04 | 26-Aug-04 | ESU service | Service | 1 | 25 |

Cambridge Roadside

| | | | | | | | |
|-----------------|-------|-----------|-----------|------------------|---|-----|----|
| NO ₂ | 89.0% | 08-Jul-04 | 08-Jul-04 | Air conditioning | Air conditioning unit malfunction giving elevated site temperatures and causing NO _x analyser response problems. | 0.4 | 10 |
| | | 10-Jul-04 | 12-Jul-04 | Air conditioning | Temporary portable air conditioning unit installed. | 2 | 48 |
| | | 23-Jul-04 | 26-Jul-04 | Air conditioning | Portable air conditioning unit | 2.4 | 57 |

| | | | | | | | |
|-----------------------|-------|-----------|-----------|----------------------|--|------|------|
| | | | | | failed resulting in unstable analyser response again. Original a/c unit reinstalled following repair | | |
| | | 10-Sep-04 | 13-Sep-04 | Monitoring suspended | Site operation suspended to allow up-grading of the communications system within the Council building. | 2.8 | 68 |
| | | 16-Sep-04 | 17-Sep-04 | Operator error | NO _x analyser accidentally left out of service following calibration visit | 0.8 | 19 |
| | | 23-Sep-04 | 24-Sep-04 | No mV data collected | Possible ESU service | 1 | 24 |
| Glazebury | | | | | | | |
| NO ₂ | 89.9% | 02-Sep-04 | 07-Sep-04 | ESU service | Data deleted due to spurious response after service. | 5.3 | 128 |
| High Muffles | | | | | | | |
| NO ₂ | 53.8% | 12-Aug-04 | 23-Sep-04 | Instrument fault | Fault found at audit. Sample flow and reaction cell pressure problems causing slow response. Also extreme autocalibration run-on problem resulting in up to 11 hours data loss per day. (See Section 2.10) | 42.2 | 1012 |
| Hove Roadside | | | | | | | |
| NO ₂ | 83.2% | 17-Jul-04 | 26-Jul-04 | Pump fault | Pump fault due to residue around pump valves. | 9.5 | 227 |
| | | 19-Aug-04 | 23-Aug-04 | Pump fault | Pump failure | 4.5 | 107 |
| | | 16-Sep-04 | 17-Sep-04 | ESU service | 6-month service | 1 | 25 |
| Ladybower | | | | | | | |
| General | | | | | | | |
| O ₃ | 50.9% | 06-Aug-04 | 07-Aug-04 | Power cut | Site power cuts and modem problems. Logger battery back up system not working properly resulting in several days data loss. New modem fitted on 20 th August 2004. Power cut causing communications fault. | 0.5 | 13 |
| | | 09-Aug-04 | 22-Sep-04 | Sampling fault | New API analyser installed but found to be leaking at audit. Data deleted until repair of analyser on 3 rd September. Following repair, spurious high data were recorded and further attention to clear a blockage in the sampling system was carried out on 22/9/04. | 44.3 | 1064 |
| Leamington Spa | | | | | | | |
| CO | 86.2% | 25-Jun-04 | 11-Jul-04 | Baseline truncated | Step change in zero baseline resulting a response truncation. | 16.4 | 394 |
| | | 15-Sep-04 | 16-Sep-04 | ESU service | Service | 1.1 | 26 |

Leeds Centre

| | | | | | | | |
|-----------------|-------|-----------|-----------|-------------------|--|------|------|
| CO | 86.1% | 23-Jul-04 | 23-Jul-04 | ESU visit | ESU call-out to investigate NO _x and O ₃ analyser response instability. | 0.3 | 6 |
| | | 29-Jul-04 | 29-Jul-04 | No mV data | Reason not given. | 0.3 | 7 |
| | | 24-Aug-04 | 02-Sep-04 | Air conditioning | Air conditioning unit iced up giving rise to elevated rack temperatures and unstable analyser response. | 9.1 | 218 |
| NO ₂ | 89.4% | 23-Jul-04 | 23-Jul-04 | Pump fault | ESU call-out to investigate NO _x and O ₃ analyser response instability. Charcoal bag on NO _x pump replaced. | 0.3 | 6 |
| | | 31-Aug-04 | 02-Sep-04 | ESU service | Service | 2.1 | 50 |
| | | 09-Sep-04 | 15-Sep-04 | Sampling fault | NO _x analyser flow fault. Leak in charcoal scrubber found. | 6.4 | 153 |
| O ₃ | 53.4% | 22-Jul-04 | 02-Sep-04 | Internal sampling | Leak in O ₃ analyser sampling system coincided with an O ₃ scrubber leak from the NO _x analyser exhaust resulting in artificially elevated O ₃ concentrations. (See Section 3.2) | 42.5 | 1019 |
| SO ₂ | 85.0% | 23-Aug-04 | 24-Aug-04 | Instrument fault | Air conditioning unit malfunction causing over-heating and unstable response. | 1 | 25 |
| | | 31-Aug-04 | 02-Sep-04 | ESU service | Service | 2.1 | 50 |
| | | 18-Sep-04 | 28-Sep-04 | Pump fault | Pump fault. Repaired on 20 th September but fault recurred 4 days later. | 9.7 | 233 |

Leicester Centre

| | | | | | | | |
|-----------------|-------|-----------|-----------|-------------|--|----|------|
| NO ₂ | 72.2% | 08-Jun-04 | 26-Jul-04 | ESU service | Low NO _x data and unstable calibration response recorded after new analyser installed on 8 th June 2004. | 48 | 1153 |
|-----------------|-------|-----------|-----------|-------------|--|----|------|

London Brent

| | | | | | | | |
|-----------------|-------|-----------|-----------|--------------------------------|---|-----|-----|
| SO ₂ | 79.2% | 02-Jul-04 | 08-Jul-04 | Instrument fault | UV lamp and driver board fault | 5.6 | 135 |
| | | 15-Jul-04 | 20-Jul-04 | Instrument fault | Analyser not responding to span gas at calibration and switched out of service. ESU visit found no obvious fault. | 5.4 | 129 |
| | | 30-Jul-04 | 04-Aug-04 | Analyser fault and ESU service | UV lamp fault. Lamp replaced at the service on 3 rd August 2004. | 5.3 | 127 |

London Bromley

| | | | | | | | |
|----|-------|-----------|-----------|------------------|---|-----|----|
| CO | 87.2% | 01-Jul-04 | 05-Jul-04 | Operator error | Analyser not switched back into sampling mode after calibration. | 4.1 | 99 |
| | | 15-Jul-04 | 16-Jul-04 | Power cut | Site power cut | 0.8 | 20 |
| | | 29-Jul-04 | 30-Jul-04 | Air Conditioning | Air conditioning failure giving high cabin temperatures and data loss | 0.5 | 13 |
| | | 31-Jul-04 | 31-Jul-04 | Air Conditioning | As above | 0.3 | 7 |

| | | | | | | | | |
|---------------------------|-------|-----------|-----------|-----------------------------------|--|------|-----|--|
| | | | | | or Temp fault | | | |
| | | 04-Aug-04 | 08-Aug-04 | Air Conditioning | As above | 4.3 | 104 | |
| | | 26-Aug-04 | 27-Aug-04 | ESU service | 6-month service visit | 1.1 | 26 | |
| London Hackney | | | | | | | | |
| General | | | | | | | | |
| | | | | | O ₃ analyser suffered intermittent faults during resulting in short periods of data loss. The problem eventually resulted in a persistent internal temperature sensor fault in October 2004 | | | |
| O ₃ | 70.5% | 28-Jul-04 | 28-Jul-04 | Flat response | Intermittent fault | 0.3 | 7 | |
| | | 18-Aug-04 | 18-Aug-04 | Flat response | As above | 0.4 | 9 | |
| | | 31-Aug-04 | 31-Aug-04 | Flat response | As above | 0.3 | 8 | |
| | | 01-Sep-04 | 01-Sep-04 | Flat response | A above | 0.4 | 9 | |
| | | 07-Sep-04 | 11-Oct-04 | Instrument fault | Internal temperature sensor fault | 34.4 | 825 | |
| London Hillingdon | | | | | | | | |
| O ₃ | 78.7% | 06-Jul-04 | 09-Jul-04 | ESU service | Service | 2.9 | 69 | |
| | | 11-Aug-04 | 27-Aug-04 | Instrument fault | Flat response data deleted until repair of 3-way solenoid valve. | 16 | 384 | |
| London Teddington | | | | | | | | |
| NO ₂ | 89.9% | 29-Jun-04 | 06-Jul-04 | Internal Sampling | Sample manifold fan fault. Spurious low data rejected. | 7.4 | 177 | |
| London Westminster | | | | | | | | |
| CO | 81.7% | 09-Aug-04 | 25-Aug-04 | ESU service and internal sampling | Manifold fan accidentally left switched off after routine service. | 16.3 | 390 | |
| NO ₂ | 79.4% | 22-Jul-04 | 23-Jul-04 | Instrument fault | Photomultiplier tube temperature fault. | 0.6 | 14 | |
| | | 09-Aug-04 | 25-Aug-04 | ESU service and internal sampling | Manifold fan left off after service. | 16.3 | 390 | |
| | | 22-Sep-04 | 23-Sep-04 | Instrument fault | Recurrence of PMT temperature fault. | 1.4 | 34 | |
| O ₃ | 81.8% | 09-Aug-04 | 25-Aug-04 | ESU service and internal sampling | Manifold fan left off after service | 16.2 | 389 | |
| SO ₂ | 81.3% | 03-Aug-04 | 04-Aug-04 | No mV data collected | No reason given | 0.3 | 6 | |
| | | 06-Aug-04 | 06-Aug-04 | QA/QC audit | Audit | 0.3 | 7 | |
| | | 09-Aug-04 | 25-Aug-04 | ESU service and internal sampling | Manifold fan left off after service | 16.2 | 389 | |
| Lullington Heath | | | | | | | | |
| SO ₂ | 77.9% | 02-Jul-04 | 19-Jul-04 | Instrument fault | SO ₂ analyser not resetting properly after power cuts causing intermittent periods of data loss | 16.5 | 397 | |
| | | 10-Sep-04 | 11-Sep-04 | Power cut | Analyser fault following power cut | 0.9 | 22 | |

| | | | | | | | |
|------------------------------|-------|-----------|-----------|-----------------------------------|---|------|------|
| | | 14-Sep-04 | 14-Sep-04 | Power cut | As above | 0.4 | 9 |
| | | 29-Sep-04 | 30-Sep-04 | ESU service | Service | 1.6 | 38 |
| Manchester Piccadilly | | | | | | | |
| NO ₂ | 81.7% | 31-Aug-04 | 02-Sep-04 | ESU service | Service | 2 | 48 |
| | | 06-Sep-04 | 10-Sep-04 | NO _x converter fault | Analyser failed to respond to span gas due to a converter fault. Analyser returned to workshop for repair. | 4.5 | 107 |
| | | 19-Sep-04 | 28-Sep-04 | NO _x converter fault | Recurrence of converter fault and analyser removed for further investigation. Converter and temperature control boards replaced. | 9.5 | 228 |
| SO ₂ | 86.7% | 31-Aug-04 | 10-Sep-04 | ESU service and unstable response | Unstable response after service | 9.6 | 231 |
| | | 22-Sep-04 | 24-Sep-04 | Unstable response | Unstable response data deleted | 2 | 49 |
| Manchester South | | | | | | | |
| NO ₂ | 59.4% | 27-Jul-04 | 02-Sep-04 | NO _x converter fault | Low converter efficiency (92%) found at audit. (See Section 2.5) | 37.1 | 890 |
| O ₃ | 89.7% | 01-Sep-04 | 10-Sep-04 | Instrument fault | Spurious low ambient data recorded after service. Malfunction of analyser's pressure and temperature switch. Sample manifold also cleaned | 9.1 | 219 |
| Manchester Town Hall | | | | | | | |
| CO | 61.9% | 07-Jun-04 | 03-Aug-04 | Instrument fault | Noisy and erratic response data deleted due to IR source fault. (See Section 3.3) | 57.3 | 1374 |
| | | 31-Aug-04 | 01-Sep-04 | ESU service | Six monthly service | 1.2 | 28 |
| Middlesbrough | | | | | | | |
| CO | 82.2% | 13-Sep-04 | 14-Sep-04 | ESU service | Service | 1.3 | 31 |
| | | 16-Sep-04 | 07-Oct-04 | Sampling fault | Sample filter holder not closed properly causing leak and internal sampling. | 20.6 | 495 |
| NO ₂ | 16.9% | 18-May-04 | 14-Sep-04 | NO _x converter fault | Converter fault (78%) identified at audit. Data deleted from start of NO ₂ calibration span divergence on 18 th May until service on 14 th September 04. (See Section 2.5) | 119 | 2863 |
| Northampton General | | | | | | | |
| CO | 72.0% | 20-Jul-04 | 21-Jul-04 | ESU service | The station uses a mobile telephone for telemetry. Problems with the mobile network provider and the College administration resulted in a 3-week disruption to data collection. Service | 1.1 | 27 |

| | | | | | | | | |
|-----------------------------|-------|-----------|-----------|---------------------------------|---|-------------------------------|----------|-----|
| | | | 27-Aug-04 | 20-Sep-04 | Telemetry | Mobile phone service problems | 24.1 | 579 |
| NO ₂ | 65.4% | 02-Jul-04 | 05-Jul-04 | Power cut | Analysers failed to reset correctly after site power cut | 2.9 | 69 | |
| | | 20-Jul-04 | 21-Jul-04 | ESU service | Service | 1.1 | 27 | |
| | | 27-Aug-04 | 23-Sep-04 | Telemetry | Mobile phone service problems | 27.4 | 658 | |
| O ₃ | 68.9% | 20-Jul-04 | 21-Jul-04 | ESU service | Service | 1.1 | 27 | |
| | | 20-Aug-04 | 23-Aug-04 | Instrument fault | Faulty flow meter sensor. | 2.9 | 69 | |
| | | 27-Aug-04 | 20-Sep-04 | Telemetry | Mobile phone service problems | 24.1 | 579 | |
| SO ₂ | 67.9% | 16-Jul-04 | 21-Jul-04 | Instrument fault | SO ₂ analyser found to be switched out of service at the audit due to a fault with the hydrocarbon kicker. Repaired at service on 20/7/04 | 5.1 | 122 | |
| | | 27-Aug-04 | 20-Sep-04 | Telemetry | Mobile phone service problems | 24.1 | 579 | |
| Oxford Centre | | | | | | | | |
| NO ₂ | 85.0% | 02-Jun-04 | 13-Jul-04 | NO _x converter fault | NO _x converter low (88%) at audit on 7/7/04. (See Section 2.5) | 41.3 | 991 | |
| Plymouth Centre | | | | | | | | |
| CO | 75.0% | 09-Aug-04 | 31-Aug-04 | ESU service | High noise data deleted after routine service. | 22.7 | 544 | |
| NO ₂ | 89.4% | 09-Aug-04 | 17-Aug-04 | ESU service and sampling fault | Service followed by pump fault | 8.3 | 200 | |
| | | 23-Aug-04 | 23-Aug-04 | High noise | Short period of high noise data rejected | 0.3 | 7 | |
| Rotherham Centre | | | | | | | | |
| SO ₂ | 72.1% | 30-Jun-04 | 23-Jul-04 | Sampling fault | High noise data and drifting response due to pump fault. | 23.6 | 567 | |
| | | 23-Aug-04 | 25-Aug-04 | ESU service | Service | 2.1 | 51 | |
| Somerton | | | | | | | | |
| NO ₂ | 85.1% | Daily | | Autocal run-on | NO ₂ autocal run-on (6 ppb) resulting in 3 hours data loss each day | | 3 hr/day | |
| | | 09-Aug-04 | 11-Aug-04 | ESU service | Service | 1.7 | 41 | |
| Southend-on-Sea | | | | | | | | |
| CO | 65.6% | 10-Feb-04 | 29-Jul-04 | High noise | High noise and negative data deleted. IR source and pump replaced on 19 th May 2004. Continuation of noise and drift in calibration sensitivity until analyser replaced on 29 th July 2004. (See Section 3.4) | 170 | 4091 | |
| | | 09-Aug-04 | 11-Aug-04 | ESU service | Service | 2.3 | 56 | |
| Stockport Shaw Heath | | | | | | | | |
| CO | 36.7% | 12-Jul-04 | 12-Jul-04 | Power cut | Power supply interruptions | 0.5 | 12 | |
| | | 04-Aug-04 | 30-Sep-04 | Instrument fault | Intermittent reference voltage fault. Problem investigated by ESU on several occasions in | 57.6 | 1382 | |

| | | | | | | | | |
|------------------------------|------------|-------------------------------------|-------------------------------------|---|--|-----------------|------------------|--|
| | | | | | September but fault persisted. Replacement detector assembly fitted on October 11 th 2004. Further intermitted data loss occurred indicating recurrence of fault. | | | |
| NO ₂ | 67.7% | 12-Jul-04 20-Jul-04 | 12-Jul-04 18-Aug-04 | Power cut Sampling fault | Power supply interruptions. Spurious elevated NO ₂ levels recorded between routine LSO visits. NO ₂ cylinder possibly not closed properly after calibration. | 0.5 29 | 12 696 | |
| SO ₂ | 0.0% | 09-Jun-04 | 30-Oct-04 | Analyser fault | UV lamp board failure. Delay whilst awaiting provision of new UV lamp driver board. Board replaced on 12 th August but further faults with the lamp and autocal switching valve resulted in extended data loss. Service was delayed due ingress of rainwater at the site from a leak in the roof. Still awaiting delivery of second replacement UV lamp driver board. | 144 | 3456 | |
| PM ₁₀ | 70.8% | 12-Jul-04 12-Aug-04 | 12-Jul-04 07-Sep-04 | Power cut Instrument fault | Power cut TEOM response failed to stabilise after site power cut. Response improved after ESU service in September. | 0.5 26.2 | 13 629 | |
| Stoke-on-Trent Centre | | | | | | | | |
| PM ₁₀ | 88.30 % | 04-Aug-04 31-Aug-04 15-Sep-04 | 04-Aug-04 02-Sep-04 23-Sep-04 | Unstable response ESU service Unstable response | High noise data deleted data after filter change. Service TEOM response instability again after filter change. Filter reseated. This analyser has been identified by QA/QC Unit as a needing to be up-graded/replaced. A new TEOM analyser was installed in October 2004. | 0.3 2 8 | 6 49 192 | |
| Wigan Leigh | | | | | | | | |
| General | | | | | | | | |
| O ₃ | 88.2% | 03-Aug-04 03-Sep-04 28-Sep-04 | 04-Aug-04 07-Sep-04 30-Sep-04 | Power cut Instrument fault Monitoring suspended | Wigan Leigh site closed on 28 th September due to the necessary redevelopment of the Police Station. Analysers were relocated to Wigan Centre and monitoring commenced after the audit on 11 th October 2004. Power cut. 3-way solenoid valve fault. Site closed for relocation | 0.8 4.5 2 | 19 108 785 | |

Wolverhampton Centre

| | | | | | | | |
|-----------------|-------|-----------|-----------|--------------------------|--|------|-----|
| NO ₂ | 77.0% | 13-Sep-04 | 08-Oct-04 | Analysers/sampling fault | Spurious low data deleted. Not sampling from manifold and flow blockage. (See Section 3.1) | 25.2 | 605 |
|-----------------|-------|-----------|-----------|--------------------------|--|------|-----|

SCOTLAND**Aberdeen**

| | | | | | | | |
|-----------------|-------|-----------|-----------|------------------|---|-----|-----|
| NO ₂ | 87.7% | 07-Jul-04 | 14-Jul-04 | Instrument fault | Unstable response following repair of photomultiplier tube. | 6.5 | 156 |
| | | 05-Aug-04 | 06-Aug-04 | ESU service | Service | 1 | 25 |

Glasgow Centre**General**

| | | | | | | | |
|------------------|-------|-----------|-----------|--------------------------------------|---|------|------|
| | | | | Air Conditioning | Air conditioning unit malfunction causing significant effect on NO _x and TEOM analyser performance. Air conditioning unit replaced on 11 th August. | | |
| CO | 88.5% | 07-Jul-04 | 08-Jul-04 | Operator error | LSO failed to switch analyser back into service after calibration | 0.8 | 20 |
| | | 26-Jul-04 | 28-Jul-04 | ESU service | Service | 2 | 47 |
| | | 11-Aug-04 | 18-Aug-04 | Instrument fault | Unexplained 50% drop in analyser response. Repaired by ESU. | 7 | 169 |
| NO ₂ | 74.3% | 07-Jul-04 | 08-Jul-04 | Operator error | Not switched back into service after calibration | 0.8 | 20 |
| | | 26-Jul-04 | 17-Aug-04 | Air conditioning | Data deleted due to site temperature problems effecting analyser response stability. Analyser replaced on August 11 th but not operating satisfactorily so replaced again on 17 th August | 22.2 | 533 |
| PM ₁₀ | 51.0% | 20-Apr-04 | 13-Aug-04 | Instrument fault | High noise data deleted. TEOM unit replaced on June 9 th but spare analyser not working correctly so original re-installed. Audit showed main flow leak (-73%) so data deleted until repair at service on 28 th July. Further temperature problems effecting response stability until TEOM replaced on 13 th August. (See Section 3.6) | 116 | 2772 |
| | | 18-Aug-04 | 19-Aug-04 | Operator error | LSO failed to switch TEOM back into service after calibration | 0.8 | 18 |
| SO ₂ | 88.6% | 07-Jul-04 | 08-Jul-04 | Operator error | Not switched back into service after calibration | 0.8 | 20 |
| | | 21-Jul-04 | 28-Jul-04 | Response instability and ESU service | Spurious step change in baseline prior to service, probably due to site temperature problems. | 7 | 168 |
| | | 11-Aug-04 | 12-Aug-04 | Air Conditioning or Temp fault | ESU on site to attend air conditioning problems. | 1 | 24 |

| | | | | | | | |
|-------------------------|---------|-----------|-----------|---------------------------------|---|-----------------|------|
| | | 18-Aug-04 | 19-Aug-04 | Operator error | LSO failed to switch TEOM back into service after calibration | 0.8 | 18 |
| Glasgow Kerbside | | | | | | | |
| NO ₂ | 89.2% | 01-Jul-04 | 01-Jul-04 | No mV data | No reason given | 0.3 | 6 |
| | | 19-Jul-04 | 28-Jul-04 | NO ₂ converter fault | NO _x converter found to be low (90%) at audit. (See Section 2.5) | 9.1 | 219 |
| Strath Vaich | | | | | | | |
| General | | | | | | | |
| O ₃ | 80.5% | 05-Aug-04 | 10-Aug-04 | Instrument fault | Problem with the ozone analyser giving intermittent periods of erratic noisy data. Erratic data deleted | 5 | 119 |
| | | 07-Sep-04 | 09-Sep-04 | Instrument fault | As above | 2.3 | 55 |
| | | 15-Sep-04 | 18-Sep-04 | Instrument fault | As above | 3.1 | 75 |
| | | 22-Sep-04 | 29-Sep-04 | Instrument fault | As above. The O ₃ analyser was replaced on 29 th September 2004. | 7.1 | 170 |
| WALES | | | | | | | |
| Aston Hill | | | | | | | |
| General | | | | | | | |
| O ₃ | 71.1% | 12-Aug-04 | 13-Aug-04 | ESU service | Major problems with ozone analyser associated with the IZS cycle. Analyser replaced 4 times over a 3-month period (See Section 3.5). Site also prone to frequent power cuts. Service. Original site analyser re-installed after repair. | 1.1 | 26 |
| | | 15-Aug-04 | 19-Aug-04 | Power cut | Faulty analyser response after power cut. Analyser replaced. | 4.2 | 101 |
| | | 25-Aug-04 | 31-Aug-04 | Instrument fault | Erratic data due to IZS temperature fault. Original site analyser re-instated. | 5.6 | 135 |
| | | 06-Sep-04 | 20-Sep-04 | Instrument fault | Erratic data due to faulty IZS and central processing unit failure. Analyser replaced. | 14.4 | 346 |
| Narberth | | | | | | | |
| NO ₂ | 89.1% | Daily | | Autocal run-on | NO ₂ autocal run-on (1.9 ppb) resulting in 3 hours data loss each day | 3 hours per day | |
| | | 27-Sep-04 | 29-Sep-04 | ESU service | Service | 1.9 | 46 |
| PM ₁₀ | 83.40 % | 31-Jul-04 | 12-Aug-04 | Response instability | High noise and negative response data deleted | 12.4 | 297 |
| | | 27-Sep-04 | 29-Sep-04 | ESU service | Service | 1.9 | 46 |
| Port Talbot | | | | | | | |
| NO ₂ | 69.7% | 03-Sep-04 | 15-Oct-04 | Response Instability | Analyser unable to maintain stable span response during calibrations. Analyser removed at service on 3/9/04 and re-instated after repair on 15 October 2004 | 42 | 1008 |

Swansea

| | | | | | | | |
|------------------|-------|-----------|-----------|-------------|--|-----|------|
| PM ₁₀ | 0.00% | 01-Apr-04 | 06-Oct-04 | ESU service | Data deleted for this period. Major leak was found at audit on 20 September 2004. Investigated by ESU and TEOM main flow found to be 45% low. Leak due to cracked DFU. (See Section 3.7) | 189 | 4530 |
|------------------|-------|-----------|-----------|-------------|--|-----|------|

4.1 Gravimetric PM₁₀ Sites with Data Capture Below 90%

This section gives details of the main operational problems which have resulted in gravimetric PM₁₀ data capture below the required 90% level during the reporting period July to September 2004. Casella Stanger has supplied the measured data, undertaken the filter weighing and calculated the particulate concentrations.

Bournemouth (Data capture 86%)

There was one recurrence on 20th August of the error code 40000 problem (i.e. coefficient of variation of average flow too high) which was seen repeatedly in the previous quarter. A further 10 days data (15-25th September) were lost due to a breakdown in laboratory procedures which prevented the filters from being properly weighed.

| Month | Comment | Data Loss |
|-----------|---|----------------|
| August | 12 th August, Power failure 20 th August, Large variation in flow (error code 40000) | 1 day 1 day |
| September | 15-25 th Sept, laboratory procedure problem | 10 days |

Brighton Roadside (Data capture 84%)

Two days data (18th August and 29th September) were lost due to damaged filters. A further 14-day gap occurred from 16th – 28th September due to a breakdown in laboratory procedures which prevented the filters from being properly weighed.

| Month | Comment | Data Loss |
|-----------|---|-----------|
| August | 18 th August, Filter damaged | 1 day |
| September | 16 th -28 th Sept, laboratory procedure problem | 10 days |

Northampton (Data capture 88%)

Four days data (2nd – 5th July) were lost due to a power failure. A further 7 days were lost due to filter exchange failures (6th July, 20-23rd August, and 30-31st August). One filter (23rd Sept) was not returned for weighing.

| Month | Comment | Data Loss |
|-----------|---|-----------------|
| July | 2 nd –5 th July: power failure 6 th July: filter exchange failure | 4 days 1 day |
| August | 20-23 rd and 30-31 st : filter exchange failure | 6 days |
| September | 23 rd Sept: filter not returned | 1 day |

Dumfries

Although high data capture was achieved in the period, frequent occurrences of error codes P, R and PR continued as report in the previous quarter. If left unattended these may result in future data loss.

Recommendation

| |
|---|
| The ESUs should investigate the cause of the frequent R and P error codes recorded at Dumfries. |
|---|

5 Ratified Data Capture Statistics

Table 5.1 provides the ratified data capture figures for each site for the 3-month period July to September 2004. Data capture values below 90% are shown in the shaded boxes.

Table 5.1 AURN Ratified Data Capture (%) for July to September 2004
(Using the start date of any new site or end date of site closed)

| Site | CO | NO ₂ | O ₃ | PM ₁₀ | PM _{2.5} | SO ₂ | Site Average |
|------------------------------------|------|-----------------|----------------|------------------|-------------------|-----------------|--------------|
| England | | | | | | | |
| Barnsley 12 | - | - | - | - | - | 98.4 | 98.4 |
| Barnsley Gawber | 90.5 | 91.9 | 88.8 | - | - | 91.8 | 90.8 |
| Bath Roadside | 98.3 | 98.2 | - | - | - | - | 98.3 |
| Billingham | - | 98.7 | - | - | - | - | 98.7 |
| Birmingham Centre | 97.1 | 92.8 | 96.3 | 97.4 | - | 68.5 | 90.4 |
| Birmingham East ¹ | 97.3 | 89.3 | 97.3 | 89.5 | - | 97.3 | 94.1 |
| Birmingham Tyburn | 99.6 | 99.6 | 99.5 | 99.7 | - | 99.2 | 99.5 |
| Blackpool | 99.1 | 94.4 | 97.2 | 96.4 | - | 81.1 | 93.7 |
| Bolton | 97.2 | 83.6 | 97.3 | 96.7 | - | 97.4 | 94.4 |
| Bottesford | - | - | 99.5 | - | - | - | 99.5 |
| Bournemouth | 97.0 | 92.4 | 97.2 | 85.9 | - | 96.9 | 93.9 |
| Bradford Centre | 96.3 | 91.5 | 97.6 | 96.0 | - | 97.5 | 95.8 |
| Brentford Roadside | 99.5 | 99.6 | - | - | - | - | 99.6 |
| Brighton Roadside | 98.1 | 98.1 | - | - | - | - | 98.1 |
| Brighton Roadside PM ₁₀ | - | - | - | 83.7 | - | - | 83.7 |
| Bristol Centre | 97.1 | 96.7 | 88.8 | 96.6 | - | 93.3 | 94.5 |
| Bristol Old Market | 81.4 | 98.1 | - | - | - | - | 89.8 |
| Bury Roadside | 98.2 | 94.0 | 98.3 | 97.6 | - | 83.3 | 94.3 |
| Cambridge Roadside | - | 89.0 | - | - | - | - | 89.0 |
| Camden Kerbside | - | 98.3 | - | 93.6 | - | - | 96.0 |
| Canterbury | - | 98.3 | - | 98.2 | - | - | 98.2 |
| Coventry Memorial Park | 98.0 | 98.1 | 97.9 | 98.1 | - | 97.9 | 98.0 |
| Exeter Roadside | 94.4 | 98.0 | 98.0 | - | - | 98.0 | 97.1 |
| Glazebury | - | 89.9 | 98.5 | - | - | - | 94.2 |
| Great Dun Fell | - | - | 97.6 | - | - | - | 97.6 |
| Haringey Roadside | - | 96.2 | - | 99.6 | - | - | 97.9 |
| Harwell | - | 98.1 | 98.1 | 98.1 | 91.9 | 98.1 | 96.9 |
| High Muffles | - | 53.8 | 99.2 | - | - | - | 76.5 |
| Hove Roadside | 98.2 | 83.2 | - | - | - | 98.1 | 93.2 |
| Hull Freetown | 95.5 | 95.4 | 95.6 | 95.2 | - | 95.6 | 95.5 |
| Ladybower | - | 91.4 | 50.9 | - | - | 92.9 | 78.4 |
| Leamington Spa | 86.2 | 94.0 | 98.2 | 97.1 | - | 98.1 | 94.7 |
| Leeds Centre | 86.1 | 89.4 | 53.4 | 97.0 | - | 85.0 | 82.2 |
| Leicester Centre | 99.6 | 72.2 | 99.4 | 99.2 | - | 99.5 | 94.0 |
| Liverpool Speke | 97.5 | 97.4 | 97.5 | 96.5 | - | 97.5 | 97.3 |
| London A3 Roadside | 96.0 | 91.3 | - | 95.5 | - | - | 94.2 |
| London Bexley | 97.6 | 97.4 | 97.8 | 97.6 | - | 97.6 | 97.6 |
| London Bloomsbury | 97.1 | 96.1 | 97.1 | 97.2 | 97.2 | 97.1 | 97.0 |
| London Brent | 93.9 | 92.9 | 93.8 | 93.3 | - | 79.2 | 90.6 |
| London Bromley | 87.2 | 97.3 | - | - | - | - | 92.3 |
| London Cromwell Road 2 | 95.3 | 99.3 | - | - | - | 99.0 | 97.9 |
| London Eltham | - | 92.4 | 99.3 | 98.7 | - | 99.0 | 97.3 |
| London Hackney | 92.0 | 99.0 | 70.5 | - | - | - | 87.2 |
| London Haringey | - | - | 99.5 | - | - | - | 99.5 |
| London Harlington | 91.8 | 99.7 | 98.6 | 98.7 | - | - | 97.2 |

| Site | CO | NO ₂ | O ₃ | PM ₁₀ | PM _{2.5} | SO ₂ | Site Average |
|------------------------|------|-----------------|----------------|------------------|-------------------|-----------------|--------------|
| London Hillingdon | 96.1 | 95.7 | 78.7 | 96.3 | - | 96.0 | 92.5 |
| London Lewisham | - | 99.6 | 99.5 | - | - | 99.7 | 99.6 |
| London Marylebone Road | 97.5 | 97.6 | 97.8 | 98.4 | 91.4 | 91.3 | 95.7 |
| London N. Kensington | 99.2 | 99.5 | 94.3 | 99.1 | - | 98.6 | 98.1 |
| London Southwark | 97.7 | 95.2 | 98.1 | - | - | 98.0 | 97.2 |
| London Teddington | - | 89.9 | 93.7 | - | - | 93.7 | 92.4 |
| London Wandsworth | - | 99.1 | 99.0 | - | - | - | 99.1 |
| London Westminster | 81.7 | 79.4 | 81.8 | 97.8 | - | 81.3 | 84.4 |
| Lullington Heath | - | 91.5 | 96.0 | - | - | 77.9 | 88.5 |
| Manchester Piccadilly | 97.1 | 81.7 | 97.1 | 97.0 | - | 86.7 | 91.9 |
| Manchester South | - | 59.4 | 89.7 | - | - | 98.3 | 82.5 |
| Manchester Town Hall | 61.9 | 90.1 | - | - | - | - | 76.0 |
| Market Harborough | 98.0 | 93.5 | 92.9 | - | - | - | 94.8 |
| Middlesbrough | 82.2 | 16.9 | 98.4 | 97.5 | - | 98.1 | 78.6 |
| Newcastle Centre | 97.0 | 92.9 | 97.1 | 97.1 | - | 96.6 | 96.1 |
| Northampton | 72.0 | 65.4 | 68.9 | 72.3 | - | 67.9 | 69.3 |
| Northampton PM10 | - | - | - | 88.0 | - | - | 88.0 |
| Norwich Centre | 97.1 | 92.9 | 97.3 | 97.3 | - | 97.1 | 96.3 |
| Norwich Roadside | - | 98.2 | - | - | - | - | 98.2 |
| Nottingham Centre | 96.7 | 96.7 | 96.9 | 96.4 | - | 96.8 | 96.7 |
| Oxford Centre | 99.3 | 85.0 | - | - | - | 99.5 | 94.6 |
| Plymouth Centre | 75.0 | 89.4 | 96.0 | 97.0 | - | 94.8 | 90.4 |
| Portsmouth | 98.8 | 98.4 | 99.2 | 98.1 | - | 97.6 | 98.4 |
| Preston | 99.6 | 95.1 | 99.6 | 99.3 | - | 99.4 | 98.6 |
| Reading New Town | 97.2 | 93.1 | 97.2 | 96.8 | - | 96.9 | 96.2 |
| Redcar | 97.0 | 96.9 | 97.0 | 96.9 | - | 96.9 | 97.0 |
| Rochester | - | 95.3 | 99.4 | 98.7 | 99.5 | 99.5 | 98.5 |
| Rotherham Centre | - | 95.7 | 91.1 | - | - | 72.1 | 86.3 |
| Salford Eccles | 97.0 | 97.0 | 96.9 | 97.1 | - | 97.0 | 97.0 |
| Sandwell West Bromwich | 97.8 | 98.0 | 97.8 | - | - | 98.1 | 97.9 |
| Scunthorpe Town | - | - | - | 93.9 | - | 98.1 | 96.0 |
| Sheffield Centre | 96.9 | 92.9 | 96.0 | 97.1 | - | 96.7 | 95.9 |
| Sheffield Tinsley | 93.5 | 98.3 | - | - | - | - | 95.9 |
| Sibton | - | - | 99.2 | - | - | - | 99.2 |
| Somerton | - | 85.1 | 97.6 | - | - | - | 91.3 |
| Southampton Centre | 95.5 | 93.0 | 97.2 | 97.2 | - | 97.0 | 96.0 |
| Southend-on-Sea | 65.6 | 91.3 | 96.4 | 94.1 | - | 93.6 | 88.2 |
| Southwark Roadside | 98.2 | 97.2 | - | - | - | 98.5 | 97.9 |
| St Osyth | 98.1 | 91.9 | 98.2 | - | - | - | 96.1 |
| Stockport Shaw Heath | 36.7 | 67.7 | - | 70.8 | - | 0.0 | 43.8 |
| Stockton-on-Tees Yarm | 98.2 | 98.8 | - | 97.6 | - | - | 98.2 |
| Stoke-on-Trent Centre | 97.1 | 93.0 | 97.3 | 88.3 | - | 91.7 | 93.5 |
| Sunderland | - | - | - | - | - | 99.3 | 99.3 |
| Thurrock | 95.3 | 93.7 | 98.1 | 99.5 | - | 98.1 | 96.9 |
| Tower Hamlets Roadside | 99.6 | 98.5 | - | - | - | - | 99.0 |
| Walsall Alumwell | - | 91.7 | - | - | - | - | 91.7 |
| Walsall Willenhall | - | 99.2 | - | - | - | - | 99.2 |
| West London | 97.7 | 97.7 | - | - | - | - | 97.7 |
| Weybourne | - | - | 100.0 | - | - | - | 100.0 |
| Wicken Fen | - | 97.9 | 97.5 | - | - | 97.6 | 97.7 |
| Wigan Leigh | 96.1 | 94.5 | 90.2 | 97.4 | - | 94.2 | 94.5 |
| Wirral Tranmere | 99.4 | 97.8 | 99.6 | 98.1 | - | 95.2 | 98.0 |
| Wolverhampton Centre | 92.3 | 77.0 | 96.6 | 96.3 | - | 97.1 | 91.9 |
| Yarner Wood | - | 97.0 | 92.7 | - | - | - | 94.8 |
| N Ireland | | | | | | | |
| Belfast Centre | 99.4 | 95.1 | 99.2 | 99.0 | - | 99.3 | 98.4 |

| Site | CO | NO ₂ | O ₃ | PM ₁₀ | PM _{2.5} | SO ₂ | Site Average |
|---------------------------------|------|-----------------|----------------|------------------|-------------------|-----------------|--------------|
| Belfast Clara St | - | - | - | 92.7 | - | - | 92.7 |
| Belfast East | - | - | - | - | - | 96.7 | 96.7 |
| Derry | 96.2 | 91.8 | 96.4 | 95.7 | - | 95.9 | 95.2 |
| Lough Navar | - | - | 99.7 | 99.5 | - | - | 99.6 |
| Scotland | | | | | | | |
| Aberdeen | 98.6 | 87.7 | 98.3 | 95.7 | - | 98.1 | 95.7 |
| Bush Estate | - | 93.7 | 97.8 | - | - | - | 95.7 |
| Dumfries | 97.6 | 94.3 | - | 98.9 | - | - | 96.9 |
| Edinburgh St Leonards | 98.3 | 98.3 | 94.6 | 98.5 | - | 98.1 | 97.5 |
| Eskdalemuir | - | - | 95.5 | - | - | - | 95.5 |
| Glasgow Centre | 88.5 | 74.3 | 95.1 | 51.0 | - | 88.6 | 79.5 |
| Glasgow City Chambers | 98.6 | 98.3 | - | - | - | - | 98.5 |
| Glasgow Kerbside | 97.8 | 89.2 | - | 94.3 | - | - | 93.8 |
| Grangemouth | 97.3 | 99.2 | - | 98.2 | - | 99.2 | 98.5 |
| Inverness | 98.3 | 95.1 | - | 97.8 | - | - | 97.1 |
| Strath Vaich | - | - | 80.5 | - | - | - | 80.5 |
| Wales | | | | | | | |
| Aston Hill | - | 93.7 | 71.1 | - | - | - | 82.4 |
| Cardiff Centre | 97.8 | 97.5 | 97.9 | 97.6 | - | 97.1 | 97.6 |
| Cwmbran | 99.5 | 99.4 | 99.5 | 99.0 | - | 99.2 | 99.3 |
| Narberth | - | 89.1 | 97.3 | 83.4 | - | 96.1 | 91.5 |
| Port Talbot | - | 69.7 | 97.7 | 95.2 | - | 97.5 | 90.0 |
| Swansea | 97.6 | 97.3 | 94.7 | 0.0 | - | 97.6 | 77.5 |
| Wrexham | 98.8 | 95.2 | - | 98.9 | - | 98.8 | 97.9 |
| | | | | | | | |
| Number of sites | 80 | 107 | 85 | 72 | 4 | 77 | 122* |
| Number of sites < 90% | 12 | 24 | 11 | 10 | 0 | 12 | 21 |
| Network Mean (%) | 93.9 | 91.8 | 94.4 | 93.7 | 95.0 | 93.3 | 94 |

¹ Note Birmingham East closed on 4th August 2004 and relocated to Birmingham Tyburn

* Site count of 122 as both Birmingham East and Birmingham Tyburn included

Sites and instruments established between 01/7/2004 and 30/9/2004

| Site | Status | Pollutants | Start Date |
|-------------------|-----------|--|------------|
| Birmingham Tyburn | Affiliate | NO ₂ CO O ₃ PM ₁₀ SO ₂ | 16/08/2004 |

Table 5.2 provides the ratified data capture figures for each site for the 9-month period January to September 2004. Data capture values below 90% are shown in the shaded boxes.

Table 5.2 AURN Ratified Data Capture (%) for January to September 2004
(Using the start date of any new site or end date of site closed)

| Site | CO | NO ₂ | O ₃ | PM ₁₀ | PM _{2.5} | SO ₂ | Site Average |
|------------------------------------|------|-----------------|----------------|------------------|-------------------|-----------------|--------------|
| England | | | | | | | |
| Barnsley 12 | - | - | - | - | - | 98.7 | 98.7 |
| Barnsley Gawber | 95.5 | 94.9 | 95.1 | - | - | 95.9 | 95.4 |
| Bath Roadside | 98.7 | 97.9 | - | - | - | - | 98.3 |
| Billingham | - | 99.0 | - | - | - | - | 99.0 |
| Birmingham Centre | 95.5 | 91.4 | 92.5 | 96.4 | - | 87.1 | 92.6 |
| Birmingham East | 98.5 | 90.8 | 97.9 | 97.4 | - | 98.5 | 96.6 |
| Birmingham Tyburn | 99.6 | 99.6 | 99.5 | 99.7 | - | 99.2 | 99.5 |
| Blackpool | 95.8 | 90.3 | 96.0 | 97.3 | - | 66.3 | 89.1 |
| Bolton | 97.2 | 92.6 | 97.2 | 96.4 | - | 97.2 | 96.1 |
| Bottesford | - | - | 99.6 | - | - | - | 99.6 |
| Bournemouth | 98.2 | 95.3 | 98.5 | 92.7 | - | 97.9 | 96.5 |
| Bradford Centre | 97.4 | 95.2 | 97.8 | 96.7 | - | 97.3 | 96.9 |
| Brentford Roadside | 96.7 | 97.5 | - | - | - | - | 97.1 |
| Brighton Roadside | 98.7 | 98.8 | - | - | - | - | 98.8 |
| Brighton Roadside PM ₁₀ | - | - | - | 91.6 | - | - | 91.6 |
| Bristol Centre | 97.0 | 95.7 | 90.7 | 96.8 | - | 94.4 | 94.9 |
| Bristol Old Market | 62.5 | 98.4 | - | - | - | - | 80.5 |
| Bury Roadside | 91.6 | 90.3 | 89.3 | 91.2 | - | 67.9 | 86.0 |
| Cambridge Roadside | - | 95.5 | - | - | - | - | 95.5 |
| Camden Kerbside | - | 55.1 | - | 97.3 | - | - | 76.2 |
| Canterbury | - | 96.1 | - | 99.2 | - | - | 97.6 |
| Coventry Memorial Park | 98.9 | 97.8 | 98.4 | 90.2 | - | 98.6 | 96.8 |
| Exeter Roadside | 87.1 | 96.0 | 96.2 | - | - | 80.0 | 89.8 |
| Glazebury | - | 93.1 | 95.0 | - | - | - | 94.0 |
| Great Dun Fell | - | - | 98.9 | - | - | - | 98.9 |
| Haringey Roadside | - | 98.3 | - | 98.8 | - | - | 98.5 |
| Harwell | - | 95.6 | 97.8 | 97.3 | 95.3 | 97.7 | 96.7 |
| High Muffles | - | 70.1 | 99.0 | - | - | - | 84.6 |
| Hove Roadside | 98.2 | 93.2 | - | - | - | 97.6 | 96.3 |
| Hull Freetown | 94.8 | 86.0 | 92.0 | 94.5 | - | 84.4 | 90.3 |
| Ladybower | - | 88.7 | 82.3 | - | - | 96.4 | 89.1 |
| Leamington Spa | 85.3 | 93.3 | 98.4 | 98.2 | - | 98.2 | 94.7 |
| Leeds Centre | 78.4 | 89.8 | 77.1 | 97.3 | - | 92.7 | 87.1 |
| Leicester Centre | 85.7 | 81.0 | 97.5 | 94.6 | - | 96.8 | 91.1 |
| Liverpool Speke | 98.0 | 98.0 | 97.8 | 96.9 | - | 97.7 | 97.7 |
| London A3 Roadside | 97.9 | 96.2 | - | 97.7 | - | - | 97.3 |
| London Bexley | 93.2 | 95.0 | 94.2 | 90.2 | - | 94.4 | 93.4 |
| London Bloomsbury | 96.2 | 96.9 | 96.6 | 97.6 | 97.6 | 97.0 | 97.0 |
| London Brent | 97.2 | 93.6 | 97.2 | 97.0 | - | 92.2 | 95.4 |
| London Bromley | 95.0 | 98.0 | - | - | - | - | 96.5 |
| London Cromwell Road 2 | 97.6 | 98.9 | - | - | - | 98.8 | 98.4 |
| London Eltham | - | 97.0 | 95.7 | 92.2 | - | 98.8 | 95.9 |
| London Hackney | 96.9 | 99.3 | 89.1 | - | - | - | 95.1 |
| London Haringey | - | - | 92.4 | - | - | - | 92.4 |
| London Harlington | 90.1 | 99.2 | 99.1 | 99.4 | - | - | 97.0 |

| Site | CO | NO ₂ | O ₃ | PM ₁₀ | PM _{2.5} | SO ₂ | Site Average |
|------------------------|------|-----------------|----------------|------------------|-------------------|-----------------|--------------|
| London Hillingdon | 97.4 | 97.1 | 90.4 | 97.4 | - | 97.4 | 95.9 |
| London Lewisham | - | 99.6 | 88.8 | - | - | 99.1 | 95.8 |
| London Marylebone Road | 95.1 | 97.8 | 97.6 | 97.7 | 96.0 | 92.8 | 96.2 |
| London N. Kensington | 98.7 | 98.8 | 97.7 | 94.8 | - | 96.6 | 97.3 |
| London Southwark | 93.1 | 85.0 | 93.3 | - | - | 93.2 | 91.1 |
| London Teddington | - | 93.8 | 95.3 | - | - | 95.3 | 94.8 |
| London Wandsworth | - | 99.1 | 99.2 | - | - | - | 99.1 |
| London Westminster | 92.9 | 74.3 | 91.7 | 93.8 | - | 92.7 | 89.1 |
| Lullington Heath | - | 92.1 | 94.7 | - | - | 85.8 | 90.9 |
| Manchester Piccadilly | 97.0 | 91.9 | 97.0 | 97.0 | - | 93.6 | 95.3 |
| Manchester South | - | 85.0 | 95.1 | - | - | 98.0 | 92.7 |
| Manchester Town Hall | 75.6 | 94.4 | - | - | - | - | 85.0 |
| Market Harborough | 94.2 | 90.2 | 93.1 | - | - | - | 92.5 |
| Middlesbrough | 91.3 | 53.8 | 98.9 | 97.2 | - | 98.9 | 88.0 |
| Newcastle Centre | 80.0 | 77.3 | 90.4 | 90.2 | - | 78.4 | 83.3 |
| Northampton | 87.2 | 83.1 | 83.0 | 86.4 | - | 85.8 | 85.1 |
| Northampton PM10 | - | - | - | 79.6 | - | - | 79.6 |
| Norwich Centre | 92.4 | 90.2 | 96.4 | 96.4 | - | 95.4 | 94.2 |
| Norwich Roadside | - | 97.1 | - | - | - | - | 97.1 |
| Nottingham Centre | 89.4 | 91.6 | 97.1 | 97.0 | - | 97.1 | 94.4 |
| Oxford Centre | 96.4 | 82.1 | - | - | - | 99.0 | 92.5 |
| Plymouth Centre | 85.4 | 85.6 | 97.1 | 96.6 | - | 96.8 | 92.3 |
| Portsmouth | 95.9 | 97.7 | 98.5 | 91.1 | - | 87.8 | 94.2 |
| Preston | 91.6 | 95.5 | 98.8 | 98.2 | - | 98.5 | 96.5 |
| Reading New Town | 95.1 | 92.9 | 81.5 | 95.5 | - | 88.2 | 90.6 |
| Redcar | 97.1 | 97.0 | 95.6 | 97.0 | - | 97.1 | 96.8 |
| Rochester | - | 96.1 | 99.1 | 98.5 | 99.2 | 99.0 | 98.4 |
| Rotherham Centre | - | 96.6 | 87.3 | - | - | 83.6 | 89.2 |
| Salford Eccles | 95.6 | 95.7 | 89.2 | 95.2 | - | 87.5 | 92.6 |
| Sandwell West Bromwich | 97.9 | 98.4 | 98.1 | - | - | 98.4 | 98.2 |
| Scunthorpe | - | - | - | 96.3 | - | 97.4 | 96.9 |
| Scunthorpe Town | - | - | - | 93.2 | - | 98.4 | 95.8 |
| Sheffield Centre | 97.7 | 96.3 | 97.4 | 97.7 | - | 74.9 | 92.8 |
| Sheffield Tinsley | 96.6 | 98.6 | - | - | - | - | 97.6 |
| Sibton | - | - | 97.6 | - | - | - | 97.6 |
| Somerton | - | 89.0 | 96.6 | - | - | - | 92.8 |
| Southampton Centre | 88.3 | 95.2 | 88.0 | 95.8 | - | 95.4 | 92.5 |
| Southend-on-Sea | 36.6 | 90.7 | 97.0 | 96.1 | - | 94.2 | 82.9 |
| Southwark Roadside | 98.2 | 67.7 | - | - | - | 98.6 | 88.2 |
| St Osyth | 98.7 | 89.6 | 98.8 | - | - | - | 95.7 |
| Stockport Shaw Heath | 78.0 | 88.3 | - | 86.9 | - | 57.7 | 77.7 |
| Stockton-on-Tees Yarm | 96.5 | 98.3 | - | 97.7 | - | - | 97.5 |
| Stoke-on-Trent Centre | 92.5 | 92.9 | 97.5 | 71.4 | - | 93.4 | 89.5 |
| Sunderland | - | - | - | - | - | 89.6 | 89.6 |
| Thurrock | 95.0 | 86.7 | 98.1 | 93.8 | - | 98.0 | 94.3 |
| Tower Hamlets Roadside | 99.4 | 95.2 | - | - | - | - | 97.3 |
| Walsall Alumwell | - | 93.4 | - | - | - | - | 93.4 |
| Walsall Willenhall | - | 89.5 | - | - | - | - | 89.5 |
| West London | 98.4 | 98.4 | - | - | - | - | 98.4 |
| Weybourne | - | - | 97.6 | - | - | - | 97.6 |
| Wicken Fen | - | 64.2 | 91.3 | - | - | 91.4 | 82.3 |
| Wigan Leigh | 96.9 | 96.1 | 94.4 | 97.4 | - | 69.1 | 90.8 |
| Wirral Tranmere | 94.2 | 93.2 | 98.8 | 98.1 | - | 95.4 | 95.9 |

| Site | CO | NO ₂ | O ₃ | PM ₁₀ | PM _{2.5} | SO ₂ | Site Average |
|---------------------------------|-------------|-----------------|----------------|------------------|-------------------|-----------------|--------------|
| Wolverhampton Centre | 92.1 | 88.9 | 97.3 | 97.5 | - | 97.6 | 94.7 |
| Yarner Wood | - | 98.1 | 96.7 | - | - | - | 97.4 |
| N Ireland | | | | | | | |
| Belfast Centre | 96.9 | 92.7 | 96.8 | 96.4 | - | 95.1 | 95.6 |
| Belfast Clara St | - | - | - | 91.7 | - | - | 91.7 |
| Belfast East | - | - | - | - | - | 96.0 | 96.0 |
| Derry | 96.7 | 91.0 | 96.9 | 96.2 | - | 94.6 | 95.1 |
| Lough Navar | - | - | 66.7 | 99.5 | - | - | 83.1 |
| Scotland | | | | | | | |
| Aberdeen | 97.6 | 94.8 | 99.0 | 98.0 | - | 98.8 | 97.6 |
| Bush Estate | - | 93.4 | 97.9 | - | - | - | 95.7 |
| Dumfries | 98.1 | 97.0 | - | 89.1 | - | - | 94.7 |
| Edinburgh St Leonards | 97.5 | 88.5 | 96.6 | 98.3 | - | 98.2 | 95.8 |
| Eskdalemuir | - | - | 96.0 | - | - | - | 96.0 |
| Glasgow Centre | 89.7 | 84.8 | 96.8 | 56.3 | - | 87.4 | 83.0 |
| Glasgow City Chambers | 98.7 | 97.7 | - | - | - | - | 98.2 |
| Glasgow Kerbside | 97.8 | 94.8 | - | 93.5 | - | - | 95.4 |
| Grangemouth | 74.9 | 98.2 | - | 97.9 | - | 98.2 | 92.3 |
| Inverness | 98.1 | 97.7 | - | 93.8 | - | - | 96.5 |
| Strath Vaich | - | - | 90.2 | - | - | - | 90.2 |
| Wales | | | | | | | |
| Aston Hill | - | 83.3 | 86.6 | - | - | - | 85.0 |
| Cardiff Centre | 95.0 | 97.0 | 88.4 | 97.1 | - | 96.5 | 94.8 |
| Cwmbran | 97.4 | 99.2 | 99.4 | 99.3 | - | 95.9 | 98.2 |
| Narberth | - | 88.9 | 94.2 | 59.9 | - | 88.8 | 83.0 |
| Port Talbot | - | 84.2 | 96.8 | 95.3 | - | 96.7 | 93.3 |
| Swansea | 98.0 | 89.9 | 97.0 | 2.6 | - | 97.8 | 77.1 |
| Wrexham | 98.5 | 95.6 | - | 92.0 | - | 85.7 | 93.0 |
| | | | | | | | |
| Number of sites | 80 | 107 | 85 | 73 | 4 | 78 | 123* |
| Number of sites < 90% | 15 | 28 | 13 | 8 | 0 | 19 | 27 |
| Network Mean (%) | 93.1 | 91.9 | 94.6 | 92.8 | 97.0 | 92.8 | 93 |

* Site count of 123 as both Birmingham East and Birmingham Tyburn included as well as Scunthorpe and Scunthorpe Town

Sites and instruments established between 01/1/2004 and 30/9/2004


| Site | Status | Pollutants | Start Date |
|-------------------|-----------|--|------------|
| Glazebury | Defra | NO ₂ | 26/01/2004 |
| London Harlington | Affiliate | NO ₂ CO O ₃ PM ₁₀ | 01/01/2004 |
| Scunthorpe Town | Affiliate | SO ₂ PM ₁₀ | 06/06/2004 |
| Birmingham Tyburn | Affiliate | NO ₂ CO O ₃ PM ₁₀ SO ₂ | 16/08/2004 |

Table 5.3 shows the ratified AURN data capture for the 61 **critical sites** in the network for the 9-month period January to September 2004. Sites with less than 90% data capture are shaded. Sites with less than 86.5% data capture (shown in red) for this 9-month period will not achieve the 90% data capture target for the year.

**Table 5.3 AURN Ratified Data Capture (%) for CRITICAL SITES
January to September 2004 (Calculated from 1/1/04)**

| Critical Sites | | CO | NO ₂ | O ₃ | PM ₁₀ | SO ₂ |
|------------------------------------|-----------|------|-----------------|----------------|------------------|-----------------|
| AGGLOMERATIONS | | | | | | |
| Belfast Centre | DEFRA | 96.9 | 92.7 | 96.8 | | |
| Blackpool | DEFRA | 95.8 | 90.3 | 96.0 | 97.3 | 66.3 |
| Bournemouth | Affiliate | 98.2 | 95.3 | 98.5 | 92.7 | 97.9 |
| Brighton Roadside PM ₁₀ | Affiliate | | | | 91.6 | |
| Bristol Centre | DEFRA | | 95.7 | 90.7 | 96.8 | 94.4 |
| Cardiff Centre | DEFRA | 95.0 | 97.0 | 88.4 | 97.1 | 96.5 |
| Coventry Memorial Park | DEFRA | 98.9 | 97.8 | 98.4 | 90.2 | 98.6 |
| Edinburgh St Leonards | DEFRA | 97.5 | 88.5 | 96.6 | 98.3 | 98.2 |
| Glasgow Centre | DEFRA | | 84.8 | 96.8 | | 87.4 |
| Hove Roadside | Affiliate | | | - | - | 97.6 |
| Hull Freetown | DEFRA | 94.8 | 86.0 | 92.0 | 94.5 | 84.4 |
| Leicester Centre | DEFRA | 85.7 | 81.0 | 97.5 | 94.6 | 96.8 |
| Liverpool Speke | Affiliate | 98.0 | 98.0 | 97.8 | 96.9 | 97.7 |
| Newcastle Centre | DEFRA | 80.0 | 77.3 | 90.4 | 90.2 | 78.4 |
| Nottingham Centre | DEFRA | 89.4 | 91.6 | 97.1 | 97.0 | 97.1 |
| Portsmouth | Affiliate | 95.9 | 97.7 | 98.5 | 91.1 | 87.8 |
| Preston | DEFRA | 91.6 | 95.5 | 98.8 | 98.2 | 98.5 |
| Reading New Town | DEFRA | 95.1 | 92.9 | 81.5 | 95.5 | 88.2 |
| Sheffield Centre | DEFRA | | | | 97.7 | |
| Southampton Centre | DEFRA | 88.3 | 95.2 | 88.0 | 95.8 | 95.4 |
| Southend-on-Sea | DEFRA | 36.6 | 90.7 | 97.0 | 96.1 | 94.2 |
| Stoke-on-Trent Centre | DEFRA | 92.5 | 92.9 | 97.5 | 71.4 | 93.4 |
| Swansea | Affiliate | 98.0 | | | | |
| Wirral Tranmere | DEFRA | 94.2 | 93.2 | 98.8 | 98.1 | 95.4 |
| ZONES | | | | | | |
| Aberdeen | Affiliate | 97.6 | 94.8 | 99.0 | 98.0 | 98.8 |
| Aston Hill | DEFRA | - | 83.3 | 86.6 | - | - |
| Barnsley Gawber | Affiliate | 95.5 | 94.9 | 95.1 | - | |
| Bush Estate | DEFRA | - | 93.4 | 97.9 | - | - |
| Canterbury | Affiliate | - | | - | 99.2 | - |
| Cwmbran | Affiliate | 97.4 | 99.2 | 99.4 | 99.3 | 95.9 |
| Derry | Affiliate | 96.7 | 91.0 | 96.9 | 96.2 | 94.6 |
| Dumfries | DEFRA | 98.1 | 97.0 | - | 89.1 | - |
| Eskdalemuir | DEFRA | - | - | 96.0 | - | - |
| Glazebury | DEFRA | - | 84.6 | 95.0 | - | - |
| Grangemouth | Affiliate | 74.9 | 98.2 | - | 97.9 | 98.2 |
| Great Dun Fell | DEFRA | - | - | 98.9 | - | - |
| High Muffles | DEFRA | - | 70.1 | 99.0 | - | - |
| Inverness | DEFRA | | 97.7 | - | 93.8 | - |
| Leamington Spa | Affiliate | 85.3 | 93.3 | 98.4 | 98.2 | 98.2 |
| Lough Navar | DEFRA | - | - | 66.7 | | - |
| Narberth | Affiliate | - | | 94.2 | | |
| Northampton | Affiliate | 87.2 | 83.1 | 83.0 | 86.4 | 85.8 |
| Norwich Centre | DEFRA | | 90.2 | 96.4 | | |
| Oxford Centre | Affiliate | 96.4 | | - | - | 99.0 |
| Plymouth Centre | DEFRA | | | | 96.6 | |
| Scunthorpe* | Affiliate | - | - | - | 27.4 | 27.7 |
| Scunthorpe Town* | Affiliate | - | - | - | 39.8 | 42.0 |

| Critical Sites | | CO | NO ₂ | O ₃ | PM ₁₀ | SO ₂ |
|---------------------------------|-----------|------|-----------------|----------------|------------------|-----------------|
| Sibton | DEFRA | - | - | 97.6 | - | - |
| Somerton | Affiliate | - | 89.0 | 96.6 | - | - |
| St Osyth | DEFRA | 98.7 | 89.6 | 98.8 | - | - |
| Stockton-on-Tees Yarm | Affiliate | 96.5 | 98.3 | - | 97.7 | - |
| Strath Vaich | DEFRA | - | - | 90.2 | - | - |
| Sunderland | DEFRA | - | - | - | - | 89.6 |
| Thurrock | Affiliate | | 86.7 | 98.1 | | |
| Wicken Fen | DEFRA | - | 64.2 | 91.3 | - | |
| Wigan Leigh | Affiliate | 96.2 | 95.4 | 93.7 | 96.7 | 68.6 |
| Wrexham | DEFRA | 98.5 | 95.6 | - | 85.7 | 85.7 |
| Yarner Wood | DEFRA | - | 98.1 | 96.7 | - | - |
| Number of critical analysers | | | | | | |
| | | 32 | 42 | 44 | 35 | 32 |
| Number of sites < 90% | | | | | | |
| | | 10 | 17 | 6 | 9 | 14 |

- Key  Pollutant monitored but not critical at this site
 - Not monitored
 * Scunthorpe site closed on 18/3/04 and relocated to Scunthorpe Town where monitoring commenced on 6/6/04

Note that critical sites where monitoring has not yet commenced are not included in the above table.

RECOMMENDATION

Every effort should be made to ensure that data capture is maximised for the critical sites. LSOs and ESUs should undertake call-outs and repairs as soon as possible to avoid unnecessary data loss at these sites.

PART B: Summer Intercalibration Results July-September 2004

PART B - Intercalibration Report for the Automatic Urban, Rural and London Networks, July to September 2004

6 Introduction

In Summer 2004, **netcen** undertook an intercalibration of the 121 monitoring stations in operation in the defra and the Devolved Administrations sponsored Urban, Rural and London Monitoring Networks. This has allowed data from all of the analysers in the networks to be harmonised to a single set of audit standards, thereby improving confidence in the accuracy, consistency and traceability of air pollution measurements made in the UK.

The tests were undertaken to cross-reference the individual data sets to common traceable calibration standards. This enabled the consistency of measurements throughout the network to be determined. The following major checks are made:

1. **Analyser accuracy and precision**, as a basic check to ensure reliable datasets from the analysers.
2. **Instrument linearity**, to check that doubling a concentration of gas to the analyser results in a doubling of the analyser signal response. If an analyser is not linear, data cannot be reliably scaled into concentrations.
3. **Instrument signal noise**, to check for a stable analyser response to calibration gases.
4. **Analyser response time**, to check that the analyser responds quickly to a change in gas concentrations.
5. **Leak and flow checks**, to ensure that ambient air reaches the analysers, without being compromised in any way.
6. **NO_x analyser converter efficiency**, to ensure reliable operation. This is the device that allows the measurement of NO₂ to be undertaken, so it must work acceptably.
7. **TEOM k_o evaluation**. The analyser uses this factor to calculate mass concentrations, so the value is calculated to determine its accuracy.
8. **Particulate analyser flow rate checks**, to ensure that the flow rates through critical parts of the analyser are within specified limits.
9. **SO₂ analyser hydrocarbon interference**, as certain hydrocarbons are known to interfere with the SO₂ detector.
10. **Evaluation of site cylinder concentrations**, using a set of **netcen** certified cylinders that are taken to all the sites. The concentrations of the site cylinders are used to scale pollution datasets, so it is important to ensure that the concentration of gas in the cylinder does not change.
11. **Competence of Local Site Operators (LSO)** in undertaking calibrations. As it is the calibrations by the LSO's that are used to scale pollution datasets, it is important to check that these are undertaken competently.

In addition to the above tests, a "Network Intercomparison" is conducted. This exercise utilises audit gas cylinders transported to each site in the Network. These cylinders have been recently calibrated by the Calibration Laboratory at **netcen**, and allow us to examine how different site analysers respond when they are supplied with the same gas used at other sites. For ozone analysers, the calibration is undertaken with recently calibrated ozone photometers.

The technique used to process the intercomparison results is broadly as follows:

- The analyser responses to audit gas are converted into concentrations, using provisional calibration factors obtained on the day of the intercalibration. This factor is also used for the provisional data supplied to the web/teletext.

- These individual results are tabulated, and statistical analyses undertaken (e.g. network average result, network standard deviation, deviation of individual sites from the network mean etc.)

These results are then used to pick out problem sites, or “outliers”, which are investigated further to determine reasons and investigate possible remedies for the outliers. The definition of an outlier is a site result that falls outside the following limits:

- $\pm 10\%$ of the network average for NO_x, CO and SO₂ analysers,
- $\pm 5\%$ of the reference standard photometer for Ozone analysers,
- $\pm 2.5\%$ of the stated k₀ value for TEOM analysers,
- $\pm 10\%$ for particulate analyser flow rates,
- $\pm 10\%$ for the recalculation of site cylinder concentrations.

Thus, the intercalibration investigates the quality of provisional data output by the Management Units for use in forecasting, teletext and the web. It also provides input into the ratification process by highlighting sites where close scrutiny of datasets is likely to be required.

As stated earlier, any outliers that are identified are rigorously checked to determine the cause, and corrective action taken, if necessary. There are a number of likely main causes for outlier results, as discussed below:

- Drift of an analyser between scheduled LSO calibrations. This is by far the most common cause of an outlier result, and one that is simply corrected for during ratification of data.
- Drift of site cylinder concentrations between intercalibrations. Site cylinders can sometimes become unstable, especially at low pressures. All site cylinder concentrations are checked every six months, and are replaced as necessary.
- Erroneous calibration factors. It can occasionally happen that an analyser calibration is unsuccessful, and results in unsuitable scaling factors being used to produce pollution datasets. These are identified and corrected during ratification.
- Pressurisation of the sampling system at the audit. Occasionally, an analyser can be very sensitive to small changes in applied flow rates of calibration gas. This is more difficult to identify and correct, and may have consequences for data quality.
- Leaks, sample switching valves, etc. Outliers can be generated if an analyser is not sampling ambient air properly. It is likely that if a leaking analyser is identified, data losses will result.

The procedures used to determine network performance are documented in **netcen** Work Instructions. These methods are regularly updated and improved and have been evaluated by the United Kingdom Accreditation Service (UKAS). **netcen** holds UKAS accreditation for the on-site calibration of all the analyser types (NO_x, CO, SO₂, O₃) and for the determination of the TEOM k₀ factor and PM₁₀ analyser flow rates used in the network. A UKAS Certificate of Calibration (Calibration Laboratory number 0401) for the Automatic Urban, Rural and London Networks is appended to this report.

A total of 121 sites were audited in this exercise.

The following sections of this report identify analysers that did not meet performance standards, investigates the possible causes of these results and recommends any remedial action required.

7 Results Summary

The results of the intercalibration are summarised in Table 7.1 below:

Table 7.1 – Summary of network performance

| Parameter | Number of outliers | Number in network | % outliers in total |
|--|------------------------------|-------------------|---------------------|
| NO _x analyser | 35 | 106 | 33% |
| CO analyser | 5 | 79 | 6% |
| SO ₂ analyser | 8 | 76 | 11% |
| Ozone analyser | 22 | 85 | 26% |
| TEOM and BAM analysers | 2 k ₀ , 4 flow | 69 TEOM 1 BAM | 8% |
| Gravimetric PM ₁₀ analysers | - | 7 | n/a |
| Total | 76 | 423 | 18% |

An outlier is defined as an analyser that shows a deviation from the network mean of greater than 10% for NO_x, CO and SO₂ and 5% from the standard photometer for O₃. For PM₁₀ analysers, the flow rates must be within 10% of the specified limits and the TEOM k₀ factor must be within 2.5% of the stated value.

In addition to these results, 15 of the 367 site cylinders (~4%) used to scale instrument data into concentrations appeared to have drifted by more than 10% from their certificated values. Five NO_x converters were found to be lower than the 95% acceptance limit.

The number of analyser outliers identified is better than the previous exercise. At the winter 2004 intercalibration 21% of the analysers in use were identified as outliers.

Table 7.2 below presents a breakdown of the outliers identified, on a site-by-site basis:

Table 7.2 – Performance Breakdown

| SITE | Date visited | NO _x | CO | SO ₂ | O ₃ | PM ₁₀ |
|------------------------------------|--------------|-----------------|--------------|-----------------|----------------|------------------|
| ENGLAND | | | | | | |
| Barnsley 12 | 10/8 | | | OK | | |
| Barnsley Gawber | 10/8 | Outlier +15% | OK | OK | Outlier -15% | |
| Bath Roadside | 19/7 | OK | OK | | | |
| Billingham | 7/9 | OK | | | | |
| Birmingham Centre | 4/8 | OK | OK | OK | OK | OK |
| Birmingham East | 2/8 | OK | OK | OK | Outlier +6% | OK |
| Blackpool | 27/9 | Outlier -13% | OK | OK | Outlier -7% | OK |
| Bolton | 17/8 | failed in test | OK | OK | OK | Main flow fail |
| Bottesford | 27/7 | | | | OK | |
| Bournemouth | 21/7 | Outlier -17% | OK | OK | OK | OK |
| Bradford Centre | 16/8 | Outlier -19% | OK | OK | OK | OK |
| Brentford Roadside | 25/8 | Outlier +15% | Outlier +12% | | | |
| Brighton Roadside | 7/9 | OK | OK | | | |
| Brighton Roadside PM ₁₀ | 7/9 | | | | | OK |
| Bristol Centre | 2/8 | OK | OK | OK | Outlier -16% | OK |

| SITE | Date visited | NO _x | CO | SO ₂ | O ₃ | PM ₁₀ |
|-------------------------------------|--------------|-------------------------------|--------------|-----------------|----------------|------------------|
| Bristol Old Market | 2/8 | OK | Outlier -16% | | | |
| Bury Roadside | 17/8 | OK | OK | Outlier +12% | OK | OK |
| Cambridge Roadside | 9/8 | OK | | | | |
| Camden Kerbside | 7/7 | OK | | | | OK |
| Canterbury | 21/7 | OK | | | | OK |
| Coventry Memorial Park | 8/7 | Outlier -16% | OK | OK | OK | OK |
| Exeter Roadside | 3/8 | OK | OK | OK | Outlier -12% | |
| Glazebury | 19/8 | OK | | | Outlier +8% | |
| Great Dun Fell | 15/9 | | | | OK | |
| Haringey Roadside | 14/7 | OK | | | | OK |
| Harwell | 5/7 | OK | | OK | OK | |
| High Muffles | 7/9 | | | | OK | |
| Hove Roadside | 6/9 | Outlier +11% | OK | OK | | |
| Hull Freetown | 29/7 | Outlier +45% | OK | OK | Outlier +8% | OK |
| Ladybower | 24/8 | Outlier -12% | | OK | Outlier +14% | |
| Leamington Spa | 9/9 | OK | OK | OK | OK | OK |
| Leeds Centre | 16/8 | OK | OK | OK | Outlier -8% | OK |
| Leicester Centre | 16/6 | OK | OK | Outlier +12% | OK | OK |
| Liverpool Speke | 7/9 | OK | OK | OK | OK | OK |
| London A3 Roadside | 8/7 | Outlier +22% | OK | | | OK |
| London Bexley | 19/7 | Outlier +11% | OK | OK | OK | OK |
| London Bloomsbury | 6/7 | OK | OK | OK | OK | OK |
| London Brent | 20/8 | Outlier +14% | OK | OK | OK | OK |
| London Bromley | 19/8 | OK | OK | | | |
| London Cromwell Road 2 | 20/9 | Outlier -13% | OK | OK | OK | |
| London Eltham | 23/8 | Outlier +17% | | OK | OK | OK |
| London Hackney | 24/8 | Outlier +16% | Outlier +15% | | OK | |
| London Haringey | 14/7 | | | | Outlier -12% | |
| London Harlington | 2/9 | OK | OK | | Outlier +7% | OK |
| London Hillingdon | 5/7 | Outlier -32% | OK | Outlier -17% | OK | OK |
| London Lewisham | 24/9 | OK | | OK | OK | |
| London Marylebone Road | 15/7 | OK | OK | OK | OK | OK |
| London N. Kensington | 9/7 | OK | OK | OK | OK | OK |
| London Southwark | 13/7 | OK | OK | OK | OK | |
| London Teddington | 21/9 | OK | | Outlier +47% | Outlier -8% | |
| London Wandsworth | 18/8 | OK | | | OK | |
| London Westminster | 6/8 | OK | OK | OK | OK | OK |
| Lullington Heath | 6/9 | OK | | OK | OK | |
| Manchester Piccadilly | 25/8 | OK | OK | OK | OK | OK |
| Manchester South | 24/8 | Converter 92% | | OK | OK | |
| Manchester Town Hall | 25/8 | OK | OK | | | |
| Market Harborough | 30/7 | Outlier -18% | OK | | OK | |
| Middlesbrough | 8/9 | Outlier +29% Converter 72% | OK | OK | OK | OK |
| Newcastle Centre | 13/9 | OK | OK | OK | OK | OK |
| Northampton | 16/7 | OK | OK | OK | OK | OK |
| Northampton PM ₁₀ (Grav) | 16/7 | | | | | OK |

| SITE | Date visited | NO _x | CO | SO ₂ | O ₃ | PM ₁₀ |
|-------------------------|--------------|-------------------------------|--------------|-----------------|----------------|-----------------------------|
| Norwich Centre | 12/8 | Outlier +25% | OK | OK | OK | OK |
| Norwich Roadside | 11/8 | OK | | | | |
| Nottingham Centre | 27/7 | OK | OK | OK | OK | OK |
| Oxford Centre | 7/7 | Outlier +16% Converter 90% | OK | OK | | |
| Plymouth Centre | 4/8 | OK | OK | OK | Outlier -14% | OK |
| Portsmouth | 9/7 | OK | OK | OK | OK | OK |
| Preston | 27/9 | OK | OK | OK | OK | OK |
| Reading New Town | 22/7 | Outlier +26% | OK | OK | Outlier -9% | OK |
| Redcar | 7/9 | Outlier +18% | OK | OK | Outlier +11% | OK |
| Rochester | 20/7 | OK | | OK | OK | OK |
| Rotherham Centre | 9/8 | OK | | OK | OK | |
| Salford Eccles | 24/8 | Outlier +14% | OK | OK | Outlier -8% | OK |
| Sandwell West Bromwich | 8/7 | Outlier +28% | OK | OK | OK | |
| Scunthorpe | 28/7 | | | OK | | OK |
| Sheffield Centre | 10/8 | OK | OK | OK | OK | k _o -2.9% |
| Sheffield Tinsley | 9/8 | OK | OK | | | |
| Sibton | 12/8 | | | | OK | |
| Somerton | 3/8 | OK | | | OK | |
| Southampton Centre | 23/8 | OK | Outlier -19% | OK | OK | OK |
| Southend-on-Sea | 5/8 | OK | OK | OK | OK | OK |
| Southwark Roadside | 13/7 | OK | OK | OK | | |
| St Osyth | 4/8 | Outlier +33% | OK | | OK | |
| Stockport Shaw Heath | 18/8 | OK | OK | OK | | Aux flow fail |
| Stockton-on-Tees Yarm | 6/9 | OK | OK | | | OK |
| Stoke-on-Trent Centre | 16/8 | Outlier +16% | OK | OK | Outlier -9% | OK |
| Sunderland | 14/9 | | | OK | | |
| Thurrock | 22/7 | OK | OK | OK | OK | k _o 's different |
| Tower Hamlets Roadside | 23/9 | OK | OK | | | |
| Walsall Alumwell | 22/9 | Converter 86% | | | | |
| Walsall Willenhall | 3/8 | OK | | | | |
| West London | 20/9 | OK | OK | | | |
| Weybourne | 10/8 | | | | OK | |
| Wicken Fen | 9/8 | OK | | Outlier +19% | OK | |
| Wigan Leigh | 19/8 | OK | OK | OK | OK | k _o +10.1% |
| Wirral Tranmere | 28/9 | Outlier +19% | OK | OK | OK | OK |
| Wolverhampton Centre | | OK | OK | OK | OK | OK |
| Yarner Wood | 4/8 | OK | | | Outlier +15% | |
| NORTHERN IRELAND | | | | | | |
| Belfast Centre | 13/9 | OK | OK | OK | OK | OK |
| Belfast Clara St | 13/9 | | | | | OK |
| Belfast East | 13/9 | | | Outlier +16% | | |
| Derry | 15/9 | OK | OK | OK | Outlier -17% | OK |
| Lough Navar | 16/9 | | | | Outlier +10% | OK |
| SCOTLAND | | | | | | |
| Aberdeen | 27/7 | OK | OK | OK | Outlier +6% | OK |
| Bush Estate | 13/7 | Outlier +11% | | | OK | |

| SITE | Date visited | NO _x | CO | SO ₂ | O ₃ | PM ₁₀ |
|-----------------------|--------------|-----------------|--------------|-----------------|----------------|------------------|
| Dumfries | 12/7 | OK | OK | | | OK |
| Edinburgh St Leonards | 14/7 | OK | OK | OK | OK | OK |
| Eskdalemuir | 13/7 | | | | OK | |
| Glasgow Centre | 19/7 | Outlier -12% | OK | OK | OK | Total flow fail |
| Glasgow City Chambers | 20/7 | OK | OK | | | |
| Glasgow Kerbside | 20/7 | Converter 91% | OK | | | OK |
| Grangemouth | 15/7 | OK | OK | Outlier +15% | OK | OK |
| Inverness | 28/7 | OK | OK | | | OK |
| Strath Vaich | 27/7 | | | | OK | |
| WALES | | | | | | |
| Aston Hill | 9/8 | Outlier +14% | | | OK | |
| Cardiff Centre | 16/9 | OK | Outlier +11% | OK | OK | OK |
| Cwmbran | 17/9 | Outlier +21% | OK | OK | Outlier -10% | OK |
| Narberth | 21/9 | Outlier +14% | | OK | OK | OK |
| Port Talbot | 20/9 | Outlier -15% | | OK | OK | OK |
| Swansea | 20/9 | OK | OK | Outlier +15% | OK | Outlier-flows |
| Wrexham | 28/9 | Outlier -36% | OK | OK | | OK |

The following sections look at each pollutant in turn and investigate causes for outliers.

8 Oxides of Nitrogen

8.1 Intercalibration Outliers

The intercalibration highlighted that the results from 35 sites were outside the $\pm 10\%$ acceptance limit from the network mean. These outliers can be broken down into various types, as presented below:

Twelve outliers can be attributed to changes in the site cylinder concentrations, as listed below:

1. Brentford Roadside ®
2. Hull Freetown ®
3. London Eltham ®
4. London Hillingdon
5. Norwich Centre
6. Reading New Town ®
7. Redcar ®
8. St Osyth
9. Stoke-on-Trent
10. Wirral Tranmere
11. Glasgow Centre ®
12. Aston Hill

® denotes a repeat offender

Data from all the affected sites has been carefully examined and rescaled as needed. No data have been lost as a result of the rescaling. A further 21 outliers can be attributed to drifts in calibration factors between LSO calibrations, and no data will be lost as a result of

these findings. The analysers at Bolton and Middlesbrough were outliers as a result of instrument malfunctions at the time. Some data from these sites have been rejected as a result.

Using the methodology detailed in Section 6, comparison of the network averages to audit cylinder concentrations showed that the network measures concentrations of NO to within 1% of the network standard and NO₂ concentrations to within 6%. The percentage standard deviations of these results, which is an indication of how close the results are grouped together, were less than 5% in both cases. These are good results, and demonstrate that data from the vast majority of NO_x analysers are accurate, harmonised and traceable to national metrology standards.

8.2 Leaking switching valves

This phenomenon has been observed as a significant cause of outliers in NO_x analysers. When NO₂ gas is used for calibration, some analysers have been seen to produce a significant NO signal. This gives cause for concern, because a cylinder of NO₂ will be virtually 100% NO₂, very little NO will be present in the mixture.

Analysers that exhibit this behaviour could be underestimating concentrations of NO₂, as highlighted by the following five outliers:

1. Barnsley Gawber – measured 25 ppb NO in an NO₂ cylinder ®
2. Bournemouth – measured 20 ppb NO in an NO₂ cylinder ®
3. Cromwell Road 2 – measured 10 ppb NO in an NO₂ cylinder
4. Edinburgh St Leonards – measured 15 ppb NO in an NO₂ cylinder
5. Wrexham – measured 16 ppb NO in an NO₂ cylinder

In addition, whilst not identified as outliers, the following sites also measured significant concentrations of NO:

1. Brighton Roadside – measured 13 ppb NO in an NO₂ cylinder
2. Bristol Centre – measured 10 ppb NO in an NO₂ cylinder
3. Bristol Old Market – measured 17 ppb NO in an NO₂ cylinder ®
4. Canterbury – measured 14 ppb NO in an NO₂ cylinder ®
5. Leamington Spa – measured 13 ppb NO in an NO₂ cylinder
6. Bloomsbury – measured 11 ppb NO in an NO₂ cylinder
7. Bromley – measured 13 ppb NO in an NO₂ cylinder ®
8. Manchester South – measured 18 ppb NO in an NO₂ cylinder
9. Middlesbrough – measured 12 ppb NO in an NO₂ cylinder
10. Reading – measured 26 ppb NO in an NO₂ cylinder
11. Southwark Roadside – measured 14 ppb NO in an NO₂ cylinder
12. Wigan Leigh – measured 25 ppb NO in an NO₂ cylinder ®
13. Dumfries – measured 20 ppb NO in an NO₂ cylinder ®

® denotes a repeat offender

These results are worse than those found at the winter 04 exercise where 16 analysers were seen to have this response. The observation is clearly showing an increasing trend – 8 analysers were identified at the summer 03 intercomparison.

The most likely cause for this observation is a leaking switching valve inside the analyser. The valves cycle the analysers between sampling NO_x, NO and, on some models, reference gases, and any leaks within these systems appear to manifest themselves when

calibrating the analysers with NO₂ gas. In many ways, this phenomenon is similar to the leaking main valve faults common to ozone analysers. Unfortunately, as the valves are inside the analysers, it is not possible for LSO's or QA/QC to leak check these valves.

Recommendation

It is therefore recommended that LSO's pay particular attention to the NO₂ calibration results, to see whether the NO response is significantly higher (>10ppb) than that obtained for the zero calibration. These observations should be reported to CMCU as soon as possible.

These faults were highlighted to the ESU's in the weekly report emails during the intercalibration, to ensure that particular attention was paid to servicing and cleaning these switching valves during services, to try to minimise the occurrence of these outliers.

Recommendation

It is strongly recommended that ESU's clean all NOx analyser switching valves during servicing, and ensure the valve is leak checked afterwards.

netcen will continue to monitor these results at audit visits.

8.3 Converter Tests

Five converters were found to be less than 95% efficient:

- Glasgow Kerbside – 91% (9 days data rejected)
- Manchester South – 92% (repeat offender – 5 weeks data rejected)
- Middlesbrough – 72% (Engineer on site during audit – 17 weeks data rejected)
- Oxford – 90% (6 weeks data rejected)
- Walsall Alumwell – 86% (due to water ingress - 1 week data rejected)

A further 3 sites were identified as borderline fail cases where there was no resulting effect on data quality:

- Dumfries – 94.8%
- London A3 Roadside – 94.8%
- Yarner Wood - 94.9%

It is worth noting at this point that the future requirement for the performance of NOx analysers is likely to become much tighter. Converters will need to be at least 98% efficient to avoid data rescaling, and at least 95% efficient to avoid data rejection. Based on the results from the current intercalibration, data rescaling would be required on half of the NOx analysers (53 of the total 106 analysers). Clearly, significant effort would be required to rescale this amount of data. The following analysers showed a response of between 95 and 98%:

| | |
|---------------------------|--------------------------|
| Barnsley Gawber - 95.2% | Newcastle Centre – 96.8% |
| Bath Roadside – 97.7% | Norwich Centre – 96.3% |
| Billingham – 95.8% | Norwich Roadside – 95.2% |
| Birmingham Centre – 95.9% | Preston – 97.5% |
| Blackpool – 97.7% | Redcar 95.6% |
| Brighton Roadside – 95.5% | Rotherham Centre – 97.9% |

| | |
|---------------------------------|--------------------------------|
| Bristol Old Market – 95.7% | Sandwell West Bromwich – 96.4% |
| Cambridge Roadside – 97.9% | Sheffield Centre – 97.4% |
| Camden Roadside – 96.4% | Sheffield Tinsley – 96.9% |
| Canterbury – 96.3% | Somerton – 97.4% |
| Hove Roadside – 95.3% | Southwark Roadside – 95.6% |
| Leeds Centre – 95.8% | Stockton-on-Tees Yarm – 95.3% |
| Liverpool Speke – 96.6% | Stoke-on-Trent Centre – 95.1% |
| London Bloomsbury – 95.1% | Thurrock – 97% |
| London Brent – 95.7% | Wicken Fen – 96.8% |
| London Bromley – 96% | Wigan Leigh – 96% |
| London Cromwell Road 2 – 96.2% | Wirral Tranmere – 97.6% |
| London Eltham – 95.1% | Derry – 96.3% |
| London Harlington – 96.1% | Glasgow Centre – 95.5% |
| London Marylebone Road – 96.7% | Glasgow City Chambers – 96% |
| London North Kensington – 96.3% | Grangemouth – 97.5% |
| London Southwark – 95.6% | Inverness – 96.1% |
| London Wandsworth – 95.2% | Aston Hill – 96.5% |
| London Westminster – 95.9% | Cardiff Centre – 95.2% |
| Lullington Heath – 95.1% | Narberth – 96.7% |
| Manchester Piccadilly – 97.2% | Swansea – 96.6% |
| | Wrexham – 97.7% |

9 Carbon Monoxide

The intercalibration showed that the results from 5 analysers were outside the $\pm 10\%$ acceptance criterion. Of these, 2 can be attributed to drifts in calibration factors between LSO calibrations, and no data were lost as a result of this.

The analysers at Bristol Old Market, Hackney and Southampton Centre all exhibited faults at the time of the audit, and it is likely that this has compromised the audit results. The data from the sites have been examined during ratification; some data from all three sites have been rejected as a result of these investigations.

Comparison of the network average to the audit cylinder concentration showed that the network measures CO concentrations to within 1% of the reference standard. The percentage standard deviation was 3%. These are very good results, and demonstrate that data from the CO analysers are accurate, harmonised and traceable to national metrology standards.

The analyser at Stockport Shaw Heath failed during the audit. Two months data have been rejected from this analyser.

10 Sulphur Dioxide

10.1 Intercalibration Outliers

The intercalibration showed that the results from 8 analysers were outside the $\pm 10\%$ acceptance criterion. Of these, 7 can be attributed to drifts in calibration factors between LSO calibrations, and no data were lost as a result of this. The remaining outlier arose as a result of a change in the concentration of the site cylinder. Data from this site (London Teddington) have been carefully examined and rescaled as needed.

Comparison of the network average to the audit cylinder concentration showed that the network measures SO₂ concentrations to within 1% of the reference standard. The percentage standard deviation was less than 5%. These are good results, and demonstrate that data from the SO₂ analysers are accurate, harmonised and traceable to national metrology standards.

The Northampton analyser was found to have moisture in the sample tubing, which compromised the results of the audit. One week of data have been rejected as a result.

10.2 m-xylene tests

The efficiency of the hydrocarbon “kicker” was evaluated with a 1 ppm m-xylene cylinder. The kicker selectively removes hydrocarbons from the sample inlet prior to analysis. This is an important test, because m-xylene behaves in a similar manner to SO₂ when exposed to UV light within the analyser, and could therefore interfere with the analyser response, if the kicker does not function properly.

To pass the test, the analyser must not respond by more than 1% (10 ppb) of the m-xylene cylinder concentration. However, it should be noted that this particular test is very demanding; typical ambient hourly maximum concentrations of this pollutant rarely exceed 50 ppb, and annual concentrations rarely exceed 5 ppb.

The following 27 analysers were outside the required standard:

| | | |
|-----|-------------------|-------------|
| 1. | Barnsley Gawber | (16ppb) ® |
| 2. | Birmingham Centre | (19ppb) |
| 3. | Blackpool | (12ppb) 2x® |
| 4. | Bolton | (18ppb) ® |
| 5. | Bournemouth | (11ppb) |
| 6. | Bristol Centre | (20ppb) |
| 7. | Bury | (29ppb) ® |
| 8. | Exeter | (20ppb) |
| 9. | Harwell | (11ppb) |
| 10. | Hove | (14ppb) ® |
| 11. | Hull Freetown | (22ppb) ® |
| 12. | Leamington Spa | (21ppb) |
| 13. | Liverpool | (21ppb) |
| 14. | Bexley | (15ppb) |
| 15. | Bloomsbury | (17ppb) ® |
| 16. | Brent | (12ppb) ® |
| 17. | Eltham | (24ppb) |

| | | |
|-----|-----------------------|-------------|
| 18. | Lewisham | (20ppb) |
| 19. | Marylebone Road | (12ppb) |
| 20. | North Kensington | (21ppb) 2x® |
| 21. | Westminster | (21ppb) |
| 22. | Lullington Heath | (22ppb) ® |
| 23. | Manchester Piccadilly | (17ppb) 2x® |
| 24. | Manchester South | (21ppb) 2x® |
| 25. | Middlesbrough | (16ppb) |
| 26. | Newcastle | (23ppb) 2x® |
| 27. | Norwich Centre | (21ppb) 2x® |
| 28. | Oxford | (13ppb) |
| 29. | Preston | (18ppb) |
| 30. | Rochester | (11ppb) |
| 31. | Rotherham | (11ppb) ® |
| 32. | Eccles | (14ppb) |
| 33. | Sheffield Centre | (20ppb) ® |
| 34. | Southampton | (21ppb) 2x® |
| 35. | Stockport Shaw Heath | (20ppb) ® |
| 36. | Stoke-on-Trent | (22ppb) ® |
| 37. | Sunderland | (16ppb) ® |
| 38. | Thurrock | (23ppb) |
| 39. | Wicken Fen | (17ppb) |
| 40. | Belfast Centre | (20ppb) |
| 41. | Edinburgh St Leonards | (23ppb) |
| 42. | Grangemouth | (21ppb) 2x® |
| 43. | Cardiff | (11ppb) |
| 44. | Narberth | (20ppb) 2x® |
| 45. | Port Talbot | (12ppb) ® |

® denotes a repeat offender

Recommendation

The hydrocarbon kickers at Blackpool, North Kensington, Manchester Piccadilly, Manchester South, Newcastle, Norwich Centre, Southampton, Grangemouth and Narberth have now failed on three consecutive occasions and should be replaced as soon as possible. Replacement of the other kickers that are repeat offenders should be considered.

These results are significantly worse than the previous intercalibration, when 27 analyser kickers were identified as outliers. There will be a future CEN requirement that kicker response to 1ppm m-xylene must be lower than 1% (i.e. 10ppb SO₂), or data will be rejected. It is therefore concerning that an increasing number of analysers are failing this test. However, at present, none of these results give immediate cause for concern. No data have been rejected, and no specific actions are required at present, other than the replacement recommendations at the repeat offender sites listed above.

To put these results into perspective, at the expected maximum ambient concentrations of m-xylene (50ppb), the worst kicker would show an interference response of around 1.5 ppb.

11 Ozone

Calibration of the network analysers against the **netcen** reference photometers showed that 22 analysers were outside the $\pm 5\%$ acceptance criterion. This is identical to the previous exercise, where 22 analysers tested were also identified as outliers.

Of the 22 analysers, 13 had drifted by less than 10%; ratification of these datasets was straightforward, with no loss of data.

The remaining 9 analysers had drifted by less than 17%. Ratification of the data from these analysers has been more complex, to ensure that suitable scaling of the data could be applied, but no losses of data were necessary.

These results are significantly better than the winter 2004 intercalibration, where 5 analysers were found to be more than 20% from the reference photometer. This is an encouraging result, and is a reflection of the ESU's having a better understanding of what is required in terms of calibrations at service exercises.

12 Particulate analysers

12.1 TEOM k_0

There were two outliers for TEOM k_0 during this intercalibration.

The analyser at Sheffield Centre was again identified as an outlier at 2.9% from its stated value. The history of the analyser has been examined, and the dataset has been rescaled as appropriate with no loss of data. It is recommended that the k_0 values on the control and sensor units of this analyser are now adjusted accordingly.

The analyser at Wigan Leigh was found to have a sensor unit k_0 value that was more than 10% from the calculated result. However, the value held in the control unit agreed with the calculated k_0 value, thus the results from the instrument are being scaled correctly. We recommend that the value on the sensor unit is adjusted to agree with the value stored on the control unit.

All other TEOM calibration factors were calculated to be within 2.5% of their stated values.

12.2 Analyser Flow Rates

The flow rates of the analysers at four sites were found to be outside the $\pm 10\%$ acceptance limit:

- | | | |
|----|----------------|--------------------|
| 1. | Bolton | (Main Flow +13%) |
| 2. | Stockport | (Aux Flow -40%) |
| 3. | Glasgow Centre | (Total Flow -73%) |
| 4. | Swansea | (Main Flow -45%) ® |

® denotes a repeat offender

The analysers at Stockport, Glasgow Centre and Swansea also failed the leak tests. Close examination of the datasets suggests that ambient data at Stockport, Glasgow Centre and Swansea have been effected by the response leaks. The analyser at Swansea was also

identified as failing the leak test in the previous winter 2004 intercomparison, 9 months data have been rejected as a result of these findings.

12.3 Analyser Configuration Information

The PM₁₀ analysers used in the network, especially the TEOMs, are a wide range of ages and permutations. We have started to compile a database of how all the analysers are configured. Tables 12.1 and 12.2 below summarise the major settings:

Table 12.1 – TEOM Configurations:

| Site | Type | Serial Number | Software | Flow corrected to 25°C, 1atm? | Wait time = 1800s | MR/MC ave = 300 | Main Flow | Const A = 3 | Const B = 1.03 |
|-------------------------|------|---------------|----------|-------------------------------|-------------------|-----------------|-----------|-------------|----------------|
| Birmingham Centre | A | 2297 | 2.106 | No | Yes | Yes | 3 | Yes | Yes |
| Birmingham East | AB | 24637 | 3.017 | Yes | Yes | Yes | 3 | Yes | Yes |
| Blackpool | | | | | | | | | |
| Bolton | AB | 21197 | 3.003 | Yes | Yes | Yes | 3 | Yes | Yes |
| Bradford Centre | AB | 21494 | 3.008 | Yes | No - set to 180 | Yes | 2 | Yes | Yes |
| Brighton Roadside | | | | | | | | | |
| Bristol Centre | A | 24426 | 3.017 | Yes | Yes | Yes | 2 | Yes | Yes |
| Bury Roadside | AA | 658 | 3.014 | No | Yes | Yes | 2 | Yes | Yes |
| Camden Kerbside | | | | | | | | | |
| Canterbury | A | 20931 | 2.115 | No | Yes | Yes | 3 | Yes | Yes |
| Coventry Memorial Park | AB | 25026 | 3.018 | Yes | Yes | Yes | 3 | Yes | Yes |
| Haringey Roadside | A | 20695 | 2.115 | No | Yes | No - set 900 | 3 | Yes | Yes |
| Harwell | AB | 21489 | 3.013 | Yes | Yes | Yes | 3 | Yes | Yes |
| Harwell PM2.5 | AB | 21490 | 3.005 | Yes | Yes | Yes | 3 | Yes | Yes |
| Hull Freetown | A | 24445 | 3.017 | No | No - set 10 | Yes | 2 | Yes | Yes |
| Leamington Spa | A | 2075 | 2.113 | No | Yes | Yes | 3 | Yes | Yes |
| Leeds Centre | | | | | | | | | |
| Leicester Centre | | | | | | | | | |
| Liverpool Speke | | | | | | | | | |
| London A3 Roadside | | | | | | | | | |
| London Bexley | AB | 2000 | 3.005 | No | Yes | Yes | 2 | Yes | Yes |
| London Bloomsbury | AB | 24446 | 3.017 | No | Yes | Yes | 3 | Yes | Yes |
| London Bloomsbury PM2.5 | AB | 21492 | 3.005 | Yes | Yes | Yes | 3 | Yes | Yes |
| London Brent | AB | 21145 | 3.003 | No | Yes | Yes | 3 | Yes | Yes |
| London Eltham | AA | 2096 | 3.013 | No | Yes | No - set 900 | 3 | Yes | Yes |
| London Harlington | | | | | | | | | |
| London Hillingdon | | | | | | | | | |
| London Marylebone Road | AB | 21306 | 3.005 | Yes | Yes | No - set 900 | 3 | Yes | Yes |
| London N. Kensington | | | | | | | | | |
| Manchester | AA | 2000 | 3.015 | No | Yes | Yes | 2 | Yes | Yes |

| Site | Type | Serial Number | Software | Flow corrected to 25°C, 1atm? | Wait time = 1800s | MR/MC ave = 300 | Main Flow | Const A = 3 | Const B = 1.03 |
|-----------------------|------|---------------|----------|-------------------------------|-------------------|-----------------|-----------|-------------|-----------------|
| Piccadilly | | | | | | | | | |
| Middlesbrough | | | | | | | | | |
| Newcastle Centre | | | | | | | | | |
| Northampton | AB | 21621 | 3.009 | Yes | Yes | Yes | 3 | Yes | Yes |
| Norwich Centre | AB | 21495 | 3.012 | Yes | No - set180 | Yes | 2 | Yes | Yes |
| Nottingham Centre | A | 20904 | 3.016 | No | Yes | Yes | 2 | Yes | Yes |
| Plymouth Centre | AB | 24428 | 3.017 | Yes | No - set180 | Yes | 2 | Yes | Yes |
| Portsmouth | AB | 21578 | 3.009 | Yes | Yes | Yes | 3 | Yes | Yes |
| Preston | | | | | | | | | |
| Reading New Town | AB | 2000 | 3.016 | Yes | No - set180 | Yes | 2 | Yes | Yes |
| Redcar | AB | 21344 | 3.005 | No | No - set450 | Yes | 3 | Yes | Yes |
| Rochester | AB | 24381 | 3.017 | Yes | Yes | Yes | 3 | Yes | Yes |
| Rochester PM2.5 | AB | 21491 | 3.012 | Yes | Yes | Yes | 3 | Yes | Yes |
| Salford Eccles | AB | 21168 | 3.003 | Yes | Yes | Yes | 2 | Yes | Yes |
| Scunthorpe Town | A | 2000 | 3.018 | No | Yes | Yes | 3 | Yes | Yes |
| Sheffield Centre | AA | 20915 | 3.016 | No | No - set180 | Yes | 2 | Yes | Yes |
| Southampton Centre | AB | 4484 | 3.017 | Yes | No - set300 | Yes | 2 | Yes | Yes |
| Southend-on-Sea | | | | | | | | | |
| Stockport Shaw Heath | AA | 2000 | 3.015 | No | Yes | Yes | 3 | Yes | Yes |
| Stockton-on-Tees Yarm | AB | 22885 | 3.013 | Yes | Yes | Yes | 3 | Yes | Yes |
| Stoke-on-Trent Centre | AB | 21317 | 3.005 | Yes | Yes | Yes | 2 | Yes | Yes |
| Thurrock | AB | 25039 | 3.018 | Corrects to ambient | Yes | Yes | 3 | Yes | Yes |
| Wigan Leigh | AB | 22188 | 3.016 | Yes | Yes | Yes | 3 | Yes | Yes |
| Wirral Tranmere | | | | | | | | | |
| Wolverhampton Centre | | | | | | | | | |
| Belfast Centre | AB | 24423 | 3.017 | Yes | Yes | Yes | 3 | Yes | Yes |
| Derry | AB | 49608 | 3.005 | Yes | Yes | Yes | 2 | Yes | Yes |
| Lough Navar | AB | 21196 | 3.012 | Yes | No - set900 | Yes | 3 | Yes | Yes |
| Aberdeen | AB | 24427 | 3.017 | No | Yes | Yes | 3 | Yes | Yes |
| Edinburgh St Leonards | AB | 21308 | 3.005 | Yes | Yes | Yes | 2 | Yes | No - set to 1.0 |
| Glasgow Centre | A | 20913 | 2.115 | No | Yes | Yes | 2 | Yes | Yes |
| Glasgow Kerbside | AB | 24444 | 3.017 | No | Yes | Yes | 2 | Yes | Yes |
| Grangemouth | AB | 22763 | 3.012 | Yes | Yes | Yes | 3 | Yes | Yes |
| Cardiff Centre | AB | 2449 | 3.017 | Yes | Yes | Yes | 2 | Yes | Yes |
| Cwmbran | AB | 21557 | 3.009 | Yes | Yes | Yes | 3 | Yes | Yes |
| Narberth | AB | 21143 | 3.017 | Yes | No - set180 | Yes | 3 | Yes | Yes |
| Port Talbot | AA | 9402 | 3.011 | No - corrects to 0° | Yes | Yes | 3 | Yes | Yes |
| Swansea | A | 2130 | 2.103 | No | Yes | Yes | 2 | Yes | Yes |

Table 12.2 – Partisol Configurations:

| Site | Serial number | Software | Flow corrected to 25°C, 1atm? | Start time | Duration | Mode |
|--------------------|---------------|----------|-------------------------------|------------|----------|-------|
| Bournemouth | 21257 | 1.4 | Yes | 0:00 | 24h | Basic |
| Harwell PM2.5 | 21020 | 1.202 | Yes | 0:00 | 24h | Basic |
| London Westminster | 20939 | 1.202 | Yes | 0:00 | 24h | Basic |
| Northampton | | | | | | |
| Dumfries | 21221 | 1.4 | Yes | 0:00 | 24h | Basic |
| Inverness | 21255 | 1.4 | Yes | 0:00 | 24h | Basic |
| Wrexham | | | | | | |

Note - sites with blank entries will be completed during the Winter 2005 roadshow.

Values highlighted in bold are at settings that are different from the configurations being used for the PM₁₀ intercomparison studies. Once the results of these studies are known, QA/QC Unit will provide recommendations for any required flow adjustments. **No flow adjustments should, therefore, be made at this time.** However, the Wait Time settings must be 1800 and the MR/MC average and TM average settings must be 300. ESU's should therefore adjust these settings, if needed, at the next service visit"

Recommendations

Specific actions required are:

- Wait time must be set to 1800 seconds
- MR/MC average must be set to 300 seconds
- Constant B on the TEOM at Edinburgh must be set to 1.03

13 Site Cylinder Concentrations

During the intercalibration, the concentrations of the on-site cylinders were evaluated using the audit cylinder standards. The calculated results showed that 15 of the 367 cylinders (~4%) used to scale analyser data into concentrations (NO, CO and SO₂) appear to be outside the ±10% acceptance criterion. This is better than the Winter 2004 roadshow, where 5% (18 cylinders) were outside the acceptance limits.

In addition, the concentrations of 30 NO₂ cylinders appear to have drifted by more than 10%.

In total, 45 of the 367 cylinders (~12%) were outside the acceptance limits. This is better than the previous intercalibration, where 14% of the cylinders were found to be out of specification.

The site cylinder evaluations are performed by calibrating the analysers with audit and site cylinder gas through the same inlet system, and using the conditioned site cylinder regulators, thus minimising any possible errors due to contaminated tubing or regulators.

As a result of this exercise, nine cylinders were identified for replacement:

1. Teddington SO₂
2. Teddington NO₂
3. Swansea SO₂
4. Hull Freetown NO
5. Eltham NO
6. Reading New Town NO
7. Stoke-on-Trent NO
8. Wirral Tranmere NO
9. Glasgow Centre NO

14 Site Information

We have compiled additional information about the monitoring stations in the network, including the types of sampling systems deployed on site.

The Table below presents information about the sampling systems deployed on site, together with accurate, validated grid references. Considerable effort has been made, both in compiling these grid references, and in ensuring the measurements are accurate to within 1 metre (it should be noted that the uncertainty of the GPS system used is typically the order of ± 10 metres).

The following Table 41.1 presents the information collated to date:

Table 14.1 – Site Information

| Site Name | Manifold type | Grid Reference | 6 figure easting | 6 figure northing |
|-------------------|--------------------|----------------|------------------|-------------------|
| Aberdeen | Glass | NJ944074 | 394416 | 807408 |
| Aston Hill | Glass | SO299901 | 329902 | 290062 |
| Barnsley 12 | Narrow-bore Teflon | SE343065 | 434276 | 406542 |
| Barnsley Gawber | Wide-bore Teflon | SE325075 | 432529 | 407472 |
| Bath Roadside | Narrow-bore Teflon | ST759661 | 375882 | 166069 |
| Belfast Centre | Glass | lat/long | 5°55'39.3"W | 54°35'58.8"N |
| Belfast Clara St | N/A | lat/long | | |
| Belfast East | Narrow-bore Teflon | lat/long | 5°54'2.1"W | 54°35'47.5"N |
| Billingham | Glass | NZ470237 | 446962 | 523650 |
| Birmingham Centre | Glass | SP063869 | 406342 | 286862 |
| Birmingham Tyburn | Glass | SP115889 | 411536 | 288870 |
| Blackpool | Wide-bore Teflon | SD323332 | 332320 | 433215 |
| Bolton | Wide-bore Teflon | SD710086 | 371000 | 408562 |
| Bottesford | Narrow-bore Teflon | SK798377 | 479768 | 337654 |
| Bournemouth | Narrow-bore Teflon | SZ123933 | 412320 | 93344 |
| Bradford Centre | Wide-bore Teflon | SE166331 | 416615 | 433098 |

| Site Name | Manifold type | Grid Reference | 6 figure easting | 6 figure northing |
|-----------------------------------|---------------------|----------------|------------------|-------------------|
| Brentford Roadside | Narrow-bore Teflon | TQ174780 | 517425 | 178074 |
| Brighton Preston Park | Wide-bore Teflon | TQ305062 | 530508 | 106222 |
| Brighton Roadside | Glass | TQ313043 | 531307 | 104305 |
| Brighton Roadside _{PM10} | | TQ313043 | 531322 | 104302 |
| Bristol Centre | Glass | ST594733 | 359427 | 173285 |
| Bristol Old Market | Glass | ST596732 | 359570 | 173173 |
| Bury Roadside | Glass | SD809048 | 380922 | 404772 |
| Bush Estate | High Flow wide tube | NT246639 | 324626 | 663880 |
| Cambridge Roadside | Narrow-bore Teflon | SL452582 | 545248 | 258155 |
| Camden Kerbside | Narrow-bore Teflon | TQ268841 | 526786 | 184075 |
| Canterbury | Narrow-bore Teflon | TR162573 | 616198 | 157330 |
| Cardiff Centre | Glass | ST184765 | 318417 | 176505 |
| Coventry Memorial Park | Wide-bore Teflon | SP328773 | 432801 | 277340 |
| Cwmbran | Wide-bore Teflon | ST305954 | 330510 | 195436 |
| Derry | Wide-bore Teflon | lat/long | 7°19'42.1"W | 55°0'2.2"N |
| Dumfries | Narrow-bore Teflon | NX970763 | 297012 | 576278 |
| Edinburgh St Leonards | Glass | NT263731 | 326250 | 673132 |
| Eskdalemuir | Narrow-bore Teflon | NT235030 | 323528 | 603030 |
| Exeter Roadside | Stainless Steel | SX919928 | 291940 | 92840 |
| Glasgow Centre | Wide-bore Teflon | NS589650 | 258902 | 665028 |
| Glasgow City Chambers | Narrow-bore Teflon | NS595653 | 259528 | 665308 |
| Glasgow Kerbside | Wide-bore Teflon | NS587652 | 258708 | 665200 |
| Glazebury | Narrow-bore Teflon | SJ687960 | 368733 | 396034 |
| Grangemouth | Wide-bore Teflon | NS538810 | 293840 | 681032 |
| Great Dun Fell | Narrow-bore Teflon | NY710322 | 371020 | 532190 |
| Haringey Roadside | Narrow-bore Teflon | TQ339907 | 533885 | 190669 |
| Harwell | Wide-bore Teflon | SU468860 | 446772 | 186020 |
| High Muffles | Wide-bore Teflon | SE774939 | 477535 | 493865 |
| Hove Roadside | Glass | TQ301045 | 530088 | 104484 |
| Hull Freetown | Glass | TA095293 | 509478 | 429329 |
| Inverness | Glass | NH657457 | 265720 | 845680 |

| Site Name | Manifold type | Grid Reference | 6 figure easting | 6 figure northing |
|------------------------|--------------------|----------------|------------------|-------------------|
| Ladybower | Wide-bore Teflon | SK166896 | 416575 | 389565 |
| Leamington Spa | Glass | SP321659 | 465906 | 265906 |
| Leeds Centre | Glass | SE300343 | 429976 | 434268 |
| Leicester Centre | Glass | SK588041 | 458767 | 304075 |
| Liverpool Speke | Glass | SJ439836 | 343860 | 383598 |
| London A3 Roadside | Wide-bore Teflon | TQ190652 | 518983 | 165220 |
| London Bexley | Glass | TQ519764 | 551852 | 176396 |
| London Bloomsbury | Glass | TQ301820 | 530107 | 182041 |
| London Brent | Glass | TQ196893 | 519570 | 189275 |
| London Bromley | Narrow-bore Teflon | TQ405693 | 540533 | 169334 |
| London Cromwell Road 2 | Wide-bore Teflon | TQ265790 | 526530 | 178975 |
| London Eltham | Narrow-bore Teflon | TQ440747 | 543978 | 174668 |
| London Hackney | Wide-bore Teflon | TQ348862 | 534812 | 186230 |
| London Haringey | Narrow-bore Teflon | TQ299891 | 529914 | 189132 |
| London Harlington | Narrow-bore Teflon | TQ083778 | 508299 | 177809 |
| London Hillingdon | Glass | TQ082778 | 508294 | 177791 |
| London Lewisham | Narrow-bore Teflon | TQ069786 | 506933 | 178607 |
| London Marylebone Road | Glass | TQ376737 | 537637 | 173669 |
| London N. Kensington | Narrow-bore Teflon | TQ280820 | 528049 | 181989 |
| London Southwark | Glass | TQ240817 | 524049 | 178494 |
| London Teddington | Glass | TQ323785 | 532299 | 178494 |
| London Wandsworth | Narrow-bore Teflon | TQ155704 | 515538 | 170427 |
| London Westminster | Glass | TQ258747 | 525778 | 174677 |
| Lough Navar | Glass | lat/long | 7°53'55.9"W | 54°26'21.5"N |
| Lullington Heath | Wide-bore Teflon | TQ538016 | 553800 | 101600 |
| Mace Head | Narrow-bore Teflon | lat/long | 9°54'14.1"W | 53°19'35.2"N |
| Market Harborough | Glass | SP833959 | 483337 | 295905 |
| Manchester Piccadilly | Glass | SJ843983 | 384310 | 398325 |
| Manchester South | Glass | SJ839858 | 383912 | 385828 |
| Manchester Town Hall | Wide-bore Teflon | SJ839980 | 383874 | 397976 |
| Middlesbrough | Glass | NZ505196 | 450480 | 519632 |
| Narberth | Wide-bore Teflon | SN146127 | 214640 | 212700 |
| Newcastle Centre | Glass | NZ250649 | 425016 | 564940 |
| Northampton | Glass | SP761645 | 476111 | 264524 |
| Norwich Centre | Wide-bore Teflon | TG231089 | 623078 | 308910 |

| Site Name | Manifold type | Grid Reference | 6 figure easting | 6 figure northing |
|------------------------|---------------------|----------------|------------------|-------------------|
| Norwich Roadside | Narrow-bore Teflon | TG235078 | 623460 | 307817 |
| Nottingham Centre | Glass | SK574401 | 457420 | 340050 |
| Oxford Centre | Wide-bore Teflon | SP514062 | 451366 | 206152 |
| Plymouth Centre | Glass | SX477546 | 247742 | 54610 |
| Port Talbot | Glass | SS780882 | 278036 | 188249 |
| Portsmouth | Glass | SU657036 | 465686 | 103607 |
| Preston | Wide-bore Teflon | SD552301 | 355248 | 430143 |
| Reading | Wide-bore Teflon | SU734732 | 473441 | 173198 |
| Redcar | Glass | NZ600246 | 459975 | 524563 |
| Rochester | Narrow-bore Teflon | TQ831762 | 583133 | 176220 |
| Rotherham Centre | Teflon coated metal | SK431930 | 443088 | 393028 |
| Salford Eccles | Glass | SJ779987 | 377932 | 398713 |
| Sandwell West Bromwich | Glass | SO597467 | 459720 | 246684 |
| Scunthorpe | Narrow-bore Teflon | SE906107 | 490592 | 410689 |
| Scunthorpe Town | TBA | | | |
| Sheffield Centre | Glass | SE903108 | 490316 | 410837 |
| Sheffield Tinsley | Glass | SK351869 | 435134 | 386885 |
| Sibton | Wide-bore Teflon | TM363719 | 636271 | 271875 |
| Somerton | Wide-bore Teflon | ST485265 | 348544 | 126525 |
| Southampton Centre | Glass | SU426123 | 442565 | 112255 |
| Southend-on-Sea | Wide-bore Teflon | TQ856861 | 585566 | 186130 |
| Southwark Roadside | Wide-bore Teflon | TQ346777 | 534621 | 177680 |
| St Osyth | Glass | TM104132 | 610426 | 213205 |
| Stockport Shaw Heath | Glass | SJ894896 | 389386 | 389604 |
| Stockton-on-Tees Yarm | Wide-bore Teflon | NZ419129 | 441908 | 512886 |
| Stoke-on-Trent Centre | Wide-bore Teflon | SJ883479 | 388348 | 347894 |
| Strath Vaich | Wide-bore Teflon | NH348748 | 234829 | 874785 |
| Sunderland | Narrow-bore Teflon | NZ399570 | 439895 | 556970 |
| Sunderland Silksworth | Wide-bore Teflon | NZ381545 | 438142 | 554473 |
| Swansea | Glass | SS656932 | 265566 | 193158 |
| Thurrock | Glass | TQ610779 | 561018 | 177894 |
| Tower Hamlets Roadside | Narrow-bore Teflon | TQ359822 | 535914 | 182230 |
| Walsall Alumwell | Narrow-bore Teflon | SO994983 | 399374 | 298264 |

| Site Name | Manifold type | Grid Reference | 6 figure easting | 6 figure northing |
|----------------------|--------------------|----------------|------------------|-------------------|
| Walsall Willenhall | Glass | SO979012 | 397860 | 201173 |
| West London | Wide-bore Teflon | TQ250788 | 525041 | 178751 |
| Weybourne | Narrow-bore Teflon | TG098438 | 609832 | 343775 |
| Wicken Fen | Wide-bore Teflon | TL563692 | 556310 | 269210 |
| Wigan Leigh | Narrow-bore Teflon | SD578060 | 357825 | 406025 |
| Wigan Centre | TBA | | | |
| Wirral Tranmere | Wide-bore Teflon | SJ665998 | 366468 | 399842 |
| Wolverhampton Centre | Glass | SJ321866 | 332096 | 386644 |
| Wrexham | Glass | SO914989 | 391368 | 298942 |
| Yarner Wood | Wide-bore Teflon | SJ329499 | 332862 | 349904 |

TBA = to be advised in a future report

The grid references quoted in the above table are obtained from GPS measurements, confirmed by reference to Ordnance Survey 1:25000 maps and internet street mapping services. The 6 figure easting and northing references are obtained from GPS measurements, quoted to 1 metre accuracy, and also referenced to internet street mapping services. It should be noted that these figures are likely to carry an uncertainty of ± 10 metres.

For sites in Northern Ireland, Latitude and Longitude references are used to ensure accurate positioning. The GB and Irish grid reference systems are slightly different, which can lead to positioning errors.

It is suggested that Management Units check the accuracy of their databases and websites against these data, and provide feedback or update accordingly.

This table will be used to calculate a number of additional parameters, including: Latitude / Longitude of all sites and altitude of the station above sea level. Future reports will include this information, plus the height of sampling inlets above the ground.

15 CEN

The European Committee for Normalisation (CEN) have prepared a series of documents prescribing how analysers must be operated, to produce datasets that conform to the Data Quality Objectives of the EC Directives. The CEN documents for operation of air pollution analysers; ISO14211 (NO_x), ISO14212 (SO₂), ISO14626 (CO) and ISO14625 (O₃) set out a series of performance criteria for analysers which must be achieved, both in the field and under laboratory conditions.

By way of example, the performance of an analyser in the field must pass a number of tests, including:

- Linearity – the analyser must have a maximum error at any point of less than 5% of the predicted value. This is much tougher to achieve than the current criteria (r^2)

of 0.99 or better). Netcen has begun to record maximum residuals from linearity tests, to evaluate the performance of current analysers against these tougher requirements. These results will be reported in detail in the Winter 2005 intercalibration report.

- NO_x Converter efficiency must be better than 98%. Data may be rescaled for efficiencies between 95 and 98%, but rejected if below 95%. Again, this is tighter than currently, where we accept "borderline" failures. Netcen already use the CEN method for undertaking converter tests.
- The sampling system that delivers air to the analyser must remove no more than 2% of the gas to be analysed. Netcen continue to evaluate systems to calibrate sampling systems, but this is not currently undertaken on a routine basis in the UK. A report on the evaluation of methodologies to test losses of gases to sampling manifolds has been completed by QA/QC Unit. This report is available on the AURN Hub and Air Quality Archive.
- The concentration of the site cylinders will need to be determined every six months, and the revised values used to scale ambient data. This is a change to our current procedures, where no action is taken until a cylinder deviates from its stated value by more than 10%. Netcen have introduced a new procedure for handling drifting cylinder concentrations. In future, the uncertainty of this calculation will need to be substantially lower than the current 10% limit (in the order of 4-5% maximum).
- SO₂ response to a 1ppm meta xylene cylinder will need to be less than 1% (10ppb). This is the current requirement, but action is not taken unless the result is very high (>50ppb), or until an analyser repeats a failure six months later.

The CEN operating methodologies will be formally ratified in February 2005, and adopted into the requirements of the Framework Directive in August 2005. It is understood that Member States will then have up to two years to ensure their monitoring networks are compliant. Netcen are taking steps to ensure the procedures used in the UK comply with the requirements ahead of any imposed deadlines.

16 Safety

netcen undertakes regular extensive risk assessments of all its activities on-site, to ensure that its staff are not exposed to unsafe practices while working.

There are no significant issues identified that presented significant risk during this intercalibration exercise. The issue of safe roof access, to audit PM₁₀ analyser flow rates has largely been worked around. This has been achieved either by installing ladder securing points on the outside of the huts, or by auditing flow rates inside the monitoring station. However, performing flow measurements inside means that we are unable to perform leak tests on these analysers. For this reason, it would be useful if safer roof access (ladder securing points) could be considered for the following sites:

1. Blackpool (site closed on 10th November 2004 for relocation)
2. London Brent
3. Southend-on-Sea
4. Narberth

In addition, safe roof access is not possible at the following sites:

1. Bolton
2. Coventry Memorial Park

We will be undertaking a full safety review of the monitoring stations during the Winter 2005 roadshow.

Recommendation

| |
|--|
| Whilst the Blackpool site is out of service, the opportunity should be taken to ensure ladder securing points are attached to allow safer roof access prior to the site being relocated. |
|--|

17 Certification

The Network Certificate of Calibration is presented in Appendix B1. This certificate presents the results of the individual analyser scaling factors on the day of the audit, as calculated by **netcen** using the audit cylinder standards, in accordance with our UKAS accreditation.

18 Summary

The intercalibration exercise has demonstrated its value as an effective tool in determining overall site performance and assessing the reliability and traceability of air quality measurements from a large scale network. The results from this intercalibration have been used to assess data quality during the ratification of the network datasets for the period July to September 2004.

Appendix A1

As requested by the Department, QA/QC Unit has provided a list of suggestions for equipment that may need replacing or up grading in the network. The following provides a summary of the list and the actions taken to date since January 2004. Recommendations have been prioritised as follows:

| Priority | Definition | Time-scale |
|----------|--|----------------|
| High* | Immediate action necessary to avoid compromising data capture/quality or safety. Critical sites should be treated as high priority. | Within 2 weeks |
| Medium | Essential but not immediate | 3-6 months |
| Low | Desirable but not essential | As appropriate |

*Note – QA/QC Unit's practice is to notify CMCU immediately of any high priority issues at the time of the event.

| | Recommendations January 2004 | Priority | Action |
|-------------------------------------|---|-------------------------|---|
| 1 | Advice on requirements for further AURN equipment up-grades has been given to CMCU (20/1/04) | | On-going |
| 2 | Recommend up-grade/modifications to SO ₂ Ambirack bench at Blackpool and Norwich Centre to improve response noise. (Already done at Wirral Tranmere and Preston) | Blackpool Critical Site | Blackpool - new SO ₂ bench fitted 9 th March 2004 |
| Recommendations July 2004 | | | |
| 3 | Recommend up-grading or modify SO ₂ Ambirack bench at Reading New Town | Critical Site (Defra) | On-going |
| 4 | Sheffield Tinsley CO noisy and drifting response. Recommend up-grade or repair | Medium | On-going |
| 5 | Exeter Roadside CO unstable baseline. Recommend up-grading or repair. | Medium | On-going |
| Recommendations October 2004 | | | |
| 6 | Further advice for AURN equipment replacement and up-grading was given to CMCU on 8 th September 2004. | | |
| 7 | Recommend repair or up-grading of 11 unstable CO analysers detailed in Section 3.1 of this report. Of these, Barnsley Gawber (Affiliate) and Nottingham Centre (Defra) are critical for CO. | Critical sites | |
| Recommendations January 2005 | | | |
| 8 | As the Blackpool site is now closed, we recommend the opportunity be taken to install ladder securing points to allow safer access to the site roof, prior to the site being relocated. | Critical site | |
| 9 | Recommend the High Muffles NO _x autocalibration system is repaired/up-graded or turned off (span off only) until a satisfactory solution to autocalibration run-on problem is found. | Critical site | |

APPENDIX A2

CRITICAL SITES IN THE AURN (January 2005)

Table A1 Critical Sites in Agglomerations

| Site Name | Agglomeration | Critical Pollutants | | |
|--------------------------------------|---------------------------------|--|------------------|--------------------------------|
| | | DD1 | DD2 ⁷ | DD3 |
| Belfast Centre | Belfast Urban Area | NO ₂ | CO | NO ₂ O ₃ |
| Wirral Tranmere | Birkenhead Urban Area | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Blackpool | Blackpool Urban Area | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Bournemouth+ | Bournemouth Urban Area | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Brighton Preston Park | Brighton/Worthing/Littlehampton | | | NO ₂ O ₃ |
| Brighton Roadside PM ₁₀ + | Brighton/Worthing/Littlehampton | PM ₁₀ | | |
| Hove Roadside+ | Brighton/Worthing/Littlehampton | SO ₂ | | |
| Bristol Centre | Bristol Urban Area | PM ₁₀ SO ₂ | | NO ₂ O ₃ |
| Cardiff Centre | Cardiff Urban Area | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Coventry Memorial Park+ | Coventry/Bedworth | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Edinburgh St Leonards | Edinburgh Urban Area | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Glasgow Centre | Glasgow Urban Area | SO ₂ | | NO ₂ O ₃ |
| Hull Freetown | Kingston upon Hull | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Leicester Centre | Leicester Urban Area | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Liverpool Speke | Liverpool Urban Area | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Nottingham Centre | Nottingham Urban Area | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Portsmouth+ | Portsmouth Urban Area | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Preston | Preston Urban Area | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Reading New Town | Reading/Wokingham Urban Area | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Sheffield Centre | Sheffield Urban Area | PM ₁₀ | | |
| Southampton Centre | Southampton Urban Area | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Southend-on-Sea | Southend Urban Area | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Swansea+ | Swansea Urban Area | | CO | |
| Stoke-on-Trent Centre | The Potteries | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Newcastle Centre | Tyneside | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |

"+" indicates Affiliate site"

Note 2: PM₁₀ monitored by Gravimetric and TEOM

Note 3: DD3 Critical as Rural Background station

Note 4: If NO₂ at West Midlands is Suburban then NO₂ at Leamington Spa is no longer critical for DD1

Note 6: Not Affiliated/Monitoring yet.

Note 7: Addresses CO, Benzene not included here

Table A2 Critical Sites in Zones

| Site Name | Zone | Critical Pollutant | | |
|----------------------------------|-------------------------|---|------------------|--|
| | | DD1 | DD2 ⁷ | DD3 |
| Grangemouth+ | Central Scotland | NO ₂ PM ₁₀ SO ₂ | CO | |
| Bush Estate | Central Scotland | | | NO ₂ O ₃ |
| Northampton+ | East Midlands | NO ₂ PM ₁₀ ² SO ₂ | CO | NO ₂ O ₃ |
| Sibton | Eastern | | | O ₃ ³ |
| St Osyth | Eastern | | | NO ₂ O ₃ |
| Norwich Centre | Eastern | | | NO ₂ O ₃ |
| Wicken Fen | Eastern | | | NO ₂ O ₃ |
| Thurrock | Eastern | | | NO ₂ O ₃ |
| Fort William | Highland | | | NO ₂ ⁶ O ₃ ⁶ |
| Strath Vaich | Highland | | | O ₃ ³ |
| Inverness | Highland | NO ₂ PM ₁₀ | | |
| Sunderland Silkworth+ | North East | | | NO ₂ O ₃ |
| Stockton-on-Tees Yarm+ | North East | NO ₂ PM ₁₀ | CO | |
| Sunderland | North East | SO ₂ | | |
| Aberdeen+ | North East Scotland | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Aston Hill | North Wales | | | NO ₂ O ₃ |
| Wrexham | North Wales | NO ₂ PM ₁₀ SO ₂ | CO | |
| Great Dunn Fell | North West & Merseyside | | | O ₃ ³ |
| Wigan Leigh+/Centre ⁸ | North West & Merseyside | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Glazebury | North West & Merseyside | | | NO ₂ O ₃ |
| Lough Navar | Northern Ireland | | | O ₃ ³ |
| Derry+ | Northern Ireland | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Eskdalemuir | Scottish Borders | | | NO ₂ O ₃ |
| Dumfries | Scottish Borders | NO ₂ PM ₁₀ | CO | |
| Canterbury+ | South East | PM ₁₀ | | |
| Oxford Centre+ | South East | SO ₂ | CO | |
| Narberth | South Wales | | | O ₃ ³ |
| Cwmbran+ | South Wales | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Somerton | South West | | | NO ₂ O ₃ |
| Yarner Wood | South West | | | NO ₂ O ₃ |
| Plymouth Centre | South West | PM ₁₀ | | |
| Leominster | West Midlands | | | NO ₂ ^{4&6} O ₃ ⁶ |
| Leamington Spa+ | West Midlands | NO ₂ PM ₁₀ SO ₂ | CO | NO ₂ O ₃ |
| Barnsley Gawber+ | Yorkshire & Humberside | NO ₂ | CO | NO ₂ O ₃ |
| High Muffles | Yorkshire & Humberside | | | NO ₂ O ₃ |
| Scunthorpe Town+ | Yorkshire & Humberside | PM ₁₀ | | |

Total of 61 Critical Sites (25 in Agglomerations and 36 in Zones)
 51% of network stations critical under one or more Daughter Directives
 "+ indicates Affiliate site"

Note 2: PM₁₀ monitored by Gravimetric and TEOM

Note 3: DD3 Critical as Rural Background station

Note 4: If NO₂ at Leominster is Suburban then NO₂ at Leamington Spa is no longer critical for DD1

Note 6: Not Affiliated/Monitoring yet

Note 7: Addresses CO, Benzene not included here

Note 8: Wigan Leigh relocated to Wigan Centre on 11th October 2004

APPENDIX B1

Network Certificate of Calibration

CERTIFICATE OF CALIBRATION

551 Harwell, Didcot, Oxfordshire OX11 0QJ. Telephone 0870 1906465 Facsimile 0870 1906377

0401
0401 51

Certificate No: 01214-

AEA Identification Number: 45077030

Page 1 of 14

Approved Signatories:

K. Stevenson

✓ S. Eaton

Signed:

Date: 28 Jan 2005

Date of issue:

21 January 2005

Customer Name and Address:

Dr Janet Dixon
AEQ Division
Department for Environment, Food and Rural Affairs
Ashdown House (Zone E14)
123 Victoria Street
London SW1E 6DE

Description: Calibration factors for monitoring stations in the Automatic Urban and Rural Monitoring Network

1. Carbon Monoxide

| Date Year =2004 | Site | Analyser number | ¹ Zero output | Uncertainty (ppm) | ² Calibration Factor | Uncertainty (%) | *R ² |
|-----------------------|--------------------------|--------------------|-----------------------------|----------------------|------------------------------------|--------------------|-----------------|
| Scottish Sites | | | | | | | |
| 27/07 | Aberdeen | 10269 | 0 | 0.3 | 1.015 | 3 | 0.9987 |
| 12/07 | Dumfries | 12555 | -5 | 0.3 | 0.020 | 3 | 0.9983 |
| 14/07 | Edinburgh St Leonards | 14331 | -1 | 0.3 | 1.020 | 3 | 0.9998 |
| 19/07 | Glasgow Centre | gra410009 | 33 | 0.3 | 0.052 | 3 | 0.9992 |
| 20/07 | Glasgow City Chambers | 721 | 0 | 0.3 | 1.015 | 3 | 0.9985 |
| 20/07 | Glasgow Kerbside | HAR 002 | -3 | 0.3 | 0.050 | 3 | 0.9987 |
| 15/07 | Grangemouth | 12894 | -1 | 0.3 | 0.976 | 3 | 0.9997 |
| 28/07 | Inverness | 12557 | 35 | 0.3 | 0.020 | 3 | 0.9986 |
| Welsh Sites | | | | | | | |
| 16/09 | Cardiff Centre | 242 | 0 | 0.3 | 1.005 | 3 | 0.9996 |
| 17/09 | Cwmbran | 103006 | 0 | 0.3 | 1.057 | 3 | 0.9998 |
| 20/09 | Swansea | 70 | 2 | 0.3 | 0.050 | 3 | 0.9996 |
| 28/09 | Wrexham | api-1499 | 1 | 0.3 | 0.967 | 3 | 0.9984 |
| N.Irish Sites | | | | | | | |
| 13/09 | Belfast Centre | m491 | 56 | 0.3 | 0.051 | 3 | 0.9992 |
| 15/09 | Derry | j-ar-009 | 3 | 0.3 | 0.058 | 3 | 0.9984 |

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor $k = 2$, providing a level of confidence of approximately 95%. The uncertainty evaluation has been carried out in accordance with UKAS requirements.

AEA Technology Environment is a business of AEA Technology plc

This certificate is issued in accordance with the requirements of the United Kingdom Accreditation Service. It provides traceability of measurement to recognised national standards, and its units of measurement realised at the National Physical Laboratory or other recognised national standards laboratories. This certificate may not be reproduced other than in full, except with the prior written approval of the issuing laboratory.

CERTIFICATE OF CALIBRATION

551 Harwell, Didcot, Oxfordshire OX11 0QJ. Telephone 0870 1906465 Facsimile 0870 1906377

0401
0401 S1

Certificate No: 01214-

AEA Identification Number: 45077030

Page 2 of 14

| Date Year =2004 | Site | Analyser number | ¹ Zero output | Uncertainty (ppm) | ² Calibration Factor | Uncertainty (%) | *R ² |
|-----------------|------------------------|-----------------|--------------------------|-------------------|---------------------------------|-----------------|-----------------|
| | English Sites | | | | | | |
| 10/08 | Barnsley Gawber | | -3 | 0.3 | 0.052 | 3 | 0.9983 |
| 19/07 | Bath Roadside | 11388 | -7 | 0.3 | 0.053 | 3 | 0.9988 |
| 04/08 | Birmingham Centre | 14418 | -10 | 0.3 | 0.049 | 3 | 0.9999 |
| 02/08 | Birmingham East | 106006 | 0 | 0.3 | 0.992 | 3 | 0.9999 |
| 27/09 | Blackpool | L-AR010 | -11 | 0.3 | 0.044 | 3 | 0.9998 |
| 17/08 | Bolton | 2371 | 0 | 0.3 | 0.997 | 3 | 0.9998 |
| 21/07 | Bournemouth | 1501 | 1 | 0.3 | 1.129 | 3 | 0.9997 |
| 16/08 | Bradford Centre | | 4 | 0.3 | 0.057 | 3 | 0.9999 |
| 25/08 | Brentford Roadside | 93034 | 7 | 0.3 | 0.971 | 3 | 0.9987 |
| 07/09 | Brighton Roadside | 1434 | 1 | 0.3 | 1.029 | 3 | 0.9996 |
| 02/08 | Bristol Centre | 257 | -1 | 0.3 | 1.015 | 3 | 0.9958 |
| 02/08 | Bristol Old Market | 121 | -1 | 0.3 | 0.058 | 3 | 0.9945 |
| 17/08 | Bury Roadside | 1357 | 0 | 0.3 | 0.958 | 3 | 0.9999 |
| 08/07 | Coventry Memorial Park | 207001 | 0 | 0.3 | 1.041 | 3 | 0.9964 |
| 03/08 | Exeter Roadside | 8830-244 | 24 | 0.3 | 0.051 | 3 | 0.9942 |
| 06/09 | Hove Roadside | 1433 | 2 | 0.3 | 1.000 | 3 | 0.9994 |
| 29/07 | Hull Freetown | m489 | 46 | 0.3 | 0.050 | 3 | 0.9947 |
| 09/09 | Leamington Spa | 2198 | 24 | 0.3 | 0.050 | 3 | 0.9998 |
| 16/08 | Leeds Centre | 148 | 68 | 0.3 | 0.051 | 3 | 1.0000 |
| 16/06 | Leicester Centre | 207004 | 0 | 0.3 | 1.000 | 3 | 0.9998 |
| 07/09 | Liverpool Speke | m487 | 1050 | 0.3 | 0.005 | 3 | 0.9982 |
| 08/07 | London A3 Roadside | Ambirak H | 1 | 0.3 | 0.053 | 3 | 0.9988 |
| 19/07 | London Bexley | 14871 | 0 | 0.3 | 1.005 | 3 | 0.9997 |
| 06/07 | London Bloomsbury | 14330 | -3 | 0.3 | 0.052 | 3 | 0.9983 |
| 20/08 | London Brent | 1694 | 21 | 0.3 | 0.050 | 3 | 0.9982 |
| 19/08 | London Bromley | 37853256 | 0 | 0.3 | 1.086 | 3 | 0.9999 |
| 20/09 | London Cromwell Rd 2 | 10776 | 11 | 0.3 | 0.050 | 3 | 0.9992 |
| 24/08 | London Hackney | 5156 | 33 | 0.3 | 0.050 | 3 | 0.9999 |
| 02/09 | London Harlington | 1045 | 1 | 0.3 | 0.972 | 3 | 0.9975 |
| 05/07 | London Hillingdon | 0410-005 | -38 | 0.4 | 0.055 | 3.1 | 0.9994 |
| 15/07 | London Marylebone Rd | 651 | -1 | 0.3 | 1.024 | 3 | 0.9965 |
| 09/07 | London N. Kensington | 360 | 3 | 0.3 | 0.962 | 3 | 0.9993 |
| 13/07 | London Southwark | 8043 | -1 | 0.3 | 1.009 | 3 | 0.9985 |
| 06/08 | London Westminster | 10777 | 16 | 0.3 | 0.050 | 3 | 0.9988 |
| 25/08 | Manchester Piccadilly | 0040-008 | 1 | 0.3 | 0.044 | 3 | 0.9969 |
| 25/08 | Manchester Town Hall | 720 | 4 | 0.3 | 0.050 | 3 | 0.9945 |
| 30/07 | Market Harborough | 60983-329 | 94* | 0.3* | 0.006* | 9.1* | 0.9955 |
| 08/09 | Middlesbrough | 14202 | 0 | 0.3 | 1.007 | 3 | 0.9994 |
| 13/09 | Newcastle Centre | m488 | 49 | 0.3 | 0.050 | 3 | 0.9999 |
| 16/07 | Northampton | 8905410102 | 0 | 0.3 | 1.036 | 3 | 0.9983 |
| 12/08 | Norwich Centre | | -9 | 0.3 | 0.049 | 3 | 0.9997 |
| 27/07 | Nottingham Centre | | 1 | 0.3 | 0.047 | 3.2 | 0.9911 |
| 07/07 | Oxford Centre | 214b-217 | 101 | 0.3 | 0.047 | 3 | 0.9998 |
| 04/08 | Plymouth Centre | h-rao-410 | 2 | 0.3 | 0.058 | 3 | 0.9987 |
| 09/07 | Portsmouth | 902015 | 0 | 0.3 | 1.114 | 3 | 0.9998 |
| 27/09 | Preston | 71010-02 | 3 | 0.3 | 0.046 | 3 | 0.9991 |

CERTIFICATE OF CALIBRATION

551 Harwell, Didcot, Oxfordshire OX11 0QJ. Telephone 0870 1906465 Facsimile 0870 1906377

0401
0401 51

Certificate No: 01214-

AEA Identification Number: 45077030

Page 3 of 14

| Date Year =2004 | Site | Analyser number | ¹ Zero output | Uncertainty (ppm) | ² Calibration Factor | Uncertainty (%) | *R ² |
|-----------------|------------------------|-----------------|--------------------------|-------------------|---------------------------------|-----------------|-----------------|
| 22/07 | Reading New Town | | 0 | 0.3 | 0.051 | 3 | 0.9924 |
| 07/09 | Redcar | 10620 | 0 | 0.3 | 0.042 | 3 | 0.9998 |
| 24/08 | Salford Eccles | 2386 | 0 | 0.3 | 1.003 | 3 | 0.9988 |
| 08/07 | Sandwell West Bromwich | 94603 | 11 | 0.3 | 0.049 | 3 | 0.9997 |
| 10/08 | Sheffield Centre | 410-006 | 4 | 0.3 | 0.052 | 3 | 0.9931 |
| 09/08 | Sheffield Tinsley | 517 | -13 | 0.3 | 0.049 | 3 | 0.9971 |
| 23/08 | Southampton Centre | M490 | 48 | 0.3 | 0.064 | 3 | 0.9999 |
| 05/08 | Southend-on-Sea | L-AR-011 | 0 | 0.3 | 0.050 | 3 | 0.9980 |
| 13/07 | Southwark Roadside | API 358 | -3 | 0.3 | 0.990 | 3 | 0.9985 |
| 04/08 | St Osyth | 60872 | 1* | 0.3* | 0.568* | 10.2* | 0.9982 |
| 06/09 | Stockton-on-Tees Yarm | m1368-m399 | 0 | 0.3 | 0.985 | 3 | 1.0000 |
| 16/08 | Stoke-on-Trent Centre | h-ar-003 | -41 | 0.3 | 0.053 | 3 | 0.9999 |
| 22/07 | Thurrock | 95024 | -8 | 0.3 | 0.050 | 3 | 0.9988 |
| 23/09 | Tower Hamlets Roadside | 272 | 5 | 0.3 | 1.102 | 3 | 0.9997 |
| 20/09 | West London | m300-081 | -3 | 0.7 | 0.057 | 3.9 | 0.9966 |
| 19/08 | Wigan Leigh | | 0 | 0.3 | 1.038 | 3 | 0.9985 |
| 28/09 | Wirral Tranmere | L-AR-012 | -13 | 0.3 | 0.059 | 3 | 0.9991 |

2. Sulphur Dioxide

| Date Year =2004 | Site | Analyser number | ¹ Zero output | Uncertainty (ppb) | ² Calibration Factor | Uncertainty (%) | *R ² | *m-xylene interference (ppb) |
|-----------------------|-----------------------|-----------------|--------------------------|-------------------|---------------------------------|-----------------|-----------------|------------------------------|
| Scottish Sites | | | | | | | | |
| 27/07 | Aberdeen | 12182 | -1 | 4.2 | 1.007 | 5 | 0.9910 | 8.8 |
| 14/07 | Edinburgh St Leonards | 14320 | 0 | 4.2 | 1.097 | 5 | 0.9999 | 23.1 |
| 19/07 | Glasgow Centre | gra477018 | 13 | 4.0 | 0.192 | 5 | 0.9974 | 0 |
| 15/07 | Grangemouth | 703B-214 | -1 | 4.3 | 0.810 | 5 | 0.9999 | 21.1 |
| Welsh Sites | | | | | | | | |
| 16/09 | Cardiff Centre | 70 | 7 | 4.2 | 1.247 | 5.6 | 0.9990 | 10.6 |
| 17/09 | Cwmbran | 408001 | 3 | 4.3 | 1.047 | 5.5 | 0.9956 | 5.0 |
| 21/09 | Narberth | h-rs-458 | 71 | 4.2 | 0.696 | 5 | 0.9991 | 20.4 |
| 20/09 | Port Talbot | 943 | 0 | 4.2 | 1.115 | 7.1 | 0.9992 | 12.3 |
| 20/09 | Swansea | 168 | 8 | 4.0 | 0.225 | 5 | 0.9980 | 10.1 |
| 28/09 | Wrexham | api-1181 | -7 | 4.2 | 1.103 | 5.3 | 0.9989 | 5.5 |
| N.Irish Sites | | | | | | | | |
| 13/09 | Belfast Centre | m637 | 222 | 4.1 | 0.189 | 5 | 0.9994 | 20.1 |
| 13/09 | Belfast East | 10778 | 2 | 4.2 | 0.863 | 5 | 0.9991 | 5.8 |
| 15/09 | Derry | j-ar-009 | 140 | 4.5 | 1.054 | 5 | 0.9977 | 3.2 |
| English Sites | | | | | | | | |
| 10/08 | Barnsley 12 | 706 | 5 | 4.2 | 1.209 | 5 | 0.9983 | 9.7 |
| 10/08 | Barnsley Gawber | | 86 | 5.2 | 1.220 | 5.7 | 0.9960 | 15.6 |
| 04/08 | Birmingham Centre | 14352 | 40 | 8.0 | 0.200 | 10.0 | 0.9950 | 16.6 |

CERTIFICATE OF CALIBRATION

551 Harwell, Didcot, Oxfordshire OX11 0QJ. Telephone 0870 1906465 Facsimile 0870 1906377

0401
0401 S1

Certificate No: 01214-

AEA Identification Number: 45077030

Page 4 of 14

| Date Year =2004 | Site | Analyser number | ¹ Zero output | Uncertainty (ppb) | ² Calibration Factor | Uncertainty (%) | *R ² | *m-xylene interference (ppb) |
|-----------------|------------------------|-----------------|--------------------------|-------------------|---------------------------------|-----------------|-----------------|------------------------------|
| 02/08 | Birmingham East | 301002 | 0 | 4.1 | 0.853 | 5 | 0.9960 | 6.8 |
| 27/09 | Blackpool | L-AR010 | 13 | 4.5 | 1.327 | 5.5 | 0.0000 | 11.6 |
| 17/08 | Bolton | 2344 | 2 | 4.2 | 0.982 | 5 | 0.9991 | 17.7 |
| 21/07 | Bournemouth | 1139 | 0 | 4.2 | 1.006 | 5.4 | 0.9996 | 11.3 |
| 16/08 | Bradford Centre | | 86 | 4.3 | 1.330 | 5.1 | 0.9969 | 12.0 |
| 02/08 | Bristol Centre | 73 | 1 | 4.2 | 1.172 | 5.3 | 0.9951 | 19.9 |
| 17/08 | Bury Roadside | 1581 | 1 | 4.1 | 0.890 | 5 | 0.9999 | 28.5 |
| 08/07 | Coventry Mem. Park | 215003 | 1 | 4.3 | 0.941 | 5.3 | 0.9951 | 1.6 |
| 03/08 | Exeter Roadside | 1835 | 22 | 4.2 | 1.069 | 5.3 | 0.9962 | 20.3 |
| 05/07 | Harwell | 14350 | -11 | 4.1 | 0.499 | 5 | 0.9997 | 10.8 |
| 06/09 | Hove Roadside | 1178 | 0 | 4.2 | 1.079 | 5.3 | 0.9970 | 13.6 |
| 29/07 | Hull Freetown | m686 | 245 | 4.0 | 0.210 | 5.2 | 0.9927 | 21.6 |
| 24/08 | Ladybower | 84 | 5 | 4.1 | 0.582 | 5 | 0.9972 | 5.2 |
| 09/09 | Leamington Spa | 1793 | 17 | 4.2 | 1.037 | 5.3 | 0.9973 | 20.7 |
| 16/08 | Leeds Centre | m100 053 | -15 | 4.0 | 0.190 | 5 | 0.9997 | 4.9 |
| 16/06 | Leicester Centre | 215001 | 0 | 4.2 | 1.007 | 5.6 | 0.9995 | 2.0 |
| 07/09 | Liverpool Speke | m626 | 242 | 4.1 | 0.176 | 5 | 0.9931 | 20.7 |
| 19/07 | London Bexley | 14869 | 2 | 4.2 | 0.936 | 5.3 | 0.9995 | 15.2 |
| 06/07 | London Bloomsbury | 14323 | 6 | 4.1 | 0.220 | 5 | 0.9994 | 17.0 |
| 20/08 | London Brent | 0 | 18 | 4.7 | 0.850 | 5 | 0.9939 | 11.5 |
| 20/09 | London Cromwell Rd 2 | 10779 | 2 | 4.2 | 1.112 | 5.3 | 0.9991 | 7.8 |
| 23/08 | London Eltham | 822 | 55 | 4.2 | 1.036 | 5 | 0.9976 | 23.8 |
| 05/07 | London Hillingdon | 77580-386 | 6 | 4.3 | 0.234 | 5.9 | 0.9979 | 5.3 |
| 24/09 | London Lewisham | M498 | 1 | 4.2 | 1.037 | 5.3 | 0.9993 | 19.7 |
| 15/07 | London Marylebone Rd | 411 | 24 | 4.1 | 0.767 | 5.4 | 0.9986 | 12.2 |
| 09/07 | London N. Kensington | 1020 | 38 | 4.3 | 0.983 | 5 | 0.9958 | 21.1 |
| 13/07 | London Southwark | 535 | 7 | 4.2 | 0.982 | 5 | 0.9984 | 7.9 |
| 21/09 | London Teddington | m100-374 | 3 | 4.2 | 0.795 | 5.3 | 0.9989 | 3.0 |
| 06/08 | London Westminster | 10780 | 6 | 4.1 | 0.926 | 5 | 0.9985 | 21.3 |
| 06/09 | Lullington Heath | m690 | 102 | 4.1 | 0.495 | 5.2 | 0.9949 | 22.3 |
| 25/08 | Manchester Piccadilly | 0447-013 | -58 | 4.0 | 0.203 | 5.7 | 0.9945 | 16.9 |
| 24/08 | Manchester South | e4770104 | 8 | 4.0 | 0.213 | 5.1 | 0.9949 | 21.3 |
| 08/09 | Middlesbrough | 14166 | 2 | 4.2 | 1.135 | 5.5 | 0.9997 | 15.8 |
| 13/09 | Newcastle Centre | m689 | 242 | 4.1 | 0.186 | 5 | 0.9961 | 22.5 |
| 12/08 | Norwich Centre | | 64 | 8.3 | 3.258 | 11.2 | 0.9921 | 21.2 |
| 27/07 | Nottingham Centre | 0447-016 | 231 | 4.2 | 0.223 | 5.8 | 0.9901 | 5.5 |
| 07/07 | Oxford Centre | 376b-161 | 102 | 4.5 | 0.949 | 5.6 | 0.9931 | 12.6 |
| 04/08 | Plymouth Centre | 77561-386 | 0 | 4.2 | 1.008 | 5.3 | 0.9970 | 2.1 |
| 09/07 | Portsmouth | 215004 | 1 | 4.2 | 1.031 | 5.4 | 0.9995 | 3.0 |
| 27/09 | Preston | 71010-02 | 36 | 4.2 | 1.209 | 5.3 | 0.9939 | 18.1 |
| 22/07 | Reading New Town | | 6 | 4.4 | 1.301 | 6.0 | 0.9946 | 3.6 |
| 07/09 | Redcar | 10355 | 17 | 4.1 | 0.879 | 5 | 0.9995 | 8.8 |
| 20/07 | Rochester | 95058 | 13 | 4.2 | 1.022 | 5.3 | 0.9995 | 11.2 |
| 09/08 | Rotherham Centre | 447-0109 | -15 | 4.1 | 0.876 | 5 | 0.9972 | 11.4 |
| 24/08 | Salford Eccles | 2346 | -1 | 4.3 | 0.951 | 6.4 | 0.9984 | 13.8 |
| 08/07 | Sandwell West Bromwich | 93082 | 0 | 4.3 | 1.017 | 5.5 | 0.9997 | 8.9 |
| 28/07 | Scunthorpe Town | 468 | -2 | 4.3 | 1.004 | 5.9 | 0.9971 | 8.5 |
| 10/08 | Sheffield Centre | 0477-015 | -23 | 4.0 | 0.219 | 5 | 0.9971 | 20.3 |

CERTIFICATE OF CALIBRATION

551 Harwell, Didcot, Oxfordshire OX11 0QJ. Telephone 0870 1906465 Facsimile 0870 1906377

0401
0401 51

Certificate No: 01214-

AEA Identification Number: 45077030

Page 5 of 14

| Date Year =2004 | Site | Analyser number | ¹ Zero output | Uncertainty (ppb) | ² Calibration Factor | Uncertainty (%) | *R ² | *m-xylene interference (ppb) |
|-----------------|-----------------------|-----------------|--------------------------|-------------------|---------------------------------|-----------------|-----------------|------------------------------|
| 23/08 | Southampton Centre | M1768-M676 | 230 | 4.0 | 0.151 | 5 | 0.9993 | 20.8 |
| 05/08 | Southend-on-Sea | L-AR-011 | 90 | 5.2 | 1.453 | 7.3 | 0.9988 | 5.1 |
| 13/07 | Southwark Roadside | Dasibi 659 | 4 | 4.2 | 1.071 | 6.0 | 0.9988 | 5.4 |
| 18/08 | Stockport Shaw Heath | 1690 | 19 | 4.1 | 0.485 | 5 | 0.9904 | 19.8 |
| 16/08 | Stoke-on-Trent Centre | H-AR-003 | 40 | 4.5 | 1.976 | 5 | 0.9986 | 21.7 |
| 14/09 | Sunderland | 14321 | 1 | 4.4 | 1.221 | 5 | 0.9989 | 15.6 |
| 22/07 | Thurrock | 10554 | 4 | 4.2 | 1.053 | 5.3 | 0.9995 | 23.2 |
| 09/08 | Wicken Fen | 14349 | -20 | 4.1 | 0.592 | 5 | 0.9987 | 16.6 |
| 19/08 | Wigan Leigh | 2 | 0 | 4.3 | 1.438 | 5.3 | 0.9983 | 4.2 |
| 28/09 | Wirral Tranmere | L-AR-012 | 7 | 5.1 | 3.159 | 6.1 | 0.9959 | 9.5 |

3. Ozone

| Date Year =2004 | Site | Analyser number | ¹ Zero output | Uncertainty (ppb) | ² Calibration Factor | Uncertainty (%) | *R ² |
|-----------------|-----------------------|-----------------|--------------------------|-------------------|---------------------------------|-----------------|-----------------|
| | Scottish Sites | | | | | | |
| 27/07 | Aberdeen | 13073 | 1 | 3 | 0.940 | 3.1 | 0.9999 |
| 13/07 | Bush Estate | 77087-385 | -1 | 3 | 0.503 | 3.1 | 1.0000 |
| 14/07 | Edinburgh St Leonards | 14334 | 0 | 3 | 0.991 | 3.1 | 1.0000 |
| 13/07 | Eskdalemuir | 14341 | -1 | 3 | 0.488 | 3.1 | 1.0000 |
| 19/07 | Glasgow Centre | | -6 | 6.3 | 0.204 | 4.7 | 0.9994 |
| 27/07 | Strath Vaich | 14439 | 21 | 3 | 0.507 | 3.1 | 1.0000 |
| | Welsh Sites | | | | | | |
| 09/08 | Aston Hill | 8810-367 | 7 | 3 | 0.491 | 3.2 | 0.9998 |
| 16/09 | Cardiff Centre | 168 | 0 | 3 | 0.983 | 3.2 | 0.9999 |
| 17/09 | Cwmbran | | 0 | 3 | 1.106 | 3.1 | 1.0000 |
| 21/09 | Narberth | | 3 | 4.0 | 1.028 | 3.4 | 0.9998 |
| 20/09 | Port Talbot | 339 | 4 | 3 | 0.505 | 3.1 | 0.9994 |
| 20/09 | Swansea | 156 | 6 | 3 | 0.103 | 3.1 | 0.9999 |
| | N.Irish Sites | | | | | | |
| 13/09 | Belfast Centre | m355 | 231 | 3 | 0.099 | 3.1 | 1.0000 |
| 15/09 | Derry | j-ar-009 | 0 | 3 | 1.205 | 3.2 | 0.9999 |
| 16/07 | Lough Navar | 14346 | -11 | 3 | 0.456 | 3.1 | 1.0000 |
| | English Sites | | | | | | |
| 10/08 | Barnsley Gawber | | 2 | 3 | 1.178 | 3.2 | 0.9997 |
| 04/08 | Birmingham Centre | 14357 | 25 | 3 | 0.101 | 3.1 | 1.0000 |
| 02/08 | Birmingham East | 301002 | 5 | 3 | 0.949 | 3.1 | 0.9998 |
| 27/09 | Blackpool | L-AR010 | 0 | 3 | 1.069 | 3.2 | 0.9999 |
| 17/08 | Bolton | 2371 | 0 | 3 | 0.977 | 3.1 | 1.0000 |
| 27/07 | Bottesford | 49c-ea357 | 5 | 3 | 0.992 | 3.1 | 1.0000 |
| 21/07 | Bournemouth | 854 | 0 | 3 | 0.957 | 3.1 | 0.9998 |

CERTIFICATE OF CALIBRATION

551 Harwell, Didcot, Oxfordshire OX11 0QJ. Telephone 0870 1906465 Facsimile 0870 1906377

0401
0401 S1

Certificate No: 01214-

AEA Identification Number: 45077030

Page 6 of 14

| Date Year =2004 | Site | Analyser number | ¹ Zero output | Uncertainty (ppb) | ² Calibration Factor | Uncertainty (%) | *R ² |
|-----------------|------------------------|-----------------|--------------------------|-------------------|---------------------------------|-----------------|-----------------|
| 16/08 | Bradford Centre | | 2 | 3 | 1.026 | 3.1 | 0.9999 |
| 02/08 | Bristol Centre | 155 | -2 | 3 | 1.202 | 3.2 | 1.0000 |
| 17/08 | Bury Roadside | 1453 | 0 | 3 | 1.051 | 3.1 | 0.9996 |
| 08/07 | Coventry Memorial Park | 205001 | 2 | 3 | 1.000 | 3.1 | 1.0000 |
| 03/08 | Exeter Roadside | 1317 | 21 | 3 | 1.151 | 3.2 | 0.9997 |
| 19/08 | Glazebury | 138 | 9 | 3 | 0.457 | 3.1 | 0.9999 |
| 15/09 | Great Dun Fell | 14456 | 1 | 3 | 0.512 | 3.1 | 0.9999 |
| 05/07 | Harwell | 14347 | 1 | 3 | 0.501 | 3.2 | 0.9999 |
| 07/09 | High Muffles | 14343 | -7 | 3 | 0.509 | 3.1 | 1.0000 |
| 29/07 | Hull Freetown | m356 | 228 | 3 | 0.093 | 3.1 | 1.0000 |
| 24/08 | Ladybower | 125b-101 | 56 | 3 | 0.441 | 3.1 | 0.9998 |
| 09/09 | Leamington Spa | 1469 | 21 | 3 | 0.974 | 3.1 | 1.0000 |
| 16/08 | Leeds Centre | m400 056 | 137 | 3 | 0.109 | 3.1 | 0.9999 |
| 16/06 | Leicester Centre | 205006 | 0 | 3 | 1.003 | 3.1 | 1.0000 |
| 07/09 | Liverpool Speke | 9810b-m331 | 267 | 3 | 0.097 | 3.1 | 1.0000 |
| 19/07 | London Bexley | 14872 | 0 | 3 | 0.975 | 3.1 | 0.9999 |
| 06/07 | London Bloomsbury | 14907 | 11 | 3 | 0.103 | 3.1 | 1.0000 |
| 20/08 | London Brent | 1608 | 21 | 3 | 0.956 | 3.1 | 0.9998 |
| 23/08 | London Eltham | 375 | 8 | 3 | 0.983 | 3.1 | 0.9999 |
| 24/08 | London Hackney | 5155 | 23 | 3 | 0.202 | 3.8 | 0.9997 |
| 14/07 | London Haringey | 538 | 9 | 3 | 1.146 | 3.3 | 0.9998 |
| 02/09 | London Harlington | 107 | -1 | 3 | 0.931 | 3.2 | 1.0000 |
| 05/07 | London Hillingdon | 0427-012 | 5 | 3 | 0.099 | 3.1 | 0.9968 |
| 24/09 | London Lewisham | 939B-187 | 2 | 3 | 0.975 | 3.1 | 0.9998 |
| 15/07 | London Marylebone Rd | 769 | 0 | 3 | 1.034 | 3.1 | 0.9999 |
| 09/07 | London N. Kensington | 497 | 10 | 3 | 0.967 | 3.4 | 0.9993 |
| 13/07 | London Southwark | 5776 | 4 | 3 | 1.048 | 3.1 | 1.0000 |
| 21/09 | London Teddington | 58811-320 | -23 | 3 | 0.218 | 3.3 | 0.9999 |
| 18/08 | London Wandsworth | 491 | 1 | 5.5 | 1.043 | 7.3 | 0.9964 |
| 06/08 | London Westminster | 10444 | 10 | 3 | 0.520 | 3.1 | 1.0000 |
| 06/09 | Lullington Heath | m1655-m337 | 102 | 3 | 0.479 | 3.2 | 0.9999 |
| 25/08 | Manchester Piccadilly | 427-017 | -11 | 4.3 | 0.191 | 3.8 | 0.9998 |
| 24/08 | Manchester South | e4270102 | 0 | 3 | 0.100 | 3.1 | 0.9995 |
| 30/07 | Market Harborough | 60894-328 | 5 | 3 | 0.486 | 3.2 | 0.9999 |
| 08/09 | Middlesbrough | 14203 | 0 | 3 | 0.974 | 3.1 | 1.0000 |
| 13/09 | Newcastle Centre | m1820-m357 | 240 | 3 | 0.104 | 3.1 | 0.9999 |
| 16/07 | Northampton | 8905240110 | -1 | 3 | 0.951 | 3.2 | 0.9999 |
| 12/08 | Norwich Centre | | 0 | 3 | 1.025 | 3.1 | 0.9984 |
| 27/07 | Nottingham Centre | 427-011 | -13 | 3 | 0.100 | 3.1 | 0.9999 |
| 04/08 | Plymouth Centre | | -1 | 3 | 0.585 | 3.1 | 0.9999 |
| 09/07 | Portsmouth | 205002 | 1 | 3 | 1.039 | 3.1 | 0.9999 |
| 27/09 | Preston | 71010-02 | -1 | 3 | 0.962 | 3.1 | 0.9969 |
| 22/07 | Reading New Town | | -2 | 4.5 | 1.070 | 3.5 | 0.9984 |
| 07/09 | Redcar | 10195 | 0 | 3 | 0.451 | 3.1 | 0.9999 |
| 20/07 | Rochester | 95063 | -1 | 3 | 1.015 | 3.1 | 1.0000 |
| 09/08 | Rotherham Centre | D4270106 | 5 | 3 | 0.959 | 3.1 | 0.9998 |
| 24/08 | Salford Eccles | 2363 | 0 | 3 | 1.084 | 3.2 | 0.9998 |
| 08/07 | Sandwell West Bromwich | 93083 | 6 | 3 | 0.479 | 3.1 | 1.0000 |

CERTIFICATE OF CALIBRATION

551 Harwell, Didcot, Oxfordshire OX11 0QJ. Telephone 0870 1906465 Facsimile 0870 1906377

0401
0401 51

Certificate No: 01214-

AEA Identification Number: 45077030

Page 7 of 14

| Date Year =2004 | Site | Analyser number | ¹ Zero output | Uncertainty (ppb) | ² Calibration Factor | Uncertainty (%) | *R ² |
|-----------------|-----------------------|-----------------|--------------------------|-------------------|---------------------------------|-----------------|-----------------|
| 10/08 | Sheffield Centre | 427-010 | -16 | 3 | 0.097 | 3.4 | 0.9999 |
| 12/08 | Sibton | 92416 | 5 | 3 | 0.467 | 3.1 | 0.9999 |
| 03/08 | Somerton | 427 | 3 | 3 | 0.511 | 3.1 | 1.0000 |
| 23/08 | Southampton Centre | m1802m1354 | 273 | 3 | 0.099 | 3.1 | 0.9999 |
| 05/08 | Southend-on-Sea | L-AR-011 | 0 | 3 | 1.023 | 3.1 | 0.9998 |
| 04/08 | St Osyth | 49c-60869 | 976 | 3 | 0.050 | 3.2 | 1.0000 |
| 16/08 | Stoke-on-Trent Centre | H-AR-003 | 5 | 3 | 1.119 | 3.1 | 0.9993 |
| 22/07 | Thurrock | 10788 | 1 | 3 | 0.493 | 3.1 | 0.9999 |
| 10/08 | Weybourne | 195 | -1 | 3 | 1.053 | 3.1 | 0.9999 |
| 09/08 | Wicken Fen | 14345 | -8 | 3 | 0.491 | 3.1 | 1.0000 |
| 19/08 | Wigan Leigh | 4009 | 2 | 3 | 1.031 | 3.2 | 0.9999 |
| 28/09 | Wirral Tranmere | L-AR-012 | 0 | 3 | 1.007 | 3.2 | 0.9997 |
| 04/08 | Yarner Wood | 347 | -2 | 3 | 0.430 | 3.2 | 0.9999 |

4. Oxides of Nitrogen

| Date Year =2004 | Site | | Analyser number | ¹ Zero output | Uncertainty (ppb) | ² Calibration Factor | Uncertainty (%) | *R ² | *Converter efficiency (%) |
|-----------------------|-----------------------|-----------|-----------------|--------------------------|-------------------|---------------------------------|-----------------|------------------|---------------------------|
| Scottish Sites | | | | | | | | | |
| 27/07 | Aberdeen | NO NOx | 10266 | -1 -1 | 5 5.3 | 1.013 1.038 | 5 5 | 0.9979 0.9983 | 98.5 |
| 13/07 | Bush Estate | NO NOx | 77584-386 | -3 -3 | 5 5.3 | 0.866 0.955 | 5 5 | 0.9963 0.9948 | 98.1 |
| 12/07 | Dumfries | NO NOx | 12189 | 5 6 | 5 5.4 | 0.413 0.421 | 5 5.1 | 0.9989 0.9991 | 94.8 |
| 14/07 | Edinburgh St Leonards | NO NOx | 14327 | 1 -2 | 5 5.3 | 0.809 0.775 | 5 5.1 | 0.9999 0.9999 | 98.6 |
| 19/07 | Glasgow Centre | NO NOx | gra-447 011 | -10 -5 | 5 5.2 | 0.453 0.457 | 5 5.1 | 0.9993 0.9993 | 95.5 |
| 20/07 | Glasgow City Chambers | NO NOx | 575 | 1 1 | 5 5.3 | 1.169 1.19 | 5 5.2 | 0.9961 0.9969 | 96 |
| 20/07 | Glasgow Kerbside | NO NOx | H-AR-002 | 15 13 | 5 5.6 | 2.066 2.087 | 5.1 5.2 | 0.9947 0.9949 | 90.9 |
| 15/07 | Grangemouth | NO NOx | 700B-312 | 0 2 | 5 5.4 | 1.073 1.089 | 5 5.4 | 0.9999 0.9999 | 97.5 |
| 28/07 | Inverness | NO NOx | 12184 | 8 8 | 5 5.2 | 0.443 0.465 | 5 5 | 0.9991 0.9994 | 96.1 |
| Welsh Sites | | | | | | | | | |
| 09/08 | Aston Hill | NO NOx | m200a-2221 | 8 6 | 5 5.3 | 1.174 1.168 | 5 5 | 0.999 0.9989 | 96.5 |
| 16/09 | Cardiff Centre | NO NOx | 71 | 0 0 | 5 5.5 | 1.742 1.752 | 5 5 | 0.9997 0.9996 | 95.2 |
| 17/09 | Cwmbran | NO NOx | 406003 | -1 -6 | 5 5.4 | 1.035 1.006 | 5 5 | 0.9990 0.9993 | 98.1 |
| 21/09 | Narberth | NO NOx | H-RS458 | 44 42 | 5 5.3 | 0.949 0.980 | 5 5.2 | 0.9995 0.9997 | 96.7 |

CERTIFICATE OF CALIBRATION

551 Harwell, Didcot, Oxfordshire OX11 0QJ. Telephone 0870 1906465 Facsimile 0870 1906377

0401
0401 51

Certificate No: 01214-

AEA Identification Number: 45077030

Page 8 of 14

| Date Year =2004 | Site | | Analyser number | ¹ Zero output | Uncertainty (ppb) | ² Calibration Factor | Uncertainty (%) | *R ² | *Converter efficiency (%) |
|----------------------|------------------------|-----------|-------------------|--------------------------|-------------------|---------------------------------|-----------------|------------------|---------------------------|
| 20/09 | Port Talbot | NO NOx | 320 | 2 0 | 5 5.8 | 1.234 1.225 | 7.5 7.2 | 0.9995 0.9993 | 99.5 |
| 20/09 | Swansea | NO NOx | 148 | -10 3 | 5 5.2 | 0.482 0.499 | 5 5 | 0.9995 0.9997 | 96.6 |
| 28/09 | Wrexham | NO NOx | api-1490 | 1 0 | 5 5.5 | 1.175 1.192 | 5 5 | 0.9983 0.9985 | 97.7 |
| N.Irish Sites | | | | | | | | | |
| 13/09 | Belfast Centre | NO NOx | m733 | 243 247 | 5 5.4 | 0.428 0.448 | 5 5.1 | 0.9985 0.9988 | 98.3 |
| 15/09 | Derry | NO NOx | j-ar-009 | 43 43 | 5 6.1 | 2.044 2.110 | 5.6 5.4 | 0.9991 0.9995 | 96.3 |
| English Sites | | | | | | | | | |
| 10/08 | Barnsley Gawber | NO NOx | | 57 60 | 6.6 10.5 | 2.857 2.883 | 5.9 12.4 | 0.9926 0.9949 | 95.2 |
| 19/07 | Bath Roadside | NO NOx | 12758 | 2 3 | 5 5.4 | 1.289 1.326 | 5 5.1 | 0.9980 0.9981 | 97.7 |
| 07/09 | Billingham | NO NOx | 10440 | 3 3 | 5 5.5 | 1.560 1.589 | 5 5.1 | 0.9997 0.9998 | 95.8 |
| 04/08 | Birmingham Centre | NO NOx | 14324 | 12 27 | 13.7 20.8 | 0.612 0.655 | 9.5 12.4 | 0.9980 0.9985 | 96.0 |
| 02/08 | Birmingham East | NO NOx | 209006 | 0 0 | 5 5.3 | 1.016 1.038 | 5 5 | Failed | in test |
| 27/09 | Blackpool | NO NOx | l-ar010 | 47 48 | 5 6.6 | 2.690 2.713 | 5.3 5.6 | 0.9975 0.9982 | 97.7 |
| 21/07 | Bournemouth | NO NOx | 522 | 0 0 | 5 5.3 | 1.192 1.205 | 5 5.1 | 0.9980 0.9983 | 102.5 |
| 16/08 | Bradford Centre | NO NOx | | 27 28 | 5 6.7 | 2.597 2.803 | 5.4 5.6 | 0.9992 0.9995 | 100 |
| 25/08 | Brentford Roadside | NO NOx | M1759/M7 12 | -5 -3 | 5 5.3 | 1.057 1.104 | 5 5.1 | 0.9995 0.9998 | 100 |
| 07/09 | Brighton Roadside | NO NOx | 1225 | 2 4 | 5 5.3 | 1.215 1.221 | 5 5 | 1.0000 1.0000 | 95.5 |
| 02/08 | Bristol Centre | NO NOx | 77 | 4 5 | 5 5.4 | 1.435 1.531 | 5 5 | 0.9948 0.9951 | 98.7 |
| 02/08 | Bristol Old Market | NO NOx | 653 | 2 3 | 5 5.9 | 2.845 2.886 | 5 5 | 0.9959 0.9962 | 95.7 |
| 17/08 | Bury Roadside | NO NOx | 1710 | 0 6 | 5 5.3 | 1.057 1.098 | 5 5.1 | 0.9999 0.9999 | 103.4 |
| 09/08 | Cambridge Roadside | NO NOx | 42C- 55355-303 | -1 -2 | 5 5.3 | 1.048 1.061 | 5 5 | 0.9999 0.9999 | 97.9 |
| 07/07 | Camden Kerbside | NO NOx | | 4 8 | 5 5.4 | 1.363 1.345 | 5 5 | 0.9978 0.9985 | 96.4 |
| 21/07 | Canterbury | NO NOx | 11666 | 1 -1 | 5 5.3 | 1.224 1.217 | 5 5 | 1.0000 1.0000 | 96.3 |
| 08/07 | Coventry Memorial Park | NO NOx | 210003 | 0 0 | 5 5.3 | 0.944 0.874 | 5 5 | 0.9962 0.9960 | 98.9 |
| 03/08 | Exeter Roadside | NO NOx | 9841a-85 | 21 23 | 5 5.9 | 2.623 2.767 | 5 5 | 0.995 0.9958 | 102.5 |
| 19/08 | Glazebury | NO NOx | 78 | 2 -5 | 5 5.2 | 0.446 0.438 | 5 5 | 0.9975 0.9975 | 99.6 |

CERTIFICATE OF CALIBRATION

551 Harwell, Didcot, Oxfordshire OX11 0QJ. Telephone 0870 1906465 Facsimile 0870 1906377

0401
0401 S1

Certificate No: 01214-

AEA Identification Number: 45077030

Page 9 of 14

| Date Year =2004 | Site | | Analyser number | ¹ Zero output | Uncertainty (ppb) | ² Calibration Factor | Uncertainty (%) | *R ² | *Converter efficiency (%) |
|-----------------|----------------------|-----------|-----------------|--------------------------|-------------------|---------------------------------|-----------------|------------------|---------------------------|
| 14/07 | Haringey Roadside | NO NOx | 397 | 2 2 | 5 5.3 | 1.088 1.055 | 5 5.4 | 0.9998 0.9999 | 98.8 |
| 05/07 | Harwell | NO NOx | 14366 | -1 -4 | 5 5.3 | 1.214 1.215 | 5 5.1 | 0.9995 0.9996 | 98.4 |
| 07/09 | High Muffles | NO NOx | 12553 | 24 17 | 5 5.2 | 0.594 0.630 | 5 5 | Failed | in test |
| 06/09 | Hove Roadside | NO NOx | 199 | 0 3 | 5 5.3 | 0.914 0.929 | 5 5 | 0.9998 0.9998 | 95.3 |
| 29/07 | Hull Freetown | NO NOx | m732 | 220 228 | 5 5.2 | 0.374 0.376 | 4 5 | 0.9951 0.9949 | 98.8 |
| 24/08 | Ladybower | NO NOx | 72 | 10 9 | 5 5.2 | 0.599 0.587 | 5 5 | 0.9980 0.9980 | 98.2 |
| 09/09 | Leamington Spa | NO NOx | 1705 | 24 20 | 5 6.7 | 3.068 2.951 | 5.2 5.6 | 0.9996 0.9995 | 103.2 |
| 16/08 | Leeds Centre | NO NOx | hsp00009 | 263 248 | 5 5.2 | 0.539 0.561 | 5 5.3 | 0.9999 0.9993 | 95.8 |
| 16/06 | Leicester Centre | NO NOx | apna-360-210004 | -1 -3 | 5 5.3 | 1.000 0.985 | 6.2 8.1 | 0.9996 0.9996 | 99.2 |
| 07/09 | Liverpool Speke | NO NOx | 9841b-m734 | 247 242 | 5 5.4 | 0.450 0.457 | 5 5.9 | 0.9976 0.9981 | 96.6 |
| 08/07 | London A3 Roadside | NO NOx | H-AR-001 | 65 69 | 5 7.1 | 2.877 3.122 | 5.6 7.2 | 0.9993 0.9988 | 94.8 |
| 19/07 | London Bexley | NO NOx | 14870 | 16 17 | 5 5.3 | 0.933 0.912 | 5 5 | 0.9999 0.9999 | 100 |
| 06/07 | London Bloomsbury | NO NOx | 14328 | -22 -11 | 5 5.8 | 0.485 0.500 | 5 5.4 | 0.9990 0.9995 | 95.1 |
| 20/08 | London Brent | NO NOx | 0 | 24 28 | 5 5.7 | 2.151 2.221 | 5 5.1 | 0.9971 0.9964 | 95.7 |
| 19/08 | London Bromley | NO NOx | 10669 | 0 0 | 5 5.4 | 1.276 1.308 | 5 5.1 | 0.9999 0.9999 | 96.0 |
| 20/09 | London Cromwell Rd 2 | NO NOx | 10775 | -2 8 | 5 15.3 | 2.513 2.962 | 5 9.1 | 0.9990 0.9990 | 96.2 |
| 23/08 | London Eltham | NO NOx | 307 | 2 3 | 5 5.3 | 0.706 0.937 | 5 5.1 | 0.9969 0.9972 | 95.1 |
| 24/08 | London Hackney | NO NOx | 532b-234 | 101 101 | 5 5.7 | 1.138 1.201 | 5 5.2 | 0.9998 1.0000 | 99.5 |
| 02/09 | London Harlington | NO NOx | 1090 | 0 0 | 5 5.4 | 1.292 1.314 | 5 5.1 | 0.9976 0.9977 | 96.1 |
| 05/07 | London Hillingdon | NO NOx | g-ra0447-010 | 15 27 | 5 5.6 | 0.556 0.590 | 5 5.3 | 0.9958 0.9949 | 111.2 |
| 24/09 | London Lewisham | NO NOx | M1231-M530 | -1 1 | 5 5.4 | 1.355 1.492 | 5 5.3 | 0.9990 0.9989 | 100 |
| 15/07 | London Marylebone Rd | NO NOx | 439 | 1 -2 | 5 5.5 | 1.874 1.846 | 5 5.6 | 0.9975 0.9963 | 96.7 |
| 09/07 | London N. Kensington | NO NOx | 459 | 3 5 | 5 5.3 | 1.011 1.016 | 5 5.3 | 0.9979 0.9981 | 96.3 |
| 13/07 | London Southwark | NO NOx | 14863 | 21 21 | 5 5.3 | 1.022 1.027 | 5 5.1 | 1.0000 0.9999 | 95.6 |
| 21/09 | London Teddington | NO NOx | m200-287 | 1 0 | 5 5.7 | 1.091 1.104 | 5 5.1 | 0.9993 0.9990 | 100 |

CERTIFICATE OF CALIBRATION

551 Harwell, Didcot, Oxfordshire OX11 0QJ. Telephone 0870 1906465 Facsimile 0870 1906377

0401
0401 S1

Certificate No: 01214-

AEA Identification Number: 45077030

Page 10 of 14

| Date Year =2004 | Site | | Analyser number | ¹ Zero output | Uncertainty (ppb) | ² Calibration Factor | Uncertainty (%) | *R ² | *Converter efficiency (%) |
|-----------------|------------------------|-----------|-------------------|--------------------------|-------------------|---------------------------------|-----------------|------------------|---------------------------|
| 18/08 | London Wandsworth | NO NOx | 378 | 3 3 | 5 5.4 | 1.566 1.481 | 5.2 6.5 | 0.9974 0.9979 | 95.2 |
| 06/08 | London Westminster | NO NOx | 10439 | 3 2 | 5 7.1 | 2.891 3.210 | 5.1 5.9 | 0.9958 0.9965 | 95.9 |
| 06/09 | Lullington Heath | NO NOx | m1657- m675 | 100 102 | 5 5.3 | 0.813 0.821 | 5 5 | 0.9989 0.9991 | 95.1 |
| 25/08 | Manchester Piccadilly | NO NOx | G-RA0447- 006 | 5 13 | 5 5.5 | 0.422 0.422 | 5 5.3 | 0.9985 0.9984 | 97.2 |
| 24/08 | Manchester South | NO NOx | J-RA0447 008 | -10 3 | 5 5.3 | 0.607 0.639 | 5 5.2 | 0.9969 0.9981 | 91.9 |
| 25/08 | Manchester Town Hall | NO NOx | 846 | 1 4 | 5 5.7 | 2.338 2.400 | 5.8 5.9 | 0.9992 0.9993 | 98.9 |
| 30/07 | Market Harborough | NO NOx | 42c- 61963-333 | 0 1 | 5 5.2 | 0.507 0.513 | 5 5 | 0.9943 0.9955 | 100.6 |
| 08/09 | Middlesbrough | NO NOx | 13160 | 0 0 | 5 5.3 | 0.974 1.001 | 5 5 | 0.9999 0.9995 | 71.5 |
| 13/09 | Newcastle Centre | NO NOx | m1800- m730 | 243 250 | 5 5.2 | 0.396 0.402 | 5.4 5.8 | 0.9997 0.9997 | 96.8 |
| 16/07 | Northampton | NO NOx | 8513180611 | -1 -6 | 5 5.4 | 0.969 0.972 | 5 5.2 | 0.9979 0.9984 | 100.9 |
| 12/08 | Norwich Centre | NO NOx | H-AR005 | 77 81 | 5 5.6 | 2.125 2.182 | 5 5.2 | 0.9983 0.9984 | 96.3 |
| 11/08 | Norwich Roadside | NO NOx | 94604 | 0 1 | 5 5.3 | 1.120 1.150 | 5 5.1 | 0.9997 0.9998 | 95.2 |
| 27/07 | Nottingham Centre | NO NOx | GRA0447- 009 | 10 9 | 5 5.3 | 0.416 0.408 | 5 5 | 0.9938 0.9938 | 98.7 |
| 07/07 | Oxford Centre | NO NOx | 411b-179 | 101 102 | 5 5.5 | 1.171 1.213 | 5 5.2 | 0.9983 0.9987 | 89.6 |
| 04/08 | Plymouth Centre | NO NOx | 42c- 66639-353 | 0 -1 | 5 5.6 | 2.061 2.038 | 5 5 | 0.9983 0.9984 | 98.5 |
| 09/07 | Portsmouth | NO NOx | 903005 | 0 0 | 5 5.3 | 1.034 0.985 | 5 5.1 | 0.9999 0.9998 | 100.8 |
| 27/09 | Preston | NO NOx | 71010-02 | 58 60 | 15.5 12.7 | 5.659 6.063 | 11.4 8.4 | 0.9972 0.9983 | 97.5 |
| 22/07 | Reading New Town | NO NOx | H-AR-004 | 10 10 | 5 5.7 | 1.093 1.186 | 5 5.1 | 0.9935 0.9938 | 99.1 |
| 07/09 | Redcar | NO NOx | 10196 | 1 1 | 5 5.3 | 1.176 1.208 | 5 5 | 1.0000 0.9999 | 95.6 |
| 20/07 | Rochester | NO NOx | 95059 | 0 3 | 5 5.3 | 1.149 1.154 | 5 5 | 0.9999 0.9999 | 98.7 |
| 09/08 | Rotherham Centre | NO NOx | Q-RA0447- 001 | 4 3 | 5 5.4 | 1.285 1.326 | 5 5.1 | 0.9978 0.9980 | 97.9 |
| 24/08 | Salford Eccles | NO NOx | 2381 | 1 7 | 5 5.4 | 1.095 1.422 | 5.6 5.4 | 0.9963 0.9976 | 101.5 |
| 08/07 08/07 | Sandwell West Bromwich | NO NOx | 93081 | -3 -3 | 5 5.4 | 0.985 0.991 | 5 5.1 | 0.9998 0.9998 | 96.4 |
| 10/08 | Sheffield Centre | NO NOx | G-RA0447- 008 | 10 8 | 5 5.2 | 0.425 0.429 | 5 5.2 | 0.9969 0.997 | 97.4 |
| 09/08 | Sheffield | NO | 847 | -6 | 5 | 2.552 | 5.2 | 0.9975 | |

CERTIFICATE OF CALIBRATION

551 Harwell, Didcot, Oxfordshire OX11 0QJ. Telephone 0870 1906465 Facsimile 0870 1906377

0401
0401 51

Certificate No: 01214-

AEA Identification Number: 45077030

Page 11 of 14

| Date Year =2004 | Site | | Analyser number | ¹ Zero output | Uncertainty (ppb) | ² Calibration Factor | Uncertainty (%) | *R ² | *Converter efficiency (%) |
|-----------------|------------------------|-----------|-----------------|--------------------------|-------------------|---------------------------------|-----------------|------------------|---------------------------|
| | Tinsley | NOx | | -5 | 6.3 | 2.572 | 5.3 | 0.9971 | 96.9 |
| 03/08 | Somerton | NO NOx | 2120 | 5 9 | 5 5.2 | 0.511 0.505 | 5 5 | 0.998 0.998 | 97.4 |
| 23/08 | Southampton Centre | NO NOx | M1781-M723 | 228 244 | 5 5.3 | 0.446 0.456 | 6.4 5.1 | 0.9994 0.9992 | 100.6 |
| 05/08 | Southend-on-Sea | NO NOx | L-AR-011 | 50 53 | 5 9.4 | 2.202 2.472 | 8.2 7.4 | 0.9995 0.9994 | 102.6 |
| 13/07 | Southwark Roadside | NO NOx | API 1443 | 2 1 | 5 5.3 | 1.186 1.201 | 5 5.3 | 0.9981 0.9983 | 95.6 |
| 04/08 | St Osyth | NO NOx | 42c-60988 | 2 8 | 5 5.3 | 0.036 0.041 | 5 5 | 0.9986 0.9984 | 99.6 |
| 18/08 | Stockport Shaw Heath | NO NOx | 1853 | 20 19 | 5 5.8 | 2.643 2.653 | 5 5.2 | 0.9988 0.9987 | 100 |
| 06/09 | Stockton-on-Tees Yarm | NO NOx | 1356 | 4 7 | 5 5.4 | 1.018 1.023 | 7 5.8 | 0.9998 0.9994 | 95.3 |
| 16/08 | Stoke-on-Trent Centre | NO NOx | H-AR-003 | 17 18 | 5 6.5 | 2.681 2.758 | 5 6.5 | 0.9992 0.9992 | 95.1 |
| 22/07 | Thurrock | NO NOx | 11004 | 3 4 | 5 5.5 | 1.338 1.344 | 5 5 | 0.9999 0.9999 | 97 |
| 23/09 | Tower Hamlets Roadside | NO NOx | 306 | 4 4 | 5 5.3 | 1.299 1.135 | 5 5.3 | 0.9990 0.9990 | 98.7 |
| 22/09 | Walsall Alumwell | NO NOx | m200a-848 | 0 0 | 5 5.4 | 1.282 1.293 | 5 5.3 | 0.9981 0.9984 | 85.5 |
| 03/08 | Walsall Willenhall | NO NOx | 9800-1337 | 5 7 | 5 5.4 | 1.113 1.134 | 5 5.1 | 0.9989 0.9990 | 104 |
| 20/09 | West London | NO NOx | m200a-845 | -1 0 | 5 5.8 | 1.273 1.311 | 5 5.4 | 0.9987 0.9988 | 98.9 |
| 09/08 | Wicken Fen | NO NOx | 13069 | 15 14 | 5 5.2 | 0.522 0.518 | 5 5 | 0.9999 0.9999 | 96.8 |
| 19/08 | Wigan Leigh | NO NOx | | 0 2 | 5 5.3 | 0.982 1.012 | 5 5.2 | 0.9984 0.9986 | 96 |
| 28/09 | Wirral Tranmere | NO NOx | L-AR-012 | 39 39 | 5 6.0 | 1.315 1.345 | 6.4 5.8 | 0.9967 0.9977 | 97.6 |
| 04/08 | Yarner Wood | NO NOx | 1784 | 6 6 | 5 5.3 | 0.941 0.931 | 5 5 | 0.9914 0.9909 | 94.9 |

CERTIFICATE OF CALIBRATION

551 Harwell, Didcot, Oxfordshire OX11 0QJ. Telephone 0870 1906465 Facsimile 0870 1906377

0401
0401 51

Certificate No: 01214-

AEA Identification Number: 45077030

Page 12 of 14

5. Particulate Analysers

| Date Year =2004 | Site | Analyser number | Calculated Spring Constant k_0 | Uncertainty (%) | $^{*4}k_0$ accuracy (%) | 3 Measured Main Flow (l/min) | Uncertainty (%) | 3 Measured Total Flow / Aux Flow (l/min) | Uncertainty (%) |
|-----------------|---------------------------|-----------------|----------------------------------|-----------------|-------------------------|---------------------------------|-----------------|---|-----------------|
| | Scottish Sites | | | | | | | | |
| 27/07 | Aberdeen | 24427 | 11600 | 1 | 0.3 | 2.91 | 2.2 | 16.26 | 2.2 |
| 12/07 | Dumfries | 2025a2122 | | | | | | 17.4 | 2.2 |
| 14/07 | Edinburgh St Leonards | 21308 | 12858 | 1 | 0.3 | 1.97 | 2.2 | 14.32 | 2.2 |
| 19/07 | Glasgow Centre | 20913 | 13316 | 1 | -0.2 | 1.89 | 2.2 | 4.57 | 2.2 |
| 20/07 | Glasgow Kerbside | 24444 | 15442 | 1 | -1.2 | 2.05 | 2.2 | 15.00 | 2.2 |
| 15/07 | Grangemouth | 22763 | 12491 | 1 | -1.3 | 2.98 | 2.2 | 13.92 | 2.2 |
| 28/07 | Inverness | 21255 | | | | | | 15.55 | 2.2 |
| | Welsh Sites | | | | | | | | |
| 16/09 | Cardiff Centre | 24449 | 14114 | 1 | -1.4 | 2.04 | 2.2 | 14.32 | 2.2 |
| 17/09 | Cwmbran | 21557 | 12459 | 1 | -0.6 | 2.95 | 2.2 | 13.39 | 2.2 |
| 21/09 | Narberth | 21557 | 12415 | 1 | -0.6 | 3.01 | 2.2 | 13.53 | 2.2 |
| 20/09 | Port Talbot | 9402 | 10625 | 1 | 0.3 | 3.08 | 2.2 | 13.84 | 2.2 |
| 20/09 | Swansea | 2130 | 14285 | 1 | -1.9 | 2.39 | 2.2 | 9.15 | 2.2 |
| | N.Irish Sites | | | | | | | | |
| 13/09 | Belfast Centre | 24423 | 14238 | 1 | 0.3 | 2.04 | 2.2 | 15.64 | 2.2 |
| 13/09 | Belfast Clara St | 95366 | | | | | | 15.18 | 2.2 |
| 15/09 | Derry | 49608 | 11088 | 1 | 1.8 | 2.09 | 2.2 | 16.15 | 2.2 |
| 16/07 | Lough Navar | 21196 | 12963 | 1 | 1.1 | 2.99 | 2.2 | 13.71 | 2.2 |
| | English Sites | | | | | | | | |
| 04/08 | Birmingham Centre | 2297 | 12074 | 1 | 0 | 2.99 | 2.2 | 14.82 | 2.2 |
| 02/08 | Birmingham East | 24637 | 13607 | 1 | -0.1 | 3.02 | 2.2 | 15.76 | 2.2 |
| 27/09 | Blackpool | 24424 | 12810 | 1 | -0.7 | 2.02 | 2.2 | 15.78 | 2.2 |
| 17/08 | Bolton | 21197 | 15288 | 1 | 0.8 | 3.39 | 2.2 | 13.46 | 2.2 |
| 16/08 | Bradford Centre | 21494 | 11410 | 1 | 0.5 | 2.11 | 2.2 | 16.02 | 2.2 |
| 02/08 | Bristol Centre | 24426 | 13090 | 1 | -0.7 | 2.05 | 2.2 | 14.17 | 2.2 |
| 17/08 | Bury Roadside | 658 | 11571 | 1 | -0.2 | 2.07 | 2.2 | 15.88 | 2.2 |
| 07/07 | Camden Kerbside | 21152 | 16258 | 1 | -1 | 3.09 | 2.2 | 15.89 | 2.2 |
| 21/07 | Canterbury | 20931 | 14051 | 1 | 0.1 | 3.09 | 2.2 | 16.72 | 2.2 |
| 08/07 | Coventry Memorial Park | 25026 | 13033 | 1 | -1.2 | 2.7 | 2.2 | 12.80 | 2.2 |
| 14/07 | Haringey Roadside | 20695 | 11402 | 1 | -0.5 | 2.81 | 2.2 | 13.50 | 2.2 |
| 05/07 | Harwell PM ₁₀ | 21489 | 14972 | 1 | 0.4 | 3.04 | 2.2 | 16.69 | 2.2 |
| 05/07 | Harwell PM _{2.5} | 21490 | 10965 | 1 | 0.7 | 3.09 | 2.2 | 14.97 | 2.2 |
| 29/07 | Hull Freetown | 24445 | 14033 | 1 | -0.5 | 2.01 | 2.2 | 15.56 | 2.2 |
| 09/09 | Leamington Spa | 2075 | 10948 | 1 | 0.1 | 2.98 | 2.2 | 13.85 | 2.2 |
| 16/08 | Leeds Centre | 2032 | 13014 | 1 | 1.3 | 2.07 | 2.2 | 18.21 | 2.2 |
| 16/06 | Leicester Centre | 24442 | 13962 | 1 | -0.4 | 2 | 2.2 | 16.62 | 2.2 |

CERTIFICATE OF CALIBRATION

551 Harwell, Didcot, Oxfordshire OX11 0QJ. Telephone 0870 1906465 Facsimile 0870 1906377

0401
0401 51

Certificate No: 01214-

AEA Identification Number: 45077030

Page 13 of 14

| Date Year =2004 | Site | Analyser number | Calculated Spring Constant k_0 | Uncertainty (%) | $^{40}\text{K}_0$ accuracy (%) | $^3\text{Measured}$ Main Flow (l/min) | Uncertainty (%) | $^3\text{Measured}$ Total Flow / Aux Flow (l/min) | Uncertainty (%) |
|-----------------|---|-----------------|----------------------------------|-----------------|--------------------------------|---------------------------------------|-----------------|---|-----------------|
| 07/09 | Liverpool Speke | 24450 | 15923 | 1 | 0.7 | Not | tested | 15.37 | 2.2 |
| 08/07 | London A3 Roadside | 24425 | 12321 | 1 | -2.2 | 1.92 | 2.2 | 14.58 | 2.2 |
| 19/07 | London Bexley | 2000 | 10550 | 1 | 0.8 | 2.04 | 2.2 | 16.18 | 2.2 |
| 06/07 | London Bloomsbury PM ₁₀ | 24446 | 13719 | 1 | -0.2 | 2.98 | 2.2 | 15.66 | 2.2 |
| 06/07 | London Bloomsbury PM _{2.5} | 21492 | 15009 | 1 | 0.4 | 2.88 | 2.2 | 15.81 | 2.2 |
| 20/08 | London Brent | 21145 | 17511 | 1 | 0 | 3.02 | 2.2 | 12.55 | 2.2 |
| 23/08 | London Eltham | 2096 | 12992 | 1 | 0.1 | 2.94 | 2.2 | 13.23 | 2.2 |
| 02/09 | London Harlington | 22835 | 14095 | 1 | -0.8 | 1.99 | 2.2 | 14.79 | 2.2 |
| 05/07 | London Hillingdon | 24422 | 14050 | 1 | -1.3 | 2.03 | 2.2 | 16.09 | 2.2 |
| 15/07 | London Marylebone Road PM ₁₀ | 21306 | 13125 | 1 | -1.6 | 3.08 | 2.2 | 13.23 | 2.2 |
| 09/07 | London N. Kensington | 20715 | 10698 | 1 | -1.1 | 2.97 | 2.2 | 15.94 | 2.2 |
| 06/08 | London Westminster | | | | | | | 15.85 | 2.2 |
| 25/08 | Manchester Piccadilly | 2000 | 12113 | 1 | 0.5 | 1.97 | 2.2 | 14.34 | 2.2 |
| 08/09 | Middlesbrough | 14325 | 13925 | 1 | -1.5 | 2.09 | 2.2 | 14.68 | 2.2 |
| 13/09 | Newcastle Centre | 24448 | 13728 | 1 | -0.7 | 2.95 | 2.2 | 13.16 | 2.2 |
| 16/07 | Northampton | 21621 | 11020 | 1 | -1.2 | 2.98 | 2.2 | 13.65 | 2.2 |
| 12/08 | Norwich Centre | 21495 | 12101 | 1 | -0.9 | 2.19 | 2.2 | 14.34 | 2.2 |
| 27/07 | Nottingham Centre | 20904 | 8725 | 1 | 0.6 | Not | tested | 15.57 | 2.2 |
| 04/08 | Plymouth Centre | 24428 | 12886 | 1 | -0.5 | 2.06 | 2.2 | 14.02 | 2.2 |
| 09/07 | Portsmouth | 21578 | 10465 | 1 | -1 | 2.75 | 2.2 | 12.36 | 2.2 |
| 27/09 | Preston | 22881 | 12738 | 1 | -1.7 | 2.08 | 2.2 | 16.81 | 2.2 |
| 22/07 | Reading New Town | 0 | 13148 | 1 | -0.4 | 2.01 | 2.2 | 16.19 | 2.2 |
| 07/09 | Redcar | 21344 | 12021 | 1 | 2 | 3.07 | 2.2 | 13.39 | 2.2 |
| 20/07 | Rochester PM ₁₀ | 24381 | 12090 | 1 | 0.3 | 2.97 | 2.2 | 15.42 | 2.2 |
| 20/07 | Rochester PM _{2.5} | 21491 | 13827 | 1 | -0.8 | 3.07 | 2.2 | 15.73 | 2.2 |
| 24/08 | Salford Eccles | 21168 | 14476 | 1 | 0.4 | 1.95 | 2.2 | 13.49 | 2.2 |
| 28/07 | Scunthorpe Town | 2000 | 12466 | 1 | -0.2 | 3.18 | 2.2 | 17.94 | 2.2 |
| 10/08 | Sheffield Centre | 20915 | 10996 | 1 | -2.9 | 1.96 | 2.2 | 14.50 | 2.2 |
| 23/08 | Southampton Centre | 4484 | 13838 | 1 | -0.3 | 2.05 | 2.2 | 15.65 | 2.2 |
| 05/08 | Southend-on-Sea | 22927 | 13321 | 1 | -0.5 | 1.89 | 2.2 | 13.66 | 2.2 |
| 18/08 | Stockport Shaw Heath | 2000 | 10607 | 1 | 1.8 | 3.24 | 2.2 | 8.27 | 2.2 |
| 06/09 | Stockton-on- | 22885 | 14377 | 1 | 0.6 | 3.18 | 2.2 | 16.85 | 2.2 |

| Date Year =2004 | Site | Analyser number | Calculated Spring Constant k_0 | Uncertainty (%) | * k_0 accuracy (%) | ³ Measured Main Flow (l/min) | Uncertainty (%) | ³ Measured Total Flow / Aux Flow (l/min) | Uncertainty (%) |
|-----------------|-----------------------|-----------------|----------------------------------|-----------------|----------------------|---|-----------------|---|-----------------|
| | Tees Yarm | | | | | | | | |
| 16/08 | Stoke-on-Trent Centre | 21317 | 18391 | 1 | 0.1 | 1.88 | 2.2 | 15.22 | 2.2 |
| 22/07 | Thurrock | 25039 | 12842 | 1 | -1 | 3.09 | 2.2 | 14.28 | 2.2 |
| 19/08 | Wigan Leigh | 22015 | 13212 | 1 | 10.1 | 3.02 | 2.2 | 16.02 | 2.2 |
| 28/09 | Wirral Tranmere | 22883 | 13264 | 1 | -0.2 | 2.02 | 2.2 | 15.33 | 2.2 |

The above factors have been calculated using certified standards. The analysers listed above have been tested for zero response, calibration factor, linearity, converter efficiency (NO_x analysers), m-xylene interference (SO₂ analysers), k_0 / main flow rate (for TEOM analysers) and total flow rate (for particulate analysers), by documented methods. Note that the test results are valid on the day of test only, as analyser drift over time cannot be quantified.

The calibration results for NO_x, NO, CO, SO₂, O₃ and Particulates are those that fall within our scope of accreditation. Results marked with an asterisk (*) on this certificate are not UKAS accredited, but have been included for completeness.

¹The zero response is the zero reading on the logging system of the analyser when audit zero gas was introduced to the analysers under test.

²The calibration factor is the multiplying factor required to scale the reading on the logging system of the analyser into concentration units (ppb for NO, NO_x and SO₂, ppm for CO – 1ppm = 1000 ppb). It should be used in conjunction with the analyser output and the zero response, according to the following equation:

$$\text{Concentration} = (\text{output} - \text{zero response}) \times \text{Calibration factor}$$

³The calculated main flow rate (where this is applicable) is the flow rate through the sensor unit of a TEOM analyser. The calculated total flow rate is the flow rate through a particulate analyser sample inlet. The calculated aux flow rate is the flow rate through the auxiliary (bypass) tubing of a TEOM analyser. Where flow rates are highlighted in **bold**, it indicates that measurements were not made at the analyser sample inlet. These measurements therefore may not accurately reflect analyser performance in normal operation.

⁴The k_0 accuracy value (specifically for TEOM analysers) indicates the closeness of the calculated result to the manufacturer's specified value of k_0 .

*R² is the correlation coefficient of linearity

*Converter is the measured efficiency of the NO₂ to NO converter in the Oxides of Nitrogen analyser

*meta-xylene interference is the response of the SO₂ analyser when supplied with approx 1ppm meta-xylene

This certificate is an electronic representation of the original, signed by Stewart Eaton on 28 January 2005. Photocopies can be obtained by writing to Brian Stacey at the address given on the top of the certificate.